22-May-2000

NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices

Back to top

Insert Time	Message
21-May-2000 2:20:05	TP-LI REQUESTS NORTHPORT___4 NO LONGER OUT OF MERIT. AT 02:18 05/21/00
21-May-2000 9:12:05	TP-LI REQUESTS NORTHPORT___3 NO LONGER OUT OF MERIT. AT 09:10 05/21/00
21-May-2000 10:52:38	TP-CE REQUESTS ASTORIA___3 OUT OF MERIT FOR LOCAL SECURITY. AT 10:45 05/21/00 LOW LIMIT BLOCKED AT 150MWS FOR ACTUAL OVBERLOADS ON 99153 DUNWOODIE -E.179/TH ST. 138KV
21-May-2000 10:59:30	TP-LI REQUESTS NORTHPORT___4 OUT OF MERIT FOR ISO SECURITY. AT 10:55 05/21/00 UPPER LIMIT BLOCKED AT 310 MWS FOR PC FLOWS ON 676 GREENLAWN-SYOSSET FOR L/O 677
21-May-2000 11:34:03	TP-LI REQUESTS HOLTSVILLE_IC_9 OUT OF MERIT FOR LOCAL SECURITY. AT 11:24 05/21/00 BLOCKED AT 29MWS FOR LOSS OF TOWER CONT. 881/882 ON 69/772
21-May-2000 11:35:15	TP-LI REQUESTS NORTHPORT___3 OUT OF MERIT FOR ISO SECURITY. AT 11:24 05/21/00 HIGH LIMIT BLOCKED AT 297MWS FOR PC FLOWS 676 GREENLAWN-SYOSSET FOR L/O 677

21-May-2000 11:37:09	TP-CE REQUESTS ASTORIA___3 OUT OF MERIT FOR LOCAL SECURITY. AT 11:28 05/21/00 LOW LIMIT BLOCK RAISED FROM 150MWS TO 200MWS FOR ACTUAL OVERLOADS ON 99153 DUNWOODIE-E.179/TH ST 138KV.
21-May-2000 13:47:54	TP-CE REQUESTS RAVENSWOOD___1 OUT OF MERIT FOR LOCAL SECURITY. AT 13:42 05/21/00 LOW LIMIT BLOCKED AT 150MWS FOR PC FLOWS ON GOWANUS T14 FOR SCB 6 AT FRESHKILLS
21-May-2000 18:44:37	TP-CE REQUESTS RAVENSWOOD___1 OUT OF MERIT FOR LOCAL SECURITY. AT 18:40 05/21/00 LOW LIMIT RAISED FROM 150 TO 161 MWS FOR PC FLOWS ON GOWANUS T14 FOR SCB 6 AT FRESHKILLS
21-May-2000 21:30:22	TP-LI REQUESTS BARRETT___1 OUT OF MERIT FOR ISO SECURITY. AT 21:25 05/21/00
21-May-2000 21:41:02	TP-LI REQUESTS WADING RIVER_IC_2 OUT OF MERIT FOR ISO SECURITY. AT 20:00 05/21/00
21-May-2000 21:41:41	TP-LI REQUESTS WADING RIVER_IC_3 OUT OF MERIT FOR ISO SECURITY. AT 20:00 05/21/00
21-May-2000 22:37:06	TP-LI REQUESTS BARRETT___1 NO LONGER OUT OF MERIT. AT 22:35 05/21/00
21-May-2000 22:38:01	TP-LI REQUESTS WADING RIVER_IC_2 NO LONGER OUT OF MERIT. AT 22:20 05/21/00
21-May-2000 22:49:43	TP-LI REQUESTS WADING RIVER_IC_3 NO LONGER OUT OF MERIT. AT 23:00 05/21/00

Committed for Reliability

Back to top

Insert Time	Message
21-May-2000 11:52:44	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 00 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:45	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 01 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:46	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 02 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:48	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 03 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:49	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 04 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:50	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 05 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:51	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 06 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 11:52:52	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 07 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:53	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 08 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:54	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 09 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:55	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 10 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:56	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 11 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:57	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 12 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:52:58	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 13 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 11:52:59	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 14 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:00	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 15 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:01	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 16 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:02	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 17 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:03	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 18 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:05	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 19 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 11:53:06	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 20 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 11:53:07	Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 05/22/2000 21 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:43	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 00 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:44	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 01 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:45	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 02 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:47	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 03 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:48	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 04 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:49	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 05 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 12:03:50	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 06 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:51	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 07 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:54	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 08 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:55	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 09 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:56	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 10 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 12:03:57	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 05/22/2000 11 Energy = 65 MW. Regulation = MW. Min10 Spinning = 0 MW. Min10 Nonsynch = MW. Min30 Spinning = 0 MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:18:59	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 00 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 16:19:01	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 01 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:19:02	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 02 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:19:03	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 03 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:19:04	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 04 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:19:05	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 05 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 16:19:06	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/22/2000 06 Energy = 20 MW. Regulation = 5 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:06:55	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/21/2000 20 Energy = 20 MW. Regulation = 5 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 17:06:56	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/21/2000 21 Energy = 20 MW. Regulation = 5 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:06:57	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/21/2000 22 Energy = 20 MW. Regulation = 5 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:06:58	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 05/21/2000 23 Energy = 20 MW. Regulation = 5 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:14	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 05 Energy = 20 MW. Regulation = MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:15	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 06 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:16	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 07 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:17	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 08 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 17:50:18	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 09 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:19	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 10 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:20	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 11 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:21	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 12 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:22	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 13 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:23	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 14 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:24	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 15 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 17:50:25	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 16 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:26	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 17 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:27	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 18 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:28	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 19 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:29	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 20 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:30	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 21 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
21-May-2000 17:50:31	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 22 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

21-May-2000 17:50:33	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/22/2000 23 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 10 MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices

Back to top

Insert Time	Message
21-May-2000 16:32:09	the NYISO is reserving hours 0100, 0500, 1000 and 1800 in the 20 May 2000 Real-Time Market to verify prices. Prices in the Day-Ahead Market for 21 May 2000 are correct.