

21-Aug-2000

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)

Dispatcher Notices

[Back to top](#)

Insert Time	Message
20-Aug-2000 0:09:13	NYISO Locational based curtailment cut 200 MWs
20-Aug-2000 0:50:42	TP-LI REQUESTS PORT_JEFF_3 OUT OF MERIT FOR ISO SECURITY. AT 00:50 08/20/00 871 LINE OUTAGE
20-Aug-2000 1:21:39	NYISO Locational based curtailment cut 200 MWs
20-Aug-2000 2:26:41	NYISO Locational based curtailment cut 100 MWs ISO contingency overloads on 5018 line.
20-Aug-2000 3:43:04	TP-LI REQUESTS PORT_JEFF_3 NO LONGER OUT OF MERIT. AT 03:38 08/20/00
20-Aug-2000 5:01:54	TP-LI REQUESTS PORT_JEFF_3 OUT OF MERIT FOR LOCAL SECURITY. LOSS OF 881/882 AT 04:58 08/20/00
20-Aug-2000 5:24:52	TP-LI REQUESTS PORT_JEFF_3 NO LONGER OUT OF MERIT. AT 04:59 08/20/00
20-Aug-2000 5:25:50	TP-LI REQUESTS PORT_JEFF_4 OUT OF MERIT FOR ISO SECURITY. 871 LINE OUTAGE AT 05:00 08/20/00

20-Aug-2000 8:49:58	TP-LI REQUESTS PORT_JEFF_3 OUT OF MERIT FOR LOCAL SECURITY. AT 08:45 08/20/00 871 OUTAGE.
20-Aug-2000 9:59:20	TP-LI REQUESTS MONTAUK___DIESEL OUT OF MERIT FOR LOCAL SECURITY. AT 09:56 08/20/00 - LOCAL LOAD
20-Aug-2000 11:06:57	TP-LI REQUESTS WADING RIVER_IC_1 OUT OF MERIT FOR LOCAL SECURITY. AT 11:06 08/20/00 - 871 OUTAGE
20-Aug-2000 14:06:53	TP-LI REQUESTS MONTAUK___DIESEL NO LONGER OUT OF MERIT. AT 14:06 08/20/00
20-Aug-2000 16:34:30	TP-LI REQUESTS MONTAUK___DIESEL OUT OF MERIT FOR LOCAL SECURITY. AT 16:31 08/20/00 - LOCAL LOAD.
20-Aug-2000 17:27:28	NYISO Locational based curtailment cut 150 MWs
20-Aug-2000 17:30:11	NYISO Locational based curtailment cut 200 MWs
20-Aug-2000 17:31:21	NYISO Locational based curtailment cut 200 MWs
20-Aug-2000 19:22:10	TP-LI REQUESTS MONTAUK___DIESEL NO LONGER OUT OF MERIT. AT 19:22 08/20/00
20-Aug-2000 20:06:50	TP-CE REQUESTS ASTORIA___3 OUT OF MERIT FOR LOCAL SECURITY. ASTORIA LOAD POCKET AT 20:04 08/20/00
20-Aug-2000 21:10:13	TP-LI REQUESTS PORT_JEFF_3 AND 4 AND WADING RIVER 1 NO LONGER OUT OF MERIT. AT 21:06 08/20/00
20-Aug-2000 23:17:08	TP-CE REQUESTS ASTORIA___3 NO LONGER OUT OF MERIT. AT 23:17 08/20/00

Committed for Reliability

[Back to top](#)

Insert Time	Message
20-Aug-2000 16:00:18	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 08/21/2000 06 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
20-Aug-2000 16:00:20	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 08/21/2000 07 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices

[Back to top](#)

Insert Time	Message
20-Aug-2000 10:47:18	The NYISO is reserving hours-beginning 6, 8, and 15-23 in the 19 Aug. 2000 real-time market to verify prices. The prices for the 20 Aug. 2000 DAM are correct.