

## NYISO Operational Announcements

---

[Dispatcher Notices](#)  
[Committed for Reliability](#)  
[Market Monitor Notices](#)

### Dispatcher Notices

[Back to top](#)

Insert Time	Message
04-Feb-2001 0:47:02	TP-LI REQUESTS BARRETT___1 OUT OF MERIT FOR LOCAL SECURITY. AT 00:01 02/04/01
04-Feb-2001 0:48:32	TP-LI REQUESTS BARRETT___1 NO LONGER OUT OF MERIT. AT 01:00 02/04/01
04-Feb-2001 0:52:54	TP-CE REQUESTS ASTORIA___3 NO LONGER OUT OF MERIT. AT 00:51 02/04/01
04-Feb-2001 5:31:21	TP-CE REQUESTS ASTORIA___3 OUT OF MERIT FOR LOCAL SECURITY. AT 05:29 02/04/01
04-Feb-2001 17:04:07	TP-CE REQUESTS ASTORIA_GT_GRP4 OUT OF MERIT FOR LOCAL SECURITY. UPPER 138KV LOAD POCKET AT 17:00 02/04/01
04-Feb-2001 18:30:18	NYISO Locational based curtailment cut 150 MWs.
04-Feb-2001 19:04:57	TP-LI REQUESTS BARRETT_IC_2 OUT OF MERIT ABOVE OPCAP DMNC TEST. AT 19:00 02/04/01
04-Feb-2001 21:21:43	NYISO Locational based curtailment cut 150 MWs.

04-Feb-2001 22:11:57	NYISO Locational based curtailment cut 150 MWs.
04-Feb-2001 22:27:36	TP-CE REQUESTS ASTORIA_GT4_4 NO LONGER OUT OF MERIT. AT 22:26 02/04/01

## Committed for Reliability

[Back to top](#)

Insert Time	Message
04-Feb-2001 14:15:06	Generator: BARRETT___1 scheduled for local reliability in DAM market for 02/05/2001 23 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:15:59	Generator: BARRETT___2 scheduled for local reliability in DAM market for 02/05/2001 23 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:16:56	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 02/05/2001 20 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:16:57	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 02/05/2001 21 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:16:58	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 02/05/2001 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

04-Feb-2001 14:16:59	Generator: GLENWOOD__4 scheduled for local reliability in DAM market for 02/05/2001 23 Energy = 25 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:17:37	Generator: GLENWOOD__5 scheduled for local reliability in DAM market for 02/05/2001 20 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:17:38	Generator: GLENWOOD__5 scheduled for local reliability in DAM market for 02/05/2001 21 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:17:39	Generator: GLENWOOD__5 scheduled for local reliability in DAM market for 02/05/2001 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:17:40	Generator: GLENWOOD__5 scheduled for local reliability in DAM market for 02/05/2001 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:18:20	Generator: NYPA__HOLTSVILL scheduled for local reliability in DAM market for 02/05/2001 22 Energy = 100 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
04-Feb-2001 14:18:21	Generator: NYPA__HOLTSVILL scheduled for local reliability in DAM market for 02/05/2001 23 Energy = 100 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Insert Time	Message
04-Feb-2001 11:31:09	<p data-bbox="317 142 1499 267">The NYISO is reserving hours beginning 00:00, 09:00 in the February 3, 2001 Real-Time Market as well as the following hours per ECA20001006B to verify prices:</p> <p data-bbox="317 267 982 308">PJM: 00:00 - 05:00, 14:00 and 16:00 - 23:00</p> <p data-bbox="317 308 590 349">OH: 16:00 - 23:00</p> <p data-bbox="317 349 590 389">HQ: 16:00 - 23:00</p> <p data-bbox="317 389 743 430">NE: 06:00 and 16:00 - 23:00</p> <p data-bbox="317 479 1423 560">The NYISO is also reserving all hours in the February 4, 2001 Day-Ahead Market.</p>