NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
30-Oct-2002 05:34:41	TP-LI UPDATES WADING RIVER_IC_1 OUT OF MERIT FOR TO LOCAL SECURITY AT START TIME 10/30/2002 05:00.
30-Oct-2002 13:34:48	ISO REQUESTS ASTORIA_GT2_1 OUT OF MERIT FOR ISO SECURITY AT START TIME 10/30/2002 13:00.
30-Oct-2002 13:35:32	ISO REQUESTS ASTORIA_GT2_2 OUT OF MERIT FOR ISO SECURITY AT START TIME 10/30/2002 13:00.
30-Oct-2002 13:36:00	ISO REQUESTS ASTORIA_GT2_3 OUT OF MERIT FOR ISO SECURITY AT START TIME 10/30/2002 13:00.
30-Oct-2002 14:19:03	ISO REQUESTS ASTORIA_GT2_1 NO LONGER OUT OF MERIT. AT 14:00 10/30/02 ASTORIA GT 2-1, 2-2, & 2-3 ARE NO LONGER OOM. AST GT 2-3 FAILED TO START
30-Oct-2002 14:32:42	PJM initiated curtailment cut 353 MWs. Cut for PJM ramp at 1500
30-Oct-2002 15:19:48	PJM initiated curtailment cut 100 MWs. Erie South Erie West Transmission Constraint.
30-Oct-2002 21:57:17	PJM initiated curtailment cut 100 MWs. PJM security
30-Oct-2002 23:52:54	PJM initiated curtailment cut 197 MWs.

Committed for Reliability back to top

Insert Time	Message

Market Monitor Notices back to top

Insert Time	Message
30-Oct-2002 16:01:32	NYISO is reserving hours beginning 9:00, 12:00 and 14:00 in the October 29, 2002 Real-Time Market. Prices in the October 29, 2002 Hour-Ahead Market are correct. Prices in the October 30, 2002 Day-Ahead Market are correct.
30-Oct-2002 17:23:39	The Real Time prices have been updated in the MIS for 10/28/2002 in hours (22,23)