

NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices

[back to top](#)

Insert Time	Message
13-Jan-2003 01:27:04	PJM initiated curtailment cut 200 MWs. PJM Ramp
13-Jan-2003 06:24:30	ISO REQUESTS GILBOA___3 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 01/13/2003 06:00 FOR INDIAN PT 3 TRIPPED.
13-Jan-2003 06:27:55	ISO REMOVES GILBOA___3 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 01/13/2003 07:00.
13-Jan-2003 06:30:21	01/13/2003 06:19:01 NYISO SCD reserve pick-up executed.
13-Jan-2003 06:55:09	01/13/2003 06:45:07 NYISO SCD reserve pick-up executed.
13-Jan-2003 07:03:25	GILBOA___3 NO LONGER OOM FOR ISO SECURITY AFTER 01/13/2003 06:59.
13-Jan-2003 15:30:14	PJM initiated curtailment cut 30 MWs.
13-Jan-2003 15:53:29	TP-CE REQUESTS ASTORIA_GT2_1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 15:00 FOR OOM FOR FEEDER 99032 O/S ON EMERGENCY. PROBLEM WITH THE PAR.
13-Jan-2003 15:53:29	TP-CE REQUESTS ASTORIA_GT2_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 15:00 FOR OOM FOR FEEDER 99032 O/S ON EMERGENCY. PROBLEM WITH THE PAR.
13-Jan-2003 15:53:30	TP-CE REQUESTS ASTORIA_GT2_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 15:00 FOR OOM FOR FEEDER 99032 O/S ON EMERGENCY. PROBLEM WITH THE PAR.
13-Jan-2003 15:57:17	TP-CE UPDATES ASTORIA___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 15:00 FOR OOM FOR FEEDER 99032 O/S ON EMERGENCY. PROBLEM WITH THE PAR.
13-Jan-2003 16:02:40	TP-CE UPDATES ASTORIA___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 16:00 FOR OOM FOR FEEDER

	99032 O/S ON EMERGENCY. PROBLEM WITH THE PAR.
13-Jan-2003 16:19:31	TP-CE REQUESTS ASTORIA GT2___ AND ASTORIA__4 OUT OF MERIT FOR LOCAL SECURITY. AS OF 1553 HRS 01/13/03 AST_GT2-1, AST_GT2-2, AST_GT2-3, AND ASTORIA_4 ARE OOM FOR LOCAL SECURITY DUE TO A LINE OUTAGE.
13-Jan-2003 16:36:10	TP-CE REMOVES ASTORIA_GT2_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 16:00.
13-Jan-2003 16:52:21	TP-CE REMOVES ASTORIA_GT2_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 16:00.
13-Jan-2003 16:52:58	TP-CE REMOVES ASTORIA_GT2_1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/13/2003 16:00.
13-Jan-2003 17:06:16	TP-CE REQUESTS ASTORIA GT2___, AND ASTORIA_4 NO LONGER OUT OF MERIT. AS OF 1650 HRS 01/13/03 ASTORIA_4 AND ASTORIA_GT_GRP2 ARE NO LONGER OOM.

Committed for Reliability

[back to top](#)

Insert Time	Message
13-Jan-2003 12:48:50	Generator: RAVENSWOOD___2 scheduled for local reliability in DAM market for 01/14/2003 23 Energy = 75 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
13-Jan-2003 13:53:40	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 01/14/2003 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
13-Jan-2003 13:53:43	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 01/14/2003 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
13-Jan-2003 10:47:57	Upon further review: NYISO is reserving hour beginning 23:00 in the January 11, 2003 Real-Time Market. NYISO is reserving hour beginning 23:00 in the January 11, 2003 Hour-Ahead Market to verify energy prices. Prices in the January 12, 2003 Day-Ahead Market are correct.

13-Jan-2003 15:58:14

NYISO is reserving hour beginning 16:00 in the January 12, 2003 Real-Time Market. NYISO is reserving hours beginning 0:00 - 4:00 in the January 12, 2003 Hour-Ahead Market to verify energy prices. NYISO is reserving hours beginning 7:00 and 9:00 - 23:00 in the January 12, 2003 Hour-Ahead Market to verify locational reserve prices. Prices in the January 13, 2003 Day-Ahead Market are correct.