NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
17-Feb-2003 02:27:53	PJM initiated curtailment cut 150 MWs.
17-Feb-2003 06:29:39	PJM initiated curtailment cut 255 MWs. cutting for HB7 rampPJM
17-Feb-2003 06:44:25	02/17/2003 06:43:12 NYISO SCD reserve pick-up remains active.
17-Feb-2003 06:46:42	02/17/2003 06:33:08 NYISO SCD reserve pick-up executed.
17-Feb-2003 07:02:59	ASTORIA_GT4_1 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 06:59.
17-Feb-2003 07:02:59	ASTORIA_GT4_4 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 06:59.
17-Feb-2003 07:02:59	ASTORIA_GT4_2 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 06:59.
17-Feb-2003 07:02:59	ASTORIA_GT4_3 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 06:59.
17-Feb-2003 08:11:31	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/17/2003 08:00 FOR ISO COMPUTER FAILURE.
17-Feb-2003 08:13:57	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/17/2003 08:00.
17-Feb-2003 11:02:38	GOWANUS_GT 3_GRP NO LONGER COMMITED FOR ISO RELIABILITY AFTER 02/17/2003 10:59.
17-Feb-2003 11:30:38	PJM initiated curtailment cut 175 MWs.
17-Feb-2003 11:37:15	PJM initiated curtailment cut 377 MWs.
17-Feb-2003 19:09:27	TP-LI REQUESTS PPL_SHRM_GT3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 19:00 FOR UNIT NEEDED FOR LI.
17-Feb-2003 19:38:52	TP-CE UPDATES NYPA_HARLEM__RVR__GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 19:00 FOR FOR AST E CORONA JAM. LOAD POCKET..
17-Feb-2003 19:57:08	TP-LI REQUESTS PPL_SHRM_GT4 OUT OF

	MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 20:00 FOR UNIT NEEDED FOR LI.
17-Feb-2003 19:57:40	TP-LI REMOVES PPL_SHRM_GT3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 19:00.
17-Feb-2003 19:58:28	TP-LI REMOVES PPL_SHRM_GT4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 19:00.
17-Feb-2003 20:10:32	TP-CE REQUESTS NYPA_VERNON_____GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 20:00 FOR CE WANTED UNITS OFF DUE TO GAS SHORTAGE.
17-Feb-2003 20:11:15	TP-CE REQUESTS NYPA_VERNON_____GT3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 20:00 FOR CE WANTED UNIT OFF DUE TO GAS PROBLEMS.
17-Feb-2003 21:02:59	NYPA_HARLEM__RVR__GT2 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 20:59.
17-Feb-2003 21:35:20	ISO UPDATES LOVETT___5 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 02/17/2003 21:00 FOR UNIT HAS ACCEPTED DAM BIDS, HAM BIDS WERE REJECTED, WHEN BME RAN, UNIT WAS DERATED BELOW ITS MIN GEN>0BP.
17-Feb-2003 21:36:06	TP-CE REQUESTS NYPA_HARLEM__RVR__GT1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 22:00 FOR ON FOR AST E CORONA JAMICA LOAD POCKET UNTILASTORIA 3 GET FIRM.
17-Feb-2003 21:43:17	TP-CE REQUESTS NYPA_HARLEM__RVR__GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 21:00 FOR ON FOR AST E CORONA JAMICA LOAD POCKET UNTILASTORIA 3 GET FIRM.
17-Feb-2003 22:24:28	ISO REMOVES LOVETT___5 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 02/17/2003 22:00.
17-Feb-2003 22:39:27	TP-CE REMOVES NYPA_HARLEM__RVR__GT1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 22:00.
17-Feb-2003 22:40:11	TP-CE REMOVES NYPA_HARLEM__RVR__GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/17/2003 22:00.

17-Feb-2003 23:02:37	NYPA_HARLEM__RVR__GT1 NO LONGER OOM FOR TO LOCAL SECURITY AFTER 02/17/2003 22:59.

Committed for Reliability back to top

Insert Time	Message
17-Feb-2003 11:15:05	Generator: BARRETT___1 scheduled for local reliability in DAM market for 02/18/2003 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
17-Feb-2003 11:15:07	Generator: BARRETT___1 scheduled for local reliability in DAM market for 02/18/2003 23 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
17-Feb-2003 11:16:21	Generator: BARRETT___2 scheduled for local reliability in DAM market for 02/18/2003 23 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
17-Feb-2003 11:16:57	Generator: GLENWOOD___5 scheduled for local reliability in DAM market for 02/18/2003 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices back to top

Insert Time	Message
17-Feb-2003 14:02:57	NYISO is reserving hours beginning 0:00, 8:00, 9:00 and 16:00 - 20:00 in the February 16, 2003 Real-Time Market. NYISO is reserving hours beginning 10:00 - 13:00, 15:00, 16:00, 19:00 and 21:00 in the February 16, 2003 Hour-Ahead Market to verify locational reserve prices. Prices in the February 17, 2003 Day-Ahead Market are correct.