

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)

Dispatcher Notices

[back to top](#)

| Insert Time | Message |
|----------------------|--|
| 14-Jan-2004 00:13:03 | ISO REQUESTS NORTHPORT__2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/14/2004 00:00 FOR TAKING Y49 OUT. |
| 14-Jan-2004 02:27:24 | NYISO Locational based curtailment cut 31 MWs. NE-NYISO Interface Curtailed to keep export to NE to 600MW limit. |
| 14-Jan-2004 03:23:46 | NYISO Locational based curtailment cut 28 MWs. NE-NYISO Interface Curtailed to keep export to NE to 600MW limit. |
| 14-Jan-2004 04:27:51 | NYISO Locational based curtailment cut 32 MWs. NE-NYISO Interface Curtailed to keep export to NE to 600MW limit. |
| 14-Jan-2004 05:20:26 | NYISO Locational based curtailment cut 33 MWs. NE-NYISO Interface Curtailed to keep export to NE to 600MW limit. |
| 14-Jan-2004 05:30:04 | NPX initiated curtailment added 33 MWs. |
| 14-Jan-2004 06:24:48 | PJM initiated curtailment cut 200 MWs. PJM Curtailed for ramp. |
| 14-Jan-2004 06:46:53 | 01/14/2004 06:45:42 NYISO SCD reserve pick-up remains active. |
| 14-Jan-2004 06:49:55 | 01/14/2004 06:35:41 NYISO SCD reserve pick-up executed. |
| 14-Jan-2004 07:19:01 | NYISO Locational based curtailment cut 32 MWs. |
| 14-Jan-2004 08:18:35 | NYISO Locational based curtailment cut 50 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 08:27:17 | Metering Authority - Long Island Power Authority REQUESTS FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/14/2004 08:00 FOR SYSTEM LOAD. |
| 14-Jan-2004 08:27:58 | Metering Authority - Long Island Power Authority UPDATES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/14/2004 08:00 FOR . |
| 14-Jan-2004 09:03:06 | Metering Authority - Long Island Power Authority |

| | |
|----------------------|--|
| | REMOVES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 01/14/2004 09:00. |
| 14-Jan-2004 09:19:32 | NYISO Locational based curtailment cut 52 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 11:24:53 | NYISO Locational based curtailment cut 52 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 12:22:57 | NYISO Locational based curtailment cut 11 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 15:33:38 | NYISO Locational based curtailment cut 23 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 16:21:00 | NYISO Locational based curtailment cut 54 MWs. To maintain 600MW transfer limit NY>NE. |
| 14-Jan-2004 16:43:43 | NYISO Locational based curtailment cut 255 MWs. |
| 14-Jan-2004 16:44:40 | NYISO Locational based curtailment cut 300 MWs. |
| 14-Jan-2004 18:12:12 | ISO REQUESTS OUT OF MERIT FOR ALL GENERATORS IN NEW YORK AT18:00 01/14/04 |
| 14-Jan-2004 20:37:48 | ISO REQUESTS GILBOA___1 OUT OF MERIT AT 20:00 01/14/04 |
| 14-Jan-2004 20:38:13 | ISO REQUESTS GILBOA___1 NO LONGER OUT OF MERIT. AT 20:30 01/14/04 |
| 14-Jan-2004 22:02:14 | GILBOA___2 NO LONGER COMMITED FOR ISO RELIABILITY AFTER 01/14/2004 21:59. |

Committed for Reliability

[back to top](#)

| Insert Time | Message |
|----------------------|--|
| 14-Jan-2004 10:52:43 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 00 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:45 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 01 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:46 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 02 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:47 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 03 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |

| | |
|----------------------|--|
| 14-Jan-2004 10:52:48 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 04 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:49 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 05 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:50 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 06 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:51 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 07 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:52 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 08 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:53 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 09 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:54 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 10 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:55 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 11 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:57 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 12 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:58 | Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 01/15/2004 13 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. |

| | |
|----------------------|--|
| | Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:52:59 | Generator: INDECK__ OLEAN scheduled for local reliability in DAM market for 01/15/2004 14 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:53:00 | Generator: INDECK__ OLEAN scheduled for local reliability in DAM market for 01/15/2004 15 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:54:14 | Generator: INDECK__ OLEAN scheduled for local reliability in DAM market for 01/15/2004 22 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 10:54:15 | Generator: INDECK__ OLEAN scheduled for local reliability in DAM market for 01/15/2004 23 Energy = 67 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:30 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 00 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:31 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 01 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:33 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 02 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:34 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 03 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:35 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 04 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:36 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 05 Energy = |

| | |
|----------------------|--|
| | 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:37 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 06 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:38 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 07 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:39 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 08 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:40 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 09 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:41 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 10 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:43 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 11 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:44 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 12 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:45 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 13 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:46 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 14 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |

| | |
|----------------------|--|
| 14-Jan-2004 13:32:47 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 15 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:48 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 16 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:49 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 17 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:50 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 18 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:51 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 19 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:52 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 20 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:54 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 21 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:55 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 22 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:32:56 | Generator: ARTHUR_KILL_3 scheduled for local reliability in DAM market for 01/15/2004 23 Energy = 150 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW. |
| 14-Jan-2004 13:34:08 | Generator: ASTORIA__5 scheduled for local reliability in DAM market for 01/15/2004 23 Energy = 75 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. |

Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices

[back to top](#)

| Insert Time | Message |
|----------------------|--|
| 14-Jan-2004 13:51:34 | NYISO is reserving hour beginning 07:00 in the January 13, 2004 Real-Time Market. NYISO is reserving hours beginning 09:00 and 10:00 in the January 13, 2004 Hour-Ahead Market to verify locational reserve prices. Prices in the January 14, 2004 Day-Ahead Market are correct. |