

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
13-Mar-2004 04:45:51	Metering Authority - Long Island Power Authority REQUESTS PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 04:00 FOR OCB 1350 CAUSES OVERLOAD ON 138462.
13-Mar-2004 08:20:34	03/13/2004 08:19:42 NYISO SCD reserve pick-up remains active.
13-Mar-2004 08:20:39	03/13/2004 08:09:41 NYISO SCD reserve pick-up executed.
13-Mar-2004 09:42:07	Metering Authority - Long Island Power Authority UPDATES NYPA___HOLTSVILL OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 09:00 FOR LOCAL SECURITY LOSS OF 881/882 ON 69KV.
13-Mar-2004 09:43:12	Metering Authority - Long Island Power Authority UPDATES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 09:00 FOR LOSS OF 881/882 ON 69KV.
13-Mar-2004 09:48:51	Metering Authority - Long Island Power Authority UPDATES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 09:00 FOR LOSS OF 881/882 ON 69KV.
13-Mar-2004 09:50:54	Metering Authority - Long Island Power Authority UPDATES NYPA___HOLTSVILL OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 09:00 FOR LOCAL SECURITY LOSS OF 881/882 ON 69KV.
13-Mar-2004 10:06:35	Metering Authority - Long Island Power Authority REMOVES NYPA___HOLTSVILL OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 10:00.
13-Mar-2004 10:06:56	Metering Authority - Long Island Power Authority REMOVES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 10:00.
13-Mar-2004 10:25:04	03/13/2004 10:21:17 NYISO SCD reserve pick-up executed.
13-Mar-2004 17:57:26	Metering Authority - Long Island Power Authority

	REQUESTS WADING RIVER_IC_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 17:00 FOR LOCAL SECURITY ON 881/882.
13-Mar-2004 18:33:13	03/13/2004 18:24:28 NYISO SCD reserve pick-up executed.
13-Mar-2004 18:34:49	03/13/2004 18:31:40 NYISO SCD reserve pick-up executed.
13-Mar-2004 20:26:36	Metering Authority - Consolidated Edison of NY REQUESTS RAVENSWOOD___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 20:00 FOR UNIT STABILITY FOR TUBE LEAK.
13-Mar-2004 21:09:07	Metering Authority - Consolidated Edison of NY UPDATES RAVENSWOOD___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 21:00 FOR UNIT STABILITY FOR TUBE LEAK.
13-Mar-2004 22:20:04	Metering Authority - Long Island Power Authority REMOVES WADING RIVER_IC_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/13/2004 22:00.

Committed for Reliability

[back to top](#)

Insert Time	Message
13-Mar-2004 11:17:27	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 03/14/2004 21 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
13-Mar-2004 11:17:29	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 03/14/2004 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
13-Mar-2004 11:17:30	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 03/14/2004 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
13-Mar-2004 12:13:00	NYISO is reserving hours beginning 18:00 and 20:00 in the March 12, 2004 Real-Time Market. Prices in the March 12, 2004 Hour-Ahead Market are correct. Prices in the March 13, 2004 Day-Ahead Market are correct.