NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
23-May-2004 08:38:19	PJM initiated curtailment cut 100 MWs.
23-May-2004 09:35:45	PJM initiated curtailment cut 100 MWs.
23-May-2004 10:17:19	05/23/2004 10:16:06 NYISO SCD reserve pick-up remains active.
23-May-2004 10:17:23	05/23/2004 10:06:05 NYISO SCD reserve pick-up executed.
23-May-2004 13:51:52	ISO REQUESTS WADING RIVER_IC_1 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 05/23/2004 13:00 FOR Y50 >ACT, AND Y50 >POST LTE FOR LOSS Y49.
23-May-2004 15:19:22	ISO REQUESTS DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/23/2004 15:00 FOR 68 & 69 LINE OVER ACTUAL.
23-May-2004 15:20:02	ISO REQUESTS DUNKIRK___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/23/2004 15:00 FOR 68 & 69 LINE OVER ACTUAL.
23-May-2004 15:23:29	ISO REQUESTS WADING RIVER_IC_2 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 05/23/2004 16:00 FOR MIN RUN TIME.
23-May-2004 15:40:18	Metering Authority - Long Island Power Authority REQUESTS PPL_SHRM_GT3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 15:00 FOR LOSS OFGLENWOOD GT.
23-May-2004 16:18:17	ISO UPDATES WADING RIVER_IC_2 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 05/23/2004 16:00 FOR MIN RUN TIME, 66 MW DUE TO AMBIENT TEMP.
23-May-2004 16:18:54	ISO UPDATES WADING RIVER_IC_1 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 05/23/2004 16:00 FOR Y50 >ACT, AND Y50 >POST LTE FOR LOSS Y49.
23-May-2004 17:27:21	ISO REMOVES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/23/2004 17:00.

23-May-2004 17:27:41	ISO REMOVES DUNKIRK___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/23/2004 17:00.
23-May-2004 17:43:13	OH initiated curtailment cut 100 MWs.
23-May-2004 18:02:15	WADING RIVER_IC_2 NO LONGER OOM FOR ISO SECURITY AFTER 05/23/2004 17:59.
23-May-2004 21:29:12	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:12	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:12	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_7 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_8 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:29:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT1_5 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231.
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_1 OUT OF MERIT.

	OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_5 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_7 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:13	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 21:30:14	Metering Authority - Consolidated Edison of NY REQUESTS GOWANUS_GT2_8 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/23/2004 21:00 FOR SCHEDULED WORK ON 31231..
23-May-2004 22:07:22	ISO REMOVES WADING RIVER_IC_1 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 05/23/2004 22:00.
23-May-2004 22:37:33	NYISO Locational based curtailment cut 100 MWs.

Committed for Reliability back to top

Insert Time	Message
23-May-2004 11:18:09	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 00 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW.

	Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:10	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 01 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:11	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 02 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:12	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 03 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:13	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 04 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:15	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 05 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:16	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 06 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:17	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 07 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:18	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 08 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:19	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 09 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:20	Generator: INDECK___OLEAN scheduled for local

	reliability in DAM market for 05/24/2004 10 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:21	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 11 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:22	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 12 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:23	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 13 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:24	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 14 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:25	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 15 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:26	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 16 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:27	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 17 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 18 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:29	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 19 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

23-May-2004 11:18:31	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 20 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:32	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 21 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:33	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 22 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 11:18:34	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 05/24/2004 23 Energy = 63 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:02:14	Generator: RAVENSWOOD___1 scheduled for local reliability in DAM market for 05/24/2004 23 Energy = 75 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:05:36	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/24/2004 23 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:06:11	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 05/24/2004 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:02	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 09 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:03	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 10 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:04	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 11 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW.

	Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:05	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 12 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:06	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 13 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:07	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 14 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:08	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 15 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:10	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 16 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:11	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 17 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:12	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 18 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:13	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 19 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:14	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 20 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:15	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 21 Energy =

	90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:16	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 22 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 12:12:17	Generator: ARTHUR_KILL_2 scheduled for local reliability in DAM market for 05/24/2004 23 Energy = 90 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:36	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 00 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:38	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 01 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:39	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 02 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:40	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 03 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:41	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 04 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:42	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 05 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
23-May-2004 15:25:44	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 06 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

23-May-2004 15:25:45	Generator: ASTORIA___2 scheduled for local reliability in DAM market for 05/24/2004 07 Energy = 65 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices back to top

Insert Time	Message
23-May-2004 14:41:10	NYISO is reserving hours beginning 0:00 through 12:00 in the May 22, 2004 Real-Time Market. Prices in the May 22, 2004 Hour-Ahead Market are correct. Prices in the May 23, 2004 Day-Ahead Market are correct.