NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
03-Oct-2004 07:40:59	Metering Authority - Consolidated Edison of NY REQUESTS POLETTI____ OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/03/2004 07:00 FOR CON EDISON LIMITING UPPER OPERATING LIMIT ON POLETTI DUE TO POST CONTINGENCY LOADING ON TRANSFORMER BANK #17 @ E.13TH STREET W/ THE LOSS OF B47 E.13TH STREET TO FARRAGUT..
03-Oct-2004 08:02:14	GILBOA___4 NO LONGER ISO VOLTAGE SUPPORT AFTER 10/03/2004 07:59.
03-Oct-2004 15:08:20	PJM initiated curtailment cut 50 MWs. TAG DENIED IN E-TAG
03-Oct-2004 18:04:10	Metering Authority - Consolidated Edison of NY REMOVES POLETTI____ OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/03/2004 18:00.
03-Oct-2004 19:12:39	ISO REQUESTS HOLTSVILLE_IC_5 OUT OF MERIT. OOM FOR ISO SECURITY AT START TIME 10/03/2004 19:00 FOR Y-49 OVER NORMAL.
03-Oct-2004 19:33:19	Metering Authority - Consolidated Edison of NY REMOVES ASTORIA___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/05/2004 00:00.
03-Oct-2004 21:36:20	Metering Authority - Consolidated Edison of NY REMOVES ASTORIA___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/05/2004 20:00.
03-Oct-2004 23:16:03	Metering Authority - Consolidated Edison of NY REMOVES ASTORIA___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/05/2004 22:00.

Committed for Reliability back to top

Insert Time	Message
03-Oct-2004 11:54:15	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 06 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW.

	Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:16	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 07 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:18	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 08 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:19	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 09 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:20	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 10 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:21	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 11 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:22	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 12 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:23	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 13 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:24	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 14 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:25	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 15 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:26	Generator: GLENWOOD___4 scheduled for local

	reliability in DAM market for 10/04/2004 16 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:27	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 17 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:28	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 18 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:29	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 19 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:31	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 20 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:32	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 21 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:33	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 22 Energy = 40 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 11:54:34	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 10/04/2004 23 Energy = 20 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:37	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 00 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:39	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 01 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

03-Oct-2004 12:46:40	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 02 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:41	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 03 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:43	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 04 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:44	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 05 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:45	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 06 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:46	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 07 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:47	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 08 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:48	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 09 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:49	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 10 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:50	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 11 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW.

	Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:51	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 12 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:53	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 13 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:54	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 14 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:55	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 15 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:56	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 16 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:57	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 17 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:58	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 18 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:46:59	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 19 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:47:00	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 20 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:47:01	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 21 Energy =

	60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:47:03	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 22 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.
03-Oct-2004 12:47:04	Generator: EAST RIVER___7 scheduled for local reliability in DAM market for 10/04/2004 23 Energy = 60 MW. Regulation = MW. Min10 Spinning = MW. Min10 Nonsynch = MW. Min30 Spinning = MW. Min30 Nonsynch = MW. Operating Cap = MW.

Market Monitor Notices back to top

Insert Time	Message
03-Oct-2004 13:11:26	NYISO is reserving hours beginning 04:00, 17:00, 18:00 and 21:00 in the October 02, 2004 Real-Time Market. Prices in the October 02, 2004 Hour-Ahead Market are correct. Prices in the October 03, 2004 Day-Ahead Market are correct.