NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
06-May-2005 10:27:53	ISO REQUESTS BARRETT___2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 10:00 FOR 262 OVER POST CONTINGENCY FOR LOSS OF NEWBRG 461 AND BK 6 OR 8..
06-May-2005 10:37:42	05/06/2005 10:35:59 NYISO large event reserve pick-up executed.
06-May-2005 10:40:51	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 10:00 FOR OOM FOR RPU (UP 200 FROM 2150 TO 2350)..
06-May-2005 10:42:41	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 10:00.
06-May-2005 10:53:40	ISO REMOVES BARRETT___2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 11:00.
06-May-2005 11:53:05	ISO REQUESTS POLETTI____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 11:00 FOR PLACING POLETTI OOM AND SENDING UNIT UP TO BASEPOINT (BASEPOINT JUMPED FROM MIN GEN UP TO 650+) - DUE TO DATABASE UPDATES..
06-May-2005 12:03:32	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 12:00 FOR .
06-May-2005 12:14:44	ISO UPDATES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 12:00 FOR ACE > +500 MWS - REDUCED NIAGARA DOWN 200MWS. AT 1208 REDUCED NIAGARA ANOTHER 150MWS TO 1750..
06-May-2005 12:19:22	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 12:00.
06-May-2005 12:28:17	ISO REMOVES POLETTI____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/06/2005 13:00.

06-May-2005 22:36:51	Metering Authority - Consolidated Edison of NY REQUESTS EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/06/2005 22:00 FOR SUPPLYING STEAM FOR CON ED.

Committed for Reliability back to top

Insert Time	Message
06-May-2005 11:03:23	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 00 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:25	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 01 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:26	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 02 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:26	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 03 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:27	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 04 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:27	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 06 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:27	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 05 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0

	MW.
06-May-2005 11:03:28	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 07 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:28	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 10 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:28	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 09 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:28	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 08 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:29	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 11 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:29	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 12 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:29	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 14 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:29	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 13 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

06-May-2005 11:03:30	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 15 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:30	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 18 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:30	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 17 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:30	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 16 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:31	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 19 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:31	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 20 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:31	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 22 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:31	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/07/2005 21 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:03:32	Generator: ASTORIA___3 scheduled for local

	reliability in DAM market for 05/07/2005 23 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:38	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 00 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:38	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 01 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:39	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 02 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:39	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 03 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:39	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 04 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:40	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 05 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:40	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 07 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:40	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 08 Energy =

	40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:40	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 06 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:41	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 09 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:41	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 10 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:41	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 11 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:42	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 12 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:42	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 14 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:42	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 13 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:43	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 15 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0

	MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:43	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 18 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:43	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 17 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:43	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 16 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:44	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 19 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:44	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 20 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:44	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 22 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:44	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 21 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:04:45	Generator: BARRETT___1 scheduled for local reliability in DAM market for 05/07/2005 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0

	MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 11:06:32	Generator: BARRETT___2 scheduled for local reliability in DAM market for 05/07/2005 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:11	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 18 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:11	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 19 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:11	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 20 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:11	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 22 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:11	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 21 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:23:12	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/06/2005 23 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:24:58	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 00 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0

	MW.
06-May-2005 16:24:58	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 02 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:24:58	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 03 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 16:24:58	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 01 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 04 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 05 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 07 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 06 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 08 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 10 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 12 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 14 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 13 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 11 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:20	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 09 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 15 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 16 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local

	reliability in DAM market for 05/07/2005 18 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 20 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 22 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 23 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 21 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 19 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 17:25:21	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 05/07/2005 17 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 20:17:41	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/06/2005 22 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
06-May-2005 20:17:42	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/06/2005 23 Energy =

	75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message
06-May-2005 15:51:17	NYISO is reserving hours beginning 1:00 thru 6:00, 8:00, 9:00, 15:00, 20:00, 21:00, 22:00 and 23:00 in the May 5, 2005 Real-Time Market, encompassing Energy, Regulation and Operating Reserve prices. NYISO is reserving hours beginning 9:00, 15:00 and 21:00 in the May 5, 2005 Hour-Ahead Market, encompassing Energy, Regulation and Operating Reserve prices. Prices in the May 6, 2005 Day-Ahead Market are correct. message 1 of 2
06-May-2005 15:52:02	The NYISO and LECG have determined that there may be an incorrect calculation of LBMPs on the proxy buses necessitating the reservations in Real Time for HB 1:00 thru 6:00, 22:00 and 23:00. Additionally, the following subset of hours are reserved in the Real Time Market for other reasons: Hours beginning 8:00, 9:00, 15:00, 20:00, 21:00 and 22:00. message 2 of 2