NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
19-Feb-2006 01:13:50	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 01:00 FOR Steam System Security.
19-Feb-2006 06:16:13	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 06:00 FOR steam system sendout.
19-Feb-2006 06:47:41	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 06:00 FOR steam system sendout.
19-Feb-2006 07:24:40	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 07:00 FOR steam system sendout.
19-Feb-2006 07:36:47	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 07:00 FOR steam system sendout.
19-Feb-2006 09:10:47	ISO REQUESTS BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/19/2006 09:00 FOR Loss of bus 2 at Barrett on to 138_262.
19-Feb-2006 10:25:23	ISO UPDATES BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/19/2006 10:00 FOR Loss of bus 2 at Barrett on to 138_262 & 262 over normal.
19-Feb-2006 11:04:35	ISO UPDATES BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/19/2006 11:00 FOR Loss of bus 2 at Barrett on to 138_262 & 262 over normal.
19-Feb-2006 19:13:53	ISO UPDATES BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/19/2006 19:00 FOR Loss of bus 2 at Barrett on to 138_262 & 262 over normal.
19-Feb-2006 19:24:01	ISO UPDATES BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START

	TIME 02/19/2006 19:00 FOR Loss of bus 2 at Barrett on to 138_262 & 262 over normal.
19-Feb-2006 22:31:47	ISO REMOVES BARRETT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 02/19/2006 22:00.
19-Feb-2006 22:53:45	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 02/19/2006 22:00 FOR steam system sendout.

Committed for Reliability back to top

Insert Time	Message
19-Feb-2006 10:53:33	Generator: POLETTI____ scheduled for local reliability in DAM market for 02/20/2006 22 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
19-Feb-2006 10:53:34	Generator: POLETTI____ scheduled for local reliability in DAM market for 02/20/2006 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message
19-Feb-2006 13:49:44	NYISO is reserving HB 07 and 18 EST in the February 18, 2006 Real-Time Market, encompassing Energy, Regulation and Operating Reserves. Prices in the February 18, 2006 Hour-Ahead Market are correct. Prices in the February 19, 2006 Day-Ahead Market are correct.