

# NYISO Operational Announcements

[Dispatcher Notices](#)  
[Committed for Reliability](#)  
[Market Monitor Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
03-Mar-2006 00:09:59	OH initiated curtailment cut 63 MWs.
03-Mar-2006 01:47:26	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 01:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 01:47:57	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 01:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 04:07:06	ISO REQUESTS GILBOA___1 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 03/03/2006 04:00 FOR RTD/RTC INFO CONFLICTING, CYCLING UNIT AT 1/2 HOUR INTERVALS, CANNOT DETERMINE CAUSE..
03-Mar-2006 04:09:37	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 04:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 04:10:28	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 04:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 04:25:15	ISO REMOVES GILBOA___1 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 03/03/2006 04:00.
03-Mar-2006 06:19:08	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 06:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 06:19:34	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 06:00 FOR STEAM SYSTEM SECURITY.

03-Mar-2006 07:04:16	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 07:00 FOR .
03-Mar-2006 07:05:10	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 07:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 07:22:40	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 07:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 08:16:50	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 08:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 08:29:10	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 08:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 08:57:32	Metering Authority - Consolidated Edison of NY REQUESTS BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 08:00 FOR IF CB 1 FAILS, 32711 OVERLOADS..
03-Mar-2006 08:58:22	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 08:00 FOR IF CB 1 FAILS, 32711 OVERLOADS. CANNOT BE CONTROLLED BY LOAD POCKET..
03-Mar-2006 09:05:49	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 09:00 FOR IF CB 1 HUDSON AVE FAILS, 32711 OVERLOADS. CANNOT BE CONTROLLED BY LOAD POCKET..
03-Mar-2006 09:08:24	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 09:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 10:17:40	Metering Authority - Consolidated Edison of NY <del>UPDATES EAST RIVER___6 OUT OF MERIT.</del> OOM FOR TO LOCAL SECURITY AT START

	TIME 03/03/2006 10:00 FOR STEAM SYSTEM SECURITY.
03-Mar-2006 16:30:22	Metering Authority - Consolidated Edison of NY REMOVES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 03/03/2006 16:00.

Committed for Reliability

[back to top](#)

Insert Time	Message
03-Mar-2006 10:43:00	Generator: BARRETT___1 scheduled for local reliability in DAM market for 03/04/2006 22 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
03-Mar-2006 10:43:00	Generator: BARRETT___1 scheduled for local reliability in DAM market for 03/04/2006 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
03-Mar-2006 10:47:13	Generator: POLETTI_____ scheduled for local reliability in DAM market for 03/04/2006 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
03-Mar-2006 16:06:31	Prices in the March 02, 2006 Real-Time Market, encompassing Energy, Regulation and Operating Reserves are correct. Prices in the March 02, 2006 Hour-Ahead Market are correct. Prices in the March 03, 2006 Day-Ahead Market are correct.
03-Mar-2006 18:07:06	The Real Time Energy prices have been updated in the MIS for 03/01/2006 in hours (03,12,13)
03-Mar-2006 18:07:08	The Real Time ANCILLARY prices have been updated in the MIS for 03/01/2006 in hours (03,12,13)
03-Mar-2006 18:20:37	The Hour Ahead Market (HAM) Energy prices have been updated in the MIS for 03/01/2006 in hours (12,13)
03-Mar-2006 18:20:38	The Hour Ahead Market (HAM) ANCILLARY prices have been updated in the MIS for 03/01/2006 in hours (12,13)