NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
02-May-2006 09:19:03	Metering Authority - Long Island Power Authority UPDATES NORTHPORT___3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/01/2006 23:00 FOR prev code(Gen Derate), Modified existing OOM to accommodate SRE entry. Locust Grove 558/559 outage. sre entered by tsa pv.
02-May-2006 21:11:31	Metering Authority - Consolidated Edison of NY REQUESTS EAST RIVER___6 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/02/2006 21:00 FOR STEAM SYSTEM SECURITY.

Committed for Reliability back to top

Insert Time	Message
02-May-2006 10:44:48	Generator: POLETTI____ scheduled for local reliability in DAM market for 05/03/2006 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-May-2006 11:41:42	Generator: NORTHPORT___3 scheduled for local reliability in DAM market for 05/03/2006 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-May-2006 11:42:02	Generator: NORTHPORT___4 scheduled for local reliability in DAM market for 05/03/2006 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-May-2006 11:42:21	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 05/03/2006 22 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-May-2006 11:42:21	Generator: FAR ROCKAWAY___4 scheduled for

	local reliability in DAM market for 05/03/2006 23 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message
02-May-2006 15:03:06	NYISO is reserving hours beginning 8 and 15 in the May 1, 2006 Real-Time Market, encompassing Energy, Regulation and Operating Reserve prices. Prices in the May 1, 2006 Hour-Ahead Market are correct. Prices in the May 2, 2006 Day-Ahead Market are correct.
02-May-2006 17:51:59	The Real Time Energy prices have been updated in the MIS for 05/01/2006 in hours (08,15)