NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
10-May-2006 00:12:49	ISO REQUESTS NYPA___ASTORIA_CC1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/10/2006 00:00 FOR COMMITMENT ISSUE W/ MODEL.
10-May-2006 02:18:43	NPX initiated curtailment cut 166 MWs.
10-May-2006 04:21:49	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 04:00 FOR Steam send out.
10-May-2006 05:06:25	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 05:00 FOR Steam send out.
10-May-2006 06:06:59	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 06:00 FOR Steam send out.
10-May-2006 06:46:33	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 06:00 FOR Steam send out.
10-May-2006 07:25:00	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 07:00 FOR Steam send out.
10-May-2006 11:32:54	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 11:00 FOR Steam send out.
10-May-2006 13:45:22	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 13:00 FOR Steam send out.
10-May-2006 15:22:31	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 15:00 FOR Steam send out.
10-May-2006 16:17:22	Metering Authority - Consolidated Edison of NY

	UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 05/10/2006 16:00 FOR Steam send out.
10-May-2006 20:40:07	ISO REQUESTS PORT_JEFF_4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/10/2006 20:00 FOR LOSS OF NORTHPORT UNITS ON 462 AND 463.
10-May-2006 22:43:44	ISO REMOVES PORT_JEFF_4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 05/10/2006 22:00.

Committed for Reliability back to top

Insert Time	Message
10-May-2006 10:36:37	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/11/2006 23 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
10-May-2006 10:37:31	Generator: POLETTI____ scheduled for local reliability in DAM market for 05/11/2006 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
10-May-2006 10:38:07	Generator: RAVENSWOOD___4 scheduled for local reliability in DAM market for 05/11/2006 23 Energy = 125 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
10-May-2006 10:38:38	Generator: ASTORIA___3 scheduled for local reliability in DAM market for 05/11/2006 22 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message
10-May-2006 16:38:16	NYISO is reserving hours beginning 4, 5, 6, 9 and 10 in the May 9, 2006 Real-Time Market, encompassing Energy, Regulation and Operating Reserve prices. NYISO is reserving hours beginning 4, 5, 9 and 10 in the May 9, 2006 Hour-Ahead Market. Prices in the May 10, 2006 Day-Ahead Market are correct.