

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
26-Oct-2006 02:01:22	ISO REQUESTS NORTHPORT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 02:00 FOR SCB CONTINGENCY FOR LOSS OF BRKR 1350 @ EGC ON 138 KV 463 OVER LTE..
26-Oct-2006 02:01:49	ISO REQUESTS NORTHPORT___2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 02:00 FOR SCB CONTINGENCY FOR LOSS OF BRKR 1350 @ EGC ON 138 KV 463 OVER LTE..
26-Oct-2006 02:02:05	ISO REQUESTS NORTHPORT___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 02:00 FOR SCB CONTINGENCY FOR LOSS OF BRKR 1350 @ EGC ON 138 KV 463 OVER LTE..
26-Oct-2006 04:51:41	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 04:00 FOR Con Ed steam.
26-Oct-2006 04:52:50	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 04:00 FOR Con Ed steam.
26-Oct-2006 05:16:12	ISO REMOVES NORTHPORT___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 05:00.
26-Oct-2006 05:16:28	ISO REMOVES NORTHPORT___2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 05:00.
26-Oct-2006 05:16:54	ISO REMOVES NORTHPORT___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 10/26/2006 05:00.
26-Oct-2006 06:09:27	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 06:00 FOR Con Ed steam.
26-Oct-2006 06:09:45	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT.

	OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 06:00 FOR Con Ed steam.
26-Oct-2006 06:10:03	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER__2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 06:00 FOR Con Ed steam.
26-Oct-2006 06:14:19	10/26/2006 06:11:39 NYISO large event reserve pick-up executed.
26-Oct-2006 09:32:51	Metering Authority - Long Island Power Authority UPDATES FAR ROCKAWAY__4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/25/2006 18:00 FOR Nothing had to be done, already in system for TO Local Secyrity. TSA PV. 69KV CONTINGENCY.
26-Oct-2006 09:56:57	Metering Authority - Long Island Power Authority UPDATES FAR ROCKAWAY__4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/25/2006 18:00 FOR 69KV CONTINGENCY.
26-Oct-2006 09:58:42	Metering Authority - Long Island Power Authority UPDATES FAR ROCKAWAY__4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/25/2006 22:00 FOR In system for TO Local Security nothing has to be changed, TSA PV Record deleted in current hour..
26-Oct-2006 14:35:29	Metering Authority - Long Island Power Authority UPDATES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 14:00 FOR 881/882 LOSS ON 69KV.
26-Oct-2006 14:36:55	Metering Authority - Long Island Power Authority UPDATES PORT_JEFF_4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 14:00 FOR LOSS OF 881/882 ON 69KV.
26-Oct-2006 15:55:58	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 15:00 FOR LOSS OF 862 ON BK8 PORT JEFF.
26-Oct-2006 16:28:24	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 16:00 FOR LOSS OF 862 ON BK 8 AT PORT JEFF.
26-Oct-2006 16:42:01	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 16:00 FOR LOSS OF 862 ON BK 8 AT PORT JEFF.

26-Oct-2006 16:42:16	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 16:00 FOR LOSS OF 862 ON BK8 PORT JEFF.
26-Oct-2006 16:51:03	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 16:00 FOR LOSS OF 862 ON BK 8 AT PORT JEFF.
26-Oct-2006 17:00:21	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00 FOR LOSS OF 862 ON BK8 PORT JEFF.
26-Oct-2006 17:00:43	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00 FOR LOSS OF 862 ON BK 8 AT PORT JEFF.
26-Oct-2006 17:11:51	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00 FOR .
26-Oct-2006 17:13:05	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00 FOR LOSS OF 862 ON BK8 PORT JEFF.
26-Oct-2006 17:20:17	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00.
26-Oct-2006 17:20:27	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00.
26-Oct-2006 17:20:36	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00.
26-Oct-2006 17:21:05	Metering Authority - Long Island Power Authority REMOVES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 17:00.
26-Oct-2006 17:21:17	Metering Authority - Long Island Power Authority REMOVES PORT_JEFF_4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME

	10/26/2006 17:00.
26-Oct-2006 18:02:53	Metering Authority - Long Island Power Authority UPDATES HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 18:00 FOR . LOSS OF 881/882 ON 69KV 758.
26-Oct-2006 18:23:39	Metering Authority - Niagara Mohawk REQUESTS OXBOW___ OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 18:00 FOR WALCK RD-HUNTLEY CONTINGENCY.
26-Oct-2006 18:27:52	Metering Authority - Niagara Mohawk REMOVES OXBOW___ OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 18:00.
26-Oct-2006 18:58:46	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 19:00 FOR . LOSS OF 881/882 ON 69KV 758.
26-Oct-2006 19:15:22	NPX initiated curtailment cut 162 MWs.
26-Oct-2006 19:39:36	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 20:00 FOR . LOSS OF 881/882 ON 69KV 758.
26-Oct-2006 19:48:31	Metering Authority - Long Island Power Authority REQUESTS FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 19:00 FOR LOSS OF BANK 6 @ VALLEY STREAM ON 69KV 361 OVER LTE..
26-Oct-2006 20:34:51	Metering Authority - Long Island Power Authority REMOVES FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 20:00.
26-Oct-2006 20:35:04	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 21:00 FOR . LOSS OF 881/882 ON 69KV 758.
26-Oct-2006 20:50:46	Metering Authority - Long Island Power Authority REQUESTS PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 20:00 FOR LOSS OF 881/882 ON 69KV 758 OVER POST LTE..
26-Oct-2006 20:51:17	Metering Authority - Long Island Power Authority REQUESTS PORT_JEFF_4 OUT OF MERIT. OOM

	FOR TO LOCAL SECURITY AT START TIME 10/26/2006 20:00 FOR LOSS OF 881/882 ON 69KV 758 OVER POST LTE..
26-Oct-2006 21:10:43	Metering Authority - Long Island Power Authority REMOVES PORT_JEFF_3 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 21:00.
26-Oct-2006 21:10:51	Metering Authority - Long Island Power Authority REMOVES PORT_JEFF_4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 21:00.
26-Oct-2006 21:24:10	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_10 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/26/2006 21:00.

Committed for Reliability

[back to top](#)

Insert Time	Message
26-Oct-2006 10:20:46	Generator: POLETTI___ scheduled for local reliability in DAM market for 10/27/2006 22 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
26-Oct-2006 10:20:46	Generator: POLETTI___ scheduled for local reliability in DAM market for 10/27/2006 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
26-Oct-2006 10:21:08	Generator: RAVENSWOOD___4 scheduled for local reliability in DAM market for 10/27/2006 23 Energy = 160 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
26-Oct-2006 11:08:56	Generator: BARRETT___1 scheduled for local reliability in DAM market for 10/27/2006 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
26-Oct-2006 11:09:15	Generator: BARRETT___2 scheduled for local reliability in DAM market for 10/27/2006 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

26-Oct-2006 11:09:40	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 10/27/2006 22 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
26-Oct-2006 11:09:40	Generator: FAR ROCKAWAY___4 scheduled for local reliability in DAM market for 10/27/2006 23 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
26-Oct-2006 14:02:36	Prices in the 25 October 2006 Real-Time Market encompassing Energy, Regulation and Operating Reserves are correct. Prices in the 25 October 2006 Hour-Ahead Market are correct. Prices in the 27 October 2006 Day-Ahead Market are correct.