

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
11-Oct-2006 00:22:44	OH initiated curtailment cut 298 MWs.
11-Oct-2006 00:38:39	ISO REQUESTS DUNKIRK___3 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 00:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 00:39:30	ISO REQUESTS DUNKIRK___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 00:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 01:11:05	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 01:00 FOR CON ED SYSTEM STEAM.
11-Oct-2006 01:12:07	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 01:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 01:12:19	ISO UPDATES DUNKIRK___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 01:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 01:25:37	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 01:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 01:25:50	ISO UPDATES DUNKIRK___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 01:00 FOR CASCADE LOSS OF 73 ON 74.
11-Oct-2006 05:11:15	ISO REMOVES DUNKIRK___3 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 05:00.
11-Oct-2006 05:11:23	ISO REMOVES DUNKIRK___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 05:00.
11-Oct-2006 06:25:52	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF

	MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 06:00 FOR CON ED SYSTEM STEAM.
11-Oct-2006 06:49:26	Metering Authority - Long Island Power Authority REQUESTS FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 06:00 FOR 69KV CONT.
11-Oct-2006 06:53:35	Metering Authority - Long Island Power Authority REQUESTS BARRETT___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 06:00 FOR 69KV CONT.
11-Oct-2006 07:07:21	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 07:00 FOR CON ED SYSTEM STEAM.
11-Oct-2006 10:37:57	Metering Authority - Consolidated Edison of NY UPDATES EAST_RIVER___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/06/2006 18:00 FOR Modified existing OOM, prev code (Gen Derate), this change is per the operational announcements. Offline entered by tsa PV.
11-Oct-2006 11:06:51	Metering Authority - Long Island Power Authority UPDATES BARRETT___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 11:00 FOR 69KV CONT.
11-Oct-2006 11:07:15	Metering Authority - Long Island Power Authority UPDATES BARRETT___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 11:00 FOR .
11-Oct-2006 11:12:57	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 11:00 FOR CON ED SYSTEM STEAM.
11-Oct-2006 11:33:10	Metering Authority - Long Island Power Authority UPDATES FPL FAR_ROCK_GT1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 11:00 FOR loss of bk 6 onto 69kv @ valley stream.
11-Oct-2006 14:23:45	Metering Authority - Long Island Power Authority UPDATES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 14:00 FOR loss of bank 6 onto 69kv at valley stream.
11-Oct-2006 19:32:56	Metering Authority - Long Island Power Authority UPDATES BARRETT___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME

	10/11/2006 19:00 FOR 69KV CONT.
11-Oct-2006 19:33:10	Metering Authority - Long Island Power Authority UPDATES BARRETT___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 19:00 FOR .
11-Oct-2006 20:41:07	Metering Authority - Consolidated Edison of NY UPDATES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 20:00 FOR CON ED SYSTEM STEAM.
11-Oct-2006 21:01:25	The NYISO has experienced a problem with RTC posting
11-Oct-2006 21:38:21	Metering Authority - Long Island Power Authority REMOVES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 21:00.
11-Oct-2006 22:06:30	ISO REQUESTS BOWLINE___1 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 10/11/2006 22:00 FOR Unit came off-line during comp outage.
11-Oct-2006 22:14:47	Metering Authority - Long Island Power Authority REMOVES BARRETT___1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 22:00.
11-Oct-2006 22:14:48	Metering Authority - Long Island Power Authority UPDATES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 22:00 FOR . Record deleted in evaluating hour..
11-Oct-2006 22:14:56	Metering Authority - Long Island Power Authority REMOVES BARRETT___2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 22:00.
11-Oct-2006 22:20:37	Metering Authority - Long Island Power Authority REMOVES FPL FAR_ROCK_GT1 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 22:00.
11-Oct-2006 22:20:52	Metering Authority - Long Island Power Authority REMOVES FPL FAR_ROCK_GT2 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 22:00.
11-Oct-2006 23:20:42	Metering Authority - Long Island Power Authority REMOVES FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO LOCAL SECURITY AT START TIME 10/11/2006 23:00.

Insert Time	Message
11-Oct-2006 10:50:14	Generator: NORTHPORT___3 scheduled for local reliability in DAM market for 10/12/2006 21 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Oct-2006 10:50:15	Generator: NORTHPORT___3 scheduled for local reliability in DAM market for 10/12/2006 22 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Oct-2006 10:50:15	Generator: NORTHPORT___3 scheduled for local reliability in DAM market for 10/12/2006 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
11-Oct-2006 15:33:45	NYISO is reserving hour beginning 12 in the October 10, 2006 Real-Time Market, encompassing Energy, Regulation and Operating Reserve prices. Prices in the October 10, 2006 Hour-Ahead Market are correct. Prices in the October 12, 2006 Day-Ahead Market are correct.