NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices

Dispatcher Notices back to top

Insert Time	Message
11-Jun-2009 04:41:58	O H initiated curtailment cut 100 MWs. 06/11/2009 04:41 EDT
11-Jun-2009 08:48:24	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 08:00 FOR P/C LOADING.
11-Jun-2009 08:49:08	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 08:00 FOR 120 OOM DUE TO P/C LOADING 143 DERATE DUE TO HIGH PRESSURE LEAK.
11-Jun-2009 09:02:48	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR 120 OOM DUE TO P/C LOADING 143 DERATE DUE TO HIGH PRESSURE LEAK.
11-Jun-2009 09:03:02	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:09:57	ISO REQUESTS DUNKIRK___1 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:10:30	ISO REQUESTS DUNKIRK___2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:11:09	ISO REQUESTS DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:11:50	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:12:23	ISO REQUESTS DUNKIRK___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:18:26	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:18:41	ISO UPDATES DUNKIRK___4 OUT OF MERIT.

	COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:23:53	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:24:33	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:29:34	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:30:21	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:30:41	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:30:58	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADINGS.
11-Jun-2009 09:31:23	Metering Authority - Niagara Mohawk UPDATES HUNTLEY___67 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR 120 OOM DUE TO P/C LOADING 143 DERATE DUE TO HIGH PRESSURE LEAK.
11-Jun-2009 09:31:41	Metering Authority - Niagara Mohawk UPDATES HUNTLEY___68 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR P/C LOADING.
11-Jun-2009 09:51:00	Metering Authority - Niagara Mohawk REQUESTS NIAGARA____ OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 09:00 FOR 115KV P/C LOADING.
11-Jun-2009 10:20:09	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADING.
11-Jun-2009 10:20:31	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADING.
11-Jun-2009 10:20:48	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___3 OUT OF MERIT. OOM FOR TO

	RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADINGS.
11-Jun-2009 10:21:15	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADINGS.
11-Jun-2009 10:22:07	Metering Authority - Niagara Mohawk UPDATES HUNTLEY___68 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADING.
11-Jun-2009 10:25:56	Metering Authority - Niagara Mohawk UPDATES NIAGARA____ OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR 115KV P/C LOADING.
11-Jun-2009 10:46:12	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADING.
11-Jun-2009 10:46:35	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADING.
11-Jun-2009 10:48:19	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 10:00 FOR P/C LOADINGS.
11-Jun-2009 11:01:24	Metering Authority - Long Island Power Authority REQUESTS FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 11:00 FOR 69KV SECURITY.
11-Jun-2009 11:02:43	Metering Authority - Long Island Power Authority UPDATES FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 11:00 FOR 33KV SECURITY.
11-Jun-2009 11:12:21	Metering Authority - Niagara Mohawk UPDATES NIAGARA____ OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 11:00 FOR 115KV P/C LOADING.
11-Jun-2009 11:30:55	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 11:00 FOR OOM P/C LOADINGS DERATED TO 170 DUE TO COAL QUALITY.
11-Jun-2009 13:23:38	Metering Authority - Niagara Mohawk REMOVES DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00.
11-Jun-2009 13:23:38	Metering Authority - Niagara Mohawk REMOVES

	DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00.
11-Jun-2009 13:24:06	Metering Authority - Niagara Mohawk UPDATES DUNKIRK___3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00 FOR COAL QUALITY.
11-Jun-2009 13:24:52	Metering Authority - Niagara Mohawk REMOVES DUNKIRK___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00.
11-Jun-2009 13:25:47	Metering Authority - Niagara Mohawk REMOVES HUNTLEY___68 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00.
11-Jun-2009 13:26:01	Metering Authority - Niagara Mohawk REMOVES NIAGARA____ OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/11/2009 13:00.
11-Jun-2009 14:33:14	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 14:00 FOR COAL QUALITY. MINGEN OOM FOR P/C LOADING..
11-Jun-2009 14:34:09	ISO REQUESTS DUNKIRK___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 14:00 FOR P/C LOADING.
11-Jun-2009 14:35:11	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 14:00 FOR P/C LOADING.
11-Jun-2009 14:43:46	ISO UPDATES DUNKIRK___3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 14:00 FOR GEN REQUEST DERATE UOL FOR COAL QUALITY. MINGEN OOM FOR P/C LOADING..
11-Jun-2009 16:17:08	ISO REMOVES DUNKIRK___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 16:00.
11-Jun-2009 16:30:57	ISO REMOVES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 16:00.
11-Jun-2009 21:21:35	Metering Authority - Long Island Power Authority REQUESTS FAR ROCKAWAY___4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 06/12/2009 00:00 FOR 33KV SECURITY.
11-Jun-2009 23:03:52	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 23:00 FOR low system frequency.
11-Jun-2009 23:07:33	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 06/11/2009 23:00.

Committed for Reliability back to top

Insert Time	Message
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: RAVENSWOOD___4 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: ASTORIA___4 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: FAR ROCKAWAY___4 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: NORTHPORT___3 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: MILLIKEN___1 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: GREENIDGE___4 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 05:04:46	06/11/2009 05:04:46 Generator: ASTORIA___5 requested for Day Ahead Reliability in DAM market for 06/12/2009 00 to 06/12/2009 23
11-Jun-2009 10:39:44	Generator: POLETTI____ scheduled for local reliability in DAM market for 06/12/2009 23 Energy = 140 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 11:20:22	Generator: NORTHPORT___1 scheduled for local reliability in DAM market for 06/12/2009 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 11:20:46	Generator: PORT_JEFF_3 scheduled for local reliability in DAM market for 06/12/2009 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:27	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 07 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0

	MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 08 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 11 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 10 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 09 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 12 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 14 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 16 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 17 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0

	MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 15 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
11-Jun-2009 16:16:28	Generator: INDECK___OLEAN scheduled for local reliability in DAM market for 06/12/2009 13 Energy = 63 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message
11-Jun-2009 13:36:15	Day Ahead Load Pocket Thresholds have been updated for market day of: June 15, 2009 Day Ahead Load Pocket Threshold $ DUNWOODIE SOUTH $2.38 STATEN ISLAND $2.04 EAST RIVER $2.25 IN CITY 345/138 $2.03 ASTORIA EAST/COR/JAMAICA $1.86 ASTOR WEST/QUEENB/VERNON $1.93 ASTORIA WEST/QUEENSBRIDG $1.92 VERNON/GREENWOOD $2.11 GREENWOOD/STATEN ISLAND $1.82
11-Jun-2009 13:37:01	Real Time Load Pocket Thresholds will be updated as of: June 15, 2009 at 10:00:01 Real Time Load Pocket Threshold $ DUNWOODIE SOUTH $11.17 STATEN ISLAND $9.41 EAST RIVER $9.66 IN CITY 345/138 $10.03 ASTORIA EAST/COR/JAMAICA $6.89 ASTOR WEST/QUEENB/VERNON $7.09 ASTORIA WEST/QUEENSBRIDG $6.70 VERNON/GREENWOOD $9.96 GREENWOOD/STATEN ISLAND $5.37
11-Jun-2009 16:12:50	Prices in the June 10, 2009 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the June 10, 2009 Hour-Ahead Market for the period hours beginning 12 through 23 are correct. Prices in the June 12, 2009 Day-Ahead Market encompassing Energy, Regulation, and Operating Reserves are correct.
11-Jun-2009 16:20:56	Prices in the June 11, 2009 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the June 11, 2009 Hour-Ahead Market for the period hours beginning 0 through 11 are correct.