

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)
[Market Pricing Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
02-Jan-2010 01:09:38	NYISO Locational based curtailment cut 200 MWs. 01/02/2010 01:09 EST
02-Jan-2010 04:09:00	Metering Authority - Consolidated Edison of NY REMOVES BROOKLYN_NAVY_YARD OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 01/02/2010 04:00.
02-Jan-2010 10:33:08	NYISO Locational based curtailment cut 330 MWs. 01/02/2010 10:33 EST
02-Jan-2010 16:53:32	ISO REQUESTS GREENIDGE___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 16:00 FOR PV FLOWS.
02-Jan-2010 16:54:58	ISO UPDATES GREENIDGE___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 16:00 FOR PC FLOWS.
02-Jan-2010 17:01:14	ISO REQUESTS ASTORIA___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:13:24	ISO UPDATES NIAGARA___ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR INTERFACE FLOWS.
02-Jan-2010 17:14:32	ISO REQUESTS CANDIGU_WT_PWR OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:17:10	ISO UPDATES ASTORIA___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:18:54	O H initiated curtailment cut 50 MWs. Short Capacity 01/02/2010 17:18 EST
02-Jan-2010 17:23:42	ISO REQUESTS WETHRSFD_WT_PWR OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:24:28	ISO REQUESTS HISHELDN_WT_PWR OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:30:59	ISO UPDATES ASTORIA___4 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START

	TIME 01/02/2010 17:00 FOR PC FLOWS.
02-Jan-2010 17:32:44	ISO REMOVES NIAGARA___ OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00.
02-Jan-2010 17:39:55	ISO REMOVES HISHELDN_WT_PWR OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00.
02-Jan-2010 17:39:55	ISO REMOVES WETHRSFD_WT_PWR OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00.
02-Jan-2010 17:39:55	ISO REMOVES CANDIGU_WT_PWR OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00.
02-Jan-2010 17:39:55	ISO REMOVES ASTORIA___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 17:00.
02-Jan-2010 21:35:39	ISO REQUESTS GREENIDGE___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/03/2010 00:00 FOR PC FLOWS.
02-Jan-2010 23:12:22	ISO UPDATES GREENIDGE___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 23:00 FOR PC FLOWS.
02-Jan-2010 23:39:39	ISO UPDATES GREENIDGE___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 01/02/2010 23:00 FOR PC FLOWS.

Committed for Reliability

[back to top](#)

Insert Time	Message
02-Jan-2010 05:04:56	01/02/2010 05:04:56 Generator: POLETTI___ requested for Day Ahead Reliability in DAM market for 01/03/2010 00 to 01/03/2010 23
02-Jan-2010 05:04:56	01/02/2010 05:04:56 Generator: MILLIKEN___2 requested for Day Ahead Reliability in DAM market for 01/03/2010 00 to 01/03/2010 23
02-Jan-2010 14:23:54	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 07 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 15 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 16 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 17 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 18 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 19 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 20 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 21 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 22 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 08 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for

	local reliability in DAM market for 01/03/2010 09 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 14 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 13 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 11 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 12 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
02-Jan-2010 14:23:55	Generator: NEG NORTH_FLCN_SEA scheduled for local reliability in DAM market for 01/03/2010 10 Energy = 126 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices

[back to top](#)

Insert Time	Message
-------------	---------

Market Pricing Notices

[back to top](#)

Insert Time	Message
02-Jan-2010 13:34:58	Prices in the January 01, 2010 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the January 01, 2010 Hour-Ahead Market for the period hours beginning 12 through 23 are correct. Prices in the January 03, 2010 Day-Ahead Market encompassing Energy, Regulation, and Operating Reserves are correct.

02-Jan-2010 16:23:56

Prices in the January 02, 2010 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the January 02, 2010 Hour-Ahead Market for the period hours beginning 0 through 11 are correct.