NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices
Market Pricing Notices

Dispatcher Notices back to top

Insert Time	Message
30-Aug-2010 06:06:02	NYISO Locational based curtailment cut 314 MWs. 08/30/2010 06:06 EDT
30-Aug-2010 06:19:19	Consolidated Edision of NY has Declared Today a Min Oil Burn Day
30-Aug-2010 09:44:03	LONG ISLAND POWER AUTHORITY HAS DECLARED TODAY A MIN OIL BURN DAY
30-Aug-2010 10:26:57	Metering Authority - Long Island Power Authority REQUESTS EAST HAMPTON___GT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 10:00 FOR EAST END TVR.
30-Aug-2010 11:09:28	Metering Authority - New York State Electric & Gas REQUESTS NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 11:00 FOR 115KV OVERLOADS.
30-Aug-2010 11:44:38	Metering Authority - Long Island Power Authority REQUESTS GLOBAL GREEN_PORT_GT1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 11:00 FOR EAST END TVR.
30-Aug-2010 11:50:26	Metering Authority - New York State Electric & Gas UPDATES NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 11:00 FOR 115KV OVERLOADS.
30-Aug-2010 13:04:05	ISO REQUESTS ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 13:00 FOR 138KV POST CONTINGENCY LOADING.
30-Aug-2010 13:29:43	Metering Authority - New York State Electric & Gas UPDATES NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 13:00 FOR 115KV OVERLOADS.
30-Aug-2010 13:43:06	Metering Authority - Long Island Power Authority REQUESTS PPL_SHRM_GT3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 13:00 FOR TVR.
30-Aug-2010 13:43:06	Metering Authority - Long Island Power Authority REQUESTS PPL_SHRM_GT4 OUT OF MERIT.

	OOM FOR TO RELIABILITY AT START TIME 08/30/2010 13:00 FOR TVR.
30-Aug-2010 13:44:17	ISO UPDATES ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 13:00 FOR 138KV POST CONTINGENCY LOADING.
30-Aug-2010 14:46:49	Metering Authority - Long Island Power Authority UPDATES EAST_HAMPTON___DIESEL OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 14:00 FOR EAST END TVR.
30-Aug-2010 15:08:35	Metering Authority - Long Island Power Authority REQUESTS WADING RIVER_IC_2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:08:36	Metering Authority - Long Island Power Authority REQUESTS WADING RIVER_IC_3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:08:36	Metering Authority - Long Island Power Authority REQUESTS WADING RIVER_IC_1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:09:26	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_6 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:09:26	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:09:26	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_8 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 15:25:39	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 15:00 FOR .
30-Aug-2010 15:25:54	ISO UPDATES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 15:00 FOR ACE.
30-Aug-2010 15:53:10	Metering Authority - Long Island Power Authority REQUESTS HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 15:00 FOR TVR.
30-Aug-2010 16:11:59	Metering Authority - New York State Electric & Gas UPDATES NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START

	TIME 08/30/2010 16:00 FOR 115KV OVERLOADS.
30-Aug-2010 16:40:12	Metering Authority - Long Island Power Authority UPDATES WADING RIVER_IC_1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 16:00 FOR TVR.
30-Aug-2010 17:06:20	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 17:00.
30-Aug-2010 17:24:28	Metering Authority - New York State Electric & Gas UPDATES NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 17:00 FOR 115KV OVERLOADS.
30-Aug-2010 18:38:48	Metering Authority - Long Island Power Authority REMOVES EAST_HAMPTON___DIESEL OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 18:00.
30-Aug-2010 19:10:38	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_6 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:10:38	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:10:38	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_8 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:10:39	Metering Authority - Long Island Power Authority REMOVES WADING RIVER_IC_2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:10:39	Metering Authority - Long Island Power Authority REMOVES WADING RIVER_IC_3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:10:39	Metering Authority - Long Island Power Authority REMOVES HOLTSVILLE_IC_9 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 19:50:05	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 19:00 FOR ACE.
30-Aug-2010 19:55:05	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 19:00.
30-Aug-2010 20:15:40	Metering Authority - Long Island Power Authority

	REMOVES GLOBAL GREEN_PORT_GT1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 20:00.
30-Aug-2010 20:49:29	Metering Authority - Long Island Power Authority REMOVES EAST HAMPTON___GT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 20:00.
30-Aug-2010 20:51:09	Metering Authority - Long Island Power Authority REMOVES PPL_SHRM_GT4 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 20:00.
30-Aug-2010 20:51:09	Metering Authority - Long Island Power Authority REMOVES WADING RIVER_IC_1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 20:00.
30-Aug-2010 21:06:13	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 21:00 FOR ACE.
30-Aug-2010 21:13:43	ISO REQUESTS ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/31/2010 00:00 FOR 138KV POST CONTINGENCY LOADING.
30-Aug-2010 21:14:56	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 21:00.
30-Aug-2010 21:21:12	Metering Authority - New York State Electric & Gas REQUESTS NEG WEST_LEA_LOCKPORT OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/31/2010 00:00 FOR 115KV OVERLOADS.
30-Aug-2010 21:22:22	Metering Authority - Long Island Power Authority REMOVES PPL_SHRM_GT3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 21:00.
30-Aug-2010 22:59:37	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 22:00 FOR ace.
30-Aug-2010 23:10:08	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 08/30/2010 23:00.
30-Aug-2010 23:18:53	Metering Authority - Niagara Mohawk REQUESTS DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 23:00 FOR P/C loading.
30-Aug-2010 23:19:26	Metering Authority - Niagara Mohawk REQUESTS DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/30/2010 23:00

	FOR P/C Loading.
30-Aug-2010 23:19:46	Metering Authority - Niagara Mohawk REQUESTS DUNKIRK___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/31/2010 00:00 FOR P/C loading.
30-Aug-2010 23:19:46	Metering Authority - Niagara Mohawk REQUESTS DUNKIRK___2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/31/2010 00:00 FOR P/C Loading.

Committed for Reliability back to top

Insert Time	Message
30-Aug-2010 05:07:26	08/30/2010 05:07:26 Generator: RAVENSWOOD___2 requested for Day Ahead Reliability in DAM market for 08/31/2010 06 to 08/31/2010 23
30-Aug-2010 05:07:26	08/30/2010 05:07:26 Generator: GREENIDGE___4 requested for Day Ahead Reliability in DAM market for 08/31/2010 00 to 08/31/2010 23
30-Aug-2010 05:07:26	08/30/2010 05:07:26 Generator: SITHE___BATAVIA requested for Day Ahead Reliability in DAM market for 08/31/2010 00 to 08/31/2010 06
30-Aug-2010 05:07:26	08/30/2010 05:07:26 Generator: INDECK___OLEAN requested for Day Ahead Reliability in DAM market for 08/31/2010 07 to 08/31/2010 21
30-Aug-2010 11:45:39	Generator: GLENWOOD___4 scheduled for local reliability in DAM market for 08/31/2010 23 Energy = 20 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 12:23:44	Generator: NEG NORTH_FLCN_SEA scheduled for SRE as initiated by ISO in DAM market for 08/31/2010 22 Energy = 69 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 14:44:10	Generator: RAVENSWOOD___1 scheduled for local reliability in DAM market for 08/31/2010 23 Energy = 75 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 14:44:40	Generator: RAVENSWOOD___3 scheduled for local reliability in DAM market for 08/31/2010 23 Energy = 150 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0

	MW.
30-Aug-2010 16:12:50	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 07 Energy = 52 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:50	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 08 Energy = 51 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 23 Energy = 50 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 22 Energy = 50 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 21 Energy = 50 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 19 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 18 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 17 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 16 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 15 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 14 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 13 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 12 Energy = 48 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 11 Energy = 49 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 10 Energy = 50 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local reliability in DAM market for 08/31/2010 09 Energy = 50 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
30-Aug-2010 16:12:51	Generator: SITHE___BATAVIA scheduled for local

	reliability in DAM market for 08/31/2010 20 Energy = 49 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message

Market Pricing Notices back to top

Insert Time	Message
30-Aug-2010 14:31:25	Prices in the August 29, 2010 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the August 29, 2010 Hour-Ahead Market for the period hours beginning 12 through 23 are correct. Prices in the August 31, 2010 Day-Ahead Market encompassing Energy, Regulation, and Operating Reserves are correct.
30-Aug-2010 14:55:20	Prices in the August 30, 2010 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the August 30, 2010 Hour-Ahead Market for the period hours beginning 0 through 11 are correct.