NYISO Operational Announcements

Dispatcher Notices
Committed for Reliability
Market Monitor Notices
Market Pricing Notices

Dispatcher Notices back to top

Insert Time	Message
07-Sep-2010 06:06:16	09/07/2010 06:04:35 NYISO large event reserve pick-up executed.
07-Sep-2010 07:06:45	Consolidated Edison of NY has declared today a Min Oil Burn Day.
07-Sep-2010 07:21:46	NYISO Locational based curtailment cut 50 MWs. 09/07/2010 07:21 EDT
07-Sep-2010 10:22:30	Long Island Power Authority has Declared Today a Min Oil Burn Day
07-Sep-2010 10:55:41	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 10:00 FOR LOSS 111-1 & SR1-39 CASCADE ONTO 113-1.
07-Sep-2010 11:33:40	ISO UPDATES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 11:00 FOR LOSS 111-1 & SR1-39 CASCADE ONTO 113-1.
07-Sep-2010 11:37:53	ISO UPDATES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 11:00 FOR LOSS 111-1 & SR1-39 CASCADE ONTO 113-1.
07-Sep-2010 12:32:12	ISO REQUESTS HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 12:00 FOR 85 WETHERSFIELD-MEYER LOSS OF SR1-39 > P/C LTE.
07-Sep-2010 12:32:44	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 12:00 FOR 85 WETHERSFIELD-MEYER LOSS OF SR1-39 > P/C LTE.
07-Sep-2010 12:47:25	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 12:00 FOR 85 WETHERSFIELD-MEYER LOSS OF SR1-39 > P/C LTE.
07-Sep-2010 12:47:38	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START

	TIME 09/07/2010 12:00 FOR 85 WETHERSFIELD-MEYER LOSS OF SR1-39 > P/C LTE.
07-Sep-2010 12:57:03	ISO REMOVES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 12:00.
07-Sep-2010 12:57:03	ISO REMOVES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 12:00.
07-Sep-2010 13:21:05	ISO UPDATES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 13:00 FOR LOSS 111-1 & SR1-39 CASCADE ONTO 113-1.
07-Sep-2010 13:51:20	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 13:00.
07-Sep-2010 14:40:17	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/07/2010 14:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 14:40:46	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/07/2010 14:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 14:41:19	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/07/2010 14:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 14:54:13	ISO REQUESTS CANDIGU_WT_PWR OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 14:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA -HILLSIDE..
07-Sep-2010 14:58:27	ISO REMOVES CANDIGU_WT_PWR OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 14:00.
07-Sep-2010 15:07:27	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 15:00 FOR .
07-Sep-2010 15:08:43	H Q initiated curtailment cut 200 MWs. 09/07/2010 15:08 EDT
07-Sep-2010 15:17:25	09/07/2010 15:16:41 NYISO large event reserve pick-up executed.
07-Sep-2010 15:23:50	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START

	TIME 09/07/2010 15:00.
07-Sep-2010 15:45:59	ISO REQUESTS HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 15:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 15:46:34	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 15:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 16:22:45	ISO REQUESTS ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 16:00 FOR P/C LOADING AND LOAD POCKET RELIABILITY..
07-Sep-2010 16:26:06	ISO REQUESTS ARTHUR_KILL_3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 16:00 FOR ACTUAL LOADING.
07-Sep-2010 16:39:19	H Q initiated curtailment cut 200 MWs. 09/07/2010 16:39 EDT
07-Sep-2010 16:49:21	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 16:00 FOR .
07-Sep-2010 16:56:40	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 16:00.
07-Sep-2010 16:56:55	09/07/2010 16:56:41 NYISO large event reserve pick-up executed.
07-Sep-2010 17:16:18	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 17:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 17:16:36	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 17:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:15:09	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:15:25	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS

	OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:16:22	ISO REMOVES ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00.
07-Sep-2010 18:16:22	ISO REMOVES ARTHUR_KILL_3 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00.
07-Sep-2010 18:32:43	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:33:05	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:44:00	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 18:44:13	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 18:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 19:15:53	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 19:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 19:16:02	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 19:00 FOR MEYER BK 4 LOSS OF 68 CANANDAIGUA - HILLSIDE P/C FLOW > LTE..
07-Sep-2010 19:46:55	09/07/2010 19:46:41 NYISO large event reserve pick-up executed.
07-Sep-2010 19:59:04	ISO REQUESTS NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 19:00 FOR .
07-Sep-2010 20:14:51	ISO REMOVES NIAGARA____ OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 20:00.
07-Sep-2010 20:16:51	ISO UPDATES ARTHUR_KILL_2 OUT OF MERIT.

	COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 20:00 FOR 138KV CONTINGENCIES.
07-Sep-2010 20:30:30	ISO REMOVES ARTHUR_KILL_2 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 20:00.
07-Sep-2010 20:43:35	ISO REMOVES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 20:00.
07-Sep-2010 20:43:35	ISO REMOVES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 20:00.
07-Sep-2010 21:14:16	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS2 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/08/2010 00:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 21:14:16	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS3 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/08/2010 00:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 21:14:16	Metering Authority - Niagara Mohawk REQUESTS BETHLEHEM___GS1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 09/08/2010 00:00 FOR P/C FLOW ON 15 EVERETT-MEANDS FOR LOSS OF 18 ALBANY-BETHLEHEM.
07-Sep-2010 21:19:13	ISO REQUESTS HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 21:00 FOR 230kv contingencies.
07-Sep-2010 21:19:38	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 21:00 FOR 230kv contingencies.
07-Sep-2010 22:36:10	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 22:00 FOR 230kv contingencies.
07-Sep-2010 22:36:27	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 22:00 FOR 230kv contingencies.
07-Sep-2010 23:11:33	ISO UPDATES HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 23:00 FOR 230kv contingencies.
07-Sep-2010 23:11:45	ISO UPDATES HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/07/2010 23:00 FOR 230kv contingencies.
07-Sep-2010 23:28:29	ISO REQUESTS HUNTLEY___67 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START

	TIME 09/08/2010 00:00 FOR 230kv contingencies.
07-Sep-2010 23:28:30	ISO REQUESTS HUNTLEY___68 OUT OF MERIT. COMMITED FOR ISO RELIABILITY AT START TIME 09/08/2010 00:00 FOR 230kv contingencies.

Committed for Reliability back to top

Insert Time	Message
07-Sep-2010 05:08:54	09/07/2010 05:08:54 Generator: INDECK___OLEAN requested for Day Ahead Reliability in DAM market for 09/08/2010 07 to 09/08/2010 21
07-Sep-2010 05:08:54	09/07/2010 05:08:54 Generator: GREENIDGE___4 requested for Day Ahead Reliability in DAM market for 09/08/2010 00 to 09/08/2010 23
07-Sep-2010 11:06:09	Generator: NORTHPORT___2 scheduled for local reliability in DAM market for 09/08/2010 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
07-Sep-2010 11:07:09	Generator: BARRETT___2 scheduled for local reliability in DAM market for 09/08/2010 23 Energy = 45 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
07-Sep-2010 11:07:30	Generator: PORT_JEFF_3 scheduled for local reliability in DAM market for 09/08/2010 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

Market Monitor Notices back to top

Insert Time	Message

Market Pricing Notices back to top

Insert Time	Message
07-Sep-2010 14:24:44	Prices in the September 06, 2010 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the September 06, 2010 Hour-Ahead Market for the period hours beginning 12 through 23 are correct. Prices in the September 08, 2010 Day-Ahead Market encompassing Energy, Regulation, and Operating Reserves are correct.
07-Sep-2010 15:12:26	Prices in the September 07, 2010 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating

	Reserves are correct. Prices in the September 07, 2010 Hour-Ahead Market for the period hours beginning 0 through 11 are correct.