

NYISO Operational Announcements

[Dispatcher Notices](#)
[Committed for Reliability](#)
[Market Monitor Notices](#)
[Market Pricing Notices](#)

Dispatcher Notices

[back to top](#)

Insert Time	Message
20-Oct-2010 06:06:12	10/20/2010 06:04:23 NYISO large event reserve pick-up executed.
20-Oct-2010 07:15:29	NPX initiated curtailment cut 50 MWs. 10/20/2010 07:15 EDT
20-Oct-2010 07:35:28	Metering Authority - Long Island Power Authority REQUESTS GLOBAL_GREEN_PORT_GT1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 07:00 FOR P/C LOADING.
20-Oct-2010 08:07:57	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 08:00 FOR OOM up to 150 mw for Loss of 45 & 46 onto 37378. OUL limited to 150 mw due to gen issue..
20-Oct-2010 08:40:55	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 08:00 FOR OOM up to 150 mw for Loss of 45 & 46 onto 37378. OUL limited to 150 mw due to gen issue..
20-Oct-2010 09:07:07	Metering Authority - Consolidated Edison of NY UPDATES EAST RIVER___7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 09:00 FOR OOM up to 150 mw for Loss of 45 & 46 onto 37378. OUL limited to 150 mw due to gen issue..
20-Oct-2010 17:11:44	Metering Authority - Consolidated Edison of NY REMOVES EAST RIVER___7 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 17:00.
20-Oct-2010 19:26:37	NPX initiated curtailment cut 124 MWs. 10/20/2010 19:26 EDT
20-Oct-2010 20:28:39	Metering Authority - Long Island Power Authority REMOVES GLOBAL_GREEN_PORT_GT1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 10/20/2010 20:00.

Committed for Reliability

[back to top](#)

Insert Time	Message
20-Oct-2010 05:09:47	10/20/2010 05:09:47 Generator: MILLIKEN___2 requested for Day Ahead Reliability in DAM market for 10/21/2010 00 to 10/21/2010 23
20-Oct-2010 05:09:47	10/20/2010 05:09:47 Generator: GREENIDGE___4 requested for Day Ahead Reliability in DAM market for 10/21/2010 00 to 10/21/2010 23
20-Oct-2010 05:09:47	10/20/2010 05:09:47 Generator: INDECK___OLEAN requested for Day Ahead Reliability in DAM market for 10/21/2010 07 to 10/21/2010 20

Market Monitor Notices

[back to top](#)

Insert Time	Message
-------------	---------

Market Pricing Notices

[back to top](#)

Insert Time	Message
20-Oct-2010 14:07:18	Prices in the October 19, 2010 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the October 19, 2010 Hour-Ahead Market for the period hours beginning 12 through 23 are correct. Prices in the October 21, 2010 Day-Ahead Market encompassing Energy, Regulation, and Operating Reserves are correct.
20-Oct-2010 15:15:24	Prices in the October 20, 2010 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the October 20, 2010 Hour-Ahead Market for the period hours beginning 0 through 11 are correct.