

NYISO Operational Announcements

[Dispatcher Notices](#)
[Reliability Notices](#)
[15 Minute Scheduling Disabled Notices](#)
[Market Monitor Notices](#)
[Market Pricing Notices](#)
[Dispatcher Notices](#)
[back to top](#)

Insert Time	Message
04-Aug-2016 10:16:09	08/04/2016 10:14:10 NYISO large event reserve pick-up executed.
04-Aug-2016 10:16:12	08/04/2016 10:15:00 NYISO large event reserve pick-up executed.
04-Aug-2016 10:21:06	08/04/2016 10:20:00 NYISO large event reserve pick-up executed.
04-Aug-2016 15:27:32	ISO REQUESTS GILBOA___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 08/04/2016 15:00 FOR ACE.
04-Aug-2016 15:31:08	08/04/2016 15:25:10 NYISO large event reserve pick-up executed.
04-Aug-2016 15:31:11	08/04/2016 15:30:00 NYISO large event reserve pick-up executed.
04-Aug-2016 15:33:11	ISO REMOVES GILBOA___4 OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 08/04/2016 17:00.
04-Aug-2016 16:01:43	Metering Authority - Long Island Power Authority REQUESTS EAST_HAMPTON___DIESEL OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/04/2016 16:00 FOR East End TVR.
04-Aug-2016 18:53:58	Metering Authority - Long Island Power Authority REMOVES EAST_HAMPTON___DIESEL OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/04/2016 18:00.
04-Aug-2016 20:01:54	ISO REQUESTS NIAGARA___ OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 08/04/2016 20:00 FOR ACE.
04-Aug-2016 20:09:12	ISO REMOVES NIAGARA___ OUT OF MERIT. COMMITTED FOR ISO RELIABILITY AT START TIME 08/04/2016 20:00.
04-Aug-2016 21:12:16	Metering Authority - New York State Electric & Gas REQUESTS MILLIKEN___1 OUT OF MERIT. OOM FOR TO RELIABILITY AT START TIME 08/05/2016 00:00 FOR post cont./ boiler limited.

04-Aug-2016 21:53:49	Power System conditions will now allow HQTE-NYISO Chateaugay-Massena Interconnection operation above 1500MW as described in NYISO Technical Bulletin #150.
04-Aug-2016 22:29:06	Power System conditions will no longer allow HQTE-NYISO Chateaugay-Massena Interconnection operation above 1500MW as described in NYISO Technical Bulletin #150.

Committed for Reliability

[back to top](#)

Insert Time	Message
04-Aug-2016 05:03:14	08/04/2016 05:03:14 Generator: MILLIKEN___1 requested for Day Ahead Reliability in DAM market for 08/05/2016 00 to 08/05/2016 23 ARR: 29
04-Aug-2016 05:03:14	08/04/2016 05:03:14 Generator: SITHE___BATAVIA requested for Day Ahead Reliability in DAM market for 08/05/2016 08 to 08/05/2016 22 ARR: 72
04-Aug-2016 10:37:39	Generator: PORT_JEFF_3 scheduled for local reliability in DAM market for 08/05/2016 23 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
04-Aug-2016 10:37:39	Generator: PORT_JEFF_3 scheduled for local reliability in DAM market for 08/05/2016 22 Energy = 40 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
04-Aug-2016 10:40:02	Generator: NORTHPORT___2 scheduled for local reliability in DAM market for 08/05/2016 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.
04-Aug-2016 10:40:26	Generator: NORTHPORT___4 scheduled for local reliability in DAM market for 08/05/2016 23 Energy = 100 MW. Regulation = 0 MW. Min10 Spinning = 0 MW. Min10 Nonsynch = 0 MW. Min30 Spinning = 0 MW. Min30 Nonsynch = 0 MW. Operating Cap = 0 MW.

15 Minute Scheduling Disabled

[back to top](#)

Insert Time	Message
-------------	---------

Market Monitor Notices

[back to top](#)

Insert Time	Message
-------------	---------

Market Pricing Notices

[back to top](#)

Insert Time	Message
04-Aug-2016 14:33:35	Prices in the August 03, 2016 Real-Time Market for the period hours beginning 12 through 23 encompassing Energy, Regulation, and Operating Reserves are correct. Prices in the August 05, 2016 Day-Ahead Market are correct.
04-Aug-2016 14:48:43	Prices in the August 04, 2016 Real-Time Market for the period hours beginning 0 through 11 encompassing Energy, Regulation, and Operating Reserves are correct.