

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	Impact	FWD	REV
RAMAPO__345_345_PAR3500	Fri 06/24/2016	Thu 06/01/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>01/11/2017</u>	SCH - PJ - NY	(Import)	(Export)
1940	Continuous	2359				Impacts Total Transfer Capability	2200 MW	1450 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	(Import)	
0728	Continuous	2359				Impacts Total Transfer Capability	4000 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	(Import)	
1500	Continuous	2359				Impacts Total Transfer Capability	0 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/17/2017</u>	SPR/DUN-SOUTH	(Import)	
0001	Continuous	0300				Impacts Total Transfer Capability	3800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	800 MW	4600 MW
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/17/2017</u>	SPR/DUN-SOUTH	(Import)	
0001	Continuous	0300				Impacts Total Transfer Capability	3800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	800 MW	4600 MW
W49TH_ST_345KV_6	Fri 02/17/2017	Thu 03/30/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/17/2017</u>	SCH - PJM_HTP	(Import)	
0001	Continuous	0300				Impacts Total Transfer Capability	315 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	345 MW	660 MW
DUNWODIE-SHORE_RD_345_Y50	Wed 03/01/2017	Mon 03/20/2017				CONED - LIPA	(Import)	
0001	Continuous	2359				Impacts Total Transfer Capability	800 MW	
Work scheduled by: LI						TTC with All Lines In Service	700 MW	1500 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1				FWD
Wed 03/01/2017	to	Mon 03/20/2017		(Import)
0001	Continuous	2359		CONED - LIPA 1350 MW
Work scheduled by: LI				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2				FWD
Wed 03/01/2017	to	Mon 03/20/2017		(Import)
0001	Continuous	2359		CONED - LIPA 1350 MW
Work scheduled by: LI				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Thu 03/02/2017	to	Fri 03/24/2017	UPDATED by NYSEG 02/28/2017	(Import)
0500	Continuous	1530		CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
DOLSONAV-ROCKTVRN_345_DART44				FWD
Thu 03/02/2017	to	Fri 03/24/2017	UPDATED by NYSEG 02/28/2017	(Import)
0500	Continuous	1530		CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
EDIC_-FRASER_345_EF24-40				FWD
Mon 03/13/2017	to	Sun 03/19/2017	UPDATED by NYSEG 03/12/2017	(Import)
0600	Continuous	1700		CENTRAL EAST - VC 2500 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 475 MW
				TTC with All Lines In Service 2975 MW
BECK_-NIAGARA_345_PA302				FWD REV
Mon 03/13/2017	to	Fri 03/17/2017	UPDATED by NYISO 03/02/2017	(Import) (Export)
0800	Continuous	1700		SCH - OH - NY 1100 MW 950 MW
Work scheduled by: IESO				Impacts Total Transfer Capability 650 MW 950 MW
				TTC with All Lines In Service 1750 MW 1900 MW
SCH-IMO-NYISO_LIMIT_1000				FWD
Wed 03/15/2017	to	Sat 03/18/2017	UPDATED by PJM 03/14/2017	(Import)
0800	Continuous	0459		SCH - OH - NY 1300 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 1750 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_100						REV
Wed 03/15/2017	to	Sat 03/18/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/14/2017</u>	(Export)
0800	Continuous	0459				400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1450 MW
MILLWOOD_345KV_18						FWD
Thu 03/16/2017	to	Fri 03/17/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/14/2017</u>	(Import)
0001	Continuous	2200				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 750 MW
						TTC with All Lines In Service 5100 MW
LADENTWN-BUCHAN_S_345_Y88						FWD
Sat 03/18/2017	to	Mon 03/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/14/2017</u>	(Import)
0001	Continuous	2359				4150 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 5100 MW
SCH-IMO-NYISO_LIMIT_1350						FWD
Sat 03/18/2017	to	Sat 03/18/2017	<u>UPDATED</u>	<u>by IESO</u>	<u>03/16/2017</u>	(Import)
0630	Continuous	1700				1650 MW
Work scheduled by: IESO						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 1750 MW
SCH-IMO-NYISO_LIMIT_1000						FWD
Sat 03/18/2017	to	Mon 04/03/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/14/2017</u>	(Import)
1700	Continuous	1559				1300 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100						REV
Sat 03/18/2017	to	Mon 04/03/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/14/2017</u>	(Export)
1700	Continuous	1559				400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1450 MW
NINEMILE-CLAY_____345_8						FWD
Mon 03/20/2017	to	Fri 03/24/2017	<u>EXTENDED</u>	<u>by NGRID</u>	<u>03/20/2017</u>	(Import)
0001	Continuous	0200				5150 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
SCH-IMO-NYISO_NIAG_CB_3008_W/BB							
Mon 03/20/2017	to	Tue 03/21/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/17/2017</u>		
0500	Continuous	1700				SCH - OH - NY	1750 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	150 MW
						TTC with All Lines In Service	1750 MW
							1900 MW
FRASANX-COOPERS__345_UCC2-41						FWD	
						(Import)	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>		
0500	Continuous	1630				CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
MARCY__-FRASANX_345_UCC2-41						FWD	
						(Import)	
Mon 03/20/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/27/2016</u>		
0500	Continuous	1630				CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
MOSES__-ADIRNDCK_230_MA2						FWD	
						(Import)	
Mon 03/20/2017	to	Sat 03/25/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>03/13/2017</u>		
0700	Continuous	1530				MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
SCH-NE-NYISO_LIMIT_200						FWD	
						(Import)	
Tue 03/21/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/20/2017</u>		
0001	Continuous	0659				SCH - NE - NY	400 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	1400 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403						FWD	REV
						(Import)	(Export)
Tue 03/21/2017	to	Mon 05/01/2017				SCH - PJ - NY	2050 MW
0001		2359				Impacts Total Transfer Capability	250 MW
Work scheduled by:						TTC with All Lines In Service	2300 MW
							1450 MW
MARION_-FARRAGUT_345_C3403						FWD	REV
						(Import)	(Export)
Tue 03/21/2017	to	Mon 05/01/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/18/2017</u>		
0001	Continuous	2359				SCH - PJ - NY	2300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
							1450 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
HUDSONP_-FARRAGUT_345_B3402			
Tue 03/21/2017	to Tue 05/02/2017	UPDATED	by CONED 03/18/2017
0001	Continuous 2359		
Work scheduled by: ConEd			
		SCH - PJ - NY	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	2300 MW 1450 MW
		TTC with All Lines In Service	2300 MW 1450 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B			
Tue 03/21/2017	to Tue 03/21/2017		
0700	Daily(No Weekends) 1600		
Work scheduled by: NGrid			
		MOSES SOUTH	FWD (Import)
		Impacts Total Transfer Capability	3100 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B			
Tue 03/21/2017	to Tue 03/21/2017		
0700	Daily(No Weekends) 1600		
Work scheduled by: NGrid			
		SCH - HQ_CEDARS	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	100 MW 60 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
SCH-NE-NYISO_LIMIT_0			
Tue 03/21/2017	to Fri 03/24/2017	UPDATED	by ISONE 03/20/2017
0700	Continuous 2359		
Work scheduled by: ISONE			
		SCH - NE - NY	FWD (Import)
		Impacts Total Transfer Capability	200 MW
		TTC with All Lines In Service	1400 MW
<hr/>			
SCH-NYISO-IMO_NIAGARA_CB_3108			
Wed 03/22/2017	to Thu 03/23/2017	UPDATED	by NYISO 03/17/2017
0500	Continuous 1700		
Work scheduled by: NYPA			
		SCH - OH - NY	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	1750 MW 1850 MW
		TTC with All Lines In Service	1750 MW 1900 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B			
Wed 03/22/2017	to Wed 03/22/2017		
0700	Daily(No Weekends) 1600		
Work scheduled by: NGrid			
		MOSES SOUTH	FWD (Import)
		Impacts Total Transfer Capability	3100 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B			
Wed 03/22/2017	to Wed 03/22/2017		
0700	Daily(No Weekends) 1600		
Work scheduled by: NGrid			
		SCH - HQ_CEDARS	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	100 MW 60 MW
		TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800					REV
Wed 03/22/2017	to	Thu 03/23/2017			(Export)
0700	Continuous	1700		SCH - HQ - NY	800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1000 MW
MILLWOOD_345KV_18					FWD
Fri 03/24/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>03/20/2017</u>
0001	Continuous	2200			(Import)
Work scheduled by: ConEd					UPNY CONED 4350 MW
					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
BERKSHIR-ALPS_____345_393					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>
0800	Daily(No Weekends)	0900			(Import) (Export)
Work scheduled by: NGrid					SCH - NE - NY 1300 MW 1300 MW
					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
BERKSHIR-ALPS_____345_393					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>
0800	Daily(No Weekends)	0900			(Import) (Export)
Work scheduled by: NGrid					SCH - NPX_1385 100 MW 100 MW
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD REV
Fri 03/24/2017	to	Fri 03/24/2017			(Import) (Export)
0800		0900			SCH - NE - NY 1300 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
SCH-NE-NYISO_LIMIT_1000					FWD
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>
0800	Daily(No Weekends)	0900			(Import)
Work scheduled by: NGrid					SCH - NE - NY 1200 MW
					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1400 MW
SCH-NYISO-NE_LIMIT_700					REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>
0800	Daily(No Weekends)	0900			(Export)
Work scheduled by: NGrid					SCH - NE - NY 900 MW
					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312						FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>	(Import)	(Export)
0800	Continuous	1600				1400 MW	1450 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312						FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>	(Import)	(Export)
0800	Continuous	1600				100 MW	100 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
SCH-NYISO-NE_LIMIT_1000							REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/06/2017</u>		(Export)
0800	Continuous	1600					1200 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	1600 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD	
Fri 03/24/2017	to	Mon 04/17/2017				(Import)	
1700	Continuous	0900				2740 MW	
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
W49TH_ST_345KV_8						FWD	
Sat 03/25/2017	to	Thu 03/30/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/17/2017</u>	(Import)	
0201	Continuous	0200				315 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
CHAT_DC_GC1						FWD	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Import)	
0001	Continuous	0159				2850 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC1							REV
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>		(Export)
0001	Continuous	0159					500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 03/26/2017 to Sun 03/26/2017
0001 0159

Work scheduled by:

FWD
(Import)
MOSES SOUTH **2550 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 03/26/2017 to Sun 03/26/2017
0001 0159

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **1370 MW 0 MW**
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Sun 03/26/2017 to Sun 03/26/2017 **UPDATED by HQ 03/08/2017**
0001 Continuous 0159

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sun 03/26/2017 to Sun 03/26/2017 **UPDATED by HQ 03/08/2017**
0001 Continuous 0159

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1000

Sun 03/26/2017 to Sun 03/26/2017 **UPDATED by HQ 03/08/2017**
0001 Continuous 0159

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1000 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1500 MW

MARCY 345KV_CSC

Mon 03/27/2017 to Thu 04/13/2017
0500 Continuous 1630

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY 345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 03/27/2017 to Thu 04/13/2017
0500 1630

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2					FWD	
Mon 03/27/2017	to	Sat 04/01/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
FRASER -GILBOA_345_GF5-35					FWD	
Mon 03/27/2017	to	Fri 04/07/2017				(Import)
0900	Continuous	1430				CENTRAL EAST - VC 2650 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 325 MW	
					TTC with All Lines In Service 2975 MW	
HOMRC_NY-MAINS_NY_345_47					FWD	
Fri 03/31/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>03/03/2017</u>	(Import) (Export)
1600	Continuous	1600				SCH - PJ - NY 2300 MW 1450 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2300 MW 1450 MW	
MAINESBG-WATRCURE_345_30					FWD	
Fri 03/31/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>03/03/2017</u>	(Import) (Export)
1600	Continuous	1600				SCH - PJ - NY 2200 MW 1450 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 100 MW 0 MW	
					TTC with All Lines In Service 2300 MW 1450 MW	
LINDN_CG-LNDVFT_345_V-3022					FWD	
Sun 04/02/2017	to	Fri 04/07/2017				(Import) (Export)
1400	Continuous	1800				SCH - PJM_VFT 0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 315 MW 315 MW	
					TTC with All Lines In Service 315 MW 315 MW	
MOSES -ADIRNDCK_230_MA1					FWD	
Mon 04/03/2017	to	Sat 04/08/2017				(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR_138_601					FWD	
Mon 04/03/2017	to	Wed 04/12/2017				(Import) (Export)
0700		2359				SCH - NPX_1385 0 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability 200 MW 200 MW	
					TTC with All Lines In Service 200 MW 200 MW	

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_602				
Mon 04/03/2017	to	Wed 04/12/2017		
0700		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_603				
Mon 04/03/2017	to	Wed 04/12/2017		
0700		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601				
Mon 04/03/2017	to	Wed 04/12/2017		
0700	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				
Mon 04/03/2017	to	Wed 04/12/2017		
0700		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				
Mon 04/03/2017	to	Wed 04/12/2017		
0700		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				
Mon 04/03/2017	to	Wed 04/12/2017		
0700	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				
Mon 04/03/2017	to	Wed 04/12/2017		
0700		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603					FWD	REV
Mon 04/03/2017	to	Wed 04/12/2017			(Import)	(Export)
0700	Continuous	2359		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_1385					FWD	REV
Mon 04/03/2017	to	Wed 04/12/2017			(Import)	(Export)
0700	Continuous	2359		SCH - NPX_1385	0 MW	0 MW
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
SCH-IMO-NYISO_LIMIT_1000					FWD	
Tue 04/04/2017	to	Fri 04/07/2017	UPDATED	by PJM	03/17/2017	(Import)
0800	Continuous	0459				SCH - OH - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1750 MW
SCH-NYISO-PJM_LIMIT_100						REV
Tue 04/04/2017	to	Fri 04/07/2017	UPDATED	by PJM	03/17/2017	(Export)
0800	Continuous	0459				SCH - PJ - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1450 MW
W49TH_ST_345KV_6					FWD	
Wed 04/05/2017	to	Sun 04/09/2017	UPDATED	by CONED	03/17/2017	(Import)
0001	Continuous	0200				SCH - PJM_HTP
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
SCRIBA__-VOLNEY__345_20					FWD	
Thu 04/06/2017	to	Thu 04/06/2017				(Import)
0730	Daily(No Weekends)	1630				OSWEGO EXPORT
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
SCH-IMO-NYISO_LIMIT_1000					FWD	
Fri 04/07/2017	to	Tue 04/18/2017	UPDATED	by PJM	03/17/2017	(Import)
1700	Continuous	1559				SCH - OH - NY
Work scheduled by: PJM					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
SCH-NYISO-PJM_LIMIT_100								REV
Fri 04/07/2017	to	Tue 04/18/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/17/2017</u>			(Export)
1700	Continuous	1559				SCH - PJ - NY		400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability		1050 MW
						TTC with All Lines In Service		1450 MW
<hr/>								
COOPERS_-DOLSONAV_345_CCDA42								FWD
Mon 04/10/2017	to	Mon 04/24/2017						(Import)
0630	Continuous	1700				CENTRAL EAST - VC		2720 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability		255 MW
						TTC with All Lines In Service		2975 MW
<hr/>								
DOLSONAV-ROCKTVRN_345_DART44								FWD
Mon 04/10/2017	to	Mon 04/24/2017						(Import)
0630	Continuous	1700				CENTRAL EAST - VC		2720 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability		255 MW
						TTC with All Lines In Service		2975 MW
<hr/>								
MOSES_-ADIRNDCK_230_MA1								FWD
Mon 04/10/2017	to	Thu 04/13/2017						(Import)
0700	Continuous	1530				MOSES SOUTH		2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability		850 MW
						TTC with All Lines In Service		3150 MW
<hr/>								
N.SCTLND-LEEDS___345_93								FWD
Mon 04/10/2017	to	Mon 04/10/2017						(Import)
1100	Daily(No Weekends)	1500				CENTRAL EAST - VC		2650 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		325 MW
						TTC with All Lines In Service		2975 MW
<hr/>								
LEEDS_-PLSNTVLY_345_92								FWD
Tue 04/11/2017	to	Thu 04/13/2017						(Import)
0730	Continuous	1600				UPNY CONED		3800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		1300 MW
						TTC with All Lines In Service		5100 MW
<hr/>								
SHOR_NPX-SHOREHAM_138_CSC								FWD
Mon 04/17/2017	to	Sat 04/22/2017						(Import)
0500	Continuous	1600				SCH - NPX_CSC		0 MW
Work scheduled by: LI						Impacts Total Transfer Capability		330 MW
						TTC with All Lines In Service		330 MW
								REV
								(Export)
								0 MW
								0 MW
								330 MW
								330 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA2

Mon 04/17/2017 to Thu 04/20/2017
0700 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 03/19/2017

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER__-COOPERS_345_33

Mon 04/17/2017 to Fri 04/21/2017
0900 Continuous 1400

Work scheduled by: NYSEG

UPDATED by NY 01/12/2017

FWD
(Import)
CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

EFISHKIL-WOOD_ST_345_F39

Mon 04/17/2017 to Wed 04/19/2017
2100 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

Mon 04/17/2017 to Wed 04/19/2017
2100 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

PORTER__-ROTTRDAM_230_31

Tue 04/18/2017 to Tue 04/18/2017
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2805 MW**
Impacts Total Transfer Capability 170 MW
TTC with All Lines In Service 2975 MW

PLSNTVLY-WOOD_ST_345_F30

Wed 04/19/2017 to Thu 04/20/2017
2200 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Wed 04/19/2017 to Thu 04/20/2017
2200 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Thu 04/20/2017 to Thu 04/20/2017
 0230 Continuous 0300
 Work scheduled by: ConEd

UPDATED by CONED 03/17/2017

SCH - PJM_HTP
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

FWD
 (Import)

DUNWODIE_345KV_6

Fri 04/21/2017 to Fri 04/21/2017
 0001 Continuous 0100
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

DUNWODIE_345KV_8

Fri 04/21/2017 to Fri 04/21/2017
 0001 Continuous 0100
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

PLSNTVLE-DUNWODIE_345_W90

Fri 04/21/2017 to Sun 04/23/2017
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

FWD
 (Import)

WOOD_ST_-PLSNTVLE_345_Y87

Fri 04/21/2017 to Sun 04/23/2017
 0001 Continuous 0200
 Work scheduled by: ConEd

UPNY CONED
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

FWD
 (Import)

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 04/21/2017 to Sat 05/27/2017
 1400 Continuous 0459
 Work scheduled by: NYISO

CENTRAL EAST - VC
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

FWD
 (Import)

SPRNBRK_-W49TH_ST_345_M51

Sat 04/22/2017 to Mon 05/01/2017
 0700 Continuous 1900
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

FWD
 (Import)

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5					FWD
Sat 04/22/2017	to	Mon 05/01/2017			(Import)
0700	Continuous	1900		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
BERKSHIR-ALPS_____345_393					FWD
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NGRID 03/06/2017</u>	(Import) (Export)
1500	Daily	1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<hr/>					
BERKSHIR-ALPS_____345_393					FWD
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NGRID 03/06/2017</u>	(Import) (Export)
1500	Daily	1600		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<hr/>					
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD
Sat 04/22/2017	to	Sat 04/22/2017			(Import) (Export)
1500		1600		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 100 MW 300 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<hr/>					
SCH-NE-NYISO_LIMIT_1000					FWD
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NGRID 03/06/2017</u>	(Import)
1500	Daily	1600		SCH - NE - NY	1200 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1400 MW
<hr/>					
SCH-NYISO-NE_LIMIT_700					REV
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by NGRID 03/06/2017</u>	(Export)
1500	Daily	1600		SCH - NE - NY	900 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1600 MW
<hr/>					
DUNWODIE_345KV_6					FWD
Sun 04/23/2017	to	Sun 04/23/2017			(Import)
0100	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8				FWD	
Sun 04/23/2017	to	Sun 04/23/2017		(Import)	
0100	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
ROSETON_-EFISHKIL_345_RFK305				FWD	
Mon 04/24/2017	to	Fri 05/05/2017		(Import)	
0001	Continuous	1900	UPNY CONED	4100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
CLAY_-EDIC_345_1-16				FWD	
Mon 04/24/2017	to	Tue 04/25/2017		(Import)	
0630	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
STLAWRNC-MOSES_230_L34P				FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017		(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW	1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	1750 MW	1900 MW
MOSES_-ADIRNDCK_230_MA2				FWD	
Mon 04/24/2017	to	Sat 04/29/2017	UPDATED by NYPA 10/23/2016	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
ALCOA_-DENNISON_115_12				FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import)	(Export)
0700	Daily(No Weekends)	1800	SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
ALCOA_-DENNISON_115_12 & ALCOA_-NOGDNBRG_115_13				FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import)	(Export)
0700		1800	SCH - HQ_CEDARS	100 MW	60 MW
Work scheduled by:			Impacts Total Transfer Capability	99 MW	40 MW
			TTC with All Lines In Service	199 MW	100 MW

ARR: 38

ARR: 38

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 3100 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - HQ_CEDARS 100 MW 60 MW</p> <p>Impacts Total Transfer Capability 99 MW 40 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Fri 04/28/2017 to Fri 04/28/2017</p> <p>0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>NEPTUNE_-DUFFYAVE_345_NEPTUNE</p> <p>Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>NEWBRDGE-DUFFYAVE_345_501</p> <p>Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>MARCY_-N.SCTLND_345_18</p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2090 MW</p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY_-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Mon 05/01/2017 to Fri 05/05/2017</p> <p>0600 1630</p> <p>Work scheduled by: ARR: 19</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 1855 MW</p> <p>Impacts Total Transfer Capability 1120 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Mon 05/01/2017	to	Fri 05/05/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ROCHESTR-PANNELL_345_RP2					
Mon 05/01/2017	to	Mon 05/01/2017			
0630	Continuous	0700			
Work scheduled by: RGE					
				DYSINGER EAST	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
PANNELL_-CLAY_345_2					
Mon 05/01/2017	to	Fri 05/05/2017			
0630	Continuous	1530			
Work scheduled by: NYPA					
				WEST CENTRAL	1300 MW
				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					
Tue 05/02/2017	to	Tue 05/02/2017			
0001		2359			
Work scheduled by:					
				SCH - PJ - NY	2050 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
MARION_-FARRAGUT_345_C3403					
Tue 05/02/2017	to	Sat 05/20/2017	UPDATED by CE 01/28/2017		
0001	Continuous	2359			
Work scheduled by: PJM					
				SCH - PJ - NY	2050 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
ROCHESTR-PANNELL_345_RP2					
Fri 05/05/2017	to	Fri 05/05/2017			
1500	Continuous	1530			
Work scheduled by: RGE					
				DYSINGER EAST	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3					
Mon 05/08/2017	to	Fri 05/12/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>PANNELL_-CLAY_____345_2</p> <p>Mon 05/08/2017 to Mon 05/08/2017 0700 Continuous 0730</p> <p>Work scheduled by: RGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>
<p>ROCHESTR-PANNELL__345_RP2</p> <p>Mon 05/08/2017 to Wed 05/10/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ROSETON_-ROCKTVRN_345_311</p> <p>Mon 05/08/2017 to Fri 05/26/2017 0800 Continuous 1600</p> <p>Work scheduled by: CHGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4400 MW</p> <p>Impacts Total Transfer Capability 700 MW</p> <p>TTC with All Lines In Service 5100 MW</p>
<p>PANNELL_-CLAY_____345_2</p> <p>Wed 05/10/2017 to Wed 05/10/2017 1500 Continuous 1530</p> <p>Work scheduled by: RGE</p>	<p style="text-align: right;">FWD (Import)</p> <p>WEST CENTRAL 1300 MW</p> <p>Impacts Total Transfer Capability 950 MW</p> <p>TTC with All Lines In Service 2250 MW</p>
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Mon 05/15/2017 to Fri 05/19/2017 0600 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 70 MW 40 MW</p> <p>Impacts Total Transfer Capability 120 MW 0 MW</p> <p>TTC with All Lines In Service 190 MW 40 MW</p>
<p>FRASER_-GILBOA_____345_GF5-35</p> <p>Mon 05/15/2017 to Fri 05/19/2017 0630 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>STONYRDG-HILLSIDE_230_72</p> <p>Mon 05/15/2017 to Mon 05/15/2017 0800 Continuous 1700</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

ARR: 38

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<p>FRASER___345_FRASER SVC</p> <p>Mon 05/15/2017 to Fri 05/19/2017 0900 Continuous 1430</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2935 MW</p> <p>Impacts Total Transfer Capability 40 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>FRASER___345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Mon 05/15/2017 to Fri 05/19/2017 0900 Continuous 1430</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2700 MW</p> <p>Impacts Total Transfer Capability 275 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		
<hr/>			
<p>RAMAPO__-LADENTWN_345_W72</p> <p>Tue 05/16/2017 to Tue 05/16/2017 0001 Continuous 2330</p> <p>Work scheduled by: ORU</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4400 MW</p> <p>Impacts Total Transfer Capability 700 MW</p> <p>TTC with All Lines In Service 5100 MW</p>		
<hr/>			
<p>MARCY___765_345_AT1</p> <p>Mon 05/22/2017 to Fri 05/26/2017 0500 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>		
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Mon 05/22/2017 to Fri 05/26/2017 0600 Continuous 1900</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 70 MW 40 MW</p> <p>Impacts Total Transfer Capability 120 MW 0 MW</p> <p>TTC with All Lines In Service 190 MW 40 MW</p>		
<hr/>			
<p>LINDEN__-GOETHALS_230_A2253</p> <p>Fri 05/26/2017 to Sat 05/27/2017 0001 Continuous 2359</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 2050 MW 1300 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 2050 MW 1300 MW</p>		
<hr/>			
<p>MARCY___-N.SCTLND_345_18</p> <p>Sat 05/27/2017 to Sat 05/27/2017 0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2090 MW</p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>		

ARR: 19

ARR: 38

UPDATED by CE 02/01/2017

ARR: 19

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S			FWD	REV
Sat 05/27/2017	to	Sat 08/05/2017	(Import)	
1600	Continuous	0459	CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW
			TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4			FWD	REV
Tue 05/30/2017	to	Fri 06/02/2017	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
BROWNFLS-TAYLORVL_115_4			FWD	REV
Mon 06/05/2017	to	Fri 06/09/2017	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
STONYRDG-HILLSIDE_230_72			FWD	REV
Mon 06/05/2017	to	Mon 06/05/2017	(Import)	
0800	Continuous	1000	DYSINGER EAST	2850 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
STONYRDG-HILLSIDE_230_72			FWD	REV
Fri 06/09/2017	to	Fri 06/09/2017	(Import)	
1500	Continuous	1700	DYSINGER EAST	2850 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_4			FWD	REV
Mon 06/12/2017	to	Fri 06/16/2017	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				
BROWNFLS-TAYLORVL_115_4			FWD	REV
Mon 06/19/2017	to	Fri 06/23/2017	(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
ARR: 38				

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3				
Mon 06/26/2017	to	Fri 06/30/2017		FWD
0600	Continuous	1900		(Import) (Export)
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				
Wed 07/05/2017	to	Fri 07/07/2017	UPDATED	
0600	Continuous	1900	by NGRID	03/02/2017
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				
Mon 07/10/2017	to	Fri 07/14/2017	UPDATED	
0600	Continuous	1900	by NGRID	03/02/2017
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3				
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED	
0600	Continuous	1900	by NGRID	03/02/2017
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				
Mon 07/24/2017	to	Fri 07/28/2017		FWD
0600	Continuous	1900		(Import) (Export)
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				
Mon 07/31/2017	to	Fri 08/04/2017		FWD
0600	Continuous	1900		(Import) (Export)
Work scheduled by: NGrid			ARR: 38	
			SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
MARCY___-N.SCTLND_345_18				
Sat 08/05/2017	to	Sat 08/05/2017		FWD
0500	Continuous	1530		(Import)
Work scheduled by: NYPA			ARR: 19	
			CENTRAL EAST - VC	2090 MW
			Impacts Total Transfer Capability	885 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 11/06/2017
1600 Continuous 0559

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

BROWNFLS-TAYLORVL_115_4

Mon 08/07/2017 to Fri 08/11/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_4

Mon 08/14/2017 to Fri 08/18/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_3

Mon 08/21/2017 to Fri 08/25/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_3

Mon 08/28/2017 to Fri 09/01/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Tue 09/05/2017	to	Fri 09/08/2017			
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			ARR: 38		
BROWNFLS-TAYLORVL_115_3					
Mon 09/11/2017	to	Fri 09/15/2017			
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
			ARR: 38		
HURLYAVE-ROSETON__345_303					
Mon 09/11/2017	to	Fri 09/29/2017			
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
DUNWODIE_345KV_5					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_7					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBRK_-DUNWODIE_345_W75					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBRK__345KV_RNS3					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_4						
Mon 09/18/2017	to	Fri 09/22/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
GILBOA_-N.SCTLND_345_GNS-1						
Mon 09/18/2017	to	Fri 10/06/2017				
0630	Continuous	1700				
Work scheduled by: NYPA						
					CENTRAL EAST - VC	2520 MW
					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
NIAGARA_345_230_AT4						
Mon 09/18/2017	to	Tue 09/19/2017				
0700	Continuous	1530				
Work scheduled by: NYPA						
					SCH - OH - NY	1750 MW 1300 MW
					Impacts Total Transfer Capability	0 MW 300 MW
					TTC with All Lines In Service	1750 MW 1600 MW
BROWNFLS-TAYLORVL_115_4						
Mon 09/25/2017	to	Fri 09/29/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 10/02/2017	to	Fri 10/06/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
NIAGARA_-ROCHESTR_345_NR2						
Mon 10/02/2017	to	Fri 10/06/2017				
0700	Continuous	1530				
Work scheduled by: NYPA						
					DYSINGER EAST	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_4						
Mon 10/09/2017	to	Fri 10/13/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1550 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040			FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
MARCY__765_345_AT1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	3150 MW
				ARR: 19
MARCY__765_345_AT2			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
				ARR: 19
MASSENA_-MARCY__765_MSU1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	710 MW
			TTC with All Lines In Service	2975 MW
MASSENA_-MARCY__765_MSU1			FWD	
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW
			TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1			FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW 0 MW
			TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA -MARCY 765_MSU1 & ILCTLIMIT MARCY_SO_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2080 MW**
Impacts Total Transfer Capability 895 MW
TTC with All Lines In Service 2975 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

BROWNFLS-TAYLORVL 115_3

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 03/03/2017

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

FRASANX-COOPERS 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY -FRASANX 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3					FWD	REV
Mon 11/06/2017	to	Thu 11/09/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0700	Continuous	1900			100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
BROWNFLS-TAYLORVL_115_4					FWD	REV
Mon 11/13/2017	to	Fri 11/17/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0600	Continuous	1900			100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Fri 11/17/2017	to	Sat 02/01/2020			(Import)	
1700	Continuous	0000			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
BROWNFLS-TAYLORVL_115_4					FWD	REV
Mon 11/20/2017	to	Wed 11/22/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0600	Continuous	1900			100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
BROWNFLS-TAYLORVL_115_4					FWD	REV
Mon 11/27/2017	to	Thu 11/30/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0600	Continuous	1900			100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
					ARR: 38	100 MW
<hr/>						
MARCY___765_345_AT2					FWD	
Mon 12/04/2017	to	Fri 12/08/2017			(Import)	
0500	Continuous	1630			MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
					ARR: 19	
<hr/>						
MOSES___-ADIRNDCK_230_MA2					FWD	
Mon 12/11/2017	to	Fri 12/15/2017			(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,March 20, 2017 to Wednesday,September19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

UPDATED by NYPA 10/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

FWD

Tue 12/26/2017 to Thu 12/28/2017
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW