

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	Impact	FWD (Import)	REV (Export)
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	2200 MW	1450 MW
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sat 04/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>02/01/2017</u>	UPNY CONED	4000 MW	
0728	Continuous	2359				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/25/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Thu 04/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/25/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6	Fri 02/17/2017	Thu 03/30/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/25/2017</u>	SCH - PJM_HTP	315 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	345 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
DUNWODIE-SHORE_RD_345_Y50	Wed 03/01/2017	Mon 03/20/2017				CONED - LIPA	800 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	700 MW	
Work scheduled by: LI						TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 1				FWD
Wed 03/01/2017	to	Mon 03/20/2017		(Import)
0001	Continuous	2359	CONED - LIPA	1350 MW
Work scheduled by: LI				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2				FWD
Wed 03/01/2017	to	Mon 03/20/2017		(Import)
0001	Continuous	2359	CONED - LIPA	1350 MW
Work scheduled by: LI				Impacts Total Transfer Capability 150 MW
				TTC with All Lines In Service 1500 MW
COOPERS_-DOLSONAV_345_CCDA42				FWD
Thu 03/02/2017	to	Fri 03/24/2017	UPDATED by NYSEG 02/28/2017	(Import)
0500	Continuous	1530	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
DOLSONAV-ROCKTVRN_345_DART44				FWD
Thu 03/02/2017	to	Fri 03/24/2017	UPDATED by NYSEG 02/28/2017	(Import)
0500	Continuous	1530	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
LADENTWN-BUCHAN_S_345_Y88				FWD
Sat 03/18/2017	to	Mon 03/20/2017	UPDATED by CONED 03/24/2017	(Import)
0001	Continuous	2359	UPNY CONED	4150 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 5100 MW
SCH-IMO-NYISO_LIMIT_1000				FWD
Sat 03/18/2017	to	Wed 03/22/2017	UPDATED by NYISO 03/21/2017	(Import)
1700	Continuous	2359	SCH - OH - NY	1300 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 450 MW
				TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100				REV
Sat 03/18/2017	to	Mon 04/03/2017	UPDATED by NYISO 03/21/2017	(Export)
1700	Continuous	1559	SCH - PJ - NY	400 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 1450 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY _____ 345_8					FWD	
Mon 03/20/2017	to	Sun 03/26/2017	EXTENDED	by NGRID	03/25/2017	(Import)
0001	Continuous	1000				OSWEGO EXPORT 5150 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 5250 MW	
SCH-IMO-NYISO_NIAG_CB_3008_W/BB					FWD REV	
Mon 03/20/2017	to	Tue 03/21/2017	UPDATED	by NYISO	03/17/2017	(Import) (Export)
0500	Continuous	1700				SCH - OH - NY 1750 MW 1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW 150 MW	
					TTC with All Lines In Service 1750 MW 1900 MW	
FRASANX-COOPERS _____ 345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	UPDATED	by NYISO	10/27/2016	(Import)
0500	Continuous	1630				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW	
					TTC with All Lines In Service 2975 MW	
MARCY _____ -FRASANX_345_UCC2-41					FWD	
Mon 03/20/2017	to	Fri 03/24/2017	UPDATED	by NYISO	10/27/2016	(Import)
0500	Continuous	1630				CENTRAL EAST - VC 2500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW	
					TTC with All Lines In Service 2975 MW	
MOSES _____ -ADIRNDCK_230_MA2					FWD	
Mon 03/20/2017	to	Sat 03/25/2017	UPDATED	by NYPA	03/13/2017	(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
SCH-NE-NYISO_LIMIT_200					FWD	
Tue 03/21/2017	to	Fri 03/24/2017	UPDATED	by ISONE	03/21/2017	(Import)
0001	Continuous	0659				SCH - NE - NY 400 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 1000 MW	
					TTC with All Lines In Service 1400 MW	
HUDSONP _____ -FARRAGUT_345_B3402 & MARION _____ -FARRAGUT_345_C3403					FWD REV	
Tue 03/21/2017	to	Mon 05/01/2017				(Import) (Export)
0001		2359				SCH - PJ - NY 2050 MW 1450 MW
Work scheduled by:					Impacts Total Transfer Capability 250 MW 0 MW	
					TTC with All Lines In Service 2300 MW 1450 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARION__-FARRAGUT_345_C3403					FWD	REV
Tue 03/21/2017	to	Mon 05/01/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/21/2017</u>	(Import) (Export)
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2300 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
HUDSONP_-FARRAGUT_345_B3402					FWD	REV
Tue 03/21/2017	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/21/2017</u>	(Import) (Export)
0001	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2300 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B					FWD	
Tue 03/21/2017	to	Tue 03/21/2017				(Import)
0700	Daily(No Weekends)	1600				
Work scheduled by: NGrid					MOSES SOUTH	3100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B					FWD	REV
Tue 03/21/2017	to	Tue 03/21/2017				(Import) (Export)
0700	Daily(No Weekends)	1600				
Work scheduled by: NGrid					SCH - HQ_CEDARS	100 MW 60 MW
					Impacts Total Transfer Capability	99 MW 40 MW
					TTC with All Lines In Service	199 MW 100 MW
SCH-NE-NYISO_LIMIT_0					FWD	
Tue 03/21/2017	to	Thu 03/23/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Import)
0700	Continuous	2359				
Work scheduled by: ISONE					SCH - NE - NY	200 MW
					Impacts Total Transfer Capability	1200 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-IMO_NIAGARA_CB_3108					FWD	REV
Wed 03/22/2017	to	Thu 03/23/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/17/2017</u>	(Import) (Export)
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1750 MW 1850 MW
					Impacts Total Transfer Capability	0 MW 50 MW
					TTC with All Lines In Service	1750 MW 1900 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B					FWD	
Wed 03/22/2017	to	Wed 03/22/2017	<u>CANCELLED</u>	<u>by NGrid</u>	<u>03/22/2017</u>	(Import)
0700	Daily(No Weekends)	1600				
Work scheduled by: NGrid					MOSES SOUTH	3100 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				FWD	REV
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B				(Import)	(Export)
Wed 03/22/2017	to	Wed 03/22/2017	CANCELLED by NGrid <u>03/22/2017</u>		
0700	Daily(No Weekends)	1600		SCH - HQ_CEDARS	100 MW 60 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	99 MW 40 MW
				TTC with All Lines In Service	199 MW 100 MW
<hr/>					
SCH-NYISO-HQ_LIMIT_800					REV
Wed 03/22/2017	to	Thu 03/23/2017	CANCELLED by HQ <u>03/21/2017</u>		(Export)
0700	Continuous	1700		SCH - HQ - NY	800 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1000 MW
<hr/>					
SCH-NE-NYISO_LIMIT_0				FWD	
Fri 03/24/2017	to	Fri 03/24/2017	UPDATED by ISONE <u>03/21/2017</u>	(Import)	
0700	Continuous	1800		SCH - NE - NY	200 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	1200 MW
				TTC with All Lines In Service	1400 MW
<hr/>					
SCH-NYISO-HQ_LIMIT_800					REV
Fri 03/24/2017	to	Sat 03/25/2017			(Export)
0700	Daily	1700		SCH - HQ - NY	800 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1000 MW
<hr/>					
BERKSHIR-ALPS _____ 345_393				FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	UPDATED by ISONE <u>03/21/2017</u>	(Import)	(Export)
0800	Daily(No Weekends)	0900		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<hr/>					
BERKSHIR-ALPS _____ 345_393				FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017	UPDATED by ISONE <u>03/21/2017</u>	(Import)	(Export)
0800	Daily(No Weekends)	0900		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<hr/>					
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312				FWD	REV
Fri 03/24/2017	to	Fri 03/24/2017		(Import)	(Export)
0800		0900		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:				Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_700						REV
Fri 03/24/2017	to	Fri 03/24/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Export)
0800	Daily(No Weekends)	0900				900 MW
Work scheduled by: NGrid					SCH - NE - NY	700 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	
BERKSHIR-NORTHFLD_345_312						FWD REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Import) (Export)
0800	Continuous	1600				1400 MW 1450 MW
Work scheduled by: ISONE					SCH - NE - NY	150 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	
BERKSHIR-NORTHFLD_345_312						FWD REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Import) (Export)
0800	Continuous	1600				100 MW 100 MW
Work scheduled by: ISONE					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	
SCH-NE-NYISO_LIMIT_900						FWD
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Import)
0800	Continuous	1600				1100 MW
Work scheduled by: ISONE					SCH - NE - NY	300 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	
SCH-NYISO-NE_LIMIT_900						REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>03/21/2017</u>	(Export)
0800	Continuous	1600				1100 MW
Work scheduled by: ISONE					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD
Fri 03/24/2017	to	Mon 04/17/2017				(Import)
1700	Continuous	0900				2740 MW
Work scheduled by: NYISO					CENTRAL EAST - VC	235 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
MILLWOOD_345KV_18						FWD
Sat 03/25/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>03/21/2017</u>	(Import)
0001	Continuous	2200				4350 MW
Work scheduled by: ConEd					UPNY CONED	750 MW
					Impacts Total Transfer Capability	5100 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					FWD	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Import)
0001	Continuous	0159				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Export)
0001	Continuous	0159				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sun 03/26/2017	to	Sun 03/26/2017				(Import)
0001		0159				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV
Sun 03/26/2017	to	Sun 03/26/2017				(Import) (Export)
0001		0159				SCH - HQ - NY 1370 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2					FWD	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Import)
0001	Continuous	0159				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2					REV	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Export)
0001	Continuous	0159				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1000					FWD	
Sun 03/26/2017	to	Sun 03/26/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>03/08/2017</u>	(Import)
0001	Continuous	0159				SCH - HQ - NY 1000 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Sun 03/26/2017 to Sun 03/26/2017
 1400 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Sun 03/26/2017 to Sun 03/26/2017
 1400 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

MARCY___345KV_CSC

Mon 03/27/2017 to Thu 04/13/2017 UPDATED by NYPA 03/21/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 03/27/2017 to Thu 04/13/2017
 0500 1630
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2690 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Mon 03/27/2017 to Sat 04/01/2017 UPDATED by NYPA 10/23/2016
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SCH-NE-NYISO_LIMIT_0

Mon 03/27/2017 to Mon 03/27/2017
 0800 Daily 1500
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NE - NY **200 MW**
 Impacts Total Transfer Capability 1200 MW
 TTC with All Lines In Service 1400 MW

SCH-NPX_1385-NYISO_LIMIT_100

Mon 03/27/2017 to Mon 03/27/2017
 0800 Daily 1500
 Work scheduled by: ISONE

FWD
 (Import)
 SCH - NPX_1385 **100 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35				FWD	
Mon 03/27/2017	to	Fri 04/07/2017		(Import)	
0900	Continuous	1430	CENTRAL EAST - VC	2650 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	
SCH-NE-NYISO_LIMIT_0				FWD	
Tue 03/28/2017	to	Tue 03/28/2017		(Import)	
0800	Daily	1700	SCH - NE - NY	200 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	1200 MW	
			TTC with All Lines In Service	1400 MW	
SCH-NPX_1385-NYISO_LIMIT_100				FWD	
Tue 03/28/2017	to	Tue 03/28/2017		(Import)	
0800	Daily	1700	SCH - NPX_1385	100 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	200 MW	
SCH-NYISO-HQ_LIMIT_500					REV
Tue 03/28/2017	to	Wed 03/29/2017		(Export)	
1500	Continuous	1800	SCH - HQ - NY	500 MW	
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	1000 MW	
HOMRC_NY-MAINS_NY_345_47				FWD	REV
Fri 03/31/2017	to	Fri 04/14/2017	UPDATED by NYSEG 03/03/2017	(Import)	(Export)
1600	Continuous	1600	SCH - PJ - NY	2300 MW	1450 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2300 MW	1450 MW
MAINESBG-WATRCURE_345_30				FWD	REV
Fri 03/31/2017	to	Fri 04/14/2017	UPDATED by NYSEG 03/03/2017	(Import)	(Export)
1600	Continuous	1600	SCH - PJ - NY	2200 MW	1450 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	100 MW	0 MW
			TTC with All Lines In Service	2300 MW	1450 MW
LADENTWN-BUCHAN_S_345_Y88				FWD	
Sun 04/02/2017	to	Sun 04/02/2017		(Import)	
0001	Continuous	2359	UPNY CONED	4150 MW	
Work scheduled by: ORU			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	5100 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT___345_V-3022

Sun 04/02/2017 to Fri 04/07/2017
1400 Continuous 1800

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

SCH-NYISO-HQ_LIMIT_800

Mon 04/03/2017 to Thu 04/13/2017
0600 Continuous 1800

Work scheduled by: HQ

		REV
		(Export)
SCH - HQ - NY		800 MW
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1000 MW

MOSES___-ADIRNDCK_230_MAL

Mon 04/03/2017 to Sat 04/08/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	
	(Import)	
MOSES SOUTH	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_601

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_602

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-NORTHFLD_345_312 & NRTH1385-NOR HBR__138_603

Mon 04/03/2017 to Wed 04/12/2017
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_601

Mon 04/03/2017 to Wed 04/12/2017
0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	Continuous 2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	Continuous 2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NRTHPORT_138_1385		FWD	REV
		(Import)	(Export)
Mon 04/03/2017	to Wed 04/12/2017		
0700	Continuous 2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by: LI		Impacts Total Transfer Capability	200 MW 200 MW
		TTC with All Lines In Service	200 MW 200 MW
SCH-IMO-NYISO_LIMIT_1000		FWD	
		(Import)	
Tue 04/04/2017	to Fri 04/07/2017		
0800	Continuous 0459	UPDATED	by PJM 03/17/2017
Work scheduled by: PJM		SCH - OH - NY	1300 MW
		Impacts Total Transfer Capability	450 MW
		TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_100						REV
Tue 04/04/2017	to	Fri 04/07/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/17/2017</u>	(Export)
0800	Continuous	0459				400 MW
Work scheduled by: PJM						1050 MW
						1450 MW
W49TH_ST_345KV_6						FWD
Wed 04/05/2017	to	Thu 04/13/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/25/2017</u>	(Import)
0001	Continuous	0200				315 MW
Work scheduled by: ConEd						345 MW
						660 MW
SCRIBA__VOLNEY__345_20						FWD
Thu 04/06/2017	to	Thu 04/06/2017				(Import)
0730	Daily(No Weekends)	1630				5250 MW
Work scheduled by: NGrid						0 MW
						5250 MW
SCH-IMO-NYISO_LIMIT_1000						FWD
Fri 04/07/2017	to	Tue 04/18/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/17/2017</u>	(Import)
1700	Continuous	1559				1300 MW
Work scheduled by: PJM						450 MW
						1750 MW
SCH-NYISO-PJM_LIMIT_100						REV
Fri 04/07/2017	to	Tue 04/18/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>03/17/2017</u>	(Export)
1700	Continuous	1559				400 MW
Work scheduled by: PJM						1050 MW
						1450 MW
W49TH_ST_345KV_8						FWD
Sat 04/08/2017	to	Thu 04/13/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>03/25/2017</u>	(Import)
0201	Continuous	0200				315 MW
Work scheduled by: ConEd						345 MW
						660 MW
COOPERS_-DOLSONAV_345_CCDA42						FWD
Mon 04/10/2017	to	Mon 04/24/2017				(Import)
0630	Continuous	1700				2720 MW
Work scheduled by: NYPA						255 MW
						2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DOLSONAV-ROCKTVRN_345_DART44				FWD
Mon 04/10/2017	to	Mon 04/24/2017		(Import)
0630	Continuous	1700	CENTRAL EAST - VC	2720 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 255 MW
				TTC with All Lines In Service 2975 MW
MOSES__-ADIRNDCK_230_MAI				FWD
Mon 04/10/2017	to	Thu 04/13/2017		(Import)
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
N. SCTLND-LEEDS__345_93				FWD
Mon 04/10/2017	to	Mon 04/10/2017		(Import)
1100	Daily(No Weekends)	1500	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW
LEEDS__-PLSNTVLY_345_92				FWD
Tue 04/11/2017	to	Thu 04/13/2017		(Import)
0730	Continuous	1600	UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
SHOR_NPX-SHOREHAM_138_CSC				FWD
Mon 04/17/2017	to	Sat 04/22/2017		(Import) (Export)
0500	Continuous	1600	SCH - NPX_CSC	0 MW 0 MW
Work scheduled by: LI				Impacts Total Transfer Capability 330 MW 330 MW
				TTC with All Lines In Service 330 MW 330 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Mon 04/17/2017	to	Thu 04/20/2017	UPDATED by NYPA 03/19/2017	(Import)
0700	Continuous	1930	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
FRASER__-COOPERS__345_33				FWD
Mon 04/17/2017	to	Fri 04/21/2017	UPDATED by NY 01/12/2017	(Import)
0900	Continuous	1400	CENTRAL EAST - VC	2395 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 580 MW
				TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39

Mon 04/17/2017 to Wed 04/19/2017
 2100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

Mon 04/17/2017 to Wed 04/19/2017
 2100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

PORTER_-ROTTRDAM_230_31

Tue 04/18/2017 to Tue 04/18/2017
 0800 Daily(No Weekends) 1500
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2805 MW**
 Impacts Total Transfer Capability 170 MW
 TTC with All Lines In Service 2975 MW

VOLNEY_-CLAY_____345_6

Wed 04/19/2017 to Wed 04/19/2017
 0730 Daily(No Weekends) 1700
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

PLSNTVLY-WOOD_ST__345_F30

Wed 04/19/2017 to Thu 04/20/2017
 2200 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Wed 04/19/2017 to Thu 04/20/2017
 2200 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

W49TH_ST_345KV_6

Thu 04/20/2017 to Thu 04/20/2017 **UPDATED by CONED 03/25/2017**
 0230 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Fri 04/21/2017 to Fri 04/21/2017
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Fri 04/21/2017 to Fri 04/21/2017
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

Fri 04/21/2017 to Sun 04/23/2017
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

WOOD_ST_-PLSNTVLE_345_Y87

Fri 04/21/2017 to Sun 04/23/2017
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 04/21/2017 to Sat 05/27/2017
 1400 Continuous 0459
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

SPRNBRK_-W49TH_ST_345_M51

Sat 04/22/2017 to Mon 05/01/2017
 0700 Continuous 1900
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS5

Sat 04/22/2017 to Mon 05/01/2017
 0700 Continuous 1900
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by NGRID 03/06/2017	(Import)	(Export)
1500	Daily	1600			1300 MW	1300 MW
Work scheduled by: NGrid						
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS _____ 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by NGRID 03/06/2017	(Import)	(Export)
1500	Daily	1600			100 MW	100 MW
Work scheduled by: NGrid						
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017			(Import)	(Export)
1500		1600			1300 MW	1300 MW
Work scheduled by:						
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_1000					FWD	
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by NGRID 03/06/2017	(Import)	
1500	Daily	1600			1200 MW	
Work scheduled by: NGrid						
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_700						REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by NGRID 03/06/2017		(Export)
1500	Daily	1600				900 MW
Work scheduled by: NGrid						
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1600 MW
DUNWODIE_345KV_6					FWD	
Sun 04/23/2017	to	Sun 04/23/2017			(Import)	
0100	Continuous	0200			3800 MW	
Work scheduled by: ConEd						
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Sun 04/23/2017	to	Sun 04/23/2017			(Import)	
0100	Continuous	0200			3800 MW	
Work scheduled by: ConEd						
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305			FWD
Mon 04/24/2017	to	Fri 05/05/2017	(Import)
0001	Continuous	1900	UPNY CONED 4100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 5100 MW
CLAY_-EDIC_345_1-16			FWD
Mon 04/24/2017	to	Tue 04/25/2017	(Import)
0630	Continuous	1530	OSWEGO EXPORT 4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 5250 MW
STLAWRNC-MOSES_230_L34P			FWD REV
Mon 04/24/2017	to	Fri 04/28/2017	(Import) (Export)
0700	Continuous	1530	SCH - OH - NY 1750 MW 1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 0 MW 0 MW
			TTC with All Lines In Service 1750 MW 1900 MW
MOSES_-ADIRNDCK_230_MA2			FWD
Mon 04/24/2017	to	Sat 04/29/2017	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
ALCOA_-DENNISON_115_12			FWD REV
Wed 04/26/2017	to	Wed 04/26/2017	(Import) (Export)
0700	Daily(No Weekends)	1800	SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 99 MW 0 MW
			TTC with All Lines In Service 199 MW 100 MW
ALCOA_-DENNISON_115_12 & ALCOA_-NOGDNRG_115_13			FWD REV
Wed 04/26/2017	to	Wed 04/26/2017	(Import) (Export)
0700		1800	SCH - HQ_CEDARS 100 MW 60 MW
Work scheduled by:			Impacts Total Transfer Capability 99 MW 40 MW
			TTC with All Lines In Service 199 MW 100 MW
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B			FWD
Wed 04/26/2017	to	Wed 04/26/2017	(Import)
0700	Daily(No Weekends)	1800	MOSES SOUTH 3100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B	FWD	REV
	(Import)	(Export)
Wed 04/26/2017 to Wed 04/26/2017 0700 Daily(No Weekends) 1800 Work scheduled by: NGrid	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	100 MW 60 MW 99 MW 40 MW 199 MW 100 MW

NIAGARA_-ROCHESTR_345_NR2	FWD	
Fri 04/28/2017 to Fri 04/28/2017 0700 Continuous 1530 Work scheduled by: NYPA	DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service	1700 MW 1450 MW 3150 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE	FWD	
Mon 05/01/2017 to Tue 05/16/2017 0400 Continuous 1800 Work scheduled by: LI	SCH - PJM_NEPTUNE Impacts Total Transfer Capability TTC with All Lines In Service	0 MW 660 MW 660 MW

NEWBRDGE-DUFFYAVE_345_501	FWD	
Mon 05/01/2017 to Tue 05/16/2017 0400 Continuous 1800 Work scheduled by: LI	SCH - PJM_NEPTUNE Impacts Total Transfer Capability TTC with All Lines In Service	0 MW 660 MW 660 MW

MARCY_-N.SCTLND_345_18	FWD	
Mon 05/01/2017 to Fri 05/05/2017 0600 Continuous 1630 Work scheduled by: NYPA	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	2090 MW 885 MW 2975 MW

MARCY_-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	
Mon 05/01/2017 to Fri 05/05/2017 0600 Continuous 1630 Work scheduled by:	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	1855 MW 1120 MW 2975 MW

BROWNFLS-TAYLORVL_115_3	FWD	REV
Mon 05/01/2017 to Fri 05/05/2017 0600 Continuous 1900 Work scheduled by: NGrid	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	70 MW 40 MW 120 MW 0 MW 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2					FWD
Mon 05/01/2017	to	Mon 05/01/2017			(Import)
0630	Continuous	0700		DYSINGER EAST	2300 MW
Work scheduled by: RGE					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
PANNELL_-CLAY_____345_2					FWD
Mon 05/01/2017	to	Fri 05/05/2017			(Import)
0630	Continuous	1530		WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 950 MW
					TTC with All Lines In Service 2250 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD REV
Tue 05/02/2017	to	Tue 05/02/2017			(Import) (Export)
0001		2359		SCH - PJ - NY	2050 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2050 MW 1300 MW
MARION_-FARRAGUT_345_C3403					FWD REV
Tue 05/02/2017	to	Sat 05/20/2017	UPDATED	by CE	01/28/2017
0001	Continuous	2359			(Import) (Export)
Work scheduled by: PJM					2050 MW 1300 MW
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2050 MW 1300 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD
Thu 05/04/2017	to	Thu 05/04/2017			(Import)
0730	Daily(No Weekends)	0800		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
OSWEGO_-ELBRIDGE_345_17					FWD
Thu 05/04/2017	to	Thu 05/04/2017			(Import)
0730	Daily(No Weekends)	1700		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD
Thu 05/04/2017	to	Thu 05/04/2017			(Import)
1630	Daily(No Weekends)	1700		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2		FWD	
Fri 05/05/2017	to Fri 05/05/2017	(Import)	
1500	Continuous 1530	DYSINGER EAST	2300 MW
Work scheduled by: RGE		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3		FWD	REV
Mon 05/08/2017	to Fri 05/12/2017	(Import)	(Export)
0600	Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	120 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW
PANNELL_-CLAY____345_2		FWD	
Mon 05/08/2017	to Mon 05/08/2017	(Import)	
0700	Continuous 0730	WEST CENTRAL	1300 MW
Work scheduled by: RGE		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL__345_RP2		FWD	
Mon 05/08/2017	to Wed 05/10/2017	(Import)	
0700	Continuous 1530	DYSINGER EAST	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311		FWD	
Mon 05/08/2017	to Fri 05/26/2017	(Import)	
0800	Continuous 1600	UPNY CONED	4400 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	5100 MW
PANNELL_-CLAY____345_2		FWD	
Wed 05/10/2017	to Wed 05/10/2017	(Import)	
1500	Continuous 1530	WEST CENTRAL	1300 MW
Work scheduled by: RGE		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
BROWNFLS-TAYLORVL_115_3		FWD	REV
Mon 05/15/2017	to Fri 05/19/2017	(Import)	(Export)
0600	Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	120 MW 0 MW
		TTC with All Lines In Service	190 MW 40 MW

ARR: 38

ARR: 38

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE 230_72

Mon 05/15/2017 to Mon 05/15/2017
 0800 Continuous 1700
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017
 0900 Continuous 1430
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

FRASER 345_FRASER SVC & ILCTLIMT_MARCY_SO_COMP_I/S

Mon 05/15/2017 to Fri 05/19/2017
 0900 1430
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2700 MW**
 Impacts Total Transfer Capability 275 MW
 TTC with All Lines In Service 2975 MW

RAMAPO -LADENTWN 345_W72

Tue 05/16/2017 to Tue 05/16/2017
 0001 Continuous 2330
 Work scheduled by: ORU

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

MARCY 765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL 115_3

Mon 05/22/2017 to Fri 05/26/2017
 0600 Continuous 1900
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
LINDEN__-GOETHALS_230_A2253					(Import)	(Export)
Fri 05/26/2017	to	Sun 05/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>02/01/2017</u>	
0001	Continuous	2300				
Work scheduled by: PJM					SCH - PJ - NY	2050 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
<hr/>					FWD	REV
MARCY__-N.SCTLND_345_18					(Import)	(Export)
Sat 05/27/2017	to	Sat 05/27/2017				
0500	Continuous	1530				
Work scheduled by: NYPA					CENTRAL EAST - VC	2090 MW
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
<hr/>					FWD	REV
ILCTLIMIT_MARCY_SO_COMP_I/S					(Import)	(Export)
Sat 05/27/2017	to	Sat 08/05/2017				
1600	Continuous	0459				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Tue 05/30/2017	to	Fri 06/02/2017				
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Mon 06/05/2017	to	Fri 06/09/2017				
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<hr/>					FWD	REV
STONYRDG-HILLSIDE_230_72					(Import)	(Export)
Mon 06/05/2017	to	Mon 06/05/2017				
0800	Continuous	1000				
Work scheduled by: NYSEG					DYSINGER EAST	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<hr/>					FWD	REV
STONYRDG-HILLSIDE_230_72					(Import)	(Export)
Fri 06/09/2017	to	Fri 06/09/2017				
1500	Continuous	1700				
Work scheduled by: NYSEG					DYSINGER EAST	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4					
Mon 06/12/2017	to	Fri 06/16/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 06/19/2017	to	Fri 06/23/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 06/26/2017	to	Fri 06/30/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Wed 07/05/2017	to	Fri 07/07/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 07/10/2017	to	Fri 07/14/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 07/24/2017	to	Fri 07/28/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Mon 07/31/2017	to	Fri 08/04/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY -N.SCTLND_345_18					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				CENTRAL EAST - VC	2090 MW
				Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
MARCY 765_345_AT2					
Sat 08/05/2017	to	Sat 08/05/2017			
0500	Continuous	1530			
Work scheduled by: NYPA			ARR: 19		
				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					
Sat 08/05/2017	to	Mon 10/02/2017			
1600	Continuous	0659			
Work scheduled by: NYISO					
				CENTRAL EAST - VC	2740 MW
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4					
Mon 08/07/2017	to	Fri 08/11/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 08/14/2017	to	Fri 08/18/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 08/21/2017	to	Fri 08/25/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Mon 08/28/2017	to	Fri 09/01/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
MARCY_765_345_AT2					
Tue 09/05/2017	to	Sun 09/10/2017			
0500	Continuous	1630			
Work scheduled by: NYPA			ARR: 19		
				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3					
Tue 09/05/2017	to	Fri 09/08/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 09/11/2017	to	Fri 09/15/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
HURLYAVE-ROSETON_345_303					
Mon 09/11/2017	to	Fri 09/29/2017			
0800	Continuous	1600			
Work scheduled by: CHGE					
				UPNY CONED	4100 MW
				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
DUNWODIE_345KV_5					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7					
Fri 09/15/2017	to	Sun 09/17/2017			
2200	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBK_-DUNWODIE_345_W75			FWD
Fri 09/15/2017	to	Sun 09/17/2017	(Import)
2200	Continuous	0200	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			
		Impacts Total Transfer Capability 800 MW	
		TTC with All Lines In Service 4600 MW	
<hr/>			
SPRNBK_345KV_RNS3			FWD
Fri 09/15/2017	to	Sun 09/17/2017	(Import)
2200	Continuous	0200	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			
		Impacts Total Transfer Capability 800 MW	
		TTC with All Lines In Service 4600 MW	
<hr/>			
BROWNFLS-TAYLORVL_115_4			FWD REV
Mon 09/18/2017	to	Fri 09/22/2017	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid		UPDATED by NGRID 03/02/2017	Impacts Total Transfer Capability 120 MW 0 MW
		ARR: 38	TTC with All Lines In Service 190 MW 40 MW
<hr/>			
GILBOA_-N.SCTLND_345_GNS-1			FWD
Mon 09/18/2017	to	Fri 10/06/2017	(Import)
0630	Continuous	1700	CENTRAL EAST - VC 2520 MW
Work scheduled by: NYPA			
		Impacts Total Transfer Capability 455 MW	
		TTC with All Lines In Service 2975 MW	
<hr/>			
NIAGARA_345_230_AT4			FWD REV
Mon 09/18/2017	to	Tue 09/19/2017	(Import) (Export)
0700	Continuous	1530	SCH - OH - NY 1750 MW 1300 MW
Work scheduled by: NYPA			
		Impacts Total Transfer Capability 0 MW 300 MW	
		TTC with All Lines In Service 1750 MW 1600 MW	
<hr/>			
BROWNFLS-TAYLORVL_115_4			FWD REV
Mon 09/25/2017	to	Fri 09/29/2017	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid		UPDATED by NGRID 03/02/2017	Impacts Total Transfer Capability 120 MW 0 MW
		ARR: 38	TTC with All Lines In Service 190 MW 40 MW
<hr/>			
BROWNFLS-TAYLORVL_115_4			FWD REV
Mon 10/02/2017	to	Fri 10/06/2017	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid		UPDATED by NGRID 03/02/2017	Impacts Total Transfer Capability 120 MW 0 MW
		ARR: 38	TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2				FWD
Mon 10/02/2017	to	Fri 10/06/2017		(Import)
0700	Continuous	1530		DYSINGER EAST 1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1450 MW
				TTC with All Lines In Service 3150 MW
FRASER_-COOPERS_345_33				FWD
Mon 10/02/2017	to	Fri 10/13/2017		(Import)
0700	Continuous	1900		CENTRAL EAST - VC 2395 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 580 MW
				TTC with All Lines In Service 2975 MW
BROWNFLS-TAYLORVL_115_4				FWD
Mon 10/09/2017	to	Fri 10/13/2017	UPDATED by NGRID 03/02/2017	(Import) (Export)
0600	Continuous	1900		SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 120 MW 0 MW
				TTC with All Lines In Service 190 MW 40 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD
Fri 10/13/2017	to	Mon 11/06/2017		(Import)
1900	Continuous	0559		CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability 235 MW
				TTC with All Lines In Service 2975 MW
CHATGUAY-MASSENA_765_7040				FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)
0700	Continuous	1530		MOSES SOUTH 1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW
				TTC with All Lines In Service 3150 MW
CHATGUAY-MASSENA_765_7040				FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import) (Export)
0700	Continuous	1530		SCH - HQ - NY 0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
MARCY_765_345_AT1				FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)
0700	Continuous	1530		MOSES SOUTH 1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

UPDATED by NYISO 03/24/2017

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

UPDATED by NYISO 03/24/2017

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2265 MW**
Impacts Total Transfer Capability 710 MW
TTC with All Lines In Service 2975 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

UPDATED by NYISO 03/24/2017

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1

Sat 10/14/2017 to Sat 10/28/2017
0700 Continuous 1530

UPDATED by NYISO 03/24/2017

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2080 MW**
Impacts Total Transfer Capability 895 MW
TTC with All Lines In Service 2975 MW

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-HURLYAVE_345_301				FWD	
Mon 10/16/2017	to	Fri 11/03/2017		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
BROWNFLS-TAYLORVL_115_3				FWD	REV
Mon 10/30/2017	to	Fri 11/03/2017	<u>UPDATED</u> <u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0700	Continuous	1900		70 MW	40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
FRASANX-COOPERS__345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	475 MW	
			TTC with All Lines In Service	2975 MW	
MARCY___-FRASANX_345_UCC2-41				FWD	
Mon 11/06/2017	to	Fri 11/17/2017		(Import)	
0600	Continuous	1700	CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
Mon 11/06/2017	to	Thu 11/09/2017	<u>UPDATED</u> <u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0700	Continuous	1900		100 MW	100 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
				TTC with All Lines In Service	199 MW 100 MW
LINDN_CG-LNDVFT___345_V-3022				FWD	REV
Mon 11/06/2017	to	Thu 11/09/2017		(Import)	(Export)
0800	Continuous	1500	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
Mon 11/13/2017	to	Fri 11/17/2017	<u>UPDATED</u> <u>by NGRID</u> <u>03/03/2017</u>	(Import)	(Export)
0600	Continuous	1900		100 MW	100 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
				TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 25, 2017 to Monday ,September24, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
				(Import)	
Fri 11/17/2017	to	Sat 02/01/2020		CENTRAL EAST - VC	2740 MW
1700	Continuous	0000		Impacts Total Transfer Capability	235 MW
Work scheduled by: NYISO				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
				(Import) (Export)	
Mon 11/20/2017	to	Wed 11/22/2017	<u>UPDATED</u> <u>by NGRID</u> <u>03/03/2017</u>	SCH - HQ_CEDARS	100 MW 100 MW
0600	Continuous	1900		Impacts Total Transfer Capability	99 MW 0 MW
Work scheduled by: NGrid			ARR: 38	TTC with All Lines In Service	199 MW 100 MW
MOSES__-ADIRNDCK_230_MA1				FWD	
				(Import)	
Mon 11/27/2017	to	Fri 12/01/2017		MOSES SOUTH	2300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2				FWD	
				(Import)	
Mon 12/04/2017	to	Fri 12/08/2017		MOSES SOUTH	1700 MW
0500	Continuous	1630		Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA			ARR: 19	TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
				(Import)	
Mon 12/11/2017	to	Fri 12/15/2017		MOSES SOUTH	2300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
				(Import)	
Mon 12/18/2017	to	Fri 12/22/2017	<u>UPDATED</u> <u>by NYPA</u> <u>10/23/2016</u>	MOSES SOUTH	2300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA2				FWD	
				(Import)	
Tue 12/26/2017	to	Thu 12/28/2017		MOSES SOUTH	2300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW