

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Location	Start	End	Status	By	Effective Date	SCH	FWD	REV	
RAMAPO__345_345_PAR3500							FWD	REV	
Fri 06/24/2016	to	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	(Import)	(Export)	
1940	Continuous	2359					2200 MW	1450 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	100 MW	0 MW
							TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89							FWD		
Sun 10/30/2016	to	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>	UPNY CONED	(Import)		
0728	Continuous	2059					4000 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	1100 MW	
							TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56							FWD		
Thu 11/24/2016	to	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	(Import)		
1500	Continuous	2359					0 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	660 MW	
							TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46							FWD		
Tue 12/20/2016	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/19/2017</u>	SPR/DUN-SOUTH	(Import)		
0001	Continuous	0300					3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55							FWD		
Tue 12/20/2016	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/19/2017</u>	SPR/DUN-SOUTH	(Import)		
0001	Continuous	0300					3800 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	800 MW	
							TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6							FWD		
Fri 02/17/2017	to	Wed 04/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/19/2017</u>	SCH - PJM_HTP	(Import)		
0001	Continuous	0538					315 MW		
Work scheduled by: ConEd							Impacts Total Transfer Capability	345 MW	
							TTC with All Lines In Service	660 MW	
HUDSONP_-FARRAGUT_345_B3402							FWD	REV	
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>	SCH - PJ - NY	(Import)	(Export)	
0001	Continuous	2359					2300 MW	1450 MW	
Work scheduled by: ConEd							Impacts Total Transfer Capability	0 MW	0 MW
							TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<hr/>		
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403		
Tue 03/21/2017 to Wed 05/03/2017	(Import)	(Export)
0001 2359	2050 MW	1450 MW
Work scheduled by:	Impacts Total Transfer Capability	250 MW 0 MW
	TTC with All Lines In Service	2300 MW 1450 MW
<hr/>		
MARION_-FARRAGUT_345_C3403		
Tue 03/21/2017 to Wed 05/03/2017	(Import)	(Export)
0001 Continuous 2359 UPDATED by CONED 04/03/2017	2300 MW	1450 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2300 MW 1450 MW
<hr/>		
BERKSHIR-NORTHFLD_345_312		
Fri 03/24/2017 to Sat 04/22/2017	(Import)	(Export)
0800 Continuous 1600 UPDATED by ISONE 04/13/2017	1400 MW	1450 MW
Work scheduled by: ISONE	Impacts Total Transfer Capability	0 MW 150 MW
	TTC with All Lines In Service	1400 MW 1600 MW
<hr/>		
BERKSHIR-NORTHFLD_345_312		
Fri 03/24/2017 to Sat 04/22/2017	(Import)	(Export)
0800 Continuous 1600 UPDATED by ISONE 04/13/2017	100 MW	100 MW
Work scheduled by: ISONE	Impacts Total Transfer Capability	100 MW 100 MW
	TTC with All Lines In Service	200 MW 200 MW
<hr/>		
HOMRC_NY-MAINS_NY_345_47		
Fri 03/31/2017 to Fri 04/14/2017	(Import)	(Export)
1600 Continuous 1559 UPDATED by NYSEG 03/03/2017	2300 MW	1450 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2300 MW 1450 MW
<hr/>		
MAINESBG-WATRCURE_345_30		
Fri 03/31/2017 to Fri 04/14/2017	(Import)	(Export)
1600 Continuous 1600 UPDATED by NYSEG 03/03/2017	2200 MW	1450 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability	100 MW 0 MW
	TTC with All Lines In Service	2300 MW 1450 MW
<hr/>		
SCH-NYISO-PJM_LIMIT_100		
Tue 04/04/2017 to Thu 04/20/2017		REV (Export)
0800 Continuous 1600 EXTENDED by PJM 04/07/2017		400 MW
Work scheduled by: PJM	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	1450 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3					FWD	
Fri 04/07/2017	to	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>	(Import)
0001	Continuous	2059				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
DUNWODIE_345KV_4					FWD	
Fri 04/07/2017	to	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>	(Import)
0001	Continuous	2059				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
W49TH_ST_345KV_8					FWD	
Wed 04/12/2017	to	Wed 04/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/19/2017</u>	(Import)
0201	Continuous	0200				315 MW
Work scheduled by: ConEd					SCH - PJM_HTP	345 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Wed 04/12/2017	to	Sat 04/15/2017				(Import)
1700	Continuous	0659				2740 MW
Work scheduled by: NYISO					CENTRAL EAST - VC	235 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	
SCH-IMO-NYISO_LIMIT_1400					FWD	
Thu 04/13/2017	to	Fri 04/14/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/07/2017</u>	(Import)
0500	Continuous	1730				1700 MW
Work scheduled by: NGrid					SCH - OH - NY	50 MW
					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	
SCH-NE-NYISO_LIMIT_700					FWD	
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/13/2017</u>	(Import)
0001	Continuous	1600				900 MW
Work scheduled by: ISONE					SCH - NE - NY	500 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	
SCH-NYISO-NE_LIMIT_800					REV	
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/13/2017</u>	(Export)
0001	Continuous	1600				1000 MW
Work scheduled by: ISONE					SCH - NE - NY	600 MW
					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47						
Fri 04/14/2017	to	Fri 04/28/2017	FORCED	by PJM	04/13/2017	
1600	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	2300 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2300 MW
EDIC -N.SCTLND_345_14						
Sat 04/15/2017	to	Sat 04/15/2017	FORCED	by NGRID	04/13/2017	
0700	Daily	2300				
Work scheduled by: NGrid					CENTRAL EAST - VC	2240 MW
					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
BECK -NIAGARA_345_PA302						
Sat 04/15/2017	to	Sat 04/15/2017				
0800	Continuous	1600				
Work scheduled by: IESO					SCH - OH - NY	1100 MW
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1750 MW
EDIC -N.SCTLND_345_14 & ILCTLIMIT_MARCY_SO_COMP_I/S						
Sat 04/15/2017	to	Sat 04/15/2017				
1100		2300				
Work scheduled by:					CENTRAL EAST - VC	2005 MW
					Impacts Total Transfer Capability	970 MW
					TTC with All Lines In Service	2975 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						
Sat 04/15/2017	to	Mon 04/17/2017				
1100	Continuous	0859				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
SHOR_NPX-SHOREHAM_138_CSC						
Mon 04/17/2017	to	Sat 04/22/2017				
0500	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
MOSES -ADIRNDCK_230_MAI						
Mon 04/17/2017	to	Thu 04/20/2017				
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -COOPERS_345_33						FWD
Mon 04/17/2017	to	Fri 04/21/2017	UPDATED	by NY	01/12/2017	(Import)
0900	Continuous	1400				CENTRAL EAST - VC 2395 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 580 MW
						TTC with All Lines In Service 2975 MW
DUNWODIE-MOTTHAVN_345_71						FWD
Mon 04/17/2017	to	Fri 05/05/2017	FORCED	by CE	04/18/2017	(Import)
2120	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
PORTER -ROTTRDAM_230_31						FWD
Tue 04/18/2017	to	Tue 04/18/2017				(Import)
0800	Daily(No Weekends)	1500				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
VOLNEY -CLAY_345_6						FWD
Wed 04/19/2017	to	Wed 04/19/2017				(Import)
0730	Daily(No Weekends)	1700				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
PORTER -ROTTRDAM_230_30						FWD
Wed 04/19/2017	to	Wed 04/19/2017				(Import)
0800	Continuous	1530				CENTRAL EAST - VC 2805 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 170 MW
						TTC with All Lines In Service 2975 MW
SCH-IMO-NYISO_LIMIT_1000						FWD
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	04/18/2017	(Import)
1100	Continuous	1300				SCH - OH - NY 1300 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 450 MW
						TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100						REV
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	04/18/2017	(Export)
1100	Continuous	1300				SCH - PJ - NY 400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1450 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 04/21/2017	to	Sat 05/27/2017		(Import)	
1400	Continuous	0459		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
<hr/>					
DUNWODIE_345KV_6				FWD	
Sat 04/22/2017	to	Sat 04/22/2017	CANCELLED by ConEd 04/14/2017	(Import)	
0200	Continuous	0230		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
DUNWODIE_345KV_8				FWD	
Sat 04/22/2017	to	Sat 04/22/2017	CANCELLED by ConEd 04/14/2017	(Import)	
0200	Continuous	0230		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
PLSNTVLE-DUNWODIE_345_W90				FWD	
Sat 04/22/2017	to	Sun 04/23/2017	CANCELLED by ConEd 04/14/2017	(Import)	
0200	Continuous	2359		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
<hr/>					
WOOD_ST_-PLSNTVLE_345_Y87				FWD	
Sat 04/22/2017	to	Sun 04/23/2017	CANCELLED by ConEd 04/14/2017	(Import)	
0200	Continuous	2359		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
<hr/>					
BERKSHIR-ALPS_345_393				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED by ISONE 04/18/2017	(Import)	(Export)
0900	Daily	1000		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by: NGrid			ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<hr/>					
BERKSHIR-ALPS_345_393				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED by ISONE 04/18/2017	(Import)	(Export)
0900	Daily	1000		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid			ARR: 78	Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD 345_312						
Sat 04/22/2017	to	Sat 04/22/2017				
0900		1000		SCH - NE - NY	1300 MW	1300 MW
Work scheduled by:					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE 04/18/2017</u>	(Import)	
0900	Daily	1000			800 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_300						REV
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE 04/18/2017</u>		(Export)
0900	Daily	1000				500 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	1600 MW
SCH-NYISO-HQ_LIMIT_900						REV
Sat 04/22/2017	to	Sun 04/30/2017				(Export)
2200	Continuous	0600				900 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1000 MW
DUNWODIE_345KV_6					FWD	
Sun 04/23/2017	to	Sun 04/23/2017	<u>CANCELLED</u>	<u>by ConEd 04/14/2017</u>	(Import)	
2330	Continuous	2359			3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Sun 04/23/2017	to	Sun 04/23/2017	<u>CANCELLED</u>	<u>by ConEd 04/14/2017</u>	(Import)	
2330	Continuous	2359			3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
ROSETON_EFISHKIL_345_RFK305					FWD	
Mon 04/24/2017	to	Fri 05/05/2017			(Import)	
0001	Continuous	1900			4100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16				FWD	
Mon 04/24/2017	to	Tue 04/25/2017		(Import)	
0630	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
STLAWRNC-MOSES 230_L34P				FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017		(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW	1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	1750 MW	1900 MW
MOSES -ADIRNDCK 230_MA1				FWD	
Mon 04/24/2017	to	Sat 04/29/2017		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
BEAR SWP-EASTOVER 230_E205W					
Mon 04/24/2017	to	Tue 05/30/2017	UPDATED	by NE	04/11/2017
0700	Continuous	0659	SCH - NE - NY		
Work scheduled by: NGrid			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
ALCOA -DENNISON 115_12				FWD	REV
Mon 04/24/2017	to	Wed 04/26/2017		(Import)	(Export)
0800	Continuous	0659	SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
ALCOA -DENNISON 115_12				FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import)	(Export)
0700	Daily(No Weekends)	1800	SCH - HQ_CEDARS	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
ALCOA -DENNISON 115_12 & ALCOA -NOGDNRG 115_13				FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import)	(Export)
0700		1800	SCH - HQ_CEDARS	100 MW	60 MW
Work scheduled by:			Impacts Total Transfer Capability	99 MW	40 MW
			TTC with All Lines In Service	199 MW	100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT	ALCOA	R8105	TIE	B		FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017				(Import)	
0700	Daily(No Weekends)	1800			MOSES SOUTH	3100 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	50 MW
						TTC with All Lines In Service	3150 MW
Wed 04/26/2017	to	Wed 04/26/2017				(Import)	(Export)
0700	Daily(No Weekends)	1800			SCH - HQ_CEDARS	100 MW	60 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	99 MW 40 MW
						TTC with All Lines In Service	199 MW 100 MW
Thu 04/27/2017	to	Thu 04/27/2017				(Import)	
0800	Daily(No Weekends)	1630			OSWEGO EXPORT	5250 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
Fri 04/28/2017	to	Fri 04/28/2017	<u>UPDATED</u>	<u>by PA</u>	<u>03/29/2017</u>	(Import)	
0500	Continuous	1700			DYSINGER EAST	1700 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
Sat 04/29/2017	to	Sat 04/29/2017				(Import)	
0630	Daily	1730			OSWEGO EXPORT	4850 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	400 MW
						TTC with All Lines In Service	5250 MW
Mon 05/01/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>02/14/2017</u>	(Import)	
0400	Continuous	1800			SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
Mon 05/01/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>02/14/2017</u>	(Import)	
0400	Continuous	1800			SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>									
MARCY -N.SCTLND_345_18									FWD
Mon 05/01/2017	to	Fri 05/05/2017	UPDATED	by NYPA	04/10/2017				(Import)
0500	Continuous	1700				CENTRAL EAST - VC			2090 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability			885 MW
						TTC with All Lines In Service			2975 MW
<hr/>									
MARCY -N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S									FWD
Mon 05/01/2017	to	Fri 05/05/2017							(Import)
0500		1700				CENTRAL EAST - VC			1855 MW
Work scheduled by:					ARR: 19	Impacts Total Transfer Capability			1120 MW
						TTC with All Lines In Service			2975 MW
<hr/>									
BROWNFLS-TAYLORVL_115_3									FWD
Mon 05/01/2017	to	Fri 05/05/2017							(Import)
0600	Continuous	1900				SCH - HQ_CEDARS			70 MW
Work scheduled by: NGrid					ARR: 38	Impacts Total Transfer Capability			120 MW
						TTC with All Lines In Service			190 MW
									40 MW
<hr/>									
ROCHESTR-PANNELL_345_RP2									FWD
Mon 05/01/2017	to	Mon 05/01/2017	CANCELLED	by RGE	04/19/2017				(Import)
0630	Continuous	0700				DYSINGER EAST			2300 MW
Work scheduled by: RGE						Impacts Total Transfer Capability			850 MW
						TTC with All Lines In Service			3150 MW
<hr/>									
PANNELL -CLAY_345_2									FWD
Mon 05/01/2017	to	Fri 05/05/2017							(Import)
0630	Continuous	1530				WEST CENTRAL			1300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability			950 MW
						TTC with All Lines In Service			2250 MW
<hr/>									
SCH-NYISO-HQ_LIMIT_800									REV
Mon 05/01/2017	to	Wed 05/10/2017							(Export)
2200	Continuous	0300				SCH - HQ - NY			800 MW
Work scheduled by: HQ						Impacts Total Transfer Capability			200 MW
						TTC with All Lines In Service			1000 MW
<hr/>									
W49TH_ST_345KV_6									FWD
Wed 05/03/2017	to	Wed 05/03/2017	UPDATED	by CONED	04/19/2017				(Import)
0230	Continuous	0300				SCH - PJM_HTP			320 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			340 MW
						TTC with All Lines In Service			660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday ,October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARION__-FARRAGUT_345_C3403					FWD	REV
Thu 05/04/2017	to	Wed 05/31/2017	UPDATED	by CE	04/03/2017	(Import) (Export)
0001	Continuous	2359				2050 MW 1300 MW
Work scheduled by: PJM					SCH - PJ - NY Impacts Total Transfer Capability TTC with All Lines In Service	0 MW 0 MW 2050 MW 1300 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	0800				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
OSWEGO__-ELBRIDGE_345_17					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	1700				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
1630	Daily(No Weekends)	1700				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
ROCHESTR-PANNELL__345_RP2					FWD	
Fri 05/05/2017	to	Fri 05/05/2017	CANCELLED	by RGE	04/19/2017	(Import)
1500	Continuous	1530				2300 MW
Work scheduled by: RGE						DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service
PLSNTVLE-DUNWODIE_345_W90					FWD	
Sat 05/06/2017	to	Wed 05/10/2017				(Import)
0001	Continuous	2130				4000 MW
Work scheduled by: ConEd						UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service
SPRNBRK_-W49TH_ST_345_M51					FWD	
Sat 05/06/2017	to	Tue 05/16/2017				(Import)
0700	Continuous	0300				3200 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3		FWD	REV
		(Import)	(Export)
Mon 05/08/2017	to Fri 05/12/2017		
0600	Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38		TTC with All Lines In Service	190 MW 40 MW
ROSETON_-ROCKTVRN_345_311		FWD	
		(Import)	
Mon 05/08/2017	to Fri 05/26/2017		
0800	Continuous 1600	UPNY CONED	4400 MW
Work scheduled by: CHGE		Impacts Total Transfer Capability	700 MW
		TTC with All Lines In Service	5100 MW
PANNELL_-CLAY_345_2		FWD	
		(Import)	
Mon 05/08/2017	to Mon 05/08/2017	CANCELLED by RGE 04/19/2017	
1000	Continuous 1030	WEST CENTRAL	1300 MW
Work scheduled by: RGE		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2		FWD	
		(Import)	
Mon 05/08/2017	to Wed 05/10/2017		
1000	Continuous 1700	DYSINGER EAST	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
LAFAYTTE-CLRKSCRN_345_4-46		FWD	
		(Import)	
Tue 05/09/2017	to Tue 05/09/2017		
0700	Daily(No Weekends) 1700	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	325 MW
		TTC with All Lines In Service	2975 MW
PANNELL_-CLAY_345_2		FWD	
		(Import)	
Wed 05/10/2017	to Wed 05/10/2017	CANCELLED by RGE 04/19/2017	
1630	Continuous 1700	WEST CENTRAL	1300 MW
Work scheduled by: RGE		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
SCH-NYISO-HQ_LIMIT_900			REV
			(Export)
Thu 05/11/2017	to Sun 05/14/2017		
2200	Continuous 0300	SCH - HQ - NY	900 MW
Work scheduled by: HQ		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
BECK -PACKARD 230_BP76		FWD	
Sat 05/13/2017 to Sun 05/14/2017			REV
0500 Continuous 1700		(Import)	(Export)
Work scheduled by: NGrid	SCH - OH - NY	900 MW	1150 MW
	Impacts Total Transfer Capability	850 MW	450 MW
	TTC with All Lines In Service	1750 MW	1600 MW
<hr/>			
BECK -PACKARD 230_BP76		FWD	
Sat 05/13/2017 to Sun 05/14/2017	CANCELLED by NGrid 04/14/2017		REV
0500 Continuous 1800		(Import)	(Export)
Work scheduled by: NGrid	SCH - OH - NY	900 MW	1150 MW
	Impacts Total Transfer Capability	850 MW	450 MW
	TTC with All Lines In Service	1750 MW	1600 MW
<hr/>			
BROWNFLS-TAYLORVL 115_3		FWD	
Mon 05/15/2017 to Fri 05/19/2017			REV
0600 Continuous 1900		(Import)	(Export)
Work scheduled by: NGrid	SCH - HQ_CEDARS	70 MW	40 MW
	Impacts Total Transfer Capability	120 MW	0 MW
	TTC with All Lines In Service	190 MW	40 MW
	ARR: 38		
<hr/>			
FRASER -GILBOA 345_GF5-35		FWD	
Mon 05/15/2017 to Fri 05/19/2017	UPDATED by NYPA 04/13/2017		REV
0630 Continuous 1700		(Import)	
Work scheduled by: NYPA	CENTRAL EAST - VC	2650 MW	
	Impacts Total Transfer Capability	325 MW	
	TTC with All Lines In Service	2975 MW	
<hr/>			
STONYRDG-HILLSIDE 230_72		FWD	
Mon 05/15/2017 to Mon 05/15/2017			REV
0800 Continuous 1700		(Import)	
Work scheduled by: NYSEG	DYSINGER EAST	2850 MW	
	Impacts Total Transfer Capability	300 MW	
	TTC with All Lines In Service	3150 MW	
<hr/>			
FRASER 345_FRASER SVC		FWD	
Mon 05/15/2017 to Fri 05/19/2017	UPDATED by NY 04/06/2017		REV
0900 Continuous 1430		(Import)	
Work scheduled by: NYSEG	CENTRAL EAST - VC	2935 MW	
	Impacts Total Transfer Capability	40 MW	
	TTC with All Lines In Service	2975 MW	
<hr/>			
FRASER 345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S		FWD	
Mon 05/15/2017 to Fri 05/19/2017			REV
0900 Continuous 1430		(Import)	
Work scheduled by:	CENTRAL EAST - VC	2700 MW	
	Impacts Total Transfer Capability	275 MW	
	TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72

Tue 05/16/2017 to Tue 05/16/2017
 0001 Continuous 2330

Work scheduled by: ORU

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600

Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600

Work scheduled by: HQ

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 2100

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS4			FWD
Fri 05/19/2017	to	Fri 05/19/2017	(Import)
2030	Continuous	2100	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
E13THSTA-FARRAGUT_345_45			FWD
Sat 05/20/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2359	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M54			FWD
Sat 05/20/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2359	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBK__345_W64			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	0030	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
SPRNBK__345KV_RNS5			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2130	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
EASTVIEW-SPRNBK__345_W64			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
2100	Continuous	2130	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday , October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>SPRNBK__345KV_RNS5</p> <p>Sun 05/21/2017 to Sun 05/21/2017 2100 Continuous 2130</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>MARCY____765_345_AT1</p> <p>Mon 05/22/2017 to Fri 05/26/2017 0500 Continuous 1630</p> <p>Work scheduled by: NYPA</p> <p style="text-align: right;">ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1750 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>BROWNFLS-TAYLORVL_115_3</p> <p>Mon 05/22/2017 to Fri 05/26/2017 0600 Continuous 1900</p> <p>Work scheduled by: NGrid</p> <p style="text-align: right;">ARR: 38</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ_CEDARS 70 MW 40 MW</p> <p>Impacts Total Transfer Capability 120 MW 0 MW</p> <p>TTC with All Lines In Service 190 MW 40 MW</p>
<p>CHAT_DC_GC1</p> <p>Tue 05/23/2017 to Thu 06/29/2017 UPDATED by HQ 04/13/2017 0600 Continuous 1700</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CHAT_DC_GC1</p> <p>Tue 05/23/2017 to Thu 06/29/2017 UPDATED by HQ 04/13/2017 0600 Continuous 1700</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - HQ - NY 500 MW</p> <p>Impacts Total Transfer Capability 500 MW</p> <p>TTC with All Lines In Service 1000 MW</p>
<p>EFISHKIL-WOOD_ST__345_F39</p> <p>Wed 05/24/2017 to Fri 05/26/2017 UPDATED by CE 04/13/2017 0201 Continuous 1900</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1100 MW</p> <p>TTC with All Lines In Service 5100 MW</p>
<p>WOOD_ST_-PLSNTVLE_345_Y87</p> <p>Wed 05/24/2017 to Fri 05/26/2017 UPDATED by CE 04/13/2017 0201 Continuous 1900</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4000 MW</p> <p>Impacts Total Transfer Capability 1100 MW</p> <p>TTC with All Lines In Service 5100 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday ,October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18				FWD	
Sat 05/27/2017	to	Sat 05/27/2017		(Import)	
0500	Continuous	1530		CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
SCH-HQ-NYISO_LIMIT_1150				FWD	
Sat 05/27/2017	to	Sat 05/27/2017	<u>UPDATED</u> <u>by HQ</u> <u>04/13/2017</u>	(Import)	
0500	Continuous	1530		SCH - HQ - NY	1150 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Sat 05/27/2017	to	Mon 06/05/2017		(Import)	
1600	Continuous	0659		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
Tue 05/30/2017	to	Fri 06/02/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4				FWD	REV
Mon 06/05/2017	to	Fri 06/09/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
EDIC___-FRASER___345_EF24-40				FWD	
Mon 06/05/2017	to	Sat 06/10/2017		(Import)	
0700	Continuous	1659		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72				FWD	
Mon 06/05/2017	to	Mon 06/05/2017		(Import)	
0800	Continuous	1000		DYSINGER EAST	2850 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday , October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
LINDEN__-GOETHALS_230_A2253					(Import)	(Export)
Fri 06/09/2017	to	Sun 06/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/04/2017</u>	
0200	Continuous	2300				
Work scheduled by: PJM					SCH - PJ - NY	2050 MW 1300 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2050 MW 1300 MW
<hr/>					FWD	
STONYRDG-HILLSIDE_230_72					(Import)	
Fri 06/09/2017	to	Fri 06/09/2017				
1500	Continuous	1700				
Work scheduled by: NYSEG					DYSINGER EAST	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<hr/>					FWD	
ILCTLIMIT_MARCY_SO_COMP_I/S					(Import)	
Sat 06/10/2017	to	Sat 08/05/2017				
1700	Continuous	0459				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Mon 06/12/2017	to	Fri 06/16/2017				
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_4					(Import)	(Export)
Mon 06/19/2017	to	Fri 06/23/2017				
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_3					(Import)	(Export)
Mon 06/26/2017	to	Fri 06/30/2017				
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<hr/>					FWD	REV
BROWNFLS-TAYLORVL_115_3					(Import)	(Export)
Wed 07/05/2017	to	Fri 07/07/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday ,October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_3						
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 07/24/2017	to	Fri 07/28/2017				
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38		
					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW
MARCY___-N.SCTLND_345_18						
Sat 08/05/2017	to	Sat 08/05/2017				
0500	Continuous	1530				
Work scheduled by: NYPA				ARR: 19		
					CENTRAL EAST - VC	2090 MW
					Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2						
Sat 08/05/2017	to	Sat 08/05/2017				
0500	Continuous	1530				
Work scheduled by: NYPA				ARR: 19		
					MOSES SOUTH	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						
Sat 08/05/2017	to	Mon 10/02/2017				
1600	Continuous	0659				
Work scheduled by: NYISO						
					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2						
Tue 09/05/2017	to	Sun 09/10/2017				
0500	Continuous	1630				
Work scheduled by: NYPA				ARR: 19		
					MOSES SOUTH	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday ,October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 09/11/2017 to Fri 09/29/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK__345KV_RNS3

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1300 MW
Impacts Total Transfer Capability	0 MW	300 MW
TTC with All Lines In Service	1750 MW	1600 MW

MOSES__-ADIRNDCK_230_MAI

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

MOSES__-ADIRNDCK_230_MAI

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

FRASER__-COOPERS__345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2395 MW
Impacts Total Transfer Capability	580 MW
TTC with All Lines In Service	2975 MW

HOMR_NYW-PIERC_NY_345_48

Mon 10/02/2017 to Tue 10/17/2017
0800 Continuous 1600

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2050 MW	1300 MW

WETHSRFD-MEYER__230_85/87

Mon 10/09/2017 to Fri 10/20/2017
0700 Continuous 1400

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Fri 10/13/2017	to	Mon 11/06/2017			(Import)	
1900	Continuous	0559			CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
CHATGUAY-MASSENA_765_7040					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH	1550 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
CHATGUAY-MASSENA_765_7040					FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import) (Export)
0700	Continuous	1530			SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<hr/>						
MARCY_765_345_AT1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH	1750 MW
Work scheduled by: NYPA				ARR: 19	Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
MARCY_765_345_AT2					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH	1700 MW
Work scheduled by: NYPA				ARR: 19	Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
MASSENA -MARCY_765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
MASSENA -MARCY_765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH	500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Time	Notes	Direction	Value
MASSENA -MARCY 765_MSU1	Sat 10/14/2017	Sat 10/28/2017	0700 Continuous 1530	UPDATED by NYISO 03/24/2017	FWD (Import)	475 MW
					REV (Export)	1000 MW
Work scheduled by: NYPA					SCH - HQ - NY	1000 MW
					Impacts Total Transfer Capability	1025 MW
					TTC with All Lines In Service	1500 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 10/14/2017	Sat 10/28/2017	0700 1530		FWD (Import)	500 MW
Work scheduled by:					MOSES SOUTH	2650 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
MASSENA -MARCY 765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S	Sat 10/14/2017	Sat 10/28/2017	0700 1530		FWD (Import)	2080 MW
Work scheduled by:					CENTRAL EAST - VC	895 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 10/14/2017	Sat 10/28/2017	0700 1530		FWD (Import)	850 MW
Work scheduled by:					REV (Export)	0 MW
					SCH - HQ - NY	1000 MW
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1500 MW
LEEDS -HURLYAVE 345_301	Mon 10/16/2017	Fri 11/03/2017	0800 Continuous 1600		FWD (Import)	4100 MW
Work scheduled by: CHGE					UPNY CONED	1000 MW
					Impacts Total Transfer Capability	5100 MW
					TTC with All Lines In Service	5100 MW
MOSES -ADIRNDCK 230_MA2	Mon 10/30/2017	Fri 11/03/2017	0700 Continuous 1530		FWD (Import)	2100 MW
Work scheduled by: NYPA					MOSES SOUTH	1050 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	3150 MW
FRASANX-COOPERS 345_UCC2-41	Mon 11/06/2017	Fri 11/17/2017	0600 Continuous 1700		FWD (Import)	2500 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	475 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday ,October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY___-FRASANNX_345_UCC2-41</p> <p>Mon 11/06/2017 to Fri 11/17/2017 0600 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2500 MW</p> <p>Impacts Total Transfer Capability 475 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 11/06/2017 to Thu 11/09/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Mon 11/06/2017 to Thu 11/09/2017 0800 Continuous 1500</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJM_VFT 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 11/13/2017 to Fri 11/17/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Fri 11/17/2017 to Sat 02/01/2020 1700 Continuous 0000</p> <p>Work scheduled by: NYISO</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2740 MW</p> <p>Impacts Total Transfer Capability 235 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/20/2017 to Wed 11/22/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/27/2017 to Fri 12/01/2017 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, April 19, 2017 to Friday, October 19, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW