

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)	
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	2200 MW	1450 MW	
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW	
Work scheduled by: ConEd							TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>	UPNY CONED	4000 MW		
0728	Continuous	2059				Impacts Total Transfer Capability	1100 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW		
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6	Fri 02/17/2017	Wed 04/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SCH - PJM_HTP	315 MW		
0001	Continuous	0538				Impacts Total Transfer Capability	345 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	660 MW	
HUDSONP_-FARRAGUT_345_B3402	Tue 03/21/2017	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>	SCH - PJ - NY	2300 MW	1450 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	0 MW	0 MW	
Work scheduled by: ConEd							TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD	REV
Tue 03/21/2017	to	Wed 05/03/2017		(Import)	(Export)
0001		2359		2050 MW	1450 MW
Work scheduled by:				SCH - PJ - NY	
				Impacts Total Transfer Capability	250 MW 0 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<hr/>					
MARION_-FARRAGUT_345_C3403				FWD	REV
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>
0001	Continuous	2359		SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
0800	Continuous	1300		SCH - NE - NY	1400 MW 1450 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW 150 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
0800	Continuous	1300		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<hr/>					
SCH-NYISO-PJM_LIMIT_100					REV
Tue 04/04/2017	to	Thu 04/20/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>04/07/2017</u>
0800	Continuous	1600		SCH - PJ - NY	400 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	1450 MW
<hr/>					
DUNWODIE_345KV_3				FWD	
Fri 04/07/2017	to	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>
0001	Continuous	2059		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
DUNWODIE_345KV_4				FWD	
Fri 04/07/2017	to	Sun 04/23/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/14/2017</u>
0001	Continuous	2059		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Wed 04/12/2017 to Wed 04/19/2017
 0201 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 04/20/2017

FWD
 (Import)
 SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Wed 04/12/2017 to Sat 04/15/2017
 1700 Continuous 0659
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

SCH-NE-NYISO_LIMIT_700

Fri 04/14/2017 to Sat 04/22/2017
 0001 Continuous 0959
 Work scheduled by: ISONE

UPDATED by ISONE 04/20/2017

FWD
 (Import)
 SCH - NE - NY **900 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_800

Fri 04/14/2017 to Sat 04/22/2017
 0001 Continuous 0959
 Work scheduled by: ISONE

UPDATED by ISONE 04/20/2017

REV
 (Export)
 SCH - NE - NY **1000 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1600 MW

HOMRC_NY-MAINS_NY_345_47

Fri 04/14/2017 to Fri 04/21/2017
 1600 Continuous 1600
 Work scheduled by: PJM

EXT FORCE by PJM 04/20/2017

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2300 MW 1450 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 2300 MW 1450 MW

EDIC -N.SCTLND_345_14

Sat 04/15/2017 to Sat 04/15/2017
 0700 Daily 2300
 Work scheduled by: NGrid

FORCED by NGRID 04/13/2017

FWD
 (Import)
 CENTRAL EAST - VC **2240 MW**
 Impacts Total Transfer Capability 735 MW
 TTC with All Lines In Service 2975 MW

BECK -NIAGARA_345_PA302

Sat 04/15/2017 to Sat 04/15/2017
 0800 Continuous 1600
 Work scheduled by: IESO

FWD REV
 (Import) (Export)
 SCH - OH - NY **1100 MW 950 MW**
 Impacts Total Transfer Capability 650 MW 950 MW
 TTC with All Lines In Service 1750 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC___-N.SCTLND_345_14 & ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Sat 04/15/2017	to	Sat 04/15/2017		(Import)	
1100		2300	CENTRAL EAST - VC	2005 MW	
Work scheduled by:			Impacts Total Transfer Capability	970 MW	
			TTC with All Lines In Service	2975 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Sat 04/15/2017	to	Mon 04/17/2017		(Import)	
1100	Continuous	0859	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
Mon 04/17/2017	to	Sat 04/22/2017		(Import)	(Export)
0500	Continuous	1600	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
MOSES___-ADIRNDCK_230_MAI				FWD	
Mon 04/17/2017	to	Thu 04/20/2017		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
FRASER___-COOPERS_345_33				FWD	
Mon 04/17/2017	to	Fri 04/21/2017	UPDATED by NY 01/12/2017	(Import)	
0900	Continuous	1400	CENTRAL EAST - VC	2395 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	580 MW	
			TTC with All Lines In Service	2975 MW	
DUNWODIE-MOTTHAVN_345_71				FWD	
Mon 04/17/2017	to	Fri 05/05/2017	FORCED by CE 04/18/2017	(Import)	
2120	Continuous	2359	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PORTER___-ROTTDAM_230_31				FWD	
Tue 04/18/2017	to	Tue 04/18/2017		(Import)	
0800	Daily(No Weekends)	1500	CENTRAL EAST - VC	2805 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	170 MW	
			TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -CLAY 345_6					FWD	
Wed 04/19/2017	to	Wed 04/19/2017			(Import)	
0730	Daily(No Weekends)	1700		OSWEGO EXPORT	5250 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
PORTER -ROTTDAM 230_30					FWD	
Wed 04/19/2017	to	Wed 04/19/2017			(Import)	
0800	Continuous	1530		CENTRAL EAST - VC	2805 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	170 MW
					TTC with All Lines In Service	2975 MW
SCH-IMO-NYISO_LIMIT_1000					FWD	
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	04/18/2017	
1100	Continuous	1300				
Work scheduled by: PJM					SCH - OH - NY	1300 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1750 MW
SCH-NYISO-PJM_LIMIT_100					REV	
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	04/18/2017	(Export)
1100	Continuous	1300				
Work scheduled by: PJM					SCH - PJ - NY	400 MW
					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1450 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Fri 04/21/2017	to	Sat 05/27/2017			(Import)	
1400	Continuous	0459		CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
BERKSHIR-ALPS 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE	04/20/2017	(Import) (Export)
1000	Daily	1300				
Work scheduled by: NGrid					SCH - NE - NY	1300 MW 1300 MW
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE	04/20/2017	(Import) (Export)
1000	Daily	1300				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD 345_312				FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017		(Import)	(Export)
1000		1300		SCH - NE - NY	1300 MW 1300 MW
Work scheduled by:			ARR: 78	Impacts Total Transfer Capability	100 MW 300 MW
				TTC with All Lines In Service	1400 MW 1600 MW
SCH-NE-NYISO_LIMIT_600				FWD	
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED by ISONE 04/20/2017	(Import)	
1000	Daily	1300		SCH - NE - NY	800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_400					REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED by ISONE 04/20/2017	(Export)	
1000	Daily	1300		SCH - NE - NY	600 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1600 MW
SCH-NYISO-HQ_LIMIT_900					REV
Sat 04/22/2017	to	Sun 04/30/2017		(Export)	
2200	Continuous	0600		SCH - HQ - NY	900 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1000 MW
ROSETON_-EFISHKIL_345_RFK305				FWD	
Mon 04/24/2017	to	Fri 05/05/2017		(Import)	
0001	Continuous	1900		UPNY CONED	4100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
CLAY_-EDIC_345_1-16				FWD	
Mon 04/24/2017	to	Tue 04/25/2017		(Import)	
0630	Continuous	1530		OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES_230_L34P				FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017		(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1750 MW 1900 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1				FWD
Mon 04/24/2017	to	Sat 04/29/2017		(Import)
0700	Continuous	1730		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
BEAR SWP-EASTOVER_230_E205W				
Mon 04/24/2017	to	Tue 05/30/2017	UPDATED by NE 04/20/2017	
0700	Continuous	0659		SCH - NE - NY
Work scheduled by: NGrid				Impacts Total Transfer Capability
				TTC with All Lines In Service
<hr/>				
ALCOA___-DENNISON_115_12				FWD REV
Mon 04/24/2017	to	Wed 04/26/2017		(Import) (Export)
0800	Continuous	0659		SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
				TTC with All Lines In Service 199 MW 100 MW
				ARR: 38
<hr/>				
ALCOA___-DENNISON_115_12				FWD REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import) (Export)
0700	Daily(No Weekends)	1800		SCH - HQ_CEDARS 100 MW 100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 0 MW
				TTC with All Lines In Service 199 MW 100 MW
				ARR: 38
<hr/>				
ALCOA___-DENNISON_115_12 & ALCOA___-NOGDNRBG_115_13				FWD REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import) (Export)
0700		1800		SCH - HQ_CEDARS 100 MW 60 MW
Work scheduled by:				Impacts Total Transfer Capability 99 MW 40 MW
				TTC with All Lines In Service 199 MW 100 MW
				ARR: 38
<hr/>				
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B				FWD
Wed 04/26/2017	to	Wed 04/26/2017		(Import)
0700	Daily(No Weekends)	1800		MOSES SOUTH 3100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B				FWD REV
Wed 04/26/2017	to	Wed 04/26/2017		(Import) (Export)
0700	Daily(No Weekends)	1800		SCH - HQ_CEDARS 100 MW 60 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 99 MW 40 MW
				TTC with All Lines In Service 199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCRIBA -VOLNEY 345_21

Thu 04/27/2017 to Thu 04/27/2017
 0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NIAGARA -ROCHESTR 345_NR2

Fri 04/28/2017 to Fri 04/28/2017
 0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by PA 03/29/2017

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

CLAY -EDIC 345_2-15

Sat 04/29/2017 to Sat 04/29/2017
 0630 Daily 1730

Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

NEPTUNE -DUFFYAVE 345_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017
 0400 Continuous 1800

Work scheduled by: LI

UPDATED by LI 02/14/2017

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE 345_501

Mon 05/01/2017 to Tue 05/16/2017
 0400 Continuous 1800

Work scheduled by: LI

UPDATED by LI 02/14/2017

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

MARCY -N.SCTLND 345_18

Mon 05/01/2017 to Fri 05/05/2017
 0500 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

MARCY -N.SCTLND 345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/01/2017 to Fri 05/05/2017
 0500 1700

Work scheduled by:

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **1855 MW**
 Impacts Total Transfer Capability 1120 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3

Mon 05/01/2017 to Fri 05/05/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

ROCHESTR-PANNELL_345_RP2

Mon 05/01/2017 to Mon 05/01/2017
0630 Continuous 0700

Work scheduled by: RGE

CANCELLED by RGE 04/19/2017

	FWD	
	(Import)	
DYSINGER EAST	2300 MW	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

PANNELL -CLAY_345_2

Mon 05/01/2017 to Fri 05/05/2017
0630 Continuous 1530

Work scheduled by: NYPA

	FWD	
	(Import)	
WEST CENTRAL	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

SCH-NYISO-HQ_LIMIT_800

Mon 05/01/2017 to Wed 05/10/2017
2200 Continuous 0300

Work scheduled by: HQ

		REV
		(Export)
SCH - HQ - NY		800 MW
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service		1000 MW

W49TH_ST_345KV_6

Wed 05/03/2017 to Wed 05/03/2017
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CONED 04/20/2017

	FWD	
	(Import)	
SCH - PJM_HTP	320 MW	
Impacts Total Transfer Capability	340 MW	
TTC with All Lines In Service	660 MW	

MARION -FARRAGUT_345_C3403

Thu 05/04/2017 to Wed 05/31/2017
0001 Continuous 2359

Work scheduled by: PJM

UPDATED by CE 04/03/2017

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1300 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2050 MW	1300 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 05/04/2017 to Thu 05/04/2017
0730 Daily(No Weekends) 0800

Work scheduled by: NGrid

ARR: 75

	FWD	
	(Import)	
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__-ELBRIDGE_345_17				FWD	
Thu 05/04/2017	to	Thu 05/04/2017		(Import)	
0730	Daily(No Weekends)	1700		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			ARR: 75	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE				FWD	
Thu 05/04/2017	to	Thu 05/04/2017		(Import)	
1630	Daily(No Weekends)	1700		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			ARR: 75	Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW
ROCHESTR-PANNELL__345_RP2				FWD	
Fri 05/05/2017	to	Fri 05/05/2017	CANCELLED by RGE 04/19/2017	(Import)	
1500	Continuous	1530		DYSINGER EAST	2300 MW
Work scheduled by: RGE				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
PLSNTVLE-DUNWODIE_345_W90				FWD	
Sat 05/06/2017	to	Wed 05/10/2017		(Import)	
0001	Continuous	2130		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
SPRNBK_-W49TH_ST_345_M51				FWD	
Sat 05/06/2017	to	Tue 05/16/2017		(Import)	
0700	Continuous	0300		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
BROWNFLS-TAYLORVL_115_3				FWD	REV
Mon 05/08/2017	to	Fri 05/12/2017		(Import)	(Export)
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
ROSETON_-ROCKTVRN_345_311				FWD	
Mon 05/08/2017	to	Fri 05/26/2017		(Import)	
0800	Continuous	1600		UPNY CONED	4400 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	700 MW
				TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_345_2					FWD	
Mon 05/08/2017	to	Mon 05/08/2017	CANCELLED	by RGE	04/19/2017	(Import)
1000	Continuous	1030				WEST CENTRAL 1300 MW
Work scheduled by: RGE					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
ROCHESTR-PANNELL_345_RP2					FWD	
Mon 05/08/2017	to	Wed 05/10/2017				(Import)
1000	Continuous	1700				DYSINGER EAST 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
LAFAYTTE-CLRKSCRN_345_4-46					FWD	
Tue 05/09/2017	to	Tue 05/09/2017				(Import)
0700	Daily(No Weekends)	1700				CENTRAL EAST - VC 2650 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
PANNELL_-CLAY_345_2					FWD	
Wed 05/10/2017	to	Wed 05/10/2017	CANCELLED	by RGE	04/19/2017	(Import)
1630	Continuous	1700				WEST CENTRAL 1300 MW
Work scheduled by: RGE					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
EFISHKIL-WOOD_ST_345_F39					FWD	
Thu 05/11/2017	to	Sat 05/13/2017	UPDATED	by CE	04/13/2017	(Import)
2100	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
WOOD_ST_-PLSNTVLE_345_Y87					FWD	
Thu 05/11/2017	to	Sat 05/13/2017	UPDATED	by CE	04/13/2017	(Import)
2100	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
SCH-NYISO-HQ_LIMIT_900					REV	
Thu 05/11/2017	to	Sun 05/14/2017				(Export)
2200	Continuous	0300				SCH - HQ - NY 900 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK___-PACKARD__230_BP76	FWD	REV
Sat 05/13/2017 to Sun 05/14/2017	(Import)	(Export)
0500 Continuous 1700	SCH - OH - NY	900 MW 1150 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	850 MW 450 MW
	TTC with All Lines In Service	1750 MW 1600 MW
<hr/>		
BROWNFLS-TAYLORVL_115_3	FWD	REV
Mon 05/15/2017 to Fri 05/19/2017	(Import)	(Export)
0600 Continuous 1900	SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	120 MW 0 MW
ARR: 38	TTC with All Lines In Service	190 MW 40 MW
<hr/>		
FRASER__-GILBOA__345_GF5-35	FWD	
Mon 05/15/2017 to Fri 05/19/2017	(Import)	
0630 Continuous 1700	CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
STONYRDG-HILLSIDE_230_72	FWD	
Mon 05/15/2017 to Mon 05/15/2017	(Import)	
0800 Continuous 1700	DYSINGER EAST	2850 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
FRASER__345_FRASER SVC	FWD	
Mon 05/15/2017 to Fri 05/19/2017	(Import)	
0900 Continuous 1430	CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability	40 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
FRASER__345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S	FWD	
Mon 05/15/2017 to Fri 05/19/2017	(Import)	
0900 1430	CENTRAL EAST - VC	2700 MW
Work scheduled by:	Impacts Total Transfer Capability	275 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
RAMAPO__-LADENTWN_345_W72	FWD	
Tue 05/16/2017 to Tue 05/16/2017	(Import)	
0001 Continuous 2330	UPNY CONED	4400 MW
Work scheduled by: ORU	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600
 Work scheduled by: HQ

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45			FWD
Sat 05/20/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2359	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M54			FWD
Sat 05/20/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2359	SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
EASTVIEW-SPRNBRK_345_W64			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	0030	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
SPRNBRK_345KV_RNS5			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	0030	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
MILLWOOD-EASTVIEW_345_W99			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
0001	Continuous	2130	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
EASTVIEW-SPRNBRK_345_W64			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
2100	Continuous	2130	UPNY CONED 4350 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
SPRNBRK_345KV_RNS5			FWD
Sun 05/21/2017	to	Sun 05/21/2017	(Import)
2100	Continuous	2130	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD
Mon 05/22/2017	to	Fri 05/26/2017			(Import)
0500	Continuous	1630		MOSES SOUTH	1750 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
BROWNFLS-TAYLORVL_115_3					FWD
Mon 05/22/2017	to	Fri 05/26/2017			(Import) (Export)
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid			ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
CHAT_DC_GC1					FWD
Tue 05/23/2017	to	Wed 05/31/2017	UPDATED	by HQ	04/13/2017
0600	Continuous	2100			(Import)
Work scheduled by: HQ				MOSES SOUTH	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV
Tue 05/23/2017	to	Wed 05/31/2017	UPDATED	by HQ	04/13/2017
0600	Continuous	2100			(Export)
Work scheduled by: HQ				SCH - HQ - NY	500 MW
				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
MARCY___-N.SCTLND_345_18					FWD
Sat 05/27/2017	to	Sat 05/27/2017			(Import)
0500	Continuous	1530		CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA			ARR: 19	Impacts Total Transfer Capability	885 MW
				TTC with All Lines In Service	2975 MW
SCH-HQ-NYISO_LIMIT_1150					FWD
Sat 05/27/2017	to	Sat 05/27/2017	UPDATED	by HQ	04/13/2017
0500	Continuous	1530			(Import)
Work scheduled by: HQ				SCH - HQ - NY	1150 MW
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD
Sat 05/27/2017	to	Mon 06/05/2017			(Import)
1600	Continuous	0659		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_4					
Tue 05/30/2017	to	Fri 06/02/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 06/05/2017	to	Fri 06/09/2017			
0600	Continuous	1900			
Work scheduled by: NGrid			ARR: 38		
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
EDIC -FRASER 345_EF24-40					
Mon 06/05/2017	to	Sat 06/10/2017			
0700	Continuous	1659			
Work scheduled by: NYSEG					
				CENTRAL EAST - VC	2500 MW
				Impacts Total Transfer Capability	475 MW
				TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72					
Mon 06/05/2017	to	Mon 06/05/2017			
0800	Continuous	1000			
Work scheduled by: NYSEG					
				DYSINGER EAST	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
LINDEN -GOETHALS_230_A2253					
Fri 06/09/2017	to	Sun 06/11/2017	UPDATED by CE 04/04/2017		
0200	Continuous	2300			
Work scheduled by: PJM					
				SCH - PJ - NY	2050 MW 1300 MW
				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2050 MW 1300 MW
STONYRDG-HILLSIDE_230_72					
Fri 06/09/2017	to	Fri 06/09/2017			
1500	Continuous	1700			
Work scheduled by: NYSEG					
				DYSINGER EAST	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					
Sat 06/10/2017	to	Sat 08/05/2017			
1700	Continuous	0459			
Work scheduled by: NYISO					
				CENTRAL EAST - VC	2740 MW
				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4					
Mon 06/12/2017	to	Fri 06/16/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 06/19/2017	to	Fri 06/23/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 06/26/2017	to	Fri 06/30/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Wed 07/05/2017	to	Fri 07/07/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 07/10/2017	to	Fri 07/14/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3					
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900			FWD REV
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 07/24/2017	to	Fri 07/28/2017			FWD REV
0600	Continuous	1900			(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON_345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBRK_-DUNWODIE_345_W75			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS3			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
GILBOA_-N.SCTLND_345_GNS-1			FWD	
Mon 09/18/2017	to	Fri 10/06/2017	(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	455 MW
			TTC with All Lines In Service	2975 MW
NIAGARA__345_230_AT4			FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW 1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 300 MW
			TTC with All Lines In Service	1750 MW 1600 MW
MOSES_-ADIRNDCK_230_MAL			FWD	
Mon 09/18/2017	to	Sat 09/23/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MAL			FWD	
Mon 09/25/2017	to	Sat 09/30/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2				FWD	
Mon 10/02/2017	to	Fri 10/06/2017		(Import)	
0700	Continuous	1530	DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
FRASER_-COOPERS_345_33				FWD	
Mon 10/02/2017	to	Fri 10/13/2017		(Import)	
0700	Continuous	1900	CENTRAL EAST - VC	2395 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	580 MW	
			TTC with All Lines In Service	2975 MW	
HOMR_NYW-PIERC_NY_345_48				FWD	REV
Mon 10/02/2017	to	Tue 10/17/2017		(Import)	(Export)
0800	Continuous	1600	SCH - PJ - NY	2050 MW	1300 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2050 MW	1300 MW
WETHSRFD-MEYER_230_85/87				FWD	
Mon 10/09/2017	to	Fri 10/20/2017		(Import)	
0700	Continuous	1400	DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 10/13/2017	to	Mon 11/06/2017		(Import)	
1900	Continuous	0559	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
CHATGUAY-MASSENA_765_7040				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	(Import)	
0700	Continuous	1530	by NYISO 03/24/2017	MOSES SOUTH	1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	(Import)	(Export)
0700	Continuous	1530	by NYISO 03/24/2017	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import) (Export)
0700	Continuous	1530			SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			MOSES SOUTH 500 MW
Work scheduled by:					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			CENTRAL EAST - VC 2080 MW
Work scheduled by:					Impacts Total Transfer Capability 895 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
 0700 1530

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MOSES -ADIRNDCK 230_MA2

Mon 10/30/2017 to Fri 11/03/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

FRASANX-COOPERS 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MARCY -FRASANX 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 11/06/2017 to Thu 11/09/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

LINDN_CG-LNDVFT 345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
 1700 Continuous 0000
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 20, 2017 to Saturday ,October 20, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW