

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	2200 MW	1450 MW
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Wed 05/03/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/21/2017</u>	UPNY CONED	4000 MW	
0728	Continuous	1600				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6	Fri 02/17/2017	Wed 04/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	SCH - PJM_HTP	315 MW	
0001	Continuous	0538				Impacts Total Transfer Capability	345 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
HUDSONP_-FARRAGUT_345_B3402	Tue 03/21/2017	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>	SCH - PJ - NY	2300 MW	1450 MW
0001	Continuous	2359				Impacts Total Transfer Capability	0 MW	0 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403				FWD	REV
Tue 03/21/2017	to	Wed 05/03/2017		(Import)	(Export)
0001		2359		SCH - PJ - NY	2050 MW 1450 MW
Work scheduled by:				Impacts Total Transfer Capability	250 MW 0 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<hr/>					
MARION_-FARRAGUT_345_C3403				FWD	REV
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>
0001	Continuous	2359		SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
0800	Continuous	1300		SCH - NE - NY	1400 MW 1450 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	0 MW 150 MW
				TTC with All Lines In Service	1400 MW 1600 MW
<hr/>					
BERKSHIR-NORTHFLD_345_312				FWD	REV
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
0800	Continuous	1300		SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
<hr/>					
SCH-NYISO-PJM_LIMIT_100					REV
Tue 04/04/2017	to	Thu 04/20/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>04/07/2017</u>
0800	Continuous	1600		SCH - PJ - NY	400 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	1450 MW
<hr/>					
DUNWODIE_345KV_3				FWD	
Fri 04/07/2017	to	Wed 05/03/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/21/2017</u>
0001	Continuous	1600		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
DUNWODIE_345KV_4				FWD	
Fri 04/07/2017	to	Wed 05/03/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>04/21/2017</u>
0001	Continuous	1600		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8					FWD	
Wed 04/12/2017	to	Wed 04/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/20/2017</u>	(Import)
0201	Continuous	0200				315 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 345 MW	
					TTC with All Lines In Service 660 MW	
SCH-NE-NYISO_LIMIT_700					FWD	
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>	(Import)
0001	Continuous	0959				900 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1400 MW	
SCH-NYISO-NE_LIMIT_800					REV	
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>	(Export)
0001	Continuous	0959				1000 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 1600 MW	
HOMRC_NY-MAINS_NY_345_47					FWD	
Fri 04/14/2017	to	Fri 04/28/2017	<u>EXT FORCE</u>	<u>by PJM</u>	<u>04/22/2017</u>	(Import) (Export)
1600	Continuous	1600				2300 MW 1450 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2300 MW 1450 MW	
SHOR_NPX-SHOREHAM_138_CSC					FWD	
Mon 04/17/2017	to	Sat 04/22/2017				(Import) (Export)
0500	Continuous	1600				0 MW 0 MW
Work scheduled by: LI					Impacts Total Transfer Capability 330 MW 330 MW	
					TTC with All Lines In Service 330 MW 330 MW	
MOSES__-ADIRNDCK_230_MAI					FWD	
Mon 04/17/2017	to	Thu 04/20/2017				(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
FRASER__-COOPERS__345_33					FWD	
Mon 04/17/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by NY</u>	<u>01/12/2017</u>	(Import)
0900	Continuous	1400				2395 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 580 MW	
					TTC with All Lines In Service 2975 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-MOTTHAVN_345_71					FWD
Mon 04/17/2017	to	Thu 05/18/2017	EXT FORCE	by CE	(Import)
2120	Continuous	2359		04/21/2017	3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					
PORTER_-ROTTDAM_230_31					FWD
Tue 04/18/2017	to	Tue 04/18/2017			(Import)
0800	Daily(No Weekends)	1500			CENTRAL EAST - VC
Work scheduled by: NGrid					2805 MW
					Impacts Total Transfer Capability 170 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
VOLNEY_-CLAY____345_6					FWD
Wed 04/19/2017	to	Wed 04/19/2017			(Import)
0730	Daily(No Weekends)	1700			OSWEGO EXPORT
Work scheduled by: NGrid					5250 MW
					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
<hr/>					
PORTER_-ROTTDAM_230_30					FWD
Wed 04/19/2017	to	Wed 04/19/2017			(Import)
0800	Continuous	1530			CENTRAL EAST - VC
Work scheduled by: NGrid					2805 MW
					Impacts Total Transfer Capability 170 MW
					TTC with All Lines In Service 2975 MW
<hr/>					
SCH-IMO-NYISO_LIMIT_1000					FWD
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	(Import)
1100	Continuous	1300		04/18/2017	1300 MW
Work scheduled by: PJM					SCH - OH - NY
					450 MW
					Impacts Total Transfer Capability 450 MW
					TTC with All Lines In Service 1750 MW
<hr/>					
SCH-NYISO-PJM_LIMIT_100					REV
Fri 04/21/2017	to	Fri 04/21/2017	UPDATED	by PJM	(Export)
1100	Continuous	1300		04/18/2017	400 MW
Work scheduled by: PJM					SCH - PJ - NY
					1050 MW
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1450 MW
<hr/>					
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD
Fri 04/21/2017	to	Sat 05/27/2017			(Import)
1400	Continuous	0459			CENTRAL EAST - VC
Work scheduled by: NYISO					2740 MW
					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE <u>04/20/2017</u>	(Import)	(Export)
1000	Daily	1300			1300 MW	1300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
					300 MW	1600 MW
BERKSHIR-ALPS _____ 345_393					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE <u>04/20/2017</u>	(Import)	(Export)
1000	Daily	1300			100 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
					100 MW	200 MW
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD 345_312					FWD	REV
Sat 04/22/2017	to	Sat 04/22/2017			(Import)	(Export)
1000		1300			1300 MW	1300 MW
Work scheduled by:					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
					300 MW	1600 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE <u>04/20/2017</u>	(Import)	
1000	Daily	1300			800 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_400						REV
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE <u>04/20/2017</u>		(Export)
1000	Daily	1300			600 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1600 MW
SCH-NYISO-HQ_LIMIT_900						REV
Sat 04/22/2017	to	Sun 04/30/2017				(Export)
2200	Continuous	0600			900 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1000 MW
ROSETON_-EFISHRIL_345_RFK305					FWD	
Mon 04/24/2017	to	Fri 05/05/2017			(Import)	
0001	Continuous	1900			4100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY -EDIC 345_1-16			FWD	
Mon 04/24/2017	to	Tue 04/25/2017	(Import)	
0630	Continuous	1530	OSWEGO EXPORT	4850 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW
			TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES 230_L34P			FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW 1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	1750 MW 1900 MW
MOSES -ADIRNDCK 230_MA1			FWD	
Mon 04/24/2017	to	Sat 04/29/2017	(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
BEAR SWP-EASTOVER 230_E205W				
Mon 04/24/2017	to	Tue 05/30/2017		
0700	Continuous	0659	UPDATED by NE 04/20/2017	SCH - NE - NY
Work scheduled by: NGrid			Impacts Total Transfer Capability	
			TTC with All Lines In Service	
ALCOA -DENNISON 115_12			FWD	REV
Mon 04/24/2017	to	Wed 04/26/2017	(Import)	(Export)
0800	Continuous	0659	SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW 100 MW
ALCOA -DENNISON 115_12			FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017	(Import)	(Export)
0700	Daily(No Weekends)	1800	SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	99 MW 0 MW
			TTC with All Lines In Service	199 MW 100 MW
ALCOA -DENNISON 115_12 & ALCOA -NOGDNBRG 115_13			FWD	REV
Wed 04/26/2017	to	Wed 04/26/2017	(Import)	(Export)
0700		1800	SCH - HQ_CEDARS	100 MW 60 MW
Work scheduled by:			Impacts Total Transfer Capability	99 MW 40 MW
			TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD</p> <p>(Import)</p> <p>MOSES SOUTH 3100 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ILCTLIMIT_115KV_ALCOA_R8105_TIE_B</p> <p>Wed 04/26/2017 to Wed 04/26/2017</p> <p>0700 Daily(No Weekends) 1800</p> <p>Work scheduled by: NGrid</p>	<p>FWD REV</p> <p>(Import) (Export)</p> <p>SCH - HQ_CEDARS 100 MW 60 MW</p> <p>Impacts Total Transfer Capability 99 MW 40 MW</p> <p>TTC with All Lines In Service 199 MW 100 MW</p>
<p>SCRIBA_-VOLNEY__345_21</p> <p>Thu 04/27/2017 to Thu 04/27/2017</p> <p>0800 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p>FWD</p> <p>(Import)</p> <p>OSWEGO EXPORT 5250 MW</p> <p>Impacts Total Transfer Capability 0 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Fri 04/28/2017 to Fri 04/28/2017 UPDATED by PA 03/29/2017</p> <p>0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p>FWD</p> <p>(Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CLAY_-EDIC__345_2-15</p> <p>Sat 04/29/2017 to Sat 04/29/2017</p> <p>0630 Daily 1730</p> <p>Work scheduled by: NGrid</p>	<p>FWD</p> <p>(Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>NEPTUNE_-DUFFYAVE_345_NEPTUNE</p> <p>Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>
<p>NEWBRDGE-DUFFYAVE_345_501</p> <p>Mon 05/01/2017 to Tue 05/16/2017 UPDATED by LI 02/14/2017</p> <p>0400 Continuous 1800</p> <p>Work scheduled by: LI</p>	<p>FWD</p> <p>(Import)</p> <p>SCH - PJM_NEPTUNE 0 MW</p> <p>Impacts Total Transfer Capability 660 MW</p> <p>TTC with All Lines In Service 660 MW</p>

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18					FWD	
Mon 05/01/2017	to	Fri 05/05/2017	UPDATED	by NYPA	04/10/2017	(Import)
0500	Continuous	1700				CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
MARCY___-N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Mon 05/01/2017	to	Fri 05/05/2017				(Import)
0500		1700				CENTRAL EAST - VC 1855 MW
Work scheduled by:					ARR: 19	Impacts Total Transfer Capability 1120 MW
						TTC with All Lines In Service 2975 MW
BROWNFLS-TAYLORVL_115_3					FWD	REV
Mon 05/01/2017	to	Fri 05/05/2017				(Import) (Export)
0600	Continuous	1900				SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid					ARR: 38	Impacts Total Transfer Capability 120 MW 0 MW
						TTC with All Lines In Service 190 MW 40 MW
ROCHESTR-PANNELL___345_RP2					FWD	
Mon 05/01/2017	to	Mon 05/01/2017	CANCELLED	by RGE	04/19/2017	(Import)
0630	Continuous	0700				DYSINGER EAST 2300 MW
Work scheduled by: RGE						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
PANNELL_-CLAY___345_2					FWD	
Mon 05/01/2017	to	Fri 05/05/2017				(Import)
0630	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
SCH-NYISO-HQ_LIMIT_800						REV
Mon 05/01/2017	to	Wed 05/10/2017				(Export)
2200	Continuous	0300				SCH - HQ - NY 800 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1000 MW
W49TH_ST_345KV_6					FWD	
Wed 05/03/2017	to	Wed 05/03/2017	UPDATED	by CONED	04/20/2017	(Import)
0230	Continuous	0300				SCH - PJM_HTP 320 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 340 MW
						TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARION__-FARRAGUT_345_C3403					FWD	REV
Thu 05/04/2017	to	Wed 05/31/2017	UPDATED	by CE	04/03/2017	(Import) (Export)
0001	Continuous	2359				2050 MW 1300 MW
Work scheduled by: PJM					SCH - PJ - NY Impacts Total Transfer Capability TTC with All Lines In Service	0 MW 0 MW 2050 MW 1300 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	0800				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
OSWEGO__-ELBRIDGE_345_17					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	1700				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
1630	Daily(No Weekends)	1700				5250 MW
Work scheduled by: NGrid					ARR: 75	OSWEGO EXPORT Impacts Total Transfer Capability TTC with All Lines In Service
ROCHESTR-PANNELL__345_RP2					FWD	
Fri 05/05/2017	to	Fri 05/05/2017	CANCELLED	by RGE	04/19/2017	(Import)
1500	Continuous	1530				2300 MW
Work scheduled by: RGE						DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service
PLSNTVLE-DUNWODIE_345_W90					FWD	
Sat 05/06/2017	to	Wed 05/10/2017				(Import)
0001	Continuous	2130				4000 MW
Work scheduled by: ConEd						UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service
SPRNBK_-W49TH_ST_345_M51					FWD	
Sat 05/06/2017	to	Tue 05/16/2017	CANCELLED	by ConEd	04/21/2017	(Import)
0700	Continuous	0300				3200 MW
Work scheduled by: ConEd						SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
BROWNFLS-TAYLORVL_115_3				
Mon 05/08/2017 to Fri 05/12/2017			FWD	REV
0600 Continuous 1900			(Import)	(Export)
Work scheduled by: NGrid	ARR: 38		SCH - HQ_CEDARS	70 MW 40 MW
			Impacts Total Transfer Capability	120 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<hr/>				
ROSETON_-ROCKTVRN_345_311			FWD	
Mon 05/08/2017 to Fri 05/26/2017			(Import)	
0800 Continuous 1600			UPNY CONED	4400 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability	700 MW
			TTC with All Lines In Service	5100 MW
<hr/>				
PANNELL_-CLAY____345_2			FWD	
Mon 05/08/2017 to Mon 05/08/2017		<u>CANCELLED by RGE 04/19/2017</u>	(Import)	
1000 Continuous 1030			WEST CENTRAL	1300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<hr/>				
ROCHESTR-PANNELL__345_RP2			FWD	
Mon 05/08/2017 to Wed 05/10/2017			(Import)	
1000 Continuous 1700			DYSINGER EAST	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
LAFAYTTE-CLRKSCRN_345_4-46			FWD	
Tue 05/09/2017 to Tue 05/09/2017			(Import)	
0700 Daily(No Weekends) 1700			CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
PANNELL_-CLAY____345_2			FWD	
Wed 05/10/2017 to Wed 05/10/2017		<u>CANCELLED by RGE 04/19/2017</u>	(Import)	
1630 Continuous 1700			WEST CENTRAL	1300 MW
Work scheduled by: RGE			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<hr/>				
EFISHKIL-WOOD_ST__345_F39			FWD	
Thu 05/11/2017 to Sat 05/13/2017		<u>UPDATED by CE 04/13/2017</u>	(Import)	
2100 Continuous 0200			UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87						FWD	
Thu 05/11/2017	to	Sat 05/13/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2017</u>	(Import)	
2100	Continuous	0200				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
SCH-NYISO-HQ_LIMIT_900							REV
Thu 05/11/2017	to	Sun 05/14/2017				(Export)	
2200	Continuous	0300				SCH - HQ - NY	900 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1000 MW
BECK___-PACKARD_230_BP76						FWD	REV
Sat 05/13/2017	to	Sun 05/14/2017				(Import) (Export)	
0500	Continuous	1700				SCH - OH - NY	900 MW 1150 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	850 MW 450 MW
						TTC with All Lines In Service	1750 MW 1600 MW
BROWNFLS-TAYLORVL_115_3						FWD	REV
Mon 05/15/2017	to	Fri 05/19/2017				(Import) (Export)	
0600	Continuous	1900				SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
FRASER___-GILBOA___345_GF5-35						FWD	
Mon 05/15/2017	to	Fri 05/19/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/13/2017</u>	(Import)	
0630	Continuous	1700				CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72						FWD	
Mon 05/15/2017	to	Mon 05/15/2017				(Import)	
0800	Continuous	1700				DYSINGER EAST	2850 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
FRASER___345_FRASER SVC						FWD	
Mon 05/15/2017	to	Fri 05/19/2017	<u>UPDATED</u>	<u>by NY</u>	<u>04/06/2017</u>	(Import)	
0900	Continuous	1430				CENTRAL EAST - VC	2935 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER__345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/15/2017 to Fri 05/19/2017
 0900 1430

Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2700 MW**
 Impacts Total Transfer Capability 275 MW
 TTC with All Lines In Service 2975 MW

RAMAPO__-LADENTWN_345_W72

Tue 05/16/2017 to Tue 05/16/2017
 0001 Continuous 2330

Work scheduled by: ORU

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600

Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Wed 05/17/2017 to Thu 05/18/2017
 1800 Continuous 0600

Work scheduled by: HQ

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030

Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 2100

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK_345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT_345_45

Sat 05/20/2017 to Sun 05/21/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Sat 05/20/2017 to Sun 05/21/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK_345_W64

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK_345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MARCY__765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/22/2017 to Fri 05/26/2017
 0600 Continuous 1900
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

CHAT_DC_GC1

Tue 05/23/2017 to Wed 05/31/2017
 0600 Continuous 2100
 Work scheduled by: HQ

UPDATED by HQ 04/13/2017

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Tue 05/23/2017 to Wed 05/31/2017
 0600 Continuous 2100
 Work scheduled by: HQ

UPDATED by HQ 04/13/2017

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

MARCY__-N.SCTLND_345_18

Sat 05/27/2017 to Sat 05/27/2017
 0500 Continuous 1530
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2090 MW**
 Impacts Total Transfer Capability 885 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK					IMPACTS	
DATE	TIME	DURATION	BY	REASON	IMPACTS	TTC
SCH-HQ-NYISO_LIMIT_1150						
Sat 05/27/2017	0500	Continuous	HQ	04/13/2017	SCH - HQ - NY	1150 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						
Sat 05/27/2017	1600	Continuous	NYISO		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4						
Tue 05/30/2017	0600	Continuous	NGrid	ARR: 38	SCH - HQ_CEDARS	70 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
					REV (Export)	40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 06/05/2017	0600	Continuous	NGrid	ARR: 38	SCH - HQ_CEDARS	70 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
					REV (Export)	40 MW
EDIC -FRASER 345_EF24-40						
Mon 06/05/2017	0700	Continuous	NYSEG		CENTRAL EAST - VC	2500 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72						
Mon 06/05/2017	0800	Continuous	NYSEG		DYSINGER EAST	2850 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
LINDEN -GOETHALS_230_A2253						
Fri 06/09/2017	0200	Continuous	PJM	04/04/2017	SCH - PJ - NY	2050 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
					REV (Export)	1300 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled By	Start Date	End Date	Time	Zone	Impact	TTC	FWD	REV
NYSEG	Fri 06/09/2017	Fri 06/09/2017	1500 - 1700	DYSINGER EAST	300 MW	3150 MW	(Import)	
					Impacts Total Transfer Capability		2850 MW	
					TTC with All Lines In Service			
NYISO	Sat 06/10/2017	Sat 08/05/2017	1700 - 0459	CENTRAL EAST - VC	235 MW	2975 MW	(Import)	
					Impacts Total Transfer Capability		2740 MW	
					TTC with All Lines In Service			
NGrid	Mon 06/12/2017	Fri 06/16/2017	0600 - 1900	SCH - HQ_CEDARS	120 MW	190 MW	(Import)	(Export)
					Impacts Total Transfer Capability		70 MW	40 MW
					TTC with All Lines In Service			
					ARR: 38			
NGrid	Mon 06/19/2017	Fri 06/23/2017	0600 - 1900	SCH - HQ_CEDARS	120 MW	190 MW	(Import)	(Export)
					Impacts Total Transfer Capability		70 MW	40 MW
					TTC with All Lines In Service			
					ARR: 38			
NGrid	Mon 06/26/2017	Fri 06/30/2017	0600 - 1900	SCH - HQ_CEDARS	120 MW	190 MW	(Import)	(Export)
					Impacts Total Transfer Capability		70 MW	40 MW
					TTC with All Lines In Service			
					ARR: 38			
NGrid	Wed 07/05/2017	Fri 07/07/2017	0600 - 1900	SCH - HQ_CEDARS	120 MW	190 MW	(Import)	(Export)
					Impacts Total Transfer Capability		70 MW	40 MW
					TTC with All Lines In Service			
					ARR: 38			
NGrid	Mon 07/10/2017	Fri 07/14/2017	0600 - 1900	SCH - HQ_CEDARS	120 MW	190 MW	(Import)	(Export)
					Impacts Total Transfer Capability		70 MW	40 MW
					TTC with All Lines In Service			
					ARR: 38			

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_3						
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED	by NGRID	03/02/2017	FWD
0600	Continuous	1900				(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS		70 MW 40 MW
				Impacts Total Transfer Capability		120 MW 0 MW
				TTC with All Lines In Service		190 MW 40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 07/24/2017	to	Fri 07/28/2017				FWD
0600	Continuous	1900				(Import) (Export)
Work scheduled by: NGrid			ARR: 38	SCH - HQ_CEDARS		70 MW 40 MW
				Impacts Total Transfer Capability		120 MW 0 MW
				TTC with All Lines In Service		190 MW 40 MW
MARCY___-N.SCTLND_345_18						
Sat 08/05/2017	to	Sat 08/05/2017				FWD
0500	Continuous	1530				(Import)
Work scheduled by: NYPA			ARR: 19	CENTRAL EAST - VC		2090 MW
				Impacts Total Transfer Capability		885 MW
				TTC with All Lines In Service		2975 MW
MARCY___765_345_AT2						
Sat 08/05/2017	to	Sat 08/05/2017				FWD
0500	Continuous	1530				(Import)
Work scheduled by: NYPA			ARR: 19	MOSES SOUTH		1700 MW
				Impacts Total Transfer Capability		1450 MW
				TTC with All Lines In Service		3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						
Sat 08/05/2017	to	Mon 10/02/2017				FWD
1600	Continuous	0659				(Import)
Work scheduled by: NYISO				CENTRAL EAST - VC		2740 MW
				Impacts Total Transfer Capability		235 MW
				TTC with All Lines In Service		2975 MW
MARCY___765_345_AT2						
Tue 09/05/2017	to	Sun 09/10/2017				FWD
0500	Continuous	1630				(Import)
Work scheduled by: NYPA			ARR: 19	MOSES SOUTH		1700 MW
				Impacts Total Transfer Capability		1450 MW
				TTC with All Lines In Service		3150 MW
MOSES___-ADIRNDCK_230_MAI						
Mon 09/11/2017	to	Sat 09/16/2017				FWD
0700	Continuous	1530				(Import)
Work scheduled by: NYPA				MOSES SOUTH		2100 MW
				Impacts Total Transfer Capability		1050 MW
				TTC with All Lines In Service		3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303

Mon 09/11/2017 to Fri 09/29/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK_-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS3

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/06/2017
 0630 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2520 MW**
 Impacts Total Transfer Capability 455 MW
 TTC with All Lines In Service 2975 MW

NIAGARA__345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD	REV
(Import)	(Export)
SCH - OH - NY 1750 MW	1300 MW
Impacts Total Transfer Capability 0 MW	300 MW
TTC with All Lines In Service 1750 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA1

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NIAGARA -ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASER -COOPERS_345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

HOMR_NYW-PIERC_NY_345_48

Mon 10/02/2017 to Tue 10/17/2017
0800 Continuous 1600

Work scheduled by: NYSEG

FWD REV
(Import) (Export)
SCH - PJ - NY **2050 MW 1300 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2050 MW 1300 MW

WETHSRFD-MEYER_230_85/87

Mon 10/09/2017 to Fri 10/20/2017
0700 Continuous 1400

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 10/13/2017 to Mon 11/06/2017
1900 Continuous 0559

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
CHATGUAY-MASSENA__765_7040							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	
0700	Continuous	1530				MOSES SOUTH	1550 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
CHATGUAY-MASSENA__765_7040							FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	(Export)
0700	Continuous	1530				SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>								
MARCY__765_345_AT1							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	
0700	Continuous	1530				MOSES SOUTH	1750 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
MARCY__765_345_AT2							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	
0700	Continuous	1530				MOSES SOUTH	1700 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
MASSENA_-MARCY__765_MSU1							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
MASSENA_-MARCY__765_MSU1							FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	
0700	Continuous	1530				MOSES SOUTH	500 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
MASSENA_-MARCY__765_MSU1							FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/24/2017</u>		(Import)	(Export)
0700	Continuous	1530				SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA -MARCY 765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2080 MW**
Impacts Total Transfer Capability 895 MW
TTC with All Lines In Service 2975 MW

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
0700 1530

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

MOSES -ADIRNDCK 230_MA2

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY -FRASANX 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Day	Time	Zone	Impact	TTC
MOSES -ADIRNDCK_230_MA2						FWD	
Mon 11/06/2017	to	Thu 11/09/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
LINDN_CG-LNDVFT_345_V-3022						FWD	REV
Mon 11/06/2017	to	Thu 11/09/2017				(Import) (Export)	
0800	Continuous	1500			SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	315 MW 315 MW
						TTC with All Lines In Service	315 MW 315 MW
MOSES -ADIRNDCK_230_MA2						FWD	
Mon 11/13/2017	to	Fri 11/17/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD	
Fri 11/17/2017	to	Sat 02/01/2020				(Import)	
1700	Continuous	0000			CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
MOSES -ADIRNDCK_230_MA1						FWD	
Mon 11/20/2017	to	Wed 11/22/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
MOSES -ADIRNDCK_230_MA1						FWD	
Mon 11/27/2017	to	Fri 12/01/2017				(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
MARCY_765_345_AT2						FWD	
Mon 12/04/2017	to	Fri 12/08/2017				(Import)	
0500	Continuous	1630			MOSES SOUTH	1700 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,April 23, 2017 to Tuesday ,October 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW