

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
RAMAPO___345_345_PAR3500							
Fri 06/24/2016	to	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>		
1940	Continuous	2359				SCH - PJ - NY	2200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	2300 MW
PLSNTVLE-DUNWODIE_345_W89							
Sun 10/30/2016	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0728	Continuous	1600				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
HUDSONTP-W49TH_ST_345_Y56							
Thu 11/24/2016	to	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>		
1500	Continuous	2359				SCH - PJM_HTP	0 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	660 MW
						TTC with All Lines In Service	660 MW
E13THSTA-FARRAGUT_345_46							
Tue 12/20/2016	to	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	0300				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
W49TH_ST-E13THSTA_345_M55							
Tue 12/20/2016	to	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	0300				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
HUDSONP_-FARRAGUT_345_B3402							
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>		
0001	Continuous	2359				SCH - PJ - NY	2300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403							
Tue 03/21/2017	to	Wed 05/03/2017					
0001		2359				SCH - PJ - NY	2050 MW
Work scheduled by:						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	2300 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
MARION__-FARRAGUT_345_C3403							
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>		
0001	Continuous	2359				SCH - PJ - NY	2300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
BERKSHIR-NORTHFLD_345_312							
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0800	Continuous	1300				SCH - NE - NY	1400 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312							
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0800	Continuous	1300				SCH - NPX_1385	100 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
SCH-NYISO-PJM_LIMIT_100							
Tue 04/04/2017	to	Thu 04/20/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>04/07/2017</u>		
0800	Continuous	1600				SCH - PJ - NY	400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	1450 MW
DUNWODIE_345KV_3							
Fri 04/07/2017	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	1600				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4							
Fri 04/07/2017	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	1600				SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
SCH-NE-NYISO_LIMIT_700							
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0001	Continuous	0959				SCH - NE - NY	900 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					
SCH-NYISO-NE_LIMIT_800					REV
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
0001	Continuous	0959			
Work scheduled by: ISONE					
					(Export)
					1000 MW
SCH - NE - NY					600 MW
Impacts Total Transfer Capability					1600 MW
TTC with All Lines In Service					
<hr/>					
HOMRC_NY-MAINS_NY_345_47					FWD REV
Fri 04/14/2017	to	Mon 04/24/2017	<u>RETURNED</u>	<u>by PJM</u>	<u>04/24/2017</u>
1600	Continuous	1600			
Work scheduled by: PJM					
					(Import) (Export)
					2300 MW 1450 MW
SCH - PJ - NY					0 MW 0 MW
Impacts Total Transfer Capability					2300 MW 1450 MW
TTC with All Lines In Service					
<hr/>					
SHOR_NPX-SHOREHAM_138_CSC					FWD REV
Mon 04/17/2017	to	Sat 04/22/2017			
0500	Continuous	1600			
Work scheduled by: LI					
					(Import) (Export)
					0 MW 0 MW
SCH - NPX_CSC					330 MW 330 MW
Impacts Total Transfer Capability					330 MW 330 MW
TTC with All Lines In Service					
<hr/>					
MOSES__-ADIRNDCK_230_MAL					FWD
Mon 04/17/2017	to	Thu 04/20/2017			
0700	Continuous	1730			
Work scheduled by: NYPA					
					(Import)
					2300 MW
MOSES SOUTH					850 MW
Impacts Total Transfer Capability					3150 MW
TTC with All Lines In Service					
<hr/>					
FRASER__-COOPERS__345_33					FWD
Mon 04/17/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by NY</u>	<u>01/12/2017</u>
0900	Continuous	1400			
Work scheduled by: NYSEG					
					(Import)
					2395 MW
CENTRAL EAST - VC					580 MW
Impacts Total Transfer Capability					2975 MW
TTC with All Lines In Service					
<hr/>					
DUNWODIE-MOTTHAVN_345_71					FWD
Mon 04/17/2017	to	Thu 05/18/2017	<u>EXT FORCE</u>	<u>by CE</u>	<u>04/21/2017</u>
2120	Continuous	2359			
Work scheduled by: ConEd					
					(Import)
					3800 MW
SPR/DUN-SOUTH					800 MW
Impacts Total Transfer Capability					4600 MW
TTC with All Lines In Service					
<hr/>					
SCH-IMO-NYISO_LIMIT_1000					FWD
Fri 04/21/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>04/18/2017</u>
1100	Continuous	1300			
Work scheduled by: PJM					
					(Import)
					1300 MW
SCH - OH - NY					450 MW
Impacts Total Transfer Capability					1750 MW
TTC with All Lines In Service					

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
SCH-NYISO-PJM_LIMIT_100								REV
Fri 04/21/2017	to	Fri 04/21/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>04/18/2017</u>			(Export)
1100	Continuous	1300				SCH - PJ - NY		400 MW
Work scheduled by: PJM						Impacts Total Transfer Capability		1050 MW
						TTC with All Lines In Service		1450 MW
<hr/>								
ILCTLIMIT_MARCY_SO_COMP_I/S								FWD
Fri 04/21/2017	to	Sat 05/27/2017						(Import)
1400	Continuous	0459				CENTRAL EAST - VC		2740 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability		235 MW
						TTC with All Lines In Service		2975 MW
<hr/>								
BERKSHIR-ALPS_____345_393								FWD REV
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>			(Import) (Export)
1000	Daily	1300				SCH - NE - NY		1300 MW 1300 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		100 MW 300 MW
						TTC with All Lines In Service		1400 MW 1600 MW
<hr/>								
BERKSHIR-ALPS_____345_393								FWD REV
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>			(Import) (Export)
1000	Daily	1300				SCH - NPX_1385		100 MW 100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		100 MW 100 MW
						TTC with All Lines In Service		200 MW 200 MW
<hr/>								
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312								FWD REV
Sat 04/22/2017	to	Sat 04/22/2017						(Import) (Export)
1000		1300				SCH - NE - NY		1300 MW 1300 MW
Work scheduled by:						Impacts Total Transfer Capability		100 MW 300 MW
						TTC with All Lines In Service		1400 MW 1600 MW
<hr/>								
SCH-NE-NYISO_LIMIT_600								FWD
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>			(Import)
1000	Daily	1300				SCH - NE - NY		800 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		600 MW
						TTC with All Lines In Service		1400 MW
<hr/>								
SCH-NYISO-NE_LIMIT_400								REV
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>			(Export)
1000	Daily	1300				SCH - NE - NY		600 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability		1000 MW
						TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_900

Sat 04/22/2017 to Sun 04/30/2017
 2200 Continuous 0600
 Work scheduled by: HQ

REV
 (Export)
900 MW
 SCH - HQ - NY
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 1000 MW

ROSETON_-EFISHKIL_345_RFK305

Mon 04/24/2017 to Fri 05/05/2017
 0600 Continuous 1900
 Work scheduled by: NYPA

FWD
 (Import)
4100 MW
 UPNY CONED
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

CLAY_-EDIC_345_1-16

Mon 04/24/2017 to Tue 04/25/2017
 0630 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
4850 MW
 OSWEGO EXPORT
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

STLAWRNC-MOSES_230_L34P

Mon 04/24/2017 to Fri 04/28/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
1750 MW 1900 MW
 SCH - OH - NY
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 1750 MW 1900 MW

MOSES_-ADIRNDCK_230_MA1

Mon 04/24/2017 to Sat 04/29/2017
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
2300 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

BEAR SWP-EASTOVER_230_E205W

Mon 04/24/2017 to Tue 05/30/2017 **UPDATED by NE 04/24/2017**
 0700 Continuous 0659
 Work scheduled by: NGrid

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ALCOA_-DENNISON_115_12

Mon 04/24/2017 to Wed 04/26/2017
 0800 Continuous 0659
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
100 MW 100 MW
 SCH - HQ_CEDARS
 Impacts Total Transfer Capability 99 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
ALCOA -DENNISON_115_12		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import) (Export)	
0700 Daily(No Weekends) 1800		SCH - HQ_CEDARS	100 MW 100 MW
Work scheduled by: NGrid	ARR: 38	Impacts Total Transfer Capability	99 MW 0 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
ALCOA -DENNISON_115_12 & ALCOA -NOGDNBRG_115_13		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import) (Export)	
0700 1800		SCH - HQ_CEDARS	100 MW 60 MW
Work scheduled by:	ARR: 38	Impacts Total Transfer Capability	99 MW 40 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B		FWD	
Wed 04/26/2017 to Wed 04/26/2017		(Import)	
0700 Daily(No Weekends) 1800		MOSES SOUTH	3100 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	50 MW
		TTC with All Lines In Service	3150 MW
<hr/>			
ILCTLIMIT_115KV_ALCOA_R8105_TIE_B		FWD	REV
Wed 04/26/2017 to Wed 04/26/2017		(Import) (Export)	
0700 Daily(No Weekends) 1800		SCH - HQ_CEDARS	100 MW 60 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	99 MW 40 MW
		TTC with All Lines In Service	199 MW 100 MW
<hr/>			
SCH-NYISO-HQ_CEDARS_LIMIT_0			REV
Thu 04/27/2017 to Thu 04/27/2017			(Export)
0800 Continuous 1500		SCH - HQ_CEDARS	0 MW
Work scheduled by: HQ		Impacts Total Transfer Capability	100 MW
		TTC with All Lines In Service	100 MW
<hr/>			
SCRIBA -VOLNEY_345_21		FWD	
Thu 04/27/2017 to Thu 04/27/2017		(Import)	
0800 Daily(No Weekends) 1630		OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	5250 MW
<hr/>			
NIAGARA -ROCHESTR_345_NR2		FWD	
Fri 04/28/2017 to Fri 04/28/2017		(Import)	
0500 Continuous 1700	UPDATED by PA 03/29/2017	DYSINGER EAST	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1000

Fri 04/28/2017 to Fri 04/28/2017
1100 Continuous 1300

UPDATED by PJM 04/24/2017

Work scheduled by: PJM

FWD
(Import)
SCH - OH - NY **1300 MW**
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 1750 MW

SCH-NYISO-PJM_LIMIT_100

Fri 04/28/2017 to Fri 04/28/2017
1100 Continuous 1300

UPDATED by PJM 04/24/2017

Work scheduled by: PJM

REV
(Export)
SCH - PJ - NY **400 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 1450 MW

CLAY -EDIC 345_2-15

Sat 04/29/2017 to Sat 04/29/2017
0630 Daily 1730

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NEPTUNE -DUFFYAVE_345_NEPTUNE

Mon 05/01/2017 to Tue 05/16/2017
0400 Continuous 1800

UPDATED by LI 02/14/2017

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/01/2017 to Tue 05/16/2017
0400 Continuous 1800

UPDATED by LI 02/14/2017

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

MARCY -N.SCTLND_345_18

Mon 05/01/2017 to Fri 05/05/2017
0500 Continuous 1700

UPDATED by NYPA 04/10/2017

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY -N.SCTLND_345_18 & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/01/2017 to Fri 05/05/2017
0500 1700

UPDATED by NYPA 04/10/2017

Work scheduled by:

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **1855 MW**
Impacts Total Transfer Capability 1120 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_3						
Mon 05/01/2017	to	Fri 05/05/2017				
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW
Work scheduled by: NGrid			ARR: 38		Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
PANNELL -CLAY_345_2					FWD	
Mon 05/01/2017	to	Fri 05/05/2017			(Import)	
0630	Continuous	1530			WEST CENTRAL	1300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
SCH-NYISO-HQ_LIMIT_800						REV
Mon 05/01/2017	to	Wed 05/10/2017				(Export)
2200	Continuous	0300			SCH - HQ - NY	800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
MARION -FARRAGUT_345_C3403					FWD	REV
Thu 05/04/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/03/2017</u>	(Import) (Export)
0001	Continuous	2359			SCH - PJ - NY	2050 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2050 MW
						1300 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017			(Import)	
0730	Daily(No Weekends)	0800			OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
OSWEGO -ELBRIDGE_345_17					FWD	
Thu 05/04/2017	to	Thu 05/04/2017			(Import)	
0730	Daily(No Weekends)	1700			OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017			(Import)	
1630	Daily(No Weekends)	1700			OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid			ARR: 75		Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90				FWD	
Sat 05/06/2017	to	Wed 05/10/2017		(Import)	
0001	Continuous	2130	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW	
			TTC with All Lines In Service	5100 MW	
W49TH_ST_345KV_6				FWD	
Sat 05/06/2017	to	Sat 05/06/2017	EXTENDED by CONED 04/25/2017	(Import)	
0230	Continuous	0300	SCH - PJM_HTP	320 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	340 MW	
			TTC with All Lines In Service	660 MW	
SPRNBK_-W49TH_ST_345_M51				FWD	
Sat 05/06/2017	to	Tue 05/16/2017	CANCELLED by ConEd 04/21/2017	(Import)	
0700	Continuous	0300	SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
BROWNFLS-TAYLORVL_115_3				FWD	REV
Mon 05/08/2017	to	Fri 05/12/2017		(Import)	(Export)
0600	Continuous	1900	SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
ROSETON_-ROCKTVRN_345_311				FWD	
Mon 05/08/2017	to	Fri 05/26/2017		(Import)	
0800	Continuous	1600	UPNY CONED	4400 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	700 MW	
			TTC with All Lines In Service	5100 MW	
ROCHESTR-PANNELL_345_RP2				FWD	
Mon 05/08/2017	to	Wed 05/10/2017		(Import)	
1000	Continuous	1700	DYSINGER EAST	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
LAFAYTTE-CLRKSCRN_345_4-46				FWD	
Tue 05/09/2017	to	Tue 05/09/2017		(Import)	
0700	Daily(No Weekends)	1700	CENTRAL EAST - VC	2650 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST_345_F39						FWD	
Thu 05/11/2017	to	Sat 05/13/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2017</u>	(Import)	
2100	Continuous	0200				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
WOOD_ST_-PLSNTVLE_345_Y87						FWD	
Thu 05/11/2017	to	Sat 05/13/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/13/2017</u>	(Import)	
2100	Continuous	0200				UPNY CONED	4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
SCH-NYISO-HQ_LIMIT_900							REV
Thu 05/11/2017	to	Sun 05/14/2017				(Export)	
2200	Continuous	0300				SCH - HQ - NY	900 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1000 MW
BECK_-PACKARD_230_BP76						FWD	REV
Sat 05/13/2017	to	Sun 05/14/2017				(Import)	(Export)
0500	Continuous	1700				SCH - OH - NY	900 MW 1150 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	850 MW 450 MW
						TTC with All Lines In Service	1750 MW 1600 MW
DENNISON-ROSEMNTB_115_2/22						FWD	REV
Mon 05/15/2017	to	Wed 05/17/2017				(Import)	(Export)
0600	Continuous	1900				SCH - HQ_CEDARS	95 MW 40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80						FWD	
Mon 05/15/2017	to	Wed 05/17/2017				(Import)	
0600	Continuous	1900				SCH - HQ_CEDARS	80 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	110 MW
						TTC with All Lines In Service	190 MW
BROWNFLS-TAYLORVL_115_3						FWD	REV
Mon 05/15/2017	to	Fri 05/19/2017				(Import)	(Export)
0600	Continuous	1900				SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW

ARR: 38

ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -GILBOA 345_GF5-35

Mon 05/15/2017 to Fri 05/19/2017
0630 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 04/13/2017

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

STONYRDG-HILLSIDE 230_72

Mon 05/15/2017 to Mon 05/15/2017
0800 Continuous 1700

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Mon 05/15/2017 to Fri 05/19/2017
0900 Continuous 1430

Work scheduled by: NYSEG

UPDATED by NY 04/06/2017

FWD
(Import)
CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

FRASER 345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S

Mon 05/15/2017 to Fri 05/19/2017
0900 1430

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2700 MW**
Impacts Total Transfer Capability 275 MW
TTC with All Lines In Service 2975 MW

RAMAPO -LADENTWN 345_W72

Tue 05/16/2017 to Tue 05/16/2017
0001 Continuous 2330

Work scheduled by: ORU

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

CHATGUAY-MASSENA 765_7040

Wed 05/17/2017 to Thu 05/18/2017
1800 Continuous 0600

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA 765_7040

Wed 05/17/2017 to Thu 05/18/2017
1800 Continuous 0600

Work scheduled by: HQ

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBRK__345_W65

Fri 05/19/2017 to Fri 05/19/2017
 0001 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS4

Fri 05/19/2017 to Fri 05/19/2017
 2030 Continuous 2100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT_345_45

Sat 05/20/2017 to Sun 05/21/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Sat 05/20/2017 to Sun 05/21/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sun 05/21/2017 to Sun 05/21/2017
0001 Continuous 2130

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
2100 Continuous 2130

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
2100 Continuous 2130

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MARCY__765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/22/2017 to Fri 05/26/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

FWD REV
(Import) (Export)
SCH - HQ_CEDARS **70 MW 40 MW**
Impacts Total Transfer Capability 120 MW 0 MW
TTC with All Lines In Service 190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					FWD		
Tue 05/23/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>	(Import)	
0600	Continuous	2100				MOSES SOUTH 2850 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1					REV		
Tue 05/23/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>	(Export)	
0600	Continuous	2100				SCH - HQ - NY 500 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
MARCY__-N.SCTLND_345_18					FWD		
Sat 05/27/2017	to	Sat 05/27/2017				(Import)	
0500	Continuous	1530				CENTRAL EAST - VC 2090 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	885 MW	
					TTC with All Lines In Service	2975 MW	
						ARR: 19	
SCH-HQ-NYISO_LIMIT_1150					FWD		
Sat 05/27/2017	to	Sat 05/27/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>	(Import)	
0500	Continuous	1530				SCH - HQ - NY 1150 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW	
					TTC with All Lines In Service	1500 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD		
Sat 05/27/2017	to	Mon 06/05/2017				(Import)	
1600	Continuous	0659				CENTRAL EAST - VC 2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
BROWNFLS-TAYLORVL_115_4					FWD	REV	
Tue 05/30/2017	to	Fri 06/02/2017				(Import)	(Export)
0600	Continuous	1900				SCH - HQ_CEDARS 70 MW	40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
							ARR: 38
BROWNFLS-TAYLORVL_115_4					FWD	REV	
Mon 06/05/2017	to	Fri 06/09/2017				(Import)	(Export)
0600	Continuous	1900				SCH - HQ_CEDARS 70 MW	40 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
							ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC -FRASER 345_EF24-40					FWD	
Mon 06/05/2017	to	Sat 06/10/2017			(Import)	
0700	Continuous	1659		CENTRAL EAST - VC	2500 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72					FWD	
Mon 06/05/2017	to	Mon 06/05/2017			(Import)	
0800	Continuous	1000		DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
LINDEN -GOETHALS_230_A2253					FWD	REV
Fri 06/09/2017	to	Sun 06/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/04/2017</u>	(Import) (Export)
0200	Continuous	2300				
Work scheduled by: PJM					SCH - PJ - NY	2050 MW 1300 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2050 MW 1300 MW
STONYRDG-HILLSIDE_230_72					FWD	
Fri 06/09/2017	to	Fri 06/09/2017			(Import)	
1500	Continuous	1700		DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
Sat 06/10/2017	to	Sat 08/05/2017			(Import)	
1700	Continuous	0459		CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4					FWD	REV
Mon 06/12/2017	to	Fri 06/16/2017			(Import) (Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
						ARR: 38
BROWNFLS-TAYLORVL_115_4					FWD	REV
Mon 06/19/2017	to	Fri 06/23/2017			(Import) (Export)	
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW 40 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
						ARR: 38

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_3						
Mon 06/26/2017	to	Fri 06/30/2017				
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Wed 07/05/2017	to	Fri 07/07/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/02/2017</u>	
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 07/24/2017	to	Fri 07/28/2017				
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW 40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
MARCY___-N.SCTLND_345_18						
Sat 08/05/2017	to	Sat 08/05/2017				
0500	Continuous	1530			CENTRAL EAST - VC	2090 MW
Work scheduled by: NYPA				ARR: 19	Impacts Total Transfer Capability	885 MW
					TTC with All Lines In Service	2975 MW
MARCY___765_345_AT2						
Sat 08/05/2017	to	Sat 08/05/2017				
0500	Continuous	1530			MOSES SOUTH	1700 MW
Work scheduled by: NYPA				ARR: 19	Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
 1600 Continuous 0659
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MARCY_765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON_345_303

Mon 09/11/2017 to Fri 09/29/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SPRNBK_-DUNWODIE_345_W75

Fri 09/15/2017 to Sun 09/17/2017
 2200 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS3			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
GILBOA__-N.SCTLND_345_GNS-1			FWD	
Mon 09/18/2017	to	Fri 10/06/2017	(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	455 MW
			TTC with All Lines In Service	2975 MW
NIAGARA__345_230_AT4			FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW 1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 300 MW
			TTC with All Lines In Service	1750 MW 1600 MW
MOSES__-ADIRNDCK_230_MAL			FWD	
Mon 09/18/2017	to	Sat 09/23/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MAL			FWD	
Mon 09/25/2017	to	Sat 09/30/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
NIAGARA_-ROCHESTR_345_NR2			FWD	
Mon 10/02/2017	to	Fri 10/06/2017	(Import)	
0700	Continuous	1530	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
FRASER__-COOPERS__345_33			FWD	
Mon 10/02/2017	to	Fri 10/13/2017	(Import)	
0700	Continuous	1900	CENTRAL EAST - VC	2395 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	580 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
HOMR_NYW-PIERC_NY_345_48			FWD
Mon 10/02/2017 to Tue 10/17/2017	CANCELLED	by NYSEG	REV
0800 Continuous 1600		04/25/2017	(Import) (Export)
Work scheduled by: NYSEG			SCH - PJ - NY
			2050 MW 1300 MW
			Impacts Total Transfer Capability 0 MW 0 MW
			TTC with All Lines In Service 2050 MW 1300 MW
<hr/>			
WETHSRFD-MEYER_230_85/87			FWD
Mon 10/09/2017 to Fri 10/20/2017			(Import)
0700 Continuous 1400			DYSINGER EAST
Work scheduled by: NYSEG			2850 MW
			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
ILCTLIMIT_MARCY_SO_COMP_I/S			FWD
Fri 10/13/2017 to Mon 11/06/2017			(Import)
1900 Continuous 0559			CENTRAL EAST - VC
Work scheduled by: NYISO			2740 MW
			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
CHATGUAY-MASSENA_765_7040			FWD
Sat 10/14/2017 to Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700 Continuous 1530		03/24/2017	MOSES SOUTH
Work scheduled by: NYPA			1550 MW
			Impacts Total Transfer Capability 1600 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
CHATGUAY-MASSENA_765_7040			FWD
Sat 10/14/2017 to Sat 10/28/2017	UPDATED	by NYISO	REV
0700 Continuous 1530		03/24/2017	(Import) (Export)
Work scheduled by: NYPA			SCH - HQ - NY
			0 MW 0 MW
			Impacts Total Transfer Capability 1500 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<hr/>			
MARCY_765_345_AT1			FWD
Sat 10/14/2017 to Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700 Continuous 1530		03/24/2017	MOSES SOUTH
Work scheduled by: NYPA			1750 MW
			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
		ARR: 19	
<hr/>			
MARCY_765_345_AT2			FWD
Sat 10/14/2017 to Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700 Continuous 1530		03/24/2017	MOSES SOUTH
Work scheduled by: NYPA			1700 MW
			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
		ARR: 19	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA -MARCY 765_MSU1				FWD		
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)		
0700	Continuous	1530		CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	710 MW	
				TTC with All Lines In Service	2975 MW	
MASSENA -MARCY 765_MSU1				FWD		
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)		
0700	Continuous	1530		MOSES SOUTH	500 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW	
				TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1				FWD	REV	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)	(Export)	
0700	Continuous	1530		SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW	0 MW
				TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040				FWD		
Sat 10/14/2017	to	Sat 10/28/2017		(Import)		
0700		1530		MOSES SOUTH	500 MW	
Work scheduled by:				Impacts Total Transfer Capability	2650 MW	
				TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S				FWD		
Sat 10/14/2017	to	Sat 10/28/2017		(Import)		
0700		1530		CENTRAL EAST - VC	2080 MW	
Work scheduled by:				Impacts Total Transfer Capability	895 MW	
				TTC with All Lines In Service	2975 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2				FWD	REV	
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	(Export)	
0700		1530		SCH - HQ - NY	850 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW	1000 MW
				TTC with All Lines In Service	1500 MW	1000 MW
LEEDS -HURLYAVE 345_301				FWD		
Mon 10/16/2017	to	Fri 11/03/2017		(Import)		
0800	Continuous	1600		UPNY CONED	4100 MW	
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW	
				TTC with All Lines In Service	5100 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 10/30/2017 to Fri 11/03/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS__345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANX_345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD

(Import)

CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT__345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500

Work scheduled by: PJM

FWD

(Import) (Export)

SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
1700 Continuous 0000

Work scheduled by: NYISO

FWD

(Import)

CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,April 25, 2017 to Thursday ,October 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017
 0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW