

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Outage ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)	
RAMAPO__345_345_PAR3500	Fri 06/24/2016	Fri 09/15/2017	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	SCH - PJ - NY	2200 MW	1450 MW	
1940	Continuous	2359				Impacts Total Transfer Capability	100 MW	0 MW	
Work scheduled by: ConEd							TTC with All Lines In Service	2300 MW	1450 MW
PLSNTVLE-DUNWODIE_345_W89	Sun 10/30/2016	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>	UPNY CONED	4000 MW		
0728	Continuous	1600				Impacts Total Transfer Capability	1100 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	5100 MW	
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 07/15/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>01/27/2017</u>	SCH - PJM_HTP	0 MW		
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	660 MW	
E13THSTA-FARRAGUT_345_46	Tue 12/20/2016	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M55	Tue 12/20/2016	Sat 05/06/2017	<u>EXTENDED</u>	<u>by CONED</u>	<u>04/25/2017</u>	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0300				Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd							TTC with All Lines In Service	4600 MW	
HUDSONP_-FARRAGUT_345_B3402	Tue 03/21/2017	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>	SCH - PJ - NY	2300 MW	1450 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	0 MW	0 MW	
Work scheduled by: ConEd							TTC with All Lines In Service	2300 MW	1450 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403	Tue 03/21/2017	Wed 05/03/2017				SCH - PJ - NY	2050 MW	1450 MW	
0001		2359				Impacts Total Transfer Capability	250 MW	0 MW	
Work scheduled by:							TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
MARION__-FARRAGUT_345_C3403							
Tue 03/21/2017	to	Wed 05/03/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/03/2017</u>		
0001	Continuous	2359					
Work scheduled by: ConEd						SCH - PJ - NY	2300 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2300 MW
<hr/>							
BERKSHIR-NORTHFLD_345_312							
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0800	Continuous	1300					
Work scheduled by: ISONE						SCH - NE - NY	1400 MW
						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
<hr/>							
BERKSHIR-NORTHFLD_345_312							
Fri 03/24/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0800	Continuous	1300					
Work scheduled by: ISONE						SCH - NPX_1385	100 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<hr/>							
DUNWODIE_345KV_3							
Fri 04/07/2017	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	1600					
Work scheduled by: ConEd						SPR/DUN-SOUTH	3800 MW
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
DUNWODIE_345KV_4							
Fri 04/07/2017	to	Tue 05/02/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>04/25/2017</u>		
0001	Continuous	1600					
Work scheduled by: ConEd						SPR/DUN-SOUTH	3800 MW
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<hr/>							
SCH-NE-NYISO_LIMIT_700							
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0001	Continuous	0959					
Work scheduled by: ISONE						SCH - NE - NY	900 MW
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1400 MW
<hr/>							
SCH-NYISO-NE_LIMIT_800							
Fri 04/14/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>		
0001	Continuous	0959					
Work scheduled by: ISONE						SCH - NE - NY	1000 MW
						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47					FWD	REV
					(Import)	(Export)
Fri 04/14/2017	to	Mon 04/24/2017	RETURNED	by PJM	04/24/2017	
1600	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	2300 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2300 MW
						1450 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
					(Import)	(Export)
Mon 04/17/2017	to	Sat 04/22/2017				
0500	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
						330 MW
DUNWODIE-MOTTHAVN_345_71					FWD	
					(Import)	
Mon 04/17/2017	to	Thu 05/18/2017	EXT FORCE	by CE	04/21/2017	
2120	Continuous	2359				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
ILCTLIMIT_MARCY_SO_COMP_I/S					FWD	
					(Import)	
Fri 04/21/2017	to	Mon 05/01/2017				
1400	Continuous	0400				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
BERKSHIR-ALPS_____345_393					FWD	REV
					(Import)	(Export)
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE	04/20/2017	
1000	Daily	1300				
Work scheduled by: NGrid					SCH - NE - NY	1300 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
						300 MW
						1600 MW
BERKSHIR-ALPS_____345_393					FWD	REV
					(Import)	(Export)
Sat 04/22/2017	to	Sat 04/22/2017	UPDATED	by ISONE	04/20/2017	
1000	Daily	1300				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
						200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
					(Import)	(Export)
Sat 04/22/2017	to	Sat 04/22/2017				
1000		1300				
Work scheduled by:					SCH - NE - NY	1300 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
						300 MW
						1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600				FWD	
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
1000	Daily	1300			
Work scheduled by: NGrid				SCH - NE - NY	800 MW
				Impacts Total Transfer Capability	600 MW
				TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_400				REV	
Sat 04/22/2017	to	Sat 04/22/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>04/20/2017</u>
1000	Daily	1300			
Work scheduled by: NGrid				SCH - NE - NY	600 MW
				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1600 MW
SCH-NYISO-HQ_LIMIT_900				REV	
Sat 04/22/2017	to	Sun 04/30/2017			
2200	Continuous	0600			
Work scheduled by: HQ				SCH - HQ - NY	900 MW
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	1000 MW
ROSETON_-EFISHKIL_345_RFK305				FWD	
Mon 04/24/2017	to	Fri 05/05/2017			
0600	Continuous	1900			
Work scheduled by: NYPA				UPNY CONED	4100 MW
				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW
CLAY___-EDIC___345_1-16				FWD	
Mon 04/24/2017	to	Tue 04/25/2017			
0630	Continuous	1530			
Work scheduled by: NYPA				OSWEGO EXPORT	4850 MW
				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
STLAWRNC-MOSES___230_L34P				FWD	REV
Mon 04/24/2017	to	Fri 04/28/2017			
0700	Continuous	1530			
Work scheduled by: NYPA				SCH - OH - NY	1750 MW 1900 MW
				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	1750 MW 1900 MW
MOSES___-ADIRNDCK_230_MAI				FWD	
Mon 04/24/2017	to	Sat 04/29/2017			
0700	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	2300 MW
				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BEAR SWP-EASTOVER_230_E205W

Mon 04/24/2017 to Tue 05/30/2017 **UPDATED** by **NE** 04/24/2017
 0700 Continuous 0659
 Work scheduled by: NGrid

SCH - NE - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

ALCOA -DENNISON_115_12

Mon 04/24/2017 to Wed 04/26/2017
 0800 Continuous 0659
 Work scheduled by: NGrid

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	100 MW
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

ARR: 38

ALCOA -DENNISON_115_12 & ALCOA -NOGDNRBG_115_13

Wed 04/26/2017 to Wed 04/26/2017
 0700 1800
 Work scheduled by:

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	60 MW
Impacts Total Transfer Capability	99 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

ARR: 38

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B

Wed 04/26/2017 to Wed 04/26/2017 **EXTENDED** by **NGRID** 04/27/2017
 0700 Daily(No Weekends) 1800
 Work scheduled by: NGrid

MOSES SOUTH
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD
	(Import)
MOSES SOUTH	3100 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	3150 MW

ILCTLIMIT_115KV_ALCOA_R8105_TIE_B

Wed 04/26/2017 to Wed 04/26/2017 **EXTENDED** by **NGRID** 04/27/2017
 0700 Daily(No Weekends) 1800
 Work scheduled by: NGrid

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	60 MW
Impacts Total Transfer Capability	99 MW	40 MW
TTC with All Lines In Service	199 MW	100 MW

ALCOA -DENNISON_115_12

Wed 04/26/2017 to Fri 04/28/2017 **EXTENDED** by **NGRID** 04/27/2017
 0700 Daily(No Weekends) 1800
 Work scheduled by: NGrid

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	100 MW	100 MW
Impacts Total Transfer Capability	99 MW	0 MW
TTC with All Lines In Service	199 MW	100 MW

ARR: 38

SCH-NYISO-HQ_CEDARS_LIMIT_0

Thu 04/27/2017 to Thu 04/27/2017
 0800 Continuous 1500
 Work scheduled by: HQ

SCH - HQ_CEDARS
 Impacts Total Transfer Capability
 TTC with All Lines In Service

	REV
	(Export)
SCH - HQ_CEDARS	0 MW
Impacts Total Transfer Capability	100 MW
TTC with All Lines In Service	100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCRIBA -VOLNEY 345_21					FWD
Thu 04/27/2017	to	Thu 04/27/2017			(Import)
0800	Daily(No Weekends)	1630			OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 0 MW
					TTC with All Lines In Service 5250 MW
NIAGARA -ROCHESTR 345_NR2					FWD
Fri 04/28/2017	to	Fri 04/28/2017	<u>UPDATED</u>	<u>by PA</u>	<u>03/29/2017</u>
0500	Continuous	1700			(Import)
Work scheduled by: NYPA					DYSINGER EAST 1700 MW
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
SCH-IMO-NYISO_LIMIT_1000					FWD
Fri 04/28/2017	to	Fri 04/28/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>04/26/2017</u>
1100	Continuous	1300			(Import)
Work scheduled by: PJM					SCH - OH - NY 1300 MW
					Impacts Total Transfer Capability 450 MW
					TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100					REV
Fri 04/28/2017	to	Fri 04/28/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>04/26/2017</u>
1100	Continuous	1300			(Export)
Work scheduled by: PJM					SCH - PJ - NY 400 MW
					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 1450 MW
CLAY -EDIC 345_2-15					FWD
Sat 04/29/2017	to	Sat 04/29/2017			(Import)
0630	Daily	1730			OSWEGO EXPORT 4850 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
NEPTUNE -DUFFYAVE 345_NEPTUNE					FWD
Mon 05/01/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>02/14/2017</u>
0400	Continuous	1800			(Import)
Work scheduled by: LI					SCH - PJM_NEPTUNE 0 MW
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE 345_501					FWD
Mon 05/01/2017	to	Tue 05/16/2017	<u>UPDATED</u>	<u>by LI</u>	<u>02/14/2017</u>
0400	Continuous	1800			(Import)
Work scheduled by: LI					SCH - PJM_NEPTUNE 0 MW
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__-N.SCTLND_345_18					FWD	
Mon 05/01/2017	to	Fri 05/05/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/10/2017</u>	(Import)
0500	Continuous	1700				CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA					ARR: 19	Impacts Total Transfer Capability 885 MW TTC with All Lines In Service 2975 MW
BROWNFLS-TAYLORVL_115_3					FWD	
Mon 05/01/2017	to	Fri 05/05/2017				(Import) (Export)
0600	Continuous	1900				SCH - HQ_CEDARS 70 MW 40 MW
Work scheduled by: NGrid					ARR: 38	Impacts Total Transfer Capability 120 MW 0 MW TTC with All Lines In Service 190 MW 40 MW
PANNELL_-CLAY____345_2					FWD	
Mon 05/01/2017	to	Fri 05/05/2017				(Import)
0630	Continuous	1530				WEST CENTRAL 1300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 950 MW TTC with All Lines In Service 2250 MW
SCH-NYISO-HQ_LIMIT_800					REV	
Mon 05/01/2017	to	Wed 05/10/2017				(Export)
2200	Continuous	0300				SCH - HQ - NY 800 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 200 MW TTC with All Lines In Service 1000 MW
MARION__-FARRAGUT_345_C3403					FWD	
Thu 05/04/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by CE</u>	<u>04/03/2017</u>	(Import) (Export)
0001	Continuous	2359				SCH - PJ - NY 2050 MW 1300 MW
Work scheduled by: PJM						Impacts Total Transfer Capability 250 MW 150 MW TTC with All Lines In Service 2300 MW 1450 MW
ELBRIDGE-LAFAYTTE_345_17-LE					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	0800				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					ARR: 75	Impacts Total Transfer Capability 0 MW TTC with All Lines In Service 5250 MW
OSWEGO__-ELBRIDGE_345_17					FWD	
Thu 05/04/2017	to	Thu 05/04/2017				(Import)
0730	Daily(No Weekends)	1700				OSWEGO EXPORT 5250 MW
Work scheduled by: NGrid					ARR: 75	Impacts Total Transfer Capability 0 MW TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 05/04/2017 to Thu 05/04/2017
 1630 Daily(No Weekends) 1700
 Work scheduled by: NGrid

ARR: 75

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

ILCTLIMT_MARCY_SO_COMP_I/S

Fri 05/05/2017 to Sat 05/27/2017
 1700 Continuous 0459
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLE-DUNWODIE_345_W90

Sat 05/06/2017 to Wed 05/10/2017
 0001 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

W49TH_ST_345KV_6

Sat 05/06/2017 to Sat 05/06/2017
 0230 Continuous 0300
 Work scheduled by: ConEd

EXTENDED by CONED 04/25/2017

FWD
 (Import)
 SCH - PJM_HTP **320 MW**
 Impacts Total Transfer Capability 340 MW
 TTC with All Lines In Service 660 MW

BROWNFLS-TAYLORVL_115_3

Mon 05/08/2017 to Fri 05/12/2017
 0600 Continuous 1900
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

ROSETON_-ROCKTVRN_345_311

Mon 05/08/2017 to Fri 05/26/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

ROCHESTR-PANNELL_345_RP2

Mon 05/08/2017 to Wed 05/10/2017
 1000 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>									
EFISHKIL-WOOD_ST__345_F39									FWD
Thu 05/11/2017	to	Sat 05/13/2017	UPDATED	by CE	04/13/2017				(Import)
2100	Continuous	0200				UPNY CONED			4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			1100 MW
						TTC with All Lines In Service			5100 MW
<hr/>									
WOOD_ST_-PLSNTVLE_345_Y87									FWD
Thu 05/11/2017	to	Sat 05/13/2017	UPDATED	by CE	04/13/2017				(Import)
2100	Continuous	0200				UPNY CONED			4000 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability			1100 MW
						TTC with All Lines In Service			5100 MW
<hr/>									
SCH-NYISO-HQ_LIMIT_900									REV
Thu 05/11/2017	to	Sun 05/14/2017							(Export)
2200	Continuous	0300				SCH - HQ - NY			900 MW
Work scheduled by: HQ						Impacts Total Transfer Capability			100 MW
						TTC with All Lines In Service			1000 MW
<hr/>									
DENNISON-ROSEMNTB_115_2/22									FWD
Mon 05/15/2017	to	Wed 05/17/2017							(Import)
0600	Continuous	1900				SCH - HQ_CEDARS			95 MW
Work scheduled by: HQ					ARR: 38	Impacts Total Transfer Capability			95 MW
						TTC with All Lines In Service			190 MW
<hr/>									REV
SCH-HQ_CEDARS-NYISO_LIMIT_80									(Export)
Mon 05/15/2017	to	Wed 05/17/2017							FWD
0600	Continuous	1900				SCH - HQ_CEDARS			80 MW
Work scheduled by: HQ						Impacts Total Transfer Capability			110 MW
						TTC with All Lines In Service			190 MW
<hr/>									
BROWNFLS-TAYLORVL_115_3									FWD
Mon 05/15/2017	to	Fri 05/19/2017							(Import)
0600	Continuous	1900				SCH - HQ_CEDARS			70 MW
Work scheduled by: NGrid					ARR: 38	Impacts Total Transfer Capability			120 MW
						TTC with All Lines In Service			190 MW
<hr/>									REV
FRASER_-GILBOA__345_GF5-35									(Export)
Mon 05/15/2017	to	Fri 05/19/2017	UPDATED	by NYPA	04/13/2017				FWD
0630	Continuous	1700				CENTRAL EAST - VC			2650 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability			325 MW
						TTC with All Lines In Service			2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STONYRDG-HILLSIDE_230_72					FWD		
Mon 05/15/2017	to	Mon 05/15/2017			(Import)		
0800	Continuous	1700		DYSINGER EAST	2850 MW		
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
FRASER_345_FRASER SVC					FWD		
Mon 05/15/2017	to	Fri 05/19/2017	<u>UPDATED</u>	<u>by NY</u>	<u>04/06/2017</u>	(Import)	
0900	Continuous	1430				CENTRAL EAST - VC	
Work scheduled by: NYSEG					2935 MW		
					Impacts Total Transfer Capability	40 MW	
					TTC with All Lines In Service	2975 MW	
FRASER_345_FRASER SVC & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD		
Mon 05/15/2017	to	Fri 05/19/2017				(Import)	
0900		1430				CENTRAL EAST - VC	
Work scheduled by:					2700 MW		
					Impacts Total Transfer Capability	275 MW	
					TTC with All Lines In Service	2975 MW	
RAMAPO_-LADENTWN_345_W72					FWD		
Tue 05/16/2017	to	Tue 05/16/2017				(Import)	
0001	Continuous	2330				UPNY CONED	
Work scheduled by: ORU					4400 MW		
					Impacts Total Transfer Capability	700 MW	
					TTC with All Lines In Service	5100 MW	
CHATGUAY-MASSENA_765_7040					FWD		
Wed 05/17/2017	to	Thu 05/18/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/26/2017</u>	(Import)	
1800	Continuous	0600				MOSES SOUTH	
Work scheduled by: HQ					1550 MW		
					Impacts Total Transfer Capability	1600 MW	
					TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040					FWD	REV	
Wed 05/17/2017	to	Thu 05/18/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/26/2017</u>	(Import)	(Export)
1800	Continuous	0600				SCH - HQ - NY	0 MW
Work scheduled by: HQ					0 MW	0 MW	
					Impacts Total Transfer Capability	1500 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2					FWD		
Wed 05/17/2017	to	Thu 05/18/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/26/2017</u>	(Import)	
1800	Continuous	0600				MOSES SOUTH	2850 MW
Work scheduled by: HQ					300 MW		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Day	Time	Day	Time	Day	Time	Impact	TTC	Notes
CHAT_DC_GC2												
Wed 05/17/2017	to	Thu 05/18/2017	1800	Continuous	0600					SCH - HQ - NY	500 MW	REV (Export)
Work scheduled by: HQ										Impacts Total Transfer Capability	500 MW	
										TTC with All Lines In Service	1000 MW	
MILLWOOD-EASTVIEW_345_W82												
Fri 05/19/2017	to	Fri 05/19/2017	0001	Continuous	0030					UPNY CONED	4350 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	750 MW	
										TTC with All Lines In Service	5100 MW	
SPRNBK__345KV_RNS4												
Fri 05/19/2017	to	Fri 05/19/2017	0001	Continuous	0030					SPR/DUN-SOUTH	3200 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	1400 MW	
										TTC with All Lines In Service	4600 MW	
EASTVIEW-SPRNBK__345_W65												
Fri 05/19/2017	to	Fri 05/19/2017	0001	Continuous	2100					UPNY CONED	4350 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	750 MW	
										TTC with All Lines In Service	5100 MW	
MILLWOOD-EASTVIEW_345_W82												
Fri 05/19/2017	to	Fri 05/19/2017	2030	Continuous	2100					UPNY CONED	4350 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	750 MW	
										TTC with All Lines In Service	5100 MW	
SPRNBK__345KV_RNS4												
Fri 05/19/2017	to	Fri 05/19/2017	2030	Continuous	2100					SPR/DUN-SOUTH	3200 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	1400 MW	
										TTC with All Lines In Service	4600 MW	
E13THSTA-FARRAGUT_345_45												
Sat 05/20/2017	to	Sun 05/21/2017	0001	Continuous	2359					SPR/DUN-SOUTH	3800 MW	FWD (Import)
Work scheduled by: ConEd										Impacts Total Transfer Capability	800 MW	
										TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Sat 05/20/2017 to Sun 05/21/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MILLWOOD-EASTVIEW_345_W99

Sun 05/21/2017 to Sun 05/21/2017
 0001 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBK__345_W64

Sun 05/21/2017 to Sun 05/21/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

Sun 05/21/2017 to Sun 05/21/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

MARCY____765_345_AT1

Mon 05/22/2017 to Fri 05/26/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
BROWNFLS-TAYLORVL_115_3							
Mon 05/22/2017	to	Fri 05/26/2017					
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			ARR: 38		Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW
CHAT_DC_GC1						FWD	
Tue 05/23/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>	(Import)	
0600	Continuous	2100			MOSES SOUTH	2850 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1							REV
Tue 05/23/2017	to	Wed 05/31/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>		(Export)
0600	Continuous	2100			SCH - HQ - NY		500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability		500 MW
					TTC with All Lines In Service		1000 MW
MARCY -N.SCTLND_345_18						FWD	
Sat 05/27/2017	to	Sat 05/27/2017				(Import)	
0500	Continuous	1530			CENTRAL EAST - VC	2090 MW	
Work scheduled by: NYPA			ARR: 19		Impacts Total Transfer Capability	885 MW	
					TTC with All Lines In Service	2975 MW	
SCH-HQ-NYISO_LIMIT_1150						FWD	
Sat 05/27/2017	to	Sat 05/27/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>04/13/2017</u>	(Import)	
0500	Continuous	1530			SCH - HQ - NY	1150 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW	
					TTC with All Lines In Service	1500 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD	
Sat 05/27/2017	to	Mon 06/05/2017				(Import)	
1600	Continuous	0659			CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
BROWNFLS-TAYLORVL_115_4						FWD	REV
Tue 05/30/2017	to	Fri 06/02/2017				(Import)	(Export)
0600	Continuous	1900			SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid			ARR: 38		Impacts Total Transfer Capability	120 MW	0 MW
					TTC with All Lines In Service	190 MW	40 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4

Mon 06/05/2017 to Fri 06/09/2017
0600 Continuous 1900

Work scheduled by: NGrid

ARR: 38

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	70 MW	40 MW
Impacts Total Transfer Capability	120 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

EDIC -FRASER 345_EF24-40

Mon 06/05/2017 to Sat 06/10/2017
0700 Continuous 1659

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

STONYRDG-HILLSIDE_230_72

Mon 06/05/2017 to Mon 06/05/2017
0800 Continuous 1000

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

BECK -PACKARD 230_BP76

Tue 06/06/2017 to Wed 06/07/2017
0600 Continuous 1800

Work scheduled by: NGrid

UPDATED by NGRID 04/27/2017

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	1150 MW
Impacts Total Transfer Capability	850 MW	750 MW
TTC with All Lines In Service	1750 MW	1900 MW

LINDEN -GOETHALS_230_A2253

Fri 06/09/2017 to Sun 06/11/2017
0200 Continuous 2300

Work scheduled by: PJM

UPDATED by CE 04/04/2017

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2050 MW	1300 MW
Impacts Total Transfer Capability	250 MW	150 MW
TTC with All Lines In Service	2300 MW	1450 MW

STONYRDG-HILLSIDE_230_72

Fri 06/09/2017 to Fri 06/09/2017
1500 Continuous 1700

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 06/10/2017 to Sat 08/05/2017
1700 Continuous 0459

Work scheduled by: NYISO

	FWD
	(Import)
CENTRAL EAST - VC	2740 MW
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_4						
Mon 06/12/2017	to	Fri 06/16/2017				
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 06/19/2017	to	Fri 06/23/2017				
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 06/26/2017	to	Fri 06/30/2017				
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Wed 07/05/2017	to	Fri 07/07/2017	UPDATED	by NGRID	03/02/2017	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 07/10/2017	to	Fri 07/14/2017	UPDATED	by NGRID	03/02/2017	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_3						
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED	by NGRID	03/02/2017	
0600	Continuous	1900				
Work scheduled by: NGrid				ARR: 38	SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4						
Mon 07/24/2017	to	Fri 07/28/2017				
0600	Continuous	1900		SCH - HQ_CEDARS	70 MW	40 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON___345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Fri 09/15/2017 to Sun 09/17/2017
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBRK_-DUNWODIE_345_W75			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
SPRNBRK__345KV_RNS3			FWD	
Fri 09/15/2017	to	Sun 09/17/2017	(Import)	
2200	Continuous	0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
GILBOA_-N.SCTLND_345_GNS-1			FWD	
Mon 09/18/2017	to	Fri 10/06/2017	(Import)	
0630	Continuous	1700	CENTRAL EAST - VC	2520 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	455 MW
			TTC with All Lines In Service	2975 MW
NIAGARA__345_230_AT4			FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017	(Import)	(Export)
0700	Continuous	1530	SCH - OH - NY	1750 MW 1300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW 600 MW
			TTC with All Lines In Service	1750 MW 1900 MW
MOSES_-ADIRNDCK_230_MAL			FWD	
Mon 09/18/2017	to	Sat 09/23/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MAL			FWD	
Mon 09/25/2017	to	Sat 09/30/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASER_-COOPERS_345_33

Mon 10/02/2017 to Fri 10/13/2017
 0700 Continuous 1900
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2395 MW**
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

HOMR_NYW-PIERC_NY_345_48

Mon 10/02/2017 to Tue 10/17/2017 **CANCELLED by NYSEG 04/25/2017**
 0800 Continuous 1600
 Work scheduled by: NYSEG

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2050 MW 1300 MW**
 Impacts Total Transfer Capability 250 MW 150 MW
 TTC with All Lines In Service 2300 MW 1450 MW

WETHSRFD-MEYER_230_85/87

Mon 10/09/2017 to Fri 10/20/2017
 0700 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 10/13/2017 to Mon 11/06/2017
 1900 Continuous 0559
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700	Continuous	1530		<u>03/24/2017</u>	1750 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2					FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700	Continuous	1530		<u>03/24/2017</u>	1700 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700	Continuous	1530		<u>03/24/2017</u>	2265 MW
Work scheduled by: NYPA					CENTRAL EAST - VC
					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	(Import)
0700	Continuous	1530		<u>03/24/2017</u>	500 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	(Import) (Export)
0700	Continuous	1530		<u>03/24/2017</u>	475 MW 1000 MW
Work scheduled by: NYPA					SCH - HQ - NY
					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			500 MW
Work scheduled by:					MOSES SOUTH
					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			2080 MW
Work scheduled by:					CENTRAL EAST - VC
					Impacts Total Transfer Capability 895 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
 0700 1530

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MOSES -ADIRNDCK 230_MA2

Mon 10/30/2017 to Fri 11/03/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

FRASANX-COOPERS 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MARCY -FRASANX 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 11/06/2017 to Thu 11/09/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

LINDN_CG-LNDVFT 345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
 1700 Continuous 0000
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,April 27, 2017 to Saturday ,October 27, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW