

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Time	Duration	Frequency	Reason	By	Effective Date	SCH	FWD	REV
RAMAPO___345_345_PAR3500	Fri 06/24/2016	Fri 09/15/2017	1940	Continuous	2359	<u>EXT FORCE</u>	<u>by CONED</u>	<u>03/22/2017</u>	PJ - NY	(Import)	(Export)
										1700 MW	1300 MW
										Impacts Total Transfer Capability	600 MW
										TTC with All Lines In Service	2300 MW
											1450 MW
HUDSONTP-W49TH_ST_345_Y56	Thu 11/24/2016	Sat 09/30/2017	1500	Continuous	2359	<u>UPDATED</u>	<u>by PJM</u>	<u>05/18/2017</u>	PJM_HTP	(Import)	
										0 MW	
										Impacts Total Transfer Capability	660 MW
										TTC with All Lines In Service	660 MW
SCH-HQ-NYISO_LIMIT_1400	Thu 06/08/2017	Fri 12/15/2017	0600	Continuous	1700	<u>UPDATED</u>	<u>by HQ</u>	<u>05/25/2017</u>	HQ - NY	(Import)	
										1400 MW	
										Impacts Total Transfer Capability	100 MW
										TTC with All Lines In Service	1500 MW
SCH-NYISO-HQ_LIMIT_800	Thu 06/08/2017	Fri 12/15/2017	0600	Continuous	1700	<u>UPDATED</u>	<u>by HQ</u>	<u>05/25/2017</u>	HQ - NY		(Export)
											800 MW
										Impacts Total Transfer Capability	200 MW
										TTC with All Lines In Service	1000 MW
CHAT_DC_GC1	Fri 06/09/2017	Wed 06/14/2017	0700	Continuous	2300	<u>EXTENDED</u>	<u>by HQ</u>	<u>06/13/2017</u>	MOSES SOUTH	(Import)	
										2850 MW	
										Impacts Total Transfer Capability	300 MW
										TTC with All Lines In Service	3150 MW
CHAT_DC_GC1	Fri 06/09/2017	Wed 06/14/2017	0700	Continuous	2300	<u>EXTENDED</u>	<u>by HQ</u>	<u>06/13/2017</u>	HQ - NY		(Export)
											500 MW
										Impacts Total Transfer Capability	500 MW
										TTC with All Lines In Service	1000 MW
SCH-IMO-NYISO_LIMIT_1150	Mon 06/12/2017	Tue 06/13/2017	1100	Continuous	1959				OH - NY	(Import)	
										1450 MW	
										Impacts Total Transfer Capability	300 MW
										TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MAINESBG-WATRCURE_345_30						FWD	REV
Mon 06/12/2017	to	Wed 06/14/2017	FORCED	by NY	06/14/2017	(Import)	(Export)
2118	Continuous	2359				2050 MW	1300 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	2300 MW
ILCTLIMIT_MARCY_SO_COMP_I/S						FWD	
Tue 06/13/2017	to	Thu 06/15/2017				(Import)	
0800	Daily	0600				2740 MW	
Work scheduled by: NYSEG						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_4						FWD	REV
Wed 06/14/2017	to	Fri 06/16/2017	UPDATED	by NGRID	06/08/2017	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
CEDARS__-ROSEMNTA_115_1/11						FWD	REV
Wed 06/14/2017	to	Wed 06/21/2017	UPDATED	by HQ	06/16/2017	(Import)	(Export)
0700	Continuous	1700				95 MW	40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
DENNISON-ROSEMNTA_115_1/11						FWD	REV
Wed 06/14/2017	to	Wed 06/21/2017	UPDATED	by HQ	06/16/2017	(Import)	(Export)
0700	Continuous	1700				95 MW	40 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	95 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80						FWD	
Wed 06/14/2017	to	Wed 06/21/2017	UPDATED	by HQ	06/16/2017	(Import)	
0700	Continuous	1700				80 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	110 MW
						TTC with All Lines In Service	190 MW
SCH-NYISO-NE_LIMIT_600							REV
Wed 06/14/2017	to	Wed 06/14/2017	UPDATED	by ISONE	06/12/2017		(Export)
0800	Continuous	1100					800 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Cancelled By	Cancelled Date	Zone	Impact	TTC	FWD	REV
PLSNTVLE-DUNWODIE_345_W90	Thu 06/15/2017	Thu 06/15/2017	CANCELLED	06/14/2017	UPNY CONED	4000 MW	1100 MW		
0001	Continuous	0030			Impacts Total Transfer Capability		5100 MW		
Work scheduled by: ConEd									
EDIC -N.SCTLND_345_14	Thu 06/15/2017	Fri 06/16/2017	CANCELLED	06/14/2017	CENTRAL EAST - VC	2240 MW	735 MW		
0630	Continuous	1630			Impacts Total Transfer Capability		2975 MW		
Work scheduled by: NGrid									
EDIC -N.SCTLND_345_14	Thu 06/15/2017	Fri 06/16/2017			CENTRAL EAST - VC	2240 MW	735 MW		
0630	Continuous	1630			Impacts Total Transfer Capability		2975 MW		
Work scheduled by: NGrid									
N.SCTLND-ALPS_345_2	Thu 06/15/2017	Fri 06/16/2017	CANCELLED	06/14/2017	SCH - NE - NY	750 MW	650 MW	1350 MW	
0630	Continuous	1630			Impacts Total Transfer Capability		1400 MW	1600 MW	
Work scheduled by: NGrid									
N.SCTLND-ALPS_345_2	Thu 06/15/2017	Fri 06/16/2017			SCH - NE - NY	750 MW	650 MW	1350 MW	
0630	Continuous	1630			Impacts Total Transfer Capability		1400 MW	1600 MW	
Work scheduled by: NGrid									
N.SCTLND-ALPS_345_2	Thu 06/15/2017	Fri 06/16/2017			SCH - NPX_1385	100 MW	100 MW	100 MW	
0630	Continuous	1630			Impacts Total Transfer Capability		200 MW	200 MW	
Work scheduled by: NGrid									
N.SCTLND-ALPS_345_2	Thu 06/15/2017	Fri 06/16/2017	CANCELLED	06/14/2017	SCH - NPX_1385	100 MW	100 MW	100 MW	
0630	Continuous	1630			Impacts Total Transfer Capability		200 MW	200 MW	
Work scheduled by: NGrid									

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
N. SCTLND-LEEDS	<u>345_93</u>		FWD
Thu 06/15/2017	to	Fri 06/16/2017	(Import)
0630	Continuous	1630	CENTRAL EAST - VC
Work scheduled by: NGrid			2650 MW
			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
N. SCTLND-LEEDS	<u>345_93</u>		FWD
Thu 06/15/2017	to	Fri 06/16/2017	(Import)
0630	Continuous	1630	CENTRAL EAST - VC
Work scheduled by: NGrid			2650 MW
			Impacts Total Transfer Capability 325 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
SCH-NE-NYISO_LIMIT_400			FWD
Thu 06/15/2017	to	Fri 06/16/2017	(Import)
0630	Continuous	1630	SCH - NE - NY
Work scheduled by: NGrid			600 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 1400 MW
<hr/>			
SCH-NE-NYISO_LIMIT_400			FWD
Thu 06/15/2017	to	Fri 06/16/2017	(Import)
0630	Continuous	1630	SCH - NE - NY
Work scheduled by: NGrid			600 MW
			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 1400 MW
<hr/>			
SCH-NYISO-NE_LIMIT_1000			REV
Thu 06/15/2017	to	Fri 06/16/2017	(Export)
0630	Continuous	1630	SCH - NE - NY
Work scheduled by: NGrid			1200 MW
			Impacts Total Transfer Capability 400 MW
			TTC with All Lines In Service 1600 MW
<hr/>			
SCH-NYISO-NE_LIMIT_800			REV
Thu 06/15/2017	to	Fri 06/16/2017	(Export)
0630	Continuous	1630	SCH - NE - NY
Work scheduled by: NGrid			1000 MW
			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 1600 MW
<hr/>			
ALCOA	<u>-DENNISON_115_12</u>		FWD
Thu 06/15/2017	to	Thu 06/15/2017	(Import) (Export)
0800	Daily(No Weekends)	1400	SCH - HQ_CEDARS
Work scheduled by: NGrid			70 MW
			Impacts Total Transfer Capability 120 MW
			TTC with All Lines In Service 190 MW
			40 MW
			0 MW
			40 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W90				FWD	
Thu 06/15/2017	to	Thu 06/15/2017	CANCELLED by ConEd 06/14/2017	(Import)	
1630	Continuous	1700		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
SCH-IMO-NYISO_LIMIT_800				FWD	
Fri 06/16/2017	to	Fri 06/16/2017		(Import)	
0700	Daily(No Weekends)	1830		SCH - OH - NY	1100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	650 MW
				TTC with All Lines In Service	1750 MW
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 06/16/2017	to	Sat 08/05/2017		(Import)	
1700	Continuous	0459		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
PLSNTVLY-WOOD_ST_345_F30				FWD	
Sat 06/17/2017	to	Sun 06/18/2017	UPDATED by CONED 06/17/2017	(Import)	
0100	Continuous	0700		UPNY CONED	4000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
PLSNTVLY_345KV_RNS5				FWD	
Sat 06/17/2017	to	Sun 06/18/2017	UPDATED by CONED 06/17/2017	(Import)	
0100	Continuous	0700		UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO_500_5018				FWD	REV
Sat 06/17/2017	to	Sat 06/17/2017	CANCELLED by PJM 06/16/2017	(Import)	(Export)
0500	Continuous	2100		SCH - PJ - NY	1900 MW 1000 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	400 MW 450 MW
				TTC with All Lines In Service	2300 MW 1450 MW
HOPATCON-RAMAPO_500_5018				FWD	REV
Sat 06/17/2017	to	Sat 06/17/2017		(Import)	(Export)
0500	Continuous	2100		SCH - PJ - NY	1900 MW 1000 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	400 MW 450 MW
				TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018 Sat 06/17/2017 to Sat 06/17/2017 0500 Continuous 2100 Work scheduled by: ConEd	FWD (Import) TOTAL EAST 6400 MW Impacts Total Transfer Capability 100 MW TTC with All Lines In Service 6500 MW
HOPATCON-RAMAPO___500_5018 Sat 06/17/2017 to Sat 06/17/2017 <u>CANCELLED</u> by PJM <u>06/16/2017</u> 0500 Continuous 2100 Work scheduled by: PJM	FWD (Import) TOTAL EAST 6400 MW Impacts Total Transfer Capability 100 MW TTC with All Lines In Service 6500 MW
HOPATCON-RAMAPO___500_5018 Sat 06/17/2017 to Sat 06/17/2017 0500 Continuous 2100 Work scheduled by: ConEd	FWD (Import) UPNY CONED 4000 MW Impacts Total Transfer Capability 1100 MW TTC with All Lines In Service 5100 MW
HOPATCON-RAMAPO___500_5018 Sat 06/17/2017 to Sat 06/17/2017 <u>CANCELLED</u> by PJM <u>06/16/2017</u> 0500 Continuous 2100 Work scheduled by: PJM	FWD (Import) UPNY CONED 4000 MW Impacts Total Transfer Capability 1100 MW TTC with All Lines In Service 5100 MW
RAMAPO___345_345_PAR4500 Sat 06/17/2017 to Sat 06/17/2017 <u>CANCELLED</u> by PJM <u>06/16/2017</u> 0500 Continuous 2100 Work scheduled by: PJM	FWD REV (Import) (Export) SCH - PJ - NY 1700 MW 1300 MW Impacts Total Transfer Capability 600 MW 150 MW TTC with All Lines In Service 2300 MW 1450 MW
RAMAPO___345_345_PAR4500 Sat 06/17/2017 to Sat 06/17/2017 0500 Continuous 2100 Work scheduled by: ConEd	FWD REV (Import) (Export) SCH - PJ - NY 1700 MW 1300 MW Impacts Total Transfer Capability 600 MW 150 MW TTC with All Lines In Service 2300 MW 1450 MW
RAMAPO___500_345_BK 1500 Sat 06/17/2017 to Sat 06/17/2017 <u>CANCELLED</u> by PJM <u>06/16/2017</u> 0500 Continuous 2100 Work scheduled by: PJM	FWD REV (Import) (Export) SCH - PJ - NY 1900 MW 1000 MW Impacts Total Transfer Capability 400 MW 450 MW TTC with All Lines In Service 2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__500_345_BK 1500	FWD	REV
Sat 06/17/2017 to Sat 06/17/2017	(Import)	(Export)
0500 Continuous 2100	SCH - PJ - NY Impacts Total Transfer Capability TTC with All Lines In Service	1900 MW 1000 MW 400 MW 450 MW 2300 MW 1450 MW
Work scheduled by: ConEd		
RAMAPO__500_345_BK 1500	FWD	
Sat 06/17/2017 to Sat 06/17/2017	(Import)	
0500 Continuous 2100	TOTAL EAST Impacts Total Transfer Capability TTC with All Lines In Service	6400 MW 100 MW 6500 MW
Work scheduled by: ConEd		
RAMAPO__500_345_BK 1500	FWD	
Sat 06/17/2017 to Sat 06/17/2017	(Import)	
0500 Continuous 2100	TOTAL EAST Impacts Total Transfer Capability TTC with All Lines In Service	6400 MW 100 MW 6500 MW
Work scheduled by: PJM		
RAMAPO__500_345_BK 1500	FWD	
Sat 06/17/2017 to Sat 06/17/2017	(Import)	
0500 Continuous 2100	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	4000 MW 1100 MW 5100 MW
Work scheduled by: PJM		
RAMAPO__500_345_BK 1500	FWD	
Sat 06/17/2017 to Sat 06/17/2017	(Import)	
0500 Continuous 2100	UPNY CONED Impacts Total Transfer Capability TTC with All Lines In Service	4000 MW 1100 MW 5100 MW
Work scheduled by: ConEd		
SCH-IMO-NYISO_LIMIT_1200	FWD	
Sat 06/17/2017 to Sat 06/24/2017	(Import)	
0500 Continuous 2330	SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service	1500 MW 250 MW 1750 MW
Work scheduled by: NYPA		
STONYRDG-HILLSIDE_230_72	FWD	
Sat 06/17/2017 to Sat 06/17/2017	(Import)	
1900 Continuous 1930	DYSINGER EAST Impacts Total Transfer Capability TTC with All Lines In Service	2850 MW 300 MW 3150 MW
Work scheduled by: NYSEG		

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1			FWD	
Sun 06/18/2017	to	Sun 06/18/2017	(Import)	
0001	Continuous	0200	MOSES SOUTH	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC1			REV	
Sun 06/18/2017	to	Sun 06/18/2017	(Export)	
0001	Continuous	0200	SCH - HQ - NY	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2			FWD	
Sun 06/18/2017	to	Sun 06/18/2017	(Import)	
0001		0200	MOSES SOUTH	2550 MW
Work scheduled by:			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2			FWD	REV
Sun 06/18/2017	to	Sun 06/18/2017	(Import)	(Export)
0001		0200	SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	130 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2			FWD	
Sun 06/18/2017	to	Sun 06/18/2017	(Import)	
0001	Continuous	0200	MOSES SOUTH	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC2			REV	
Sun 06/18/2017	to	Sun 06/18/2017	(Export)	
0001	Continuous	0200	SCH - HQ - NY	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_700			FWD	
Sun 06/18/2017	to	Sun 06/18/2017	(Import)	
0001	Continuous	0200	SCH - HQ - NY	700 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BROWNFLS-TAYLORVL_115_4						
Mon 06/19/2017	to	Fri 06/23/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/08/2017</u>		
0600	Continuous	1900				
Work scheduled by: NGrid						
					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW
STONYRDG-HILLSIDE_230_72						
Mon 06/19/2017	to	Mon 06/19/2017	<u>EXT FORCE</u>	<u>by NYSEG</u> <u>06/18/2017</u>		
1900	Continuous	1930				
Work scheduled by: NYSEG						
					DYSINGER EAST	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
SCH-NPX_1385-NYISO_LIMIT_25						
Tue 06/20/2017	to	Wed 06/21/2017				
0001	Continuous	2359				
Work scheduled by: LI						
					SCH - NPX_1385	25 MW
					Impacts Total Transfer Capability	175 MW
					TTC with All Lines In Service	200 MW
SCH-NYISO-NPX_1385_LIMIT_25						
Tue 06/20/2017	to	Wed 06/21/2017				
0001	Continuous	2359				
Work scheduled by: LI						
					SCH - NPX_1385	25 MW
					Impacts Total Transfer Capability	175 MW
					TTC with All Lines In Service	200 MW
SCH-NYISO-IMO_NIAGARA_CB_3022						
Tue 06/20/2017	to	Tue 06/20/2017				
0500	Continuous	1700				
Work scheduled by: NYPA						
					SCH - OH - NY	1300 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1750 MW
						1150 MW
						750 MW
						1900 MW
SCH-IMO-NYISO_LIMIT_950						
Tue 06/20/2017	to	Tue 06/20/2017				
0700	Daily(No Weekends)	1830				
Work scheduled by: NGrid						
					SCH - OH - NY	1250 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1750 MW
BROWNFLS-TAYLORVL_115_3						
Mon 06/26/2017	to	Fri 06/30/2017				
0600	Continuous	1900				
Work scheduled by: NGrid						
					SCH - HQ_CEDARS	70 MW
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-NYISO-IMO_NIAGARA_CB_3122					
Tue 06/27/2017	to	Wed 06/28/2017			
0500	Continuous	1700		1200 MW	1400 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1750 MW
MARCY_765_345_AT2					
Wed 06/28/2017	to	Wed 06/28/2017			
0500	Continuous	1730		1700 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
				ARR: 19	
SCH-IMO-NYISO_NIAGARA_CB_3302					
Thu 06/29/2017	to	Thu 06/29/2017			
0500	Continuous	1700		1000 MW	1600 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	750 MW
				TTC with All Lines In Service	1750 MW
BROWNFLS-TAYLORVL_115_3					
Wed 07/05/2017	to	Fri 07/07/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900		70 MW	40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW
				TTC with All Lines In Service	190 MW
				ARR: 38	
COOPERS_-DOLSONAV_345_CCDA42					
Mon 07/10/2017	to	Mon 07/24/2017			
0500	Continuous	1730		2720 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
DOLSONAV-ROCKTVRN_345_DART44					
Mon 07/10/2017	to	Mon 07/24/2017			
0500	Continuous	1730		2720 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3					
Mon 07/10/2017	to	Fri 07/14/2017	UPDATED	by NGRID	03/02/2017
0600	Continuous	1900		70 MW	40 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW
				TTC with All Lines In Service	190 MW
				ARR: 38	

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BROWNFLS-TAYLORVL_115_3					
Mon 07/17/2017	to	Fri 07/21/2017	UPDATED by NGRID 03/02/2017		
0600	Continuous	1900			
Work scheduled by: NGrid				ARR: 38	
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
BROWNFLS-TAYLORVL_115_4					
Mon 07/24/2017	to	Fri 07/28/2017			
0600	Continuous	1900			
Work scheduled by: NGrid				ARR: 38	
				SCH - HQ_CEDARS	70 MW 40 MW
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
CHATGUAY-MASSENA_765_7040					
Sat 07/29/2017	to	Sat 07/29/2017			
0500	Continuous	2000			
Work scheduled by: NYPA					
				MOSES SOUTH	1550 MW
				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					
Sat 07/29/2017	to	Sat 07/29/2017			
0500	Continuous	2000			
Work scheduled by: NYPA					
				SCH - HQ - NY	0 MW 0 MW
				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY_765_MSU1					
Sat 07/29/2017	to	Sat 07/29/2017			
0500	Continuous	2000			
Work scheduled by: NYPA					
				CENTRAL EAST - VC	2265 MW
				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW
MASSENA_-MARCY_765_MSU1					
Sat 07/29/2017	to	Sat 07/29/2017			
0500	Continuous	2000			
Work scheduled by: NYPA					
				MOSES SOUTH	500 MW
				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY_765_MSU1					
Sat 07/29/2017	to	Sat 07/29/2017			
0500	Continuous	2000			
Work scheduled by: NYPA					
				SCH - HQ - NY	475 MW 1000 MW
				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA___765_7040

Sat 07/29/2017 to Sat 07/29/2017
0500 2000

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1 & ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 07/29/2017 to Sat 07/29/2017
0500 2000

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2080 MW**
Impacts Total Transfer Capability 895 MW
TTC with All Lines In Service 2975 MW

ROCHESTR-PANNELL___345_RP2

Tue 08/01/2017 to Fri 08/11/2017
0700 Continuous 1700

Work scheduled by: RGE

FWD
(Import)
DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY___-N.SCTLND_345_18

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

ILCTLIMIT_MARCY_SO_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CANANDGA-STONYRDG_230_68

Mon 09/11/2017 to Mon 09/11/2017
0800 Continuous 1600

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON_345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_5

Sat 09/16/2017 to Sun 09/17/2017 **UPDATED by CE 06/15/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Sat 09/16/2017 to Sun 09/17/2017 **UPDATED by CE 06/15/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK -DUNWODIE_345_W75

Sat 09/16/2017 to Sun 09/17/2017 **UPDATED by CE 06/15/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS3

Sat 09/16/2017 to Sun 09/17/2017 **UPDATED by CE 06/15/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA__-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/13/2017
0630 Continuous 1700

Work scheduled by: NYPA

EXTENDED by NYPA 06/09/2017

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

NIAGARA_345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **1750 MW 1300 MW**
Impacts Total Transfer Capability 0 MW 600 MW
TTC with All Lines In Service 1750 MW 1900 MW

MOSES__-ADIRNDCK_230_MA1

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

RAMAPO__-LADENTWN_345_W72

Mon 10/02/2017 to Thu 10/12/2017
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASER__-COOPERS__345_33

Mon 10/02/2017 to Fri 10/13/2017
0700 Continuous 1900

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WETHSRFD-MEYER 230_85/87				FWD	
Mon 10/09/2017	to	Fri 10/20/2017		(Import)	
0700	Continuous	1400	DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
EGRDNCTY_345_138_AT1				FWD	
Fri 10/13/2017	to	Fri 11/17/2017		(Import)	
0001	Continuous	2359	CONED - LIPA	1250 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	250 MW	
			TTC with All Lines In Service	1500 MW	
EGRDNCTY_345_138_AT2				FWD	
Fri 10/13/2017	to	Fri 11/17/2017		(Import)	
0001	Continuous	2359	CONED - LIPA	1250 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	250 MW	
			TTC with All Lines In Service	1500 MW	
SPRNBRK_-EGRDNCTR_345_Y49				FWD	
Fri 10/13/2017	to	Fri 11/17/2017		(Import)	
0001	Continuous	2359	CONED - LIPA	775 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	725 MW	
			TTC with All Lines In Service	1500 MW	
ILCTLIMIT_MARCY_SO_COMP_I/S				FWD	
Fri 10/13/2017	to	Mon 11/06/2017		(Import)	
1900	Continuous	0559	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO			Impacts Total Transfer Capability	235 MW	
			TTC with All Lines In Service	2975 MW	
CHATGUAY-MASSENA_765_7040				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	03/24/2017
0700	Continuous	1530	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	03/24/2017
0700	Continuous	1530	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW	1000 MW
			TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCYS___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCYS___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCYS___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import) (Export)
0700	Continuous	1530			SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCYS___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			MOSES SOUTH 500 MW
Work scheduled by:					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCYS___765_MSU1 & ILCTLIMIT_MARCYSO_COMP_I/S					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			CENTRAL EAST - VC 2080 MW
Work scheduled by:					Impacts Total Transfer Capability 895 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
 0700 1530

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

HURLYAVE-ROSETON 345_303

Mon 10/16/2017 to Fri 11/03/2017 **UPDATED by CH 06/07/2017**
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

MOSES -ADIRNDCK 230_MA2

Mon 10/30/2017 to Fri 11/03/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

FRASANNX-COOPERS 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MARCY -FRASANNX 345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
 0600 Continuous 1700

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
CENTRAL EAST - VC	2500 MW
Impacts Total Transfer Capability	475 MW
TTC with All Lines In Service	2975 MW

MOSES -ADIRNDCK 230_MA2

Mon 11/06/2017 to Thu 11/09/2017
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Mon 11/06/2017 to Thu 11/09/2017</p> <p style="padding-left: 40px;">0800 Continuous 1500</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJM_VFT 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 11/13/2017 to Fri 11/17/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>ILCTLIMIT_MARCY_SO_COMP_I/S</p> <p>Fri 11/17/2017 to Sat 02/01/2020</p> <p style="padding-left: 40px;">1700 Continuous 0000</p> <p>Work scheduled by: NYISO</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC 2740 MW</p> <p>Impacts Total Transfer Capability 235 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/20/2017 to Wed 11/22/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/27/2017 to Fri 12/01/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY___765_345_AT2</p> <p>Mon 12/04/2017 to Fri 12/08/2017</p> <p style="padding-left: 40px;">0500 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 12/11/2017 to Fri 12/15/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,June 18, 2017 to Tuesday ,December 18, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

UPDATED by NYPA 10/23/2016

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW