

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Reason	By	Effective Date	SCH	FWD (Import)	REV (Export)
<b>RAMAPO__345_345_PAR3500</b>								
Fri 06/24/2016	to	Fri 09/15/2017	<b>EXT FORCE</b>	<b>by CONED</b>	<b>03/22/2017</b>	SCH - PJ - NY	1650 MW	1250 MW
1940	Continuous	2359				Impacts Total Transfer Capability	450 MW	100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2100 MW	1350 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>								
Thu 11/24/2016	to	Sat 09/30/2017	<b>UPDATED</b>	<b>by PJM</b>	<b>05/18/2017</b>	SCH - PJM_HTP	0 MW	
1500	Continuous	2359				Impacts Total Transfer Capability	660 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	660 MW	
<b>S.RIPLEY-DUNKIRK__230_68 &amp; RAMAPO__345_345_PAR3500</b>								
Tue 05/02/2017	to	Fri 09/15/2017				SCH - PJ - NY	1450 MW	1250 MW
1710		2359				Impacts Total Transfer Capability	650 MW	100 MW
Work scheduled by:						TTC with All Lines In Service	2100 MW	1350 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>								
Tue 05/02/2017	to	Mon 10/23/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>05/17/2017</b>	SCH - PJ - NY	1950 MW	1350 MW
1710	Continuous	0759				Impacts Total Transfer Capability	150 MW	0 MW
Work scheduled by: NYISO						TTC with All Lines In Service	2100 MW	1350 MW
<b>SCH-HQ-NYISO_LIMIT_1400</b>								
Thu 06/08/2017	to	Fri 12/15/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>05/25/2017</b>	SCH - HQ - NY	1400 MW	
0600	Continuous	1700				Impacts Total Transfer Capability	100 MW	
Work scheduled by: HQ						TTC with All Lines In Service	1500 MW	
<b>SCH-NYISO-HQ_LIMIT_800</b>								
Thu 06/08/2017	to	Fri 12/15/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>05/25/2017</b>	SCH - HQ - NY		800 MW
0600	Continuous	1700				Impacts Total Transfer Capability		200 MW
Work scheduled by: HQ						TTC with All Lines In Service		1000 MW
<b>BROWNFLS-TAYLORVL_115_4</b>								
Wed 06/14/2017	to	Fri 06/16/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>06/20/2017</b>	SCH - HQ_CEDARS	70 MW	40 MW
0600	Continuous	1900				Impacts Total Transfer Capability	120 MW	0 MW
Work scheduled by: NGrid				<b>ARR: 38</b>		TTC with All Lines In Service	190 MW	40 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>CEDARS__-ROSEMNTA_115_1/11</b>						
Wed 06/14/2017	to	Wed 06/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>06/16/2017</u>	
0700	Continuous	1700				
Work scheduled by: HQ				<b>ARR: 38</b>		
					SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<hr/>						
<b>DENNISON-ROSEMNTA_115_1/11</b>						
Wed 06/14/2017	to	Wed 06/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>06/16/2017</u>	
0700	Continuous	1700				
Work scheduled by: HQ				<b>ARR: 38</b>		
					SCH - HQ_CEDARS	<b>95 MW 40 MW</b>
					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
<hr/>						
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>						
Wed 06/14/2017	to	Wed 06/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>06/16/2017</u>	
0700	Continuous	1700				
Work scheduled by: HQ						
					SCH - HQ_CEDARS	<b>80 MW</b>
					Impacts Total Transfer Capability	110 MW
					TTC with All Lines In Service	190 MW
<hr/>						
<b>EDIC____-N.SCTLND_345_14</b>						
Thu 06/15/2017	to	Fri 06/16/2017				
0630	Continuous	1630				
Work scheduled by: NGrid						
					CENTRAL EAST - VC	<b>2240 MW</b>
					Impacts Total Transfer Capability	735 MW
					TTC with All Lines In Service	2975 MW
<hr/>						
<b>N.SCTLND-ALPS____345_2</b>						
Thu 06/15/2017	to	Fri 06/16/2017				
0630	Continuous	1630				
Work scheduled by: NGrid						
					SCH - NE - NY	<b>750 MW 1350 MW</b>
					Impacts Total Transfer Capability	650 MW 250 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>N.SCTLND-ALPS____345_2</b>						
Thu 06/15/2017	to	Fri 06/16/2017				
0630	Continuous	1630				
Work scheduled by: NGrid						
					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>						
<b>N.SCTLND-LEEDS____345_93</b>						
Thu 06/15/2017	to	Fri 06/16/2017				
0630	Continuous	1630				
Work scheduled by: NGrid						
					CENTRAL EAST - VC	<b>2650 MW</b>
					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NE-NYISO\_LIMIT\_400**

Thu 06/15/2017 to Fri 06/16/2017  
 0630 Continuous 1630  
 Work scheduled by: NGrid

FWD  
 (Import)  
 SCH - NE - NY **600 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_800**

Thu 06/15/2017 to Fri 06/16/2017  
 0630 Continuous 1630  
 Work scheduled by: NGrid

REV  
 (Export)  
 SCH - NE - NY **1000 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 1600 MW

**SCH-IMO-NYISO\_LIMIT\_800**

Fri 06/16/2017 to Fri 06/16/2017  
 0700 Daily(No Weekends) 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
 SCH - OH - NY **1100 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 2000 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

Fri 06/16/2017 to Tue 06/20/2017  
 1700 Continuous 1828  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

**PLSNTVLY-WOOD\_ST\_345\_F30**

Sat 06/17/2017 to Sun 06/18/2017 **UPDATED by CONED 06/17/2017**  
 0100 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

Sat 06/17/2017 to Sun 06/18/2017 **UPDATED by CONED 06/17/2017**  
 0100 Continuous 0700  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

**HOPATCON-RAMAPO\_500\_5018**

Sat 06/17/2017 to Sat 06/17/2017 **CANCELLED by PJM 06/16/2017**  
 0500 Continuous 2100  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1150 MW 1000 MW**  
 Impacts Total Transfer Capability 950 MW 350 MW  
 TTC with All Lines In Service 2100 MW 1350 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018					FWD	REV
Sat 06/17/2017 to Sat 06/17/2017					(Import)	(Export)
0500	Continuous	2100			SCH - PJ - NY	1150 MW 1000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	950 MW 350 MW
					TTC with All Lines In Service	2100 MW 1350 MW
HOPATCON-RAMAPO___500_5018					FWD	
Sat 06/17/2017 to Sat 06/17/2017					(Import)	
0500	Continuous	2100			TOTAL EAST	6400 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	6500 MW
HOPATCON-RAMAPO___500_5018					FWD	
Sat 06/17/2017 to Sat 06/17/2017					(Import)	
0500	Continuous	2100	<b>CANCELLED by PJM</b>	<b>06/16/2017</b>	TOTAL EAST	6400 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	6500 MW
HOPATCON-RAMAPO___500_5018					FWD	
Sat 06/17/2017 to Sat 06/17/2017					(Import)	
0500	Continuous	2100			UPNY CONED	4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO___500_5018					FWD	
Sat 06/17/2017 to Sat 06/17/2017					(Import)	
0500	Continuous	2100	<b>CANCELLED by PJM</b>	<b>06/16/2017</b>	UPNY CONED	4000 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO___500_5018 & S.RIPLEY-DUNKIRK___230_68					FWD	REV
Sat 06/17/2017 to Sat 06/17/2017					(Import)	(Export)
0500		2100			SCH - PJ - NY	1200 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability	900 MW 50 MW
					TTC with All Lines In Service	2100 MW 1350 MW
RAMAPO___345_345_PAR4500					FWD	REV
Sat 06/17/2017 to Sat 06/17/2017					(Import)	(Export)
0500	Continuous	2100			SCH - PJ - NY	1650 MW 1250 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	450 MW 100 MW
					TTC with All Lines In Service	2100 MW 1350 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>RAMAPO__345_345_PAR4500</b>						
Sat 06/17/2017	to	Sat 06/17/2017	<b>CANCELLED</b>	<b>by PJM</b>	<b>06/16/2017</b>	
0500	Continuous	2100			SCH - PJ - NY	<b>1650 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	2100 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017	<b>CANCELLED</b>	<b>by PJM</b>	<b>06/16/2017</b>	
0500	Continuous	2100			SCH - PJ - NY	<b>1900 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2100 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017				
0500	Continuous	2100			SCH - PJ - NY	<b>1900 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	2100 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017	<b>CANCELLED</b>	<b>by PJM</b>	<b>06/16/2017</b>	
0500	Continuous	2100			TOTAL EAST	<b>6400 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	6500 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017				
0500	Continuous	2100			TOTAL EAST	<b>6400 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	6500 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017	<b>CANCELLED</b>	<b>by PJM</b>	<b>06/16/2017</b>	
0500	Continuous	2100			UPNY CONED	<b>4000 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<hr/>						
<b>RAMAPO__500_345_BK 1500</b>						
Sat 06/17/2017	to	Sat 06/17/2017				
0500	Continuous	2100			UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			FWD	REV
S. RIPLEY-DUNKIRK_230_68 & RAMAPO_345_345_PAR4500			(Import)	(Export)
Sat 06/17/2017	to	Sat 06/17/2017		
0500		2100	SCH - PJ - NY	<b>1450 MW 1250 MW</b>
Work scheduled by:			Impacts Total Transfer Capability	650 MW 100 MW
			TTC with All Lines In Service	2100 MW 1350 MW
<hr/>			FWD	
STONYRDG-HILLSIDE_230_72			(Import)	
Sat 06/17/2017	to	Sat 06/17/2017	DYSINGER EAST	<b>2850 MW</b>
1900	Continuous	1930	Impacts Total Transfer Capability	300 MW
Work scheduled by: NYSEG			TTC with All Lines In Service	3150 MW
<hr/>			FWD	
CHAT_DC_GC1			(Import)	
Sun 06/18/2017	to	Sun 06/18/2017	MOSES SOUTH	<b>2850 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW
<hr/>			FWD	
CHAT_DC_GC1			(Export)	
Sun 06/18/2017	to	Sun 06/18/2017	SCH - HQ - NY	<b>500 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW
<hr/>			FWD	
CHAT_DC_GC1 & CHAT_DC_GC2			(Import)	
Sun 06/18/2017	to	Sun 06/18/2017	MOSES SOUTH	<b>2550 MW</b>
0001		0200	Impacts Total Transfer Capability	600 MW
Work scheduled by:			TTC with All Lines In Service	3150 MW
<hr/>			FWD	
CHAT_DC_GC1 & CHAT_DC_GC2			(Import)	
Sun 06/18/2017	to	Sun 06/18/2017	SCH - HQ - NY	<b>1370 MW 0 MW</b>
0001		0200	Impacts Total Transfer Capability	130 MW 1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW 1000 MW
<hr/>			FWD	
CHAT_DC_GC2			(Import)	
Sun 06/18/2017	to	Sun 06/18/2017	MOSES SOUTH	<b>2850 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT\_DC\_GC2

Sun 06/18/2017 to Sun 06/18/2017  
 0001 Continuous 0200  
 Work scheduled by: HQ

REV  
 (Export)  
**500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO\_LIMIT\_700

Sun 06/18/2017 to Sun 06/18/2017  
 0001 Continuous 0200  
 Work scheduled by: HQ

FWD  
 (Import)  
**700 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1500 MW

BROWNFLS-TAYLORVL\_115\_4

Mon 06/19/2017 to Fri 06/23/2017 **UPDATED by NGRID 06/20/2017**  
 0600 Continuous 1900  
 Work scheduled by: NGrid **ARR: 38**

FWD REV  
 (Import) (Export)  
**70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

SCH-NPX\_1385-NYISO\_LIMIT\_25

Tue 06/20/2017 to Wed 06/21/2017  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
**25 MW**  
 Impacts Total Transfer Capability 175 MW  
 TTC with All Lines In Service 200 MW

SCH-NYISO-NPX\_1385\_LIMIT\_25

Tue 06/20/2017 to Wed 06/21/2017  
 0001 Continuous 2359  
 Work scheduled by: LI

REV  
 (Export)  
**25 MW**  
 Impacts Total Transfer Capability 175 MW  
 TTC with All Lines In Service 200 MW

SCH-NYISO-IMO\_NIAGARA\_CB\_3022

Tue 06/20/2017 to Wed 06/21/2017 **EXTENDED by NYPA 06/20/2017**  
 0500 Continuous 1530  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**1300 MW 1150 MW**  
 Impacts Total Transfer Capability 700 MW 450 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

SCH-IMO-NYISO\_LIMIT\_950

Tue 06/20/2017 to Tue 06/20/2017  
 0700 Daily(No Weekends) 1830  
 Work scheduled by: NGrid

FWD  
 (Import)  
**1250 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_3</b>							
Tue 06/20/2017	to	Fri 06/23/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/20/2017</u>		
0818	Continuous	1900					
Work scheduled by: NGrid							
						SCH - HQ_CEDARS	<b>70 MW</b>
						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
							<b>40 MW</b>
							0 MW
							40 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>							
Wed 06/21/2017	to	Sat 08/05/2017				FWD	
1530	Continuous	0459				(Import)	
Work scheduled by: NYISO							
						CENTRAL EAST - VC	<b>2740 MW</b>
						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>							
Thu 06/22/2017	to	Thu 06/22/2017	<u>UPDATED</u>	<u>by LI</u>	<u>06/20/2017</u>		
0600	Continuous	2359				(Import)	(Export)
Work scheduled by: LI							
						SCH - NPX_CSC	<b>0 MW</b>
						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
							<b>0 MW</b>
							330 MW
							330 MW
<b>STONYRDG-HILLSIDE_230_72</b>							
Thu 06/22/2017	to	Thu 06/22/2017	<u>EXT FORCE</u>	<u>by NYSEG</u>	<u>06/21/2017</u>	FWD	
1500	Continuous	1600				(Import)	
Work scheduled by: NYSEG							
						DYSINGER EAST	<b>2850 MW</b>
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>W49TH_ST_345KV_6</b>							
Sat 06/24/2017	to	Sat 06/24/2017				FWD	
0001	Continuous	0500				(Import)	
Work scheduled by: ConEd							
						SCH - PJM_HTP	<b>320 MW</b>
						Impacts Total Transfer Capability	340 MW
						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>							
Sat 06/24/2017	to	Sat 06/24/2017				FWD	
0001	Continuous	0500				(Import)	
Work scheduled by: ConEd							
						SCH - PJM_HTP	<b>315 MW</b>
						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
<b>BROWNFLS-TAYLORVL_115_3</b>							
Mon 06/26/2017	to	Fri 06/30/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/21/2017</u>		
0600	Continuous	1900				(Import)	(Export)
Work scheduled by: NGrid							
						SCH - HQ_CEDARS	<b>70 MW</b>
						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
							<b>40 MW</b>
							0 MW
							40 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_4</b>					
Mon 06/26/2017	to	Fri 06/30/2017	<b>UPDATED by NYISO 06/21/2017</b>		
0600	Continuous	1900			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3122</b>					
Tue 06/27/2017	to	Wed 06/28/2017			
0500	Continuous	1700			
Work scheduled by: NYPA					
				SCH - OH - NY	<b>1200 MW 1400 MW</b>
				Impacts Total Transfer Capability	800 MW 200 MW
				TTC with All Lines In Service	2000 MW 1600 MW
<b>MARCY___765_345_AT2</b>					
Wed 06/28/2017	to	Wed 06/28/2017			
0500	Continuous	1730			
Work scheduled by: NYPA			<b>ARR: 19</b>		
				MOSES SOUTH	<b>1700 MW</b>
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>SCH-IMO-NYISO_LIMIT_600</b>					
Wed 06/28/2017	to	Thu 06/29/2017			
0800	Continuous	1700			
Work scheduled by: IESO					
				SCH - OH - NY	<b>900 MW</b>
				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	2000 MW
<b>CHATGUAY-MASSENA__765_7040</b>					
Thu 06/29/2017	to	Thu 06/29/2017			
0001	Continuous	0600			
Work scheduled by: HQ					
				MOSES SOUTH	<b>1550 MW</b>
				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>					
Thu 06/29/2017	to	Thu 06/29/2017			
0001	Continuous	0600			
Work scheduled by: HQ					
				SCH - HQ - NY	<b>0 MW 0 MW</b>
				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1</b>					
Thu 06/29/2017	to	Thu 06/29/2017			
0001	Continuous	0600			
Work scheduled by: HQ					
				MOSES SOUTH	<b>2850 MW</b>
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT\_DC\_GC1

Thu 06/29/2017 to Thu 06/29/2017  
0001 Continuous 0600

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

REV  
(Export)

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Thu 06/29/2017 to Thu 06/29/2017  
0001 0600

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH 2550 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Thu 06/29/2017 to Thu 06/29/2017  
0001 0600

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 1370 MW 0 MW  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

CHAT\_DC\_GC2

Thu 06/29/2017 to Thu 06/29/2017  
0001 Continuous 0600

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH 2850 MW  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

CHAT\_DC\_GC2

Thu 06/29/2017 to Thu 06/29/2017  
0001 Continuous 0600

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY 500 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

SCH-IMO-NYISO\_NIAGARA\_CB\_3302

Thu 06/29/2017 to Thu 06/29/2017  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY 1000 MW 1600 MW  
Impacts Total Transfer Capability 1000 MW 0 MW  
TTC with All Lines In Service 2000 MW 1600 MW

EASTVIEW-SPRNBK\_\_345\_W65

Sat 07/01/2017 to Sat 07/01/2017  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MILLWOOD-EASTVIEW\_345\_W82**

Sat 07/01/2017 to Sat 07/01/2017  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**EASTVIEW-SPRNBRK\_345\_W65**

Sun 07/02/2017 to Sun 07/02/2017  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**MILLWOOD-EASTVIEW\_345\_W82**

Sun 07/02/2017 to Sun 07/02/2017  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

**BROWNFLS-TAYLORVL\_115\_3**

Wed 07/05/2017 to Fri 07/07/2017 **UPDATED by NGRID 06/19/2017**  
 0600 Continuous 1900  
 Work scheduled by: NGrid **ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**BROWNFLS-TAYLORVL\_115\_4**

Wed 07/05/2017 to Fri 07/07/2017 **UPDATED by NGRID 06/19/2017**  
 0600 Continuous 1900  
 Work scheduled by: NGrid **ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**COOPERS\_-DOLSONAV\_345\_CCDA42**

Mon 07/10/2017 to Mon 07/24/2017  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

**DOLSONAV-ROCKTVRN\_345\_DART44**

Mon 07/10/2017 to Mon 07/24/2017  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2720 MW**  
 Impacts Total Transfer Capability 255 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_3</b>							
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>BROWNFLS-TAYLORVL_115_4</b>							
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>BROWNFLS-TAYLORVL_115_3</b>							
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>BROWNFLS-TAYLORVL_115_4</b>							
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>BROWNFLS-TAYLORVL_115_3</b>							
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>BROWNFLS-TAYLORVL_115_4</b>							
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900				SCH - HQ_CEDARS	<b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW 0 MW
						TTC with All Lines In Service	190 MW 40 MW
ARR: 38							
<b>CHATGUAY-MASSENA_765_7040</b>							
Sat 07/29/2017	to	Sat 07/29/2017					
0500	Continuous	2000				MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040	FWD	REV
Sat 07/29/2017 to Sat 07/29/2017	(Import)	(Export)
0500 Continuous 2000	SCH - HQ - NY 0 MW	0 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1500 MW
	TTC with All Lines In Service	1000 MW
		1500 MW
		1000 MW
MASSENA_-MARCY____765_MSU1	FWD	
Sat 07/29/2017 to Sat 07/29/2017	(Import)	
0500 Continuous 2000	CENTRAL EAST - VC 2265 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	710 MW
	TTC with All Lines In Service	2975 MW
MASSENA_-MARCY____765_MSU1	FWD	
Sat 07/29/2017 to Sat 07/29/2017	(Import)	
0500 Continuous 2000	MOSES SOUTH 500 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	2650 MW
	TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1	FWD	REV
Sat 07/29/2017 to Sat 07/29/2017	(Import)	(Export)
0500 Continuous 2000	SCH - HQ - NY 475 MW	1000 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1025 MW
	TTC with All Lines In Service	0 MW
		1500 MW
		1000 MW
MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040	FWD	
Sat 07/29/2017 to Sat 07/29/2017	(Import)	
0500 2000	MOSES SOUTH 500 MW	
Work scheduled by:	Impacts Total Transfer Capability	2650 MW
	TTC with All Lines In Service	3150 MW
MASSENA_-MARCY____765_MSU1 & MARCY_SO_SERIES_COMP_I/S	FWD	
Sat 07/29/2017 to Sat 07/29/2017	(Import)	
0500 2000	CENTRAL EAST - VC 2080 MW	
Work scheduled by:	Impacts Total Transfer Capability	895 MW
	TTC with All Lines In Service	2975 MW
ROCHESTR-PANNELL__345_RP2	FWD	
Tue 08/01/2017 to Fri 08/11/2017	(Import)	
0700 Continuous 1700	DYSINGER EAST 2300 MW	
Work scheduled by: RGE	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_-N.SCTLND\_345\_18

Sat 08/05/2017 to Sat 08/05/2017  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2090 MW**  
Impacts Total Transfer Capability 885 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Sat 08/05/2017 to Sat 08/05/2017  
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MARCY\_SO\_SERIES\_COMP\_I/S

Sat 08/05/2017 to Mon 10/02/2017  
1600 Continuous 0659

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Tue 09/05/2017 to Sun 09/10/2017  
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

DUNWODIE\_345KV\_5

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_7

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

SPRNBRK\_-DUNWODIE\_345\_W75

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**  
2200 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK\_\_345KV\_RNS3

FWD

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED** by CE 06/20/2017  
 2200 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

MOSES\_\_-ADIRNDCK\_230\_MAI

FWD

Mon 09/11/2017 to Sat 09/16/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

CANANDGA-STONYRDG\_230\_68

FWD

Mon 09/11/2017 to Mon 09/11/2017  
 0800 Continuous 1600

Work scheduled by: NYSEG

DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_\_345\_303

FWD

Mon 09/11/2017 to Fri 09/29/2017  
 0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

SPRNBRK\_\_345KV\_RNS5

FWD

Sat 09/16/2017 to Sat 09/16/2017  
 0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_5

FWD

Sat 09/16/2017 to Sun 09/17/2017 **CANCELLED** by ConEd 06/20/2017  
 0001 Continuous 0100

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_7

FWD

Sat 09/16/2017 to Sun 09/17/2017 **CANCELLED** by ConEd 06/20/2017  
 0001 Continuous 0100

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-DUNWODIE_345_W75</b>				FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<b>CANCELLED by ConEd 06/20/2017</b>	(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBK_345KV_RNS3</b>				FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<b>CANCELLED by ConEd 06/20/2017</b>	(Import)	
0001	Continuous	0100		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBK_-W49TH_ST_345_M51</b>				FWD	
Sat 09/16/2017	to	Tue 09/26/2017		(Import)	
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>				FWD	
Mon 09/18/2017	to	Fri 10/13/2017	<b>EXTENDED by NYPA 06/09/2017</b>	(Import)	
0630	Continuous	1700		CENTRAL EAST - VC	<b>2520 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	455 MW
				TTC with All Lines In Service	2975 MW
<b>NIAGARA_345_230_AT4</b>				FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017		(Import)	(Export)
0700	Continuous	1530		SCH - OH - NY	<b>2000 MW 1400 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	0 MW 200 MW
				TTC with All Lines In Service	2000 MW 1600 MW
<b>MOSES_-ADIRNDCK_230_MAI</b>				FWD	
Mon 09/18/2017	to	Sat 09/23/2017		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MAI</b>				FWD	
Mon 09/25/2017	to	Sat 09/30/2017		(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBRK\_\_345KV\_RNS5**

Tue 09/26/2017 to Tue 09/26/2017  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**RAMAPO\_\_-LADENTWN\_345\_W72**

Mon 10/02/2017 to Thu 10/12/2017  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_\_-COOPERS\_\_345\_33**

Mon 10/02/2017 to Fri 10/13/2017  
 0700 Continuous 1900  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

**WETHSRFD-MEYER\_\_230\_85/87**

Mon 10/09/2017 to Fri 10/20/2017  
 0700 Continuous 1400  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**EGRDNCTY\_345\_138\_AT1**

Fri 10/13/2017 to Fri 11/17/2017  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Fri 10/13/2017 to Fri 11/17/2017  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>SPRNBK_-EGRDNCTR_345_Y49</b>				FWD
Fri 10/13/2017	to	Fri 11/17/2017		(Import)
0001	Continuous	2359		<b>CONED - LIPA</b> <b>775 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 725 MW TTC with All Lines In Service 1500 MW
<hr/>				
<b>MARCY_SO_SERIES_COMP_I/S</b>				FWD
Fri 10/13/2017	to	Mon 11/06/2017		(Import)
1900	Continuous	0559		<b>CENTRAL EAST - VC</b> <b>2740 MW</b>
Work scheduled by: NYISO				Impacts Total Transfer Capability 235 MW TTC with All Lines In Service 2975 MW
<hr/>				
<b>CHATGUAY-MASSENA_765_7040</b>				FWD
Sat 10/14/2017	to	Sat 10/28/2017	<b>UPDATED by NYISO 03/24/2017</b>	(Import)
0700	Continuous	1530		<b>MOSES SOUTH</b> <b>1550 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1600 MW TTC with All Lines In Service 3150 MW
<hr/>				
<b>CHATGUAY-MASSENA_765_7040</b>				FWD      REV
Sat 10/14/2017	to	Sat 10/28/2017	<b>UPDATED by NYISO 03/24/2017</b>	(Import) (Export)
0700	Continuous	1530		<b>SCH - HQ - NY</b> <b>0 MW      0 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 1500 MW 1000 MW TTC with All Lines In Service 1500 MW 1000 MW
<hr/>				
<b>MARCY___765_345_AT1</b>				FWD
Sat 10/14/2017	to	Sat 10/28/2017	<b>UPDATED by NYISO 03/24/2017</b>	(Import)
0700	Continuous	1530		<b>MOSES SOUTH</b> <b>1750 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability 1400 MW TTC with All Lines In Service 3150 MW
<hr/>				
<b>MARCY___765_345_AT2</b>				FWD
Sat 10/14/2017	to	Sat 10/28/2017	<b>UPDATED by NYISO 03/24/2017</b>	(Import)
0700	Continuous	1530		<b>MOSES SOUTH</b> <b>1700 MW</b>
Work scheduled by: NYPA			<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 3150 MW
<hr/>				
<b>MASSENA_-MARCY___765_MSU1</b>				FWD
Sat 10/14/2017	to	Sat 10/28/2017	<b>UPDATED by NYISO 03/24/2017</b>	(Import)
0700	Continuous	1530		<b>CENTRAL EAST - VC</b> <b>2265 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 710 MW TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)	(Export)
0700	Continuous	1530		SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>				FWD	
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	
0700		1530		MOSES SOUTH	<b>500 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>				FWD	
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	
0700		1530		CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	895 MW
				TTC with All Lines In Service	2975 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	(Export)
0700		1530		SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
<b>COOPERS_-MIDDLETP_345_CCRT34</b>				FWD	
Mon 10/16/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>06/21/2017</u>	(Import)	
0700	Continuous	1500		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
<b>HURLYAVE-ROSETON_345_303</b>				FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u> <u>by CH</u> <u>06/07/2017</u>	(Import)	
0800	Continuous	1600		UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/16/2017 to Fri 11/03/2017  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

S.RIPLEY-DUNKIRK\_230\_68

Mon 10/23/2017 to Mon 03/19/2018 **UPDATED by PJM 02/17/2017**  
 0800 Continuous 0959  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1950 MW 1350 MW**  
 Impacts Total Transfer Capability 150 MW 0 MW  
 TTC with All Lines In Service 2100 MW 1350 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 10/30/2017 to Fri 11/03/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

FRASANX-COOPERS\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
 0600 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_\_-FRASANX\_345\_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017  
 0600 Continuous 1700  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/06/2017 to Thu 11/09/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Mon 11/06/2017 to Thu 11/09/2017  
 0800 Continuous 1500  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJM\_VFT **0 MW 0 MW**  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday, December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/13/2017 to Fri 11/17/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_SO\_SERIES\_COMP\_I/S**

Fri 11/17/2017 to Sat 02/01/2020  
 1700 Continuous 0000  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 11/20/2017 to Wed 11/22/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 11/27/2017 to Fri 12/01/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Mon 12/04/2017 to Fri 12/08/2017  
 0500 Continuous 1630  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/11/2017 to Fri 12/15/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 21, 2017 to Friday , December 21, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Wed 12/27/2017 to Thu 12/28/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Mon 03/19/2018 to Fri 04/20/2018  
1000 Continuous 1559

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 350 MW 100 MW  
TTC with All Lines In Service 2300 MW 1450 MW

**S.RIPLEY-DUNKIRK\_\_230\_68**

Fri 04/20/2018 to Sat 02/01/2020  
1600 Continuous 0000

Work scheduled by: NYISO

**UPDATED by NYISO 05/17/2017**

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 350 MW 100 MW  
TTC with All Lines In Service 2300 MW 1450 MW