

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__345_345_PAR3500</b>					FWD	REV
					(Import)	(Export)
Fri 06/24/2016	to	Fri 09/15/2017	<b>EXT FORCE</b>	<b>by CONED</b>	<b>03/22/2017</b>	
1940	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	<b>1650 MW</b>
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
					(Import)	
Thu 11/24/2016	to	Sat 09/30/2017	<b>UPDATED</b>	<b>by PJM</b>	<b>05/18/2017</b>	
1500	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>0 MW</b>
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>S.RIPLEY-DUNKIRK__230_68 &amp; RAMAPO__345_345_PAR3500</b>					FWD	REV
					(Import)	(Export)
Tue 05/02/2017	to	Fri 09/15/2017				
1710		2359				
Work scheduled by:					SCH - PJ - NY	<b>1450 MW</b>
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
					(Import)	(Export)
Tue 05/02/2017	to	Mon 10/23/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>05/17/2017</b>	
1710	Continuous	0759				
Work scheduled by: NYISO					SCH - PJ - NY	<b>1950 MW</b>
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
<b>SCH-HQ-NYISO_LIMIT_1400</b>					FWD	
					(Import)	
Thu 06/08/2017	to	Fri 12/15/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>05/25/2017</b>	
0600	Continuous	1700				
Work scheduled by: HQ					SCH - HQ - NY	<b>1400 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-NYISO-HQ_LIMIT_800</b>						REV
						(Export)
Thu 06/08/2017	to	Fri 12/15/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>05/25/2017</b>	
0600	Continuous	1700				
Work scheduled by: HQ					SCH - HQ - NY	<b>800 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
<b>CEDARS__-ROSEMNTA_115_1/11</b>					FWD	REV
					(Import)	(Export)
Wed 06/14/2017	to	Wed 06/21/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>06/16/2017</b>	
0700	Continuous	1700				
Work scheduled by: HQ					SCH - HQ_CEDARS	<b>95 MW</b>
					Impacts Total Transfer Capability	95 MW
					TTC with All Lines In Service	190 MW
						40 MW
						0 MW
						40 MW

**ARR: 38**

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>DENNISON-ROSEMNTA_115_1/11</b>							
Wed 06/14/2017	to	Wed 06/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>06/16/2017</u>		
0700	Continuous	1700				SCH - HQ_CEDARS	<b>95 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	40 MW
						TTC with All Lines In Service	95 MW
							0 MW
							40 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_80</b>							
Wed 06/14/2017	to	Wed 06/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>06/16/2017</u>		
0700	Continuous	1700				SCH - HQ_CEDARS	<b>80 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	110 MW
						TTC with All Lines In Service	190 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>							
Fri 06/16/2017	to	Tue 06/20/2017					
1700	Continuous	1828				CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
<b>PLSNTVLY-WOOD_ST_345_F30</b>							
Sat 06/17/2017	to	Sun 06/18/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>06/17/2017</u>		
0100	Continuous	0700				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
<b>PLSNTVLY_345KV_RNS5</b>							
Sat 06/17/2017	to	Sun 06/18/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>06/17/2017</u>		
0100	Continuous	0700				UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	1300 MW
						TTC with All Lines In Service	5100 MW
<b>CHAT_DC_GC1</b>							
Sun 06/18/2017	to	Sun 06/18/2017					
0001	Continuous	0200				MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>							
Sun 06/18/2017	to	Sun 06/18/2017					
0001	Continuous	0200				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Sun 06/18/2017	to	Sun 06/18/2017		(Import)
0001		0200	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Sun 06/18/2017	to	Sun 06/18/2017		(Import) (Export)
0001		0200	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 130 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
<b>CHAT_DC_GC2</b>				FWD
Sun 06/18/2017	to	Sun 06/18/2017		(Import)
0001	Continuous	0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>				REV
Sun 06/18/2017	to	Sun 06/18/2017		(Export)
0001	Continuous	0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>				FWD
Sun 06/18/2017	to	Sun 06/18/2017		(Import)
0001	Continuous	0200	SCH - HQ - NY	<b>700 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1500 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD
Mon 06/19/2017	to	Fri 06/23/2017	<b>UPDATED by NGRID 06/20/2017</b>	(Import) (Export)
0600	Continuous	1900	SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 120 MW 0 MW
				TTC with All Lines In Service 190 MW 40 MW
<b>SCH-NPX_1385-NYISO_LIMIT_25</b>				FWD
Tue 06/20/2017	to	Wed 06/21/2017		(Import)
0001	Continuous	2359	SCH - NPX_1385	<b>25 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 175 MW
				TTC with All Lines In Service 200 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NPX_1385_LIMIT_25</b>					REV
Tue 06/20/2017	to	Wed 06/21/2017			(Export)
0001	Continuous	2359		SCH - NPX_1385	<b>25 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 175 MW
					TTC with All Lines In Service 200 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3022</b>					FWD REV
Tue 06/20/2017	to	Wed 06/21/2017	<b><u>EXTENDED</u></b>	<b><u>by NYPA</u></b>	<b><u>06/20/2017</u></b>
0500	Continuous	1530		SCH - OH - NY	<b>1300 MW 1150 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 700 MW 450 MW
					TTC with All Lines In Service 2000 MW 1600 MW
<b>SCH-IMO-NYISO_LIMIT_950</b>					FWD
Tue 06/20/2017	to	Tue 06/20/2017			(Import)
0700	Daily(No Weekends)	1830		SCH - OH - NY	<b>1250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 2000 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD REV
Tue 06/20/2017	to	Fri 06/23/2017	<b><u>UPDATED</u></b>	<b><u>by NGRID</u></b>	<b><u>06/20/2017</u></b>
0818	Continuous	1900		SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 120 MW 0 MW
					TTC with All Lines In Service 190 MW 40 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD REV
Thu 06/22/2017	to	Thu 06/22/2017	<b><u>UPDATED</u></b>	<b><u>by LI</u></b>	<b><u>06/20/2017</u></b>
0600	Continuous	2359		SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 330 MW 330 MW
					TTC with All Lines In Service 330 MW 330 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>					FWD
Thu 06/22/2017	to	Sat 08/05/2017	<b><u>CANCELLED</u></b>	<b><u>by NYISO</u></b>	<b><u>06/22/2017</u></b>
1349	Continuous	0459		CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability 235 MW
					TTC with All Lines In Service 2975 MW
<b>STONYRDG-HILLSIDE_230_72</b>					FWD
Thu 06/22/2017	to	Thu 06/22/2017	<b><u>EXT FORCE</u></b>	<b><u>by NYSEG</u></b>	<b><u>06/21/2017</u></b>
1500	Continuous	1600		DYSINGER EAST	<b>2850 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARION__-FARRAGUT_345_C3403</b>				FWD	REV
Sat 06/24/2017	to	Tue 06/27/2017		(Import)	(Export)
0000	Continuous	2359		<b>SCH - PJ - NY</b>	<b>2100 MW 1350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	0 MW 0 MW
				TTC with All Lines In Service	2100 MW 1350 MW
<b>W49TH_ST_345KV_6</b>				FWD	
Sat 06/24/2017	to	Sat 06/24/2017		(Import)	
0001	Continuous	0500		<b>SCH - PJM_HTP</b>	<b>320 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	340 MW
				TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>				FWD	
Sat 06/24/2017	to	Sat 06/24/2017		(Import)	
0001	Continuous	0500		<b>SCH - PJM_HTP</b>	<b>315 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 06/26/2017	to	Fri 06/30/2017	<b><u>UPDATED</u> by NYISO 06/21/2017</b>	(Import)	(Export)
0600	Continuous	1900		<b>SCH - HQ_CEDARS</b>	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 06/26/2017	to	Fri 06/30/2017	<b><u>UPDATED</u> by NYISO 06/21/2017</b>	(Import)	(Export)
0600	Continuous	1900		<b>SCH - HQ_CEDARS</b>	<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>SCH-IMO-NYISO_LIMIT_1050</b>				FWD	
Mon 06/26/2017	to	Fri 06/30/2017		(Import)	
0730	Continuous	1400		<b>SCH - OH - NY</b>	<b>1350 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	650 MW
				TTC with All Lines In Service	2000 MW
<b>SCH-NYISO-PJM_LIMIT_100</b>					REV
Mon 06/26/2017	to	Thu 06/29/2017	<b><u>UPDATED</u> by PJM 06/23/2017</b>		(Export)
0800	Continuous	1600		<b>SCH - PJ - NY</b>	<b>400 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	1350 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>				FWD	REV
				(Import)	(Export)
Tue 06/27/2017	to	Wed 06/28/2017	<b>UPDATED by NYISO 06/22/2017</b>	SCH - OH - NY	<b>1700 MW 1400 MW</b>
0500	Continuous	1700		Impacts Total Transfer Capability	300 MW 200 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW 1600 MW
<b>MARCY_765_345_AT2</b>				FWD	
				(Import)	
Wed 06/28/2017	to	Wed 06/28/2017		MOSES SOUTH	<b>1700 MW</b>
0500	Continuous	1730		Impacts Total Transfer Capability	1450 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
					<b>ARR: 19</b>
<b>SCH-IMO-NYISO_LIMIT_700</b>				FWD	
				(Import)	
Wed 06/28/2017	to	Thu 06/29/2017	<b>CANCELLED by IESO 06/23/2017</b>	SCH - OH - NY	<b>1000 MW</b>
0800	Continuous	1800		Impacts Total Transfer Capability	1000 MW
Work scheduled by: IESO				TTC with All Lines In Service	2000 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	
				(Import)	
Thu 06/29/2017	to	Thu 06/29/2017		MOSES SOUTH	<b>1550 MW</b>
0001	Continuous	0600		Impacts Total Transfer Capability	1600 MW
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA_765_7040</b>				FWD	REV
				(Import)	(Export)
Thu 06/29/2017	to	Thu 06/29/2017		SCH - HQ - NY	<b>0 MW 0 MW</b>
0001	Continuous	0600		Impacts Total Transfer Capability	1500 MW 1000 MW
Work scheduled by: HQ				TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1</b>				FWD	
				(Import)	
Thu 06/29/2017	to	Thu 06/29/2017		MOSES SOUTH	<b>2850 MW</b>
0001	Continuous	0600		Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>					REV
					(Export)
Thu 06/29/2017	to	Thu 06/29/2017		SCH - HQ - NY	<b>500 MW</b>
0001	Continuous	0600		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD
Thu 06/29/2017	to	Thu 06/29/2017	(Import)
0001		0600	<b>MOSES SOUTH 2550 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW
-----			
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			FWD REV
Thu 06/29/2017	to	Thu 06/29/2017	(Import) (Export)
0001		0600	<b>SCH - HQ - NY 1370 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 130 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
-----			
<b>CHAT_DC_GC2</b>			FWD
Thu 06/29/2017	to	Thu 06/29/2017	(Import)
0001	Continuous	0600	<b>MOSES SOUTH 2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
-----			
<b>CHAT_DC_GC2</b>			REV
Thu 06/29/2017	to	Thu 06/29/2017	(Export)
0001	Continuous	0600	<b>SCH - HQ - NY 500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
-----			
<b>SCH-IMO-NYISO_NIAGARA_CB_3302</b>			FWD REV
Thu 06/29/2017	to	Thu 06/29/2017	(Import) (Export)
0500	Continuous	1700	<b>SCH - OH - NY 1000 MW 1600 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1000 MW 0 MW
			TTC with All Lines In Service 2000 MW 1600 MW
-----			
<b>EASTVIEW-SPRNBRK_345_W65</b>			FWD
Sat 07/01/2017	to	Sat 07/01/2017	(Import)
0001	Continuous	0030	<b>UPNY CONED 4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW
-----			
<b>MILLWOOD-EASTVIEW_345_W82</b>			FWD
Sat 07/01/2017	to	Sat 07/01/2017	(Import)
0001	Continuous	0030	<b>UPNY CONED 4350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 750 MW
			TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EASTVIEW-SPRNBRK__345_W65</b>					FWD
Sun 07/02/2017	to	Sun 07/02/2017			(Import)
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>					FWD
Sun 07/02/2017	to	Sun 07/02/2017			(Import)
0130	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					FWD      REV
Wed 07/05/2017	to	Fri 07/07/2017	<b>UPDATED</b>	<b>by NGRID 06/19/2017</b>	(Import) (Export)
0600	Continuous	1900			SCH - HQ_CEDARS <b>70 MW    40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 120 MW    0 MW
					TTC with All Lines In Service 190 MW    40 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD      REV
Wed 07/05/2017	to	Fri 07/07/2017	<b>UPDATED</b>	<b>by NGRID 06/19/2017</b>	(Import) (Export)
0600	Continuous	1900			SCH - HQ_CEDARS <b>70 MW    40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 120 MW    0 MW
					TTC with All Lines In Service 190 MW    40 MW
<b>E13THSTA-FARRAGUT_345_45</b>					FWD
Sun 07/09/2017	to	Sun 07/09/2017			(Import)
0001	Continuous	0215		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD
Sun 07/09/2017	to	Sun 07/09/2017			(Import)
0001	Continuous	0215		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD
Mon 07/10/2017	to	Mon 07/24/2017			(Import)
0500	Continuous	1730		CENTRAL EAST - VC	<b>2720 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
<b>DOLSONAV-ROCKTVRN_345_DART44</b>					(Import)	
Mon 07/10/2017	to	Mon 07/24/2017				
0500	Continuous	1730		CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					(Import)	(Export)
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					(Import)	(Export)
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					(Import)	(Export)
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					(Import)	(Export)
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					(Import)	(Export)
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					(Import)	(Export)
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u> <u>06/19/2017</u>		
0600	Continuous	1900			<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	120 MW
					TTC with All Lines In Service	190 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p><b>CHATGUAY-MASSENA__765_7040</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>1550 MW</b></p> <p>Impacts Total Transfer Capability 1600 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>CHATGUAY-MASSENA__765_7040</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY <b>0 MW 0 MW</b></p> <p>Impacts Total Transfer Capability 1500 MW 1000 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2265 MW</b></p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>MASSENA_-MARCY___765_MSU1</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - HQ - NY <b>475 MW 1000 MW</b></p> <p>Impacts Total Transfer Capability 1025 MW 0 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p><b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA__765_7040</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 2000</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH <b>500 MW</b></p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p><b>MASSENA_-MARCY___765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b></p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 2000</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC <b>2080 MW</b></p> <p>Impacts Total Transfer Capability 895 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL\_\_345\_RP2

Tue 08/01/2017 to Fri 08/11/2017  
 0700 Continuous 1700  
 Work scheduled by: RGE

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_\_-N.SCTLND\_345\_18

Sat 08/05/2017 to Sat 08/05/2017  
 0500 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC **2090 MW**  
 Impacts Total Transfer Capability 885 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_765\_345\_AT2

Sat 08/05/2017 to Sat 08/05/2017  
 0500 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_SO\_SERIES\_COMP\_I/S

Sat 08/05/2017 to Mon 10/02/2017  
 1600 Continuous 0659  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_765\_345\_AT2

Tue 09/05/2017 to Sun 09/10/2017  
 0500 Continuous 1630  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

DUNWODIE\_345KV\_5

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**  
 2200 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_7

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**  
 2200 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBRK_-DUNWODIE_345_W75</b>					FWD	
Sat 09/09/2017	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CE</u>	<u>06/20/2017</u>	(Import)
2200	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SPRNBRK_345KV_RNS3</b>					FWD	
Sat 09/09/2017	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CE</u>	<u>06/20/2017</u>	(Import)
2200	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>MOSES_-ADIRNDCK_230_MA1</b>					FWD	
Mon 09/11/2017	to	Sat 09/16/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW	
					TTC with All Lines In Service 3150 MW	
<b>CANANDGA-STONYRDG_230_68</b>					FWD	
Mon 09/11/2017	to	Mon 09/11/2017				(Import)
0800	Continuous	1600				DYSINGER EAST <b>2850 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
<b>HURLYAVE-ROSETON_345_303</b>					FWD	
Mon 09/11/2017	to	Fri 09/29/2017				(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability 1000 MW	
					TTC with All Lines In Service 5100 MW	
<b>SPRNBRK_345KV_RNS5</b>					FWD	
Sat 09/16/2017	to	Sat 09/16/2017				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW	
					TTC with All Lines In Service 4600 MW	
<b>DUNWODIE_345KV_5</b>					FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<u>CANCELLED</u>	<u>by ConEd</u>	<u>06/20/2017</u>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_7</b>					FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<b>CANCELLED</b>	<b>by ConEd</b>	<b>06/20/2017</b>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBRK_-DUNWODIE_345_W75</b>					FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<b>CANCELLED</b>	<b>by ConEd</b>	<b>06/20/2017</b>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBRK__345KV_RNS3</b>					FWD	
Sat 09/16/2017	to	Sun 09/17/2017	<b>CANCELLED</b>	<b>by ConEd</b>	<b>06/20/2017</b>	(Import)
0001	Continuous	0100				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SPRNBRK_-W49TH_ST_345_M51</b>					FWD	
Sat 09/16/2017	to	Tue 09/26/2017				(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>GILBOA_-N.SCTLND_345_GNS-1</b>					FWD	
Mon 09/18/2017	to	Fri 10/13/2017	<b>EXTENDED</b>	<b>by NYPA</b>	<b>06/09/2017</b>	(Import)
0630	Continuous	1700				CENTRAL EAST - VC <b>2520 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
<b>NIAGARA_345_230_AT4</b>					FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017				(Import) (Export)
0700	Continuous	1530				SCH - OH - NY <b>2000 MW 1400 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW 200 MW
					TTC with All Lines In Service	2000 MW 1600 MW
<b>MOSES_-ADIRNDCK_230_MAL</b>					FWD	
Mon 09/18/2017	to	Sat 09/23/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 09/25/2017 to Sat 09/30/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**SPRNBRK\_\_345KV\_RNS5**

Tue 09/26/2017 to Tue 09/26/2017  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**RAMAPO\_\_-LADENTWN\_345\_W72**

Mon 10/02/2017 to Thu 10/12/2017  
 0001 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

-----  
**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 10/02/2017 to Fri 10/06/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**DYSINGER EAST 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASER\_\_-COOPERS\_\_345\_33**

Mon 10/02/2017 to Fri 10/13/2017  
 0700 Continuous 1900  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**CENTRAL EAST - VC 2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

-----  
**WETHSRFD-MEYER\_\_230\_85/87**

Mon 10/09/2017 to Fri 10/20/2017  
 0700 Continuous 1400  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**DYSINGER EAST 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

-----  
**EGRDNCTY\_345\_138\_AT1**

Fri 10/13/2017 to Fri 11/17/2017  
 0001 Continuous 2359  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EGRDNCTY\_345\_138\_AT2**

Fri 10/13/2017 to Fri 11/17/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

**SPRNBRK\_-EGRDNCTR\_345\_Y49**

Fri 10/13/2017 to Fri 11/17/2017  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

Fri 10/13/2017 to Mon 11/06/2017  
1900 Continuous 0559

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2740 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2975 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_765\_345\_AT1**

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by NYISO 03/24/2017**  
0700 Continuous 1530

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>			FWD
Sat 10/14/2017 to Sat 10/28/2017	<b>UPDATED</b>	<b>by NYISO 03/24/2017</b>	(Import)
0700 Continuous 1530			<b>CENTRAL EAST - VC 2265 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
<b>MASSENA -MARCY 765_MSU1</b>			FWD
Sat 10/14/2017 to Sat 10/28/2017	<b>UPDATED</b>	<b>by NYISO 03/24/2017</b>	(Import)
0700 Continuous 1530			<b>MOSES SOUTH 500 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>MASSENA -MARCY 765_MSU1</b>			FWD REV
Sat 10/14/2017 to Sat 10/28/2017	<b>UPDATED</b>	<b>by NYISO 03/24/2017</b>	(Import) (Export)
0700 Continuous 1530			<b>SCH - HQ - NY 475 MW 1000 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<hr/>			
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>			FWD
Sat 10/14/2017 to Sat 10/28/2017			(Import)
0700 1530			<b>MOSES SOUTH 500 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
<b>MASSENA -MARCY 765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>			FWD
Sat 10/14/2017 to Sat 10/28/2017			(Import)
0700 1530			<b>CENTRAL EAST - VC 2080 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 895 MW
			TTC with All Lines In Service 2975 MW
<hr/>			
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>			FWD REV
Sat 10/14/2017 to Sat 10/28/2017			(Import) (Export)
0700 1530			<b>SCH - HQ - NY 850 MW 0 MW</b>
Work scheduled by:			Impacts Total Transfer Capability 650 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<hr/>			
<b>COOPERS -MIDDLETP 345_CCRT34</b>			FWD
Mon 10/16/2017 to Sat 10/28/2017	<b>UPDATED</b>	<b>by NYISO 06/21/2017</b>	(Import)
0700 Continuous 1500			<b>CENTRAL EAST - VC 2720 MW</b>
Work scheduled by: NYSEG			Impacts Total Transfer Capability 255 MW
			TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>					FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1000 MW
						TTC with All Lines In Service 5100 MW
<b>LEEDS__-HURLYAVE_345_301</b>					FWD	
Mon 10/16/2017	to	Fri 11/03/2017				(Import)
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>
Work scheduled by: CHGE						Impacts Total Transfer Capability 1000 MW
						TTC with All Lines In Service 5100 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Mon 10/23/2017	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>02/17/2017</u>	(Import) (Export)
0800	Continuous	0959				SCH - PJ - NY <b>1950 MW 1350 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability 150 MW 0 MW
						TTC with All Lines In Service 2100 MW 1350 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 10/30/2017	to	Fri 11/03/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
<b>FRASANX-COOPERS__345_UCC2-41</b>					FWD	
Mon 11/06/2017	to	Fri 11/17/2017				(Import)
0600	Continuous	1700				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>					FWD	
Mon 11/06/2017	to	Fri 11/17/2017				(Import)
0600	Continuous	1700				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 475 MW
						TTC with All Lines In Service 2975 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 11/06/2017	to	Thu 11/09/2017				(Import)
0700	Continuous	1530				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>LINDN_CG-LNDVFT___345_V-3022</p> <p>Mon 11/06/2017 to Thu 11/09/2017</p> <p style="padding-left: 40px;">0800 Continuous 1500</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV</p> <p style="text-align: right;">(Import) (Export)</p> <p>SCH - PJM_VFT <b>0 MW 0 MW</b></p> <p>Impacts Total Transfer Capability 315 MW 315 MW</p> <p>TTC with All Lines In Service 315 MW 315 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 11/13/2017 to Fri 11/17/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY_SO_SERIES_COMP_I/S</p> <p>Fri 11/17/2017 to Sat 02/01/2020</p> <p style="padding-left: 40px;">1700 Continuous 0000</p> <p>Work scheduled by: NYISO</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>CENTRAL EAST - VC <b>2740 MW</b></p> <p>Impacts Total Transfer Capability 235 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/20/2017 to Wed 11/22/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 11/27/2017 to Fri 12/01/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY___765_345_AT2</p> <p>Mon 12/04/2017 to Fri 12/08/2017</p> <p style="padding-left: 40px;">0500 Continuous 1630</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>1700 MW</b></p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA2</p> <p>Mon 12/11/2017 to Fri 12/15/2017</p> <p style="padding-left: 40px;">0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD</p> <p style="text-align: right;">(Import)</p> <p>MOSES SOUTH <b>2300 MW</b></p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>

ARR: 19

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Mon 12/18/2017	to	Fri 12/22/2017	<u>UPDATED</u> <u>by NYPA</u> <u>10/23/2016</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
<b>MARCY 765_345_AT2</b>				FWD	
Wed 12/27/2017	to	Thu 12/28/2017		(Import)	
0500	Continuous	1630		MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
Mon 03/19/2018	to	Fri 04/20/2018		(Import)	(Export)
1000	Continuous	1559		SCH - PJ - NY	<b>1950 MW 1350 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	350 MW 100 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<b>NEPTUNE -DUFFYAVE_345_NEPTUNE</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800		SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800		SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800		SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800		SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: PJM				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Friday ,June 23, 2017 to Sunday ,December 23, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK\_\_230\_68

Fri 04/20/2018 to Sat 02/01/2020  
 1600 Continuous 0000  
 Work scheduled by: NYISO

UPDATED by NYISO 05/17/2017

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW