

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__345_345_PAR3500					FWD	REV
Fri 06/24/2016 to Fri 09/15/2017 EXT FORCE by CONED 03/22/2017					(Import)	(Export)
1940	Continuous	2359			1650 MW	1250 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	450 MW 100 MW
					TTC with All Lines In Service	2100 MW 1350 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 11/24/2016 to Sat 09/30/2017 UPDATED by PJM 05/18/2017					(Import)	
1500	Continuous	2359			0 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK__230_68 & RAMAPO__345_345_PAR3500					FWD	REV
Tue 05/02/2017 to Fri 09/15/2017					(Import)	(Export)
1710		2359			1450 MW	1250 MW
Work scheduled by:					Impacts Total Transfer Capability	650 MW 100 MW
					TTC with All Lines In Service	2100 MW 1350 MW
S.RIPLEY-DUNKIRK__230_68					FWD	REV
Tue 05/02/2017 to Mon 10/23/2017 UPDATED by NYISO 05/17/2017					(Import)	(Export)
1710	Continuous	0759			1950 MW	1350 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
SCH-HQ-NYISO_LIMIT_1400					FWD	
Thu 06/08/2017 to Fri 12/15/2017 UPDATED by HQ 05/25/2017					(Import)	
0600	Continuous	1700			1400 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1500 MW
SCH-NYISO-HQ_LIMIT_800						REV
Thu 06/08/2017 to Fri 12/15/2017 UPDATED by HQ 05/25/2017						(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
CEDARS__-ROSEMNTA_115_1/11					FWD	REV
Wed 06/14/2017 to Wed 06/21/2017 UPDATED by HQ 06/16/2017					(Import)	(Export)
0700	Continuous	1700			95 MW	40 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	95 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW

ARR: 38

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTA_115_1/11

Wed 06/14/2017 to Wed 06/21/2017
0700 Continuous 1700

UPDATED by HQ 06/16/2017

Work scheduled by: HQ

ARR: 38

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
95 MW	40 MW
95 MW	0 MW
190 MW	40 MW

SCH-HQ_CEDARS-NYISO_LIMIT_80

Wed 06/14/2017 to Wed 06/21/2017
0700 Continuous 1700

UPDATED by HQ 06/16/2017

Work scheduled by: HQ

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
80 MW
110 MW
190 MW

MARCY_SO_SERIES_COMP_I/S

Fri 06/16/2017 to Tue 06/20/2017
1700 Continuous 1828

Work scheduled by: NYISO

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
2740 MW
235 MW
2975 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/19/2017 to Fri 06/23/2017
0600 Continuous 1900

UPDATED by NGRID 06/20/2017

Work scheduled by: NGrid

ARR: 38

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
70 MW	40 MW
120 MW	0 MW
190 MW	40 MW

SCH-NPX_1385-NYISO_LIMIT_25

Tue 06/20/2017 to Wed 06/21/2017
0001 Continuous 2359

Work scheduled by: LI

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
25 MW
175 MW
200 MW

SCH-NYISO-NPX_1385_LIMIT_25

Tue 06/20/2017 to Wed 06/21/2017
0001 Continuous 2359

Work scheduled by: LI

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

REV
(Export)
25 MW
175 MW
200 MW

SCH-NYISO-IMO_NIAGARA_CB_3022

Tue 06/20/2017 to Wed 06/21/2017
0500 Continuous 1530

EXTENDED by NYPA 06/20/2017

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
1300 MW	1150 MW
700 MW	450 MW
2000 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_950					FWD	
Tue 06/20/2017	to	Tue 06/20/2017			(Import)	
0700	Daily(No Weekends)	1830		SCH - OH - NY	1250 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	2000 MW
BROWNFLS-TAYLORVL_115_3					FWD	REV
Tue 06/20/2017	to	Fri 06/23/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/20/2017</u>	(Import) (Export)
0818	Continuous	1900				
Work scheduled by: NGrid					ARR: 38	
					SCH - HQ_CEDARS	70 MW 40 MW
					Impacts Total Transfer Capability	120 MW 0 MW
					TTC with All Lines In Service	190 MW 40 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Thu 06/22/2017	to	Thu 06/22/2017	<u>UPDATED</u>	<u>by LI</u>	<u>06/20/2017</u>	(Import) (Export)
0600	Continuous	2359				
Work scheduled by: LI					SCH - NPX_CSC	0 MW 0 MW
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
MARCY_SO_SERIES_COMP_I/S					FWD	
Thu 06/22/2017	to	Sat 08/05/2017	<u>CANCELLED</u>	<u>by NYISO</u>	<u>06/22/2017</u>	(Import)
1349	Continuous	0459				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
STONYRDG-HILLSIDE_230_72					FWD	
Thu 06/22/2017	to	Thu 06/22/2017	<u>EXT FORCE</u>	<u>by NYSEG</u>	<u>06/21/2017</u>	(Import)
1500	Continuous	1600				
Work scheduled by: NYSEG					DYSINGER EAST	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
MARION__-FARRAGUT_345_C3403					FWD	REV
Sat 06/24/2017	to	Tue 06/27/2017				(Import) (Export)
0000	Continuous	2359				
Work scheduled by: ConEd					SCH - PJ - NY	2100 MW 1350 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
W49TH_ST_345KV_6					FWD	
Sat 06/24/2017	to	Sat 06/24/2017				(Import)
0001	Continuous	0500				
Work scheduled by: ConEd					SCH - PJM_HTP	320 MW
					Impacts Total Transfer Capability	340 MW
					TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 06/24/2017 to Sat 06/24/2017
 0001 Continuous 0500
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **315 MW**
 Impacts Total Transfer Capability 345 MW
 TTC with All Lines In Service 660 MW

BROWNFLS-TAYLORVL_115_3

Mon 06/26/2017 to Fri 06/30/2017 **UPDATED by NYISO 06/21/2017**
 0600 Continuous 1900
 Work scheduled by: NGrid **ARR: 38**

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

BROWNFLS-TAYLORVL_115_4

Mon 06/26/2017 to Fri 06/30/2017 **UPDATED by NYISO 06/21/2017**
 0600 Continuous 1900
 Work scheduled by: NGrid **ARR: 38**

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **70 MW 40 MW**
 Impacts Total Transfer Capability 120 MW 0 MW
 TTC with All Lines In Service 190 MW 40 MW

SCH-IMO-NYISO_LIMIT_1050

Mon 06/26/2017 to Fri 06/30/2017
 0730 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 SCH - OH - NY **1350 MW**
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 2000 MW

SCH-NYISO-PJM_LIMIT_100

Mon 06/26/2017 to Thu 06/29/2017 **UPDATED by PJM 06/23/2017**
 0800 Continuous 1600
 Work scheduled by: PJM

REV
 (Export)
 SCH - PJ - NY **400 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 1350 MW

SCH-IMO_NY_NIAG_CB_3122_W/BB

Tue 06/27/2017 to Wed 06/28/2017 **UPDATED by NYISO 06/22/2017**
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1700 MW 1400 MW**
 Impacts Total Transfer Capability 300 MW 200 MW
 TTC with All Lines In Service 2000 MW 1600 MW

MARCY_765_345_AT2

Wed 06/28/2017 to Wed 06/28/2017
 0500 Continuous 1730
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SCH-IMO-NYISO_LIMIT_700			FWD
Wed 06/28/2017	to	Thu 06/29/2017	(Import)
0800	Continuous	1800	1000 MW
Work scheduled by: IESO			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 2000 MW
<hr/>			
CHATGUAY-MASSENA_765_7040			FWD
Thu 06/29/2017	to	Thu 06/29/2017	(Import)
0001	Continuous	0600	1550 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 1600 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
CHATGUAY-MASSENA_765_7040			FWD REV
Thu 06/29/2017	to	Thu 06/29/2017	(Import) (Export)
0001	Continuous	0600	0 MW 0 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 1500 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW
<hr/>			
CHAT_DC_GC1			FWD
Thu 06/29/2017	to	Thu 06/29/2017	(Import)
0001	Continuous	0600	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 300 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
CHAT_DC_GC1			REV
Thu 06/29/2017	to	Thu 06/29/2017	(Export)
0001	Continuous	0600	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability 500 MW
			TTC with All Lines In Service 1000 MW
<hr/>			
CHAT_DC_GC1 & CHAT_DC_GC2			FWD
Thu 06/29/2017	to	Thu 06/29/2017	(Import)
0001		0600	2550 MW
Work scheduled by:			Impacts Total Transfer Capability 600 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
CHAT_DC_GC1 & CHAT_DC_GC2			FWD REV
Thu 06/29/2017	to	Thu 06/29/2017	(Import) (Export)
0001		0600	1370 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability 130 MW 1000 MW
			TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Thu 06/29/2017 to Thu 06/29/2017
 0001 Continuous 0600
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Thu 06/29/2017 to Thu 06/29/2017
 0001 Continuous 0600
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

SCH-IMO-NYISO_NIAGARA_CB_3302

Thu 06/29/2017 to Thu 06/29/2017
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **1000 MW 1600 MW**
 Impacts Total Transfer Capability 1000 MW 0 MW
 TTC with All Lines In Service 2000 MW 1600 MW

EASTVIEW-SPRNBK__345_W65

Sat 07/01/2017 to Sat 07/01/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Sat 07/01/2017 to Sat 07/01/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBK__345_W65

Sun 07/02/2017 to Sun 07/02/2017
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W82

Sun 07/02/2017 to Sun 07/02/2017
 0130 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 750 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
BROWNFLS-TAYLORVL_115_3							
Wed 07/05/2017	to	Fri 07/07/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900					
Work scheduled by: NGrid							
						70 MW	40 MW
						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
							40 MW
BROWNFLS-TAYLORVL_115_4							
Wed 07/05/2017	to	Fri 07/07/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900					
Work scheduled by: NGrid							
						70 MW	40 MW
						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
							40 MW
E13THSTA-FARRAGUT_345_45							
Sun 07/09/2017	to	Sun 07/09/2017					
0001	Continuous	0215					
Work scheduled by: ConEd							
						3800 MW	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
W49TH_ST-E13THSTA_345_M54							
Sun 07/09/2017	to	Sun 07/09/2017					
0001	Continuous	0215					
Work scheduled by: ConEd							
						3800 MW	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
COOPERS_-DOLSONAV_345_CCDA42							
Mon 07/10/2017	to	Mon 07/24/2017					
0500	Continuous	1730					
Work scheduled by: NYPA							
						2720 MW	
						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
DOLSONAV-ROCKTVRN_345_DART44							
Mon 07/10/2017	to	Mon 07/24/2017					
0500	Continuous	1730					
Work scheduled by: NYPA							
						2720 MW	
						Impacts Total Transfer Capability	255 MW
						TTC with All Lines In Service	2975 MW
BROWNFLS-TAYLORVL_115_3							
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>		
0600	Continuous	1900					
Work scheduled by: NGrid							
						70 MW	40 MW
						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
							40 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BROWNFLS-TAYLORVL_115_4						FWD	REV
Mon 07/10/2017	to	Fri 07/14/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
BROWNFLS-TAYLORVL_115_3						FWD	REV
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
BROWNFLS-TAYLORVL_115_4						FWD	REV
Mon 07/17/2017	to	Fri 07/21/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
BROWNFLS-TAYLORVL_115_3						FWD	REV
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
BROWNFLS-TAYLORVL_115_4						FWD	REV
Mon 07/24/2017	to	Fri 07/28/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/19/2017</u>	(Import)	(Export)
0600	Continuous	1900				70 MW	40 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	120 MW
						TTC with All Lines In Service	190 MW
						ARR: 38	40 MW
CHATGUAY-MASSENA_765_7040						FWD	REV
Sat 07/29/2017	to	Sat 07/29/2017				(Import)	(Export)
0500	Continuous	2000				1550 MW	0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040						FWD	REV
Sat 07/29/2017	to	Sat 07/29/2017				(Import)	(Export)
0500	Continuous	2000				0 MW	0 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2265 MW</p> <p>Impacts Total Transfer Capability 710 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MASSENA -MARCY 765_MSU1</p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 Continuous 2000</p> <p>Work scheduled by: NYPA</p>	<p>FWD REV (Import) (Export)</p> <p>SCH - HQ - NY 475 MW 1000 MW</p> <p>Impacts Total Transfer Capability 1025 MW 0 MW</p> <p>TTC with All Lines In Service 1500 MW 1000 MW</p>
<p>MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040</p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 2000</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>MOSES SOUTH 500 MW</p> <p>Impacts Total Transfer Capability 2650 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S</p> <p>Sat 07/29/2017 to Sat 07/29/2017 0500 2000</p> <p>Work scheduled by:</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2080 MW</p> <p>Impacts Total Transfer Capability 895 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>ROCHESTR-PANNELL 345_RP2</p> <p>Tue 08/01/2017 to Fri 08/11/2017 0700 Continuous 1700</p> <p>Work scheduled by: RGE</p>	<p>FWD (Import)</p> <p>DYSINGER EAST 2300 MW</p> <p>Impacts Total Transfer Capability 850 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MARCY -N.SCTLND 345_18</p> <p>Sat 08/05/2017 to Sat 08/05/2017 0500 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>FWD (Import)</p> <p>CENTRAL EAST - VC 2090 MW</p> <p>Impacts Total Transfer Capability 885 MW</p> <p>TTC with All Lines In Service 2975 MW</p>

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 08/05/2017 to Sat 08/05/2017
0500 Continuous 1530

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY_SO_SERIES_COMP_I/S

Sat 08/05/2017 to Mon 10/02/2017
1600 Continuous 0659

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_5

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-DUNWODIE_345_W75

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_345KV_RNS3

Sat 09/09/2017 to Sun 09/10/2017 **UPDATED by CE 06/20/2017**
2200 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CANANDGA-STONYRDG_230_68

Mon 09/11/2017 to Mon 09/11/2017
0800 Continuous 1600

Work scheduled by: NYSEG

FWD
(Import)
DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

SPRNBRK__345KV_RNS5

Sat 09/16/2017 to Sat 09/16/2017
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Sat 09/16/2017 to Sun 09/17/2017 **CANCELLED by ConEd 06/20/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Sat 09/16/2017 to Sun 09/17/2017 **CANCELLED by ConEd 06/20/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-DUNWODIE_345_W75

Sat 09/16/2017 to Sun 09/17/2017 **CANCELLED by ConEd 06/20/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS3

Sat 09/16/2017 to Sun 09/17/2017
0001 Continuous 0100

CANCELLED by ConEd 06/20/2017

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SPRNBRK_-W49TH_ST_345_M51

Sat 09/16/2017 to Tue 09/26/2017
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 09/18/2017 to Fri 10/13/2017
0630 Continuous 1700

EXTENDED by NYPA 06/09/2017

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2520 MW**
Impacts Total Transfer Capability 455 MW
TTC with All Lines In Service 2975 MW

NIAGARA_345_230_AT4

Mon 09/18/2017 to Tue 09/19/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2000 MW 1600 MW

MOSES_-ADIRNDCK_230_MAI

Mon 09/18/2017 to Sat 09/23/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MAI

Mon 09/25/2017 to Sat 09/30/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS5

Tue 09/26/2017 to Tue 09/26/2017
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__-LADENTWN_345_W72

Mon 10/02/2017 to Thu 10/12/2017
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4400 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 10/02/2017 to Fri 10/06/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASER_-COOPERS_345_33

Mon 10/02/2017 to Fri 10/13/2017
 0700 Continuous 1900
 Work scheduled by: NYSEG

FWD
 (Import)
CENTRAL EAST - VC 2395 MW
 Impacts Total Transfer Capability 580 MW
 TTC with All Lines In Service 2975 MW

WETHSRFD-MEYER_230_85/87

Mon 10/09/2017 to Fri 10/20/2017
 0700 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
DYSINGER EAST 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

EGRDNCTY_345_138_AT1

Fri 10/13/2017 to Fri 11/17/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1250 MW
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Fri 10/13/2017 to Fri 11/17/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 1250 MW
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Fri 10/13/2017 to Fri 11/17/2017
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
CONED - LIPA 775 MW
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S					FWD	
Fri 10/13/2017	to	Mon 11/06/2017			(Import)	
1900	Continuous	0559		CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA__765_7040					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	1550 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040					FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	(Export)
0700	Continuous	1530		SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1500 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
MARCY__765_345_AT1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	1750 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	3150 MW
MARCY__765_345_AT2					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	1700 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2265 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW
MASSENA_-MARCY__765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO 03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	500 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start	End	Status	By	Effective Date	Direction	Value
MASSENA -MARCY 765_MSU1	Sat 10/14/2017 0700	Sat 10/28/2017 1530	UPDATED	NYISO	03/24/2017	FWD (Import)	475 MW
Work scheduled by: NYPA						REV (Export)	1000 MW
Impacts Total Transfer Capability						1025 MW	0 MW
TTC with All Lines In Service						1500 MW	1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 10/14/2017 0700	Sat 10/28/2017 1530				FWD (Import)	500 MW
Work scheduled by:						MOSES SOUTH	2650 MW
Impacts Total Transfer Capability						3150 MW	
TTC with All Lines In Service							
MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S	Sat 10/14/2017 0700	Sat 10/28/2017 1530				FWD (Import)	2080 MW
Work scheduled by:						CENTRAL EAST - VC	895 MW
Impacts Total Transfer Capability						2975 MW	
TTC with All Lines In Service							
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 10/14/2017 0700	Sat 10/28/2017 1530				FWD (Import) (Export)	850 MW 0 MW
Work scheduled by:						SCH - HQ - NY	650 MW 1000 MW
Impacts Total Transfer Capability						1500 MW 1000 MW	
TTC with All Lines In Service							
COOPERS -MIDDLETP 345_CCRT34	Mon 10/16/2017 0700	Sat 10/28/2017 1500	UPDATED	NYISO	06/21/2017	FWD (Import)	2720 MW
Work scheduled by: NYSEG						CENTRAL EAST - VC	255 MW
Impacts Total Transfer Capability						2975 MW	
TTC with All Lines In Service							
HURLYAVE-ROSETON 345_303	Mon 10/16/2017 0800	Fri 11/03/2017 1600	UPDATED	CH	06/07/2017	FWD (Import)	4100 MW
Work scheduled by: CHGE						UPNY CONED	1000 MW
Impacts Total Transfer Capability						5100 MW	
TTC with All Lines In Service							
LEEDS -HURLYAVE 345_301	Mon 10/16/2017 0800	Fri 11/03/2017 1600				FWD (Import)	4100 MW
Work scheduled by: CHGE						UPNY CONED	1000 MW
Impacts Total Transfer Capability						5100 MW	
TTC with All Lines In Service							

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
S.RIPLEY-DUNKIRK__230_68							
Mon 10/23/2017	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by PJM</u>	<u>02/17/2017</u>		
0800	Continuous	0959					
Work scheduled by: PJM						SCH - PJ - NY	1950 MW
						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2100 MW 1350 MW
MOSES__-ADIRNDCK_230_MA2							
Mon 10/30/2017	to	Fri 11/03/2017				FWD	
0700	Continuous	1530				(Import)	
Work scheduled by: NYPA						MOSES SOUTH	2100 MW
						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
FRASANNX-COOPERS__345_UCC2-41							
Mon 11/06/2017	to	Fri 11/17/2017				FWD	
0600	Continuous	1700				(Import)	
Work scheduled by: NYPA						CENTRAL EAST - VC	2500 MW
						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
MARCY__-FRASANNX_345_UCC2-41							
Mon 11/06/2017	to	Fri 11/17/2017				FWD	
0600	Continuous	1700				(Import)	
Work scheduled by: NYPA						CENTRAL EAST - VC	2500 MW
						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
							ARR: 19
MOSES__-ADIRNDCK_230_MA2							
Mon 11/06/2017	to	Thu 11/09/2017				FWD	
0700	Continuous	1530				(Import)	
Work scheduled by: NYPA						MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
LINDN_CG-LNDVFT__345_V-3022							
Mon 11/06/2017	to	Thu 11/09/2017				FWD	REV
0800	Continuous	1500				(Import)	(Export)
Work scheduled by: PJM						SCH - PJM_VFT	0 MW 0 MW
						Impacts Total Transfer Capability	315 MW 315 MW
						TTC with All Lines In Service	315 MW 315 MW
MOSES__-ADIRNDCK_230_MA2							
Mon 11/13/2017	to	Fri 11/17/2017				FWD	
0700	Continuous	1530				(Import)	
Work scheduled by: NYPA						MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Fri 11/17/2017 to Sat 02/01/2020
 1700 Continuous 0000
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017 **UPDATED by NYPA 10/23/2016**
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,June 25, 2017 to Tuesday ,December 25, 2018

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68

Mon 03/19/2018 to Fri 04/20/2018
 1000 Continuous 1559
 Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1950 MW	1350 MW
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

	FWD
	(Import)
SCH - PJM_NEPTUNE	0 MW
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

	FWD
	(Import)
SCH - PJM_NEPTUNE	0 MW
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_1

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

NEWBRDGE_345_138_BK_2

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

	FWD
	(Import)
SCH - PJM_NEPTUNE	375 MW
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

S.RIPLEY-DUNKIRK__230_68

Fri 04/20/2018 to Sat 02/01/2020 **UPDATED by NYISO 05/17/2017**
 1600 Continuous 0000
 Work scheduled by: NYISO

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1950 MW	1350 MW
Impacts Total Transfer Capability	350 MW	100 MW
TTC with All Lines In Service	2300 MW	1450 MW