

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500					FWD	REV
Fri 06/24/2016	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/02/2017</u>	(Import) (Export)
1940	Continuous	0200				1650 MW 1250 MW
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability	450 MW 100 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<hr/>						
HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 11/24/2016	to	Sat 09/30/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>05/18/2017</u>	(Import)
1500	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<hr/>						
S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR3500					FWD	REV
Tue 05/02/2017	to	Sun 09/10/2017				(Import) (Export)
1710		0200				1450 MW 1250 MW
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	650 MW 100 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<hr/>						
S.RIPLEY-DUNKIRK__230_68					FWD	REV
Tue 05/02/2017	to	Mon 10/23/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/17/2017</u>	(Import) (Export)
1710	Continuous	0759				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	
					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<hr/>						
SCH-NYISO-HQ_LIMIT_800						REV
Thu 06/08/2017	to	Fri 12/15/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>08/03/2017</u>	(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					SCH - HQ - NY	
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
<hr/>						
SCH-IMO-NYISO_LIMIT_1400					FWD	
Fri 06/30/2017	to	Tue 10/31/2017	<u>EXTENDED</u>	<u>by NYISO</u>	<u>07/28/2017</u>	(Import)
0001	Continuous	2359				1700 MW
Work scheduled by: NYISO					SCH - OH - NY	
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	2000 MW
<hr/>						
SCH-HQ-NYISO_LIMIT_1450					FWD	
Tue 08/01/2017	to	Fri 12/15/2017				(Import)
2100	Continuous	1600				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_100

REV

Mon 08/07/2017 to Fri 08/11/2017
 0800 Continuous 1500
 Work scheduled by: PJM

UPDATED by NYISO 08/04/2017

SCH - PJ - NY (Export) **400 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 1350 MW

DUNWODIE_345KV_6

FWD

Thu 08/10/2017 to Thu 08/10/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

(Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

FWD

Thu 08/10/2017 to Thu 08/10/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

(Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

FWD

Thu 08/10/2017 to Thu 08/10/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

(Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_6

FWD

Thu 08/10/2017 to Thu 08/10/2017
 1700 Continuous 1730
 Work scheduled by: ConEd

(Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

FWD

Thu 08/10/2017 to Thu 08/10/2017
 1700 Continuous 1730
 Work scheduled by: ConEd

(Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W90

FWD

Thu 08/10/2017 to Thu 08/10/2017
 1700 Continuous 1730
 Work scheduled by: ConEd

(Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Fri 08/11/2017 to Mon 08/21/2017
0001 Continuous 2359

Work scheduled by: ConEd

CANCELLED by ConEd 08/10/2017

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
2100 MW	1350 MW
0 MW	0 MW
2100 MW	1350 MW

MARION_-FARRAGUT_345_C3403

Fri 08/11/2017 to Mon 08/21/2017
0001 Continuous 2359

Work scheduled by: ConEd

CANCELLED by ConEd 08/10/2017

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD	REV
(Import)	(Export)
2100 MW	1350 MW
0 MW	0 MW
2100 MW	1350 MW

MARCY_345KV_CSC

Fri 08/11/2017 to Fri 08/11/2017
0500 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
2925 MW
50 MW
2975 MW

DUNWODIE_345KV_3

Sat 08/12/2017 to Sat 08/12/2017
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
3800 MW
800 MW
4600 MW

DUNWODIE_345KV_4

Sat 08/12/2017 to Sat 08/12/2017
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
3800 MW
800 MW
4600 MW

PLSNTVLE-DUNWODIE_345_W89

Sat 08/12/2017 to Sat 08/12/2017
0001 Continuous 2130

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
4000 MW
1100 MW
5100 MW

DUNWODIE_345KV_3

Sat 08/12/2017 to Sat 08/12/2017
2100 Continuous 2130

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)
3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<p>DUNWODIE_345KV_4</p> <p>Sat 08/12/2017 to Sat 08/12/2017 2100 Continuous 2130</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>			
<hr/>				
<p>EASTVIEW-SPRNBK__345_W64</p> <p>Sun 08/13/2017 to Sun 08/13/2017 0001 Continuous 1730</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>UPNY CONED 4350 MW</p> <p>Impacts Total Transfer Capability 750 MW</p> <p>TTC with All Lines In Service 5100 MW</p>			
<hr/>				
<p>SPRNBK__345KV_RNS5</p> <p>Sun 08/13/2017 to Sun 08/13/2017 0001 Continuous 1730</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3200 MW</p> <p>Impacts Total Transfer Capability 1400 MW</p> <p>TTC with All Lines In Service 4600 MW</p>			
<hr/>				
<p>SCH-HQ_CEDARS-NYISO_LIMIT_140</p> <p>Mon 08/14/2017 to Wed 08/16/2017 1700 Continuous 2359</p> <p>Work scheduled by: HQ</p>	<p style="text-align: right;">FWD (Import)</p> <p>FORCED by HQ 08/14/2017</p> <p>SCH - HQ_CEDARS 140 MW</p> <p>Impacts Total Transfer Capability 50 MW</p> <p>TTC with All Lines In Service 190 MW</p>			
<hr/>				
<p>HUDSONP_-FARRAGUT_345_B3402</p> <p>Tue 08/15/2017 to Sat 08/26/2017 2100 Continuous 2359</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 2100 MW 1350 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 2100 MW 1350 MW</p>			
<hr/>				
<p>HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403</p> <p>Tue 08/15/2017 to Sat 08/26/2017 2100 Continuous 2359</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 2050 MW 1300 MW</p> <p>Impacts Total Transfer Capability 50 MW 50 MW</p> <p>TTC with All Lines In Service 2100 MW 1350 MW</p>			
<hr/>				
<p>MARION_-FARRAGUT_345_C3403</p> <p>Tue 08/15/2017 to Sat 08/26/2017 2100 Continuous 2359</p> <p>Work scheduled by: ConEd</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 2100 MW 1350 MW</p> <p>Impacts Total Transfer Capability 0 MW 0 MW</p> <p>TTC with All Lines In Service 2100 MW 1350 MW</p>			

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

Mon 08/21/2017 to Sat 09/02/2017
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 08/21/2017 to Sat 09/02/2017
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2720 MW**
 Impacts Total Transfer Capability 255 MW
 TTC with All Lines In Service 2975 MW

SCH-IMO-NYISO_LIMIT_1200

Mon 08/21/2017 to Mon 08/21/2017
 1300 Continuous 1600
 Work scheduled by: IESO

FWD
 (Import)
 SCH - OH - NY **1500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 2000 MW

SCH-NYISO-IMO_LIMIT_1100

Mon 08/21/2017 to Mon 08/21/2017
 1300 Continuous 1600
 Work scheduled by: IESO

REV
 (Export)
 SCH - OH - NY **1400 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1600 MW

HOPATCON-RAMAPO__500_5018

Sun 08/27/2017 to Mon 09/11/2017 **UPDATED by CE 08/11/2017**
 0100 Continuous 0200
 Work scheduled by: ConEd

FWD REV
 (Import) (Export)
 SCH - PJ - NY **1150 MW 1000 MW**
 Impacts Total Transfer Capability 950 MW 350 MW
 TTC with All Lines In Service 2100 MW 1350 MW

HOPATCON-RAMAPO__500_5018

Sun 08/27/2017 to Mon 09/11/2017 **UPDATED by CE 08/11/2017**
 0100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 TOTAL EAST **6400 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 6500 MW

HOPATCON-RAMAPO__500_5018

Sun 08/27/2017 to Mon 09/11/2017 **UPDATED by CE 08/11/2017**
 0100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
HOPATCON-RAMAPO 500_5018 & S.RIPLEY-DUNKIRK 230_68						(Import)	(Export)
Sun 08/27/2017	to	Mon 09/11/2017				1200 MW	1300 MW
0100		0200			SCH - PJ - NY		
Work scheduled by:						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	2100 MW
<hr/>						FWD	REV
RAMAPO 345_345_PAR4500						(Import)	(Export)
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	1650 MW	1250 MW
0100	Continuous	0200					
Work scheduled by: ConEd						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	2100 MW
<hr/>						FWD	REV
RAMAPO 500_345_BK 1500						(Import)	(Export)
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	1900 MW	1000 MW
0100	Continuous	0200					
Work scheduled by: ConEd						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	2100 MW
<hr/>						FWD	REV
RAMAPO 500_345_BK 1500						(Import)	REV
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	6400 MW	
0100	Continuous	0200					
Work scheduled by: ConEd						TOTAL EAST	
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	6500 MW
<hr/>						FWD	REV
RAMAPO 500_345_BK 1500						(Import)	REV
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	4000 MW	
0100	Continuous	0200					
Work scheduled by: ConEd						UPNY CONED	
						Impacts Total Transfer Capability	1100 MW
						TTC with All Lines In Service	5100 MW
<hr/>						FWD	REV
S.RIPLEY-DUNKIRK 230_68 & RAMAPO 345_345_PAR4500						(Import)	(Export)
Sun 08/27/2017	to	Mon 09/11/2017				1450 MW	1250 MW
0100		0200					
Work scheduled by:						SCH - PJ - NY	
						Impacts Total Transfer Capability	650 MW
						TTC with All Lines In Service	2100 MW
<hr/>						FWD	REV
MARCY_SO_SERIES_COMP_I/S						(Import)	REV
Thu 08/31/2017	to	Mon 10/02/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/26/2017</u>	2740 MW	
1600	Continuous	0659					
Work scheduled by: NYISO						CENTRAL EAST - VC	
						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT__345_X28					FWD
Sat 09/02/2017	to	Sun 09/03/2017			(Import)
0001	Continuous	0100		SPR/DUN-SOUTH	4200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 4600 MW
MARCY___765_345_AT2					FWD
Tue 09/05/2017	to	Sun 09/10/2017			(Import)
0500	Continuous	1630		MOSES SOUTH	1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
E13THSTA-FARRAGUT_345_46					FWD
Sat 09/09/2017	to	Sat 09/09/2017			(Import)
0001	Continuous	0145		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_6					FWD
Sat 09/09/2017	to	Sat 09/09/2017	UPDATED	by CE	07/26/2017
0200	Continuous	0230			(Import)
Work scheduled by: ConEd					SCH - PJM_HTP 320 MW
					Impacts Total Transfer Capability 340 MW
					TTC with All Lines In Service 660 MW
W49TH_ST-E13THSTA_345_M55					FWD
Sat 09/09/2017	to	Sat 09/09/2017	UPDATED	by CE	07/26/2017
0200	Continuous	0359			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_6					FWD
Sat 09/09/2017	to	Sat 09/09/2017	UPDATED	by CE	07/26/2017
0345	Continuous	0359			(Import)
Work scheduled by: ConEd					SCH - PJM_HTP 320 MW
					Impacts Total Transfer Capability 340 MW
					TTC with All Lines In Service 660 MW
DUNWODIE_345KV_5					FWD
Sat 09/09/2017	to	Sun 09/10/2017	UPDATED	by CE	06/20/2017
2200	Continuous	0200			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH 3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Sat 09/09/2017 to Sun 09/10/2017
2200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/20/2017

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

SPRNBRK_-DUNWODIE_345_W75

Sat 09/09/2017 to Sun 09/10/2017
2200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/20/2017

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

SPRNBRK__345KV_RNS3

Sat 09/09/2017 to Sun 09/10/2017
2200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/20/2017

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD
(Import)

MOSES_-ADIRNDCK_230_MA1

Mon 09/11/2017 to Sat 09/16/2017
0700 Continuous 1730

Work scheduled by: NYPA

EXTENDED by NYPA 08/14/2017

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

CANANDGA-STONYRDG_230_68

Mon 09/11/2017 to Mon 09/11/2017
0800 Continuous 1600

Work scheduled by: NYSEG

EXTENDED by NYSEG 08/14/2017

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

HURLYAVE-ROSETON_345_303

Mon 09/11/2017 to Fri 09/29/2017
0800 Continuous 1600

Work scheduled by: CHGE

EXTENDED by CHGE 08/14/2017

UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

FWD
(Import)

STONYRDG-HILLSIDE_230_72

Wed 09/13/2017 to Wed 09/13/2017
0800 Continuous 1600

Work scheduled by: NYSEG

EXTENDED by NYSEG 08/14/2017

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FWD
(Import)

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5					FWD		
Sat 09/16/2017	to	Sat 09/16/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	(Import)	
0001	Continuous	0030				3200 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBRK_-W49TH_ST_345_M51					FWD		
Sat 09/16/2017	to	Tue 09/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	(Import)	
0001	Continuous	0300				3200 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
MARCY__-N.SCTLND_345_18					FWD		
Sat 09/16/2017	to	Sun 09/17/2017				(Import)	
0800	Continuous	1700				2090 MW	
Work scheduled by: NGrid					CENTRAL EAST - VC		
					Impacts Total Transfer Capability	885 MW	
					TTC with All Lines In Service	2975 MW	
MARCY__-N.SCTLND_345_18 & MARCY_SO_SERIES_COMP_I/S					FWD		
Sat 09/16/2017	to	Sun 09/17/2017				(Import)	
0800		1700				1855 MW	
Work scheduled by:					CENTRAL EAST - VC		
					Impacts Total Transfer Capability	1120 MW	
					TTC with All Lines In Service	2975 MW	
GILBOA__-N.SCTLND_345_GNS-1					FWD		
Mon 09/18/2017	to	Fri 10/13/2017	<u>EXTENDED</u>	<u>by NYPA</u>	<u>06/09/2017</u>	(Import)	
0630	Continuous	1700				2520 MW	
Work scheduled by: NYPA					CENTRAL EAST - VC		
					Impacts Total Transfer Capability	455 MW	
					TTC with All Lines In Service	2975 MW	
NIAGARA__345_230_AT4					FWD	REV	
Mon 09/18/2017	to	Tue 09/19/2017				(Import)	(Export)
0700	Continuous	1530				2000 MW	1400 MW
Work scheduled by: NYPA					SCH - OH - NY		
					Impacts Total Transfer Capability	0 MW	200 MW
					TTC with All Lines In Service	2000 MW	1600 MW
MOSES__-ADIRNDCK_230_MAL					FWD		
Mon 09/18/2017	to	Sat 09/23/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/15/2017</u>	(Import)	
0700	Continuous	1730				2100 MW	
Work scheduled by: NYPA					MOSES SOUTH		
					Impacts Total Transfer Capability	1050 MW	
					TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1					FWD	
Mon 09/18/2017	to	Fri 09/22/2017	<u>UPDATED</u>	<u>by PA</u>	<u>07/21/2017</u>	(Import)
0730	Continuous	1530				DYSINGER EAST 2300 MW
Work scheduled by: RGE					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
SCH-HQ_CEDARS-NYISO_LIMIT_140					FWD	
Mon 09/18/2017	to	Fri 09/29/2017				(Import)
0800	Continuous	1700				SCH - HQ_CEDARS 140 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	190 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Mon 09/18/2017	to	Fri 09/29/2017				(Export)
0800	Continuous	1700				SCH - HQ_CEDARS 0 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	40 MW
PLSNTVLY_345KV_RNS5					FWD	
Tue 09/19/2017	to	Tue 09/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	(Import)
0001	Continuous	0100				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
PLSNTVLY-WOOD_ST__345_F30					FWD	
Tue 09/19/2017	to	Wed 09/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	(Import)
0001	Continuous	2359				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
LINDEN__ -GOETHALS_230_A2253					FWD	REV
Tue 09/19/2017	to	Sun 10/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>07/28/2017</u>	(Import) (Export)
0200	Continuous	0100				SCH - PJ - NY 2100 MW 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 09/20/2017	to	Wed 09/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	(Import)
2330	Continuous	2359				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1					FWD	
Mon 09/25/2017	to	Sat 09/30/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/15/2017</u>	(Import)
0700	Continuous	1730				MOSES SOUTH 2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
FIVEMILE-STOLLERD_345_29					FWD	REV
Mon 09/25/2017	to	Mon 10/16/2017				(Import) (Export)
0800	Continuous	1400				SCH - PJ - NY 2100 MW 1350 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 0 MW 0 MW
						TTC with All Lines In Service 2100 MW 1350 MW
SPRNBK_345KV_RNS5					FWD	
Tue 09/26/2017	to	Tue 09/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	(Import)
0230	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
PANNELL -CLAY_345_2					FWD	
Tue 09/26/2017	to	Wed 09/27/2017				(Import)
0730	Continuous	1500				WEST CENTRAL 1300 MW
Work scheduled by: RGE						Impacts Total Transfer Capability 950 MW
						TTC with All Lines In Service 2250 MW
E13THSTA-FARRAGUT_345_46					FWD	
Wed 09/27/2017	to	Wed 09/27/2017				(Import)
0001	Continuous	0100				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SCH-NYISO-NE_LIMIT_800					REV	
Wed 09/27/2017	to	Wed 09/27/2017				(Export)
0600	Continuous	1600				SCH - NE - NY 1000 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 1600 MW
SPRNBK_345KV_RS3 & SPRNBK_345KV_RS4					FWD	
Sun 10/01/2017	to	Tue 10/03/2017				(Import)
0001		0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by:						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS4			FWD	
Mon 10/02/2017	to	Mon 10/02/2017	(Import)	
0001	Continuous	1900		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
W49TH_ST_345KV_5			FWD	
Mon 10/02/2017	to	Tue 10/03/2017	(Import)	
0001	Continuous	0300		SCH - PJM_HTP 315 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	345 MW
			TTC with All Lines In Service	660 MW
PLSNTVLY-EFISHKIL_345_F36			FWD	
Mon 10/02/2017	to	Mon 10/16/2017	(Import)	
0001	Continuous	0300		UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	5100 MW
SPRNBK_-W49TH_ST_345_M52			FWD	
Mon 10/02/2017	to	Wed 11/01/2017	(Import)	
0001	Continuous	0300		SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
NIAGARA_-ROCHESTR_345_NR2			FWD	
Mon 10/02/2017	to	Fri 10/06/2017	(Import)	
0700	Continuous	1530		DYSINGER EAST 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
FRASER_-COOPERS__345_33			FWD	
Mon 10/02/2017	to	Fri 10/13/2017	(Import)	
0700	Continuous	1900		CENTRAL EAST - VC 2395 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	580 MW
			TTC with All Lines In Service	2975 MW
HOMRC_NY-MAINS_NY_345_47			FWD	REV
Mon 10/02/2017	to	Fri 10/27/2017	(Import)	(Export)
0700	Continuous	1730		SCH - PJ - NY 2100 MW 1350 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2100 MW 1350 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROTRDAM-EASTOVER_230_38

Mon 10/02/2017 to Wed 10/04/2017
0800 Continuous 1200

Work scheduled by: NGrid

ARR: 77

SCH - NE - NY	1400 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1600 MW

REV
(Export)

SPRNBRK_345KV_RNS4

Mon 10/02/2017 to Fri 10/06/2017
1901 Continuous 0300

Work scheduled by: ConEd

SCH - NE - NY	1400 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

FWD
(Import)

W49TH_ST_345KV_5

Tue 10/03/2017 to Fri 10/06/2017
0301 Continuous 2100

Work scheduled by: ConEd

SCH - PJM_HTP	315 MW
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

FWD
(Import)

BECK_-NIAGARA_345_PA302

Wed 10/04/2017 to Thu 10/05/2017
0600 Continuous 1700

Work scheduled by: NYPA

UPDATED by PA 08/11/2017

SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

FWD REV
(Import) (Export)

BERKSHIR-ALPS_345_393

Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800

Work scheduled by: NGrid

ARR: 78

SCH - NE - NY	950 MW	1000 MW
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

FWD REV
(Import) (Export)

BERKSHIR-ALPS_345_393

Fri 10/06/2017 to Fri 10/06/2017
0700 Daily(No Weekends) 0800

Work scheduled by: NGrid

ARR: 78

SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

FWD REV
(Import) (Export)

BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312

Fri 10/06/2017 to Fri 10/06/2017
0700 0800

Work scheduled by:

ARR: 78

SCH - NE - NY	950 MW	1000 MW
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

FWD REV
(Import) (Export)

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BERKSHIR-NORTHFLD_345_312					
Fri 10/06/2017	to	Sat 10/28/2017			
0700	Continuous	1600	SCH - NE - NY	900 MW	1200 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	500 MW 400 MW
				TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					
Fri 10/06/2017	to	Sat 10/28/2017			
0700	Continuous	1600	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ISONE				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
SCH-NE-NYISO_LIMIT_800					
Mon 10/09/2017	to	Thu 10/12/2017			
0700	Continuous	1700	SCH - NE - NY	1000 MW	
Work scheduled by: ISONE				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1400 MW
WETHSRFD-MEYER_230_85/87					
Mon 10/09/2017	to	Fri 10/20/2017			
0700	Continuous	1400	DYSINGER EAST	2850 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
MARCY_SO_SERIES_COMP_I/S					
Fri 10/13/2017	to	Tue 10/31/2017			
1900	Continuous	2359	CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA_765_7040					
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	03/24/2017
0700	Continuous	1530	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA_765_7040					
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by NYISO	03/24/2017
0700	Continuous	1530	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1750 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW
					TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import)
0700	Continuous	1530			MOSES SOUTH 500 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u> <u>03/24/2017</u>	(Import) (Export)
0700	Continuous	1530			SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW 0 MW
					TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			MOSES SOUTH 500 MW
Work scheduled by:					Impacts Total Transfer Capability 2650 MW
					TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1 & MARCY_SO_SERIES_COMP_I/S					FWD
Sat 10/14/2017	to	Sat 10/28/2017			(Import)
0700		1530			CENTRAL EAST - VC 2080 MW
Work scheduled by:					Impacts Total Transfer Capability 895 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2

Sat 10/14/2017 to Sat 10/28/2017
 0700 1530

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

COOPERS -MIDDLETP 345_CCRT34

Mon 10/16/2017 to Sat 10/28/2017 **UPDATED by NYISO 06/21/2017**
 0700 Continuous 1500

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	2720 MW
Impacts Total Transfer Capability	255 MW
TTC with All Lines In Service	2975 MW

HURLYAVE-ROSETON 345_303

Mon 10/16/2017 to Fri 11/03/2017 **UPDATED by CH 06/07/2017**
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

LEEDS -HURLYAVE 345_301

Mon 10/16/2017 to Fri 11/03/2017
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

SPRNBRK 345KV_RNS4

Tue 10/17/2017 to Sat 10/28/2017
 0301 Continuous 0300

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

S.RIPLEY-DUNKIRK 230_68

Mon 10/23/2017 to Thu 10/26/2017 **UPDATED by NYISO 08/01/2017**
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1950 MW	1350 MW
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

S.RIPLEY-DUNKIRK 230_68

Thu 10/26/2017 to Sat 02/01/2020 **UPDATED by NYISO 05/17/2017**
 1501 Continuous 0000

Work scheduled by: NYISO

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1950 MW	1350 MW
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5			FWD	
Fri 10/27/2017	to	Wed 11/01/2017	(Import)	
0001	Continuous	0300	SCH - PJM_HTP	315 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	345 MW
			TTC with All Lines In Service	660 MW
SPRNBRK_345KV_RNS4			FWD	
Sat 10/28/2017	to	Wed 11/01/2017	(Import)	
0301	Continuous	0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW
			TTC with All Lines In Service	4600 MW
BERKSHIR-ALPS_345_393			FWD	REV
Sat 10/28/2017	to	Sat 10/28/2017	(Import)	(Export)
1500	Daily	1600	SCH - NE - NY	950 MW 1000 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW 600 MW
			TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS_345_393			FWD	REV
Sat 10/28/2017	to	Sat 10/28/2017	(Import)	(Export)
1500	Daily	1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312			FWD	REV
Sat 10/28/2017	to	Sat 10/28/2017	(Import)	(Export)
1500		1600	SCH - NE - NY	950 MW 1000 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW 600 MW
			TTC with All Lines In Service	1400 MW 1600 MW
MOSES -ADIRNDCK_230_MA2			FWD	
Mon 10/30/2017	to	Fri 11/03/2017	(Import)	
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
PLSNTVLY-EFISHKIL_345_F36			FWD	
Wed 11/01/2017	to	Sat 11/04/2017	(Import)	
0001	Continuous	0300	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46					FWD	
Thu 11/02/2017	to	Thu 11/02/2017			(Import)	
0200	Continuous	0300		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MARION_-FARRAGUT_345_C3403					FWD	REV
Thu 11/02/2017	to	Fri 11/03/2017			(Import)	(Export)
0200	Continuous	0100		SCH - PJ - NY	2300 MW	1450 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2300 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	08/02/2017	
0700	Continuous	1700				
Work scheduled by: NGrid					ARR: 78	
					SCH - NE - NY	1300 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	08/02/2017	
0700	Continuous	1700				
Work scheduled by: NGrid					ARR: 78	
					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017			(Import)	(Export)
0700		1700			1300 MW	1300 MW
Work scheduled by:					ARR: 78	
					SCH - NE - NY	1300 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	08/02/2017	
0700	Continuous	1700				
Work scheduled by: NGrid						
					SCH - NE - NY	1400 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	08/02/2017	
0700	Continuous	1700				
Work scheduled by: NGrid						
					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-EFISHKIL_345_F36		FWD	
Mon 11/06/2017	to Wed 11/08/2017	(Import)	
0001	Continuous 0300	UPNY CONED	4000 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1100 MW
		TTC with All Lines In Service	5100 MW
FRASANX-COOPERS__345_UCC2-41		FWD	
Mon 11/06/2017	to Fri 11/17/2017	(Import)	
0600	Continuous 1700	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
MARCY__-FRASANX_345_UCC2-41		FWD	
Mon 11/06/2017	to Fri 11/17/2017	(Import)	
0600	Continuous 1700	CENTRAL EAST - VC	2500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	475 MW
		TTC with All Lines In Service	2975 MW
MOSES__-ADIRNDCK_230_MA2		FWD	
Mon 11/06/2017	to Thu 11/09/2017	(Import)	
0700	Continuous 1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
LINDN_CG-LNDVFT__345_V-3022		FWD	REV
Mon 11/06/2017	to Thu 11/09/2017	(Import)	(Export)
0800	Continuous 1500	SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	315 MW 315 MW
		TTC with All Lines In Service	315 MW 315 MW
W49TH_ST_345KV_5		FWD	
Fri 11/10/2017	to Fri 11/10/2017	(Import)	
0001	Continuous 0030	SCH - PJM_HTP	315 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	345 MW
		TTC with All Lines In Service	660 MW
SPRNBK_-W49TH_ST_345_M52		FWD	
Fri 11/10/2017	to Mon 11/13/2017	(Import)	
0001	Continuous 0300	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	4600 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
SPRNBK__345KV_RNS4			FWD
Fri 11/10/2017	to	Mon 11/13/2017	(Import)
0001	Continuous	0300	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4			FWD
Sun 11/12/2017	to	Wed 11/15/2017	(Import)
0001		0300	SPR/DUN-SOUTH 3800 MW
Work scheduled by:			Impacts Total Transfer Capability 800 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
W49TH_ST_345KV_5			FWD
Mon 11/13/2017	to	Mon 11/13/2017	(Import)
0230	Continuous	0300	SCH - PJM_HTP 315 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 345 MW
			TTC with All Lines In Service 660 MW
<hr/>			
MOSES__-ADIRNDCK_230_MA2			FWD
Mon 11/13/2017	to	Fri 11/17/2017	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
SPRNBK__345KV_RNS4			FWD
Wed 11/15/2017	to	Fri 11/17/2017	(Import)
0001	Continuous	0100	SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 4600 MW
<hr/>			
EGRDNCTY_345_138_AT1			FWD
Sun 11/19/2017	to	Sat 12/23/2017	(Import)
0001	Continuous	2359	CONED - LIPA 1250 MW
Work scheduled by: LI			Impacts Total Transfer Capability 250 MW
			TTC with All Lines In Service 1500 MW
<hr/>			
EGRDNCTY_345_138_AT2			FWD
Sun 11/19/2017	to	Sat 12/23/2017	(Import)
0001	Continuous	2359	CONED - LIPA 1250 MW
Work scheduled by: LI			Impacts Total Transfer Capability 250 MW
			TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-EGRDNCTR_345_Y49					FWD
Sun 11/19/2017	to	Sat 12/23/2017	<u>UPDATED</u>	<u>by LI</u>	(Import)
0001	Continuous	2359			775 MW
Work scheduled by: LI					CONED - LIPA
					Impacts Total Transfer Capability 725 MW
					TTC with All Lines In Service 1500 MW
MOSES_-ADIRNDCK_230_MAI					FWD
Mon 11/20/2017	to	Wed 11/22/2017			(Import)
0700	Continuous	1530			2300 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
MOSES_-ADIRNDCK_230_MAI					FWD
Mon 11/27/2017	to	Fri 12/01/2017			(Import)
0700	Continuous	1530			2300 MW
Work scheduled by: NYPA					MOSES SOUTH
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
ROSETON_-EFISHKIL_345_RFK305					FWD
Mon 11/27/2017	to	Fri 12/01/2017			(Import)
0800	Continuous	1600			4100 MW
Work scheduled by: CHGE					UPNY CONED
					Impacts Total Transfer Capability 1000 MW
					TTC with All Lines In Service 5100 MW
ROTTDAM-EASTOVER_230_38					FWD
Mon 11/27/2017	to	Thu 11/30/2017			(Import) (Export)
0900	Continuous	1500			1400 MW 1400 MW
Work scheduled by: NGrid					SCH - NE - NY
					Impacts Total Transfer Capability 0 MW 200 MW
					TTC with All Lines In Service 1400 MW 1600 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD
Sun 12/03/2017	to	Tue 12/05/2017			(Import)
0001		0300			3800 MW
Work scheduled by:					UPNY CONED
					Impacts Total Transfer Capability 1300 MW
					TTC with All Lines In Service 5100 MW
LEEDS_-PLSNTVLY_345_92					FWD
Mon 12/04/2017	to	Mon 12/18/2017			(Import)
0001	Continuous	0300			3800 MW
Work scheduled by: ConEd					UPNY CONED
					Impacts Total Transfer Capability 1300 MW
					TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Mon 12/04/2017 to Mon 12/18/2017

(Import)

0001 Continuous 0300

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

MARCY_765_345_AT2

FWD

Mon 12/04/2017 to Fri 12/08/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

1700 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 12/11/2017 to Fri 12/15/2017

(Import)

0700 Continuous 1530

MOSES SOUTH

2300 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017

(Import)

0700 Continuous 1530

UPDATED by NYPA 10/23/2016

MOSES SOUTH

2300 MW

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

MARCY_765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017

(Import)

0500 Continuous 1630

MOSES SOUTH

1700 MW

Work scheduled by: NYPA

ARR: 19

Impacts Total Transfer Capability 1450 MW

TTC with All Lines In Service 3150 MW

LEEDS_-PLSNTVLY_345_92

FWD

Wed 01/03/2018 to Sat 01/06/2018

(Import)

0001 Continuous 0300

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

FWD

Wed 01/03/2018 to Sat 01/06/2018

(Import)

0001 Continuous 0300

UPNY CONED

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4
 Fri 01/05/2018 to Mon 01/08/2018
 0001 0300

Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5
 Mon 01/08/2018 to Wed 01/10/2018
 0001 Continuous 0300

Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

MARCY___765_345_AT2
 Sat 01/20/2018 to Sat 01/20/2018
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2
 Sat 02/03/2018 to Sat 02/03/2018
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2
 Mon 02/05/2018 to Fri 02/09/2018
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

HUDSONP_-FARRAGUT_345_B3402
 Sun 02/18/2018 to Sun 04/01/2018
 0001 Continuous 2359

Work scheduled by: PJM

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2300 MW 1450 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 2300 MW 1450 MW

MARCY___-EDIC___345_UE1-7
 Tue 02/20/2018 to Fri 02/23/2018
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

S.RIPLEY-DUNKIRK__230_68			FWD	REV
			(Import)	(Export)
Mon 03/19/2018	to	Fri 04/20/2018		
1000	Continuous	1559	SCH - PJ - NY	1950 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	2300 MW
				1450 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE			FWD	
			(Import)	
Mon 04/16/2018	to	Tue 05/01/2018	SCH - PJM_NEPTUNE	0 MW
0001	Continuous	1800	Impacts Total Transfer Capability	660 MW
Work scheduled by: PJM			TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501			FWD	
			(Import)	
Mon 04/16/2018	to	Tue 05/01/2018	SCH - PJM_NEPTUNE	0 MW
0001	Continuous	1800	Impacts Total Transfer Capability	660 MW
Work scheduled by: PJM			TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1			FWD	
			(Import)	
Mon 04/16/2018	to	Tue 05/01/2018	SCH - PJM_NEPTUNE	375 MW
0001	Continuous	1800	Impacts Total Transfer Capability	285 MW
Work scheduled by: PJM			TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2			FWD	
			(Import)	
Mon 04/16/2018	to	Tue 05/01/2018	SCH - PJM_NEPTUNE	375 MW
0001	Continuous	1800	Impacts Total Transfer Capability	285 MW
Work scheduled by: PJM			TTC with All Lines In Service	660 MW
MARCY___765_345_AT1			FWD	
			(Import)	
Mon 04/23/2018	to	Mon 04/23/2018	MOSES SOUTH	1750 MW
0500	Continuous	1730	Impacts Total Transfer Capability	1400 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW
ROSETON_-ROCKTVRN_345_311			FWD	
			(Import)	
Mon 04/30/2018	to	Fri 05/18/2018	UPNY CONED	4400 MW
0800	Continuous	1600	Impacts Total Transfer Capability	700 MW
Work scheduled by: CHGE			TTC with All Lines In Service	5100 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
 0001 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
CENTRAL EAST - VC 2740 MW
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1750 MW
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 09/10/2018 to Fri 10/05/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
 0500 1730
 Work scheduled by:

FWD
 (Import)
CENTRAL EAST - VC 2690 MW
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Tuesday ,August 15, 2017 to Thursday ,February 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW