

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500					FWD	REV
					(Import)	(Export)
Fri 06/24/2016	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/02/2017</u>	
1940	Continuous	0200				
Work scheduled by: ConEd					SCH - PJ - NY	1650 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
HUDSONTP-W49TH_ST_345_Y56					FWD	
					(Import)	
Thu 11/24/2016	to	Sat 09/30/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>05/18/2017</u>	
1500	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	0 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR3500					FWD	REV
					(Import)	(Export)
Tue 05/02/2017	to	Sun 09/10/2017				
1710		0200				
Work scheduled by:					SCH - PJ - NY	1450 MW
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
S.RIPLEY-DUNKIRK__230_68					FWD	REV
					(Import)	(Export)
Tue 05/02/2017	to	Mon 10/23/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/17/2017</u>	
1710	Continuous	0759				
Work scheduled by: NYISO					SCH - PJ - NY	1950 MW
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2100 MW
						1350 MW
SCH-NYISO-HQ_LIMIT_800						REV
						(Export)
Thu 06/08/2017	to	Fri 12/15/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>08/03/2017</u>	
0600	Continuous	1700				
Work scheduled by: HQ					SCH - HQ - NY	800 MW
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1000 MW
SCH-IMO-NYISO_LIMIT_1400					FWD	
					(Import)	
Fri 06/30/2017	to	Tue 10/31/2017	<u>EXTENDED</u>	<u>by NYISO</u>	<u>07/28/2017</u>	
0001	Continuous	2359				
Work scheduled by: NYISO					SCH - OH - NY	1700 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	2000 MW
SCH-HQ-NYISO_LIMIT_1450					FWD	
					(Import)	
Tue 08/01/2017	to	Fri 12/15/2017				
2100	Continuous	1600				
Work scheduled by: HQ					SCH - HQ - NY	1450 MW
					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_100

Mon 08/07/2017 to Fri 08/11/2017
 0800 Continuous 1500
 Work scheduled by: PJM

UPDATED by NYISO 08/04/2017

SCH - PJ - NY (Export) **400 MW**
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 1350 MW

MARCY_345KV_CSC

Fri 08/11/2017 to Fri 08/11/2017
 0500 Continuous 1530
 Work scheduled by: NYPA

FWD (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

DUNWODIE_345KV_3

Sat 08/12/2017 to Sat 08/12/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Sat 08/12/2017 to Sat 08/12/2017
 0001 Continuous 0030
 Work scheduled by: ConEd

FWD (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W89

Sat 08/12/2017 to Sat 08/12/2017
 0001 Continuous 2130
 Work scheduled by: ConEd

FWD (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1100 MW
 TTC with All Lines In Service 5100 MW

DUNWODIE_345KV_3

Sat 08/12/2017 to Sat 08/12/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Sat 08/12/2017 to Sat 08/12/2017
 2100 Continuous 2130
 Work scheduled by: ConEd

FWD (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W64					FWD
Sun 08/13/2017	to	Sun 08/13/2017			(Import)
0001	Continuous	1730		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
SPRNBK__345KV_RNS5					FWD
Sun 08/13/2017	to	Sun 08/13/2017			(Import)
0001	Continuous	1730		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SCH-HQ_CEDARS-NYISO_LIMIT_140					FWD
Mon 08/14/2017	to	Wed 08/16/2017	<u>FORCED</u>	<u>by HQ</u>	<u>08/14/2017</u>
1700	Continuous	2359			(Import)
Work scheduled by: HQ					SCH - HQ_CEDARS 140 MW
					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 190 MW
HUDSONP_-FARRAGUT_345_B3402					FWD REV
Tue 08/15/2017	to	Sat 08/26/2017			(Import) (Export)
2100	Continuous	2359		SCH - PJ - NY	2100 MW 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD REV
Tue 08/15/2017	to	Sat 08/26/2017			(Import) (Export)
2100		2359		SCH - PJ - NY	2050 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 50 MW 50 MW
					TTC with All Lines In Service 2100 MW 1350 MW
MARION_-FARRAGUT_345_C3403					FWD REV
Tue 08/15/2017	to	Sat 08/26/2017			(Import) (Export)
2100	Continuous	2359		SCH - PJ - NY	2100 MW 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
COOPERS_-DOLSONAV_345_CCDA42					FWD
Mon 08/21/2017	to	Sat 09/02/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>08/16/2017</u>
0500	Continuous	1730			(Import)
Work scheduled by: NYPA					CENTRAL EAST - VC 2720 MW
					Impacts Total Transfer Capability 255 MW
					TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DOLSONAV-ROCKTVRN_345_DART44					FWD	
Mon 08/21/2017	to	Sat 09/02/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>08/16/2017</u>	(Import)
0500	Continuous	1730				CENTRAL EAST - VC 2720 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 255 MW	
					TTC with All Lines In Service 2975 MW	
SCH-IMO-NYISO_LIMIT_1200					FWD	
Mon 08/21/2017	to	Mon 08/21/2017				(Import)
1300	Continuous	1600				SCH - OH - NY 1500 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 2000 MW	
SCH-NYISO-IMO_LIMIT_1100					REV	
Mon 08/21/2017	to	Mon 08/21/2017				(Export)
1300	Continuous	1600				SCH - OH - NY 1400 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW	
					TTC with All Lines In Service 1600 MW	
HOPATCON-RAMAPO__500_5018					FWD	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	(Import) (Export)
0100	Continuous	0200				SCH - PJ - NY 1150 MW 1000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 950 MW 350 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
HOPATCON-RAMAPO__500_5018					FWD	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	(Import)
0100	Continuous	0200				TOTAL EAST 6400 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 100 MW	
					TTC with All Lines In Service 6500 MW	
HOPATCON-RAMAPO__500_5018					FWD	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	(Import)
0100	Continuous	0200				UPNY CONED 4000 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1100 MW	
					TTC with All Lines In Service 5100 MW	
HOPATCON-RAMAPO__500_5018 & S.RIPLEY-DUNKIRK_230_68					FWD	
Sun 08/27/2017	to	Mon 09/11/2017				(Import) (Export)
0100		0200				SCH - PJ - NY 1200 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability 900 MW 50 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV	
RAMAPO__345_345_PAR4500						(Import)	(Export)	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	SCH - PJ - NY	1650 MW	1250 MW
0100	Continuous	0200				Impacts Total Transfer Capability	450 MW	100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2100 MW	1350 MW
<hr/>						FWD	REV	
RAMAPO__500_345_BK 1500						(Import)	(Export)	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	SCH - PJ - NY	1900 MW	1000 MW
0100	Continuous	0200				Impacts Total Transfer Capability	200 MW	350 MW
Work scheduled by: ConEd						TTC with All Lines In Service	2100 MW	1350 MW
<hr/>						FWD	REV	
RAMAPO__500_345_BK 1500						(Import)	(Export)	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	TOTAL EAST	6400 MW	
0100	Continuous	0200				Impacts Total Transfer Capability	100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	6500 MW	
<hr/>						FWD	REV	
RAMAPO__500_345_BK 1500						(Import)	(Export)	
Sun 08/27/2017	to	Mon 09/11/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/11/2017</u>	UPNY CONED	4000 MW	
0100	Continuous	0200				Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW	
<hr/>						FWD	REV	
S.RIPLEY-DUNKIRK__230_68 & RAMAPO__345_345_PAR4500						(Import)	(Export)	
Sun 08/27/2017	to	Mon 09/11/2017				SCH - PJ - NY	1450 MW	1250 MW
0100		0200				Impacts Total Transfer Capability	650 MW	100 MW
Work scheduled by:						TTC with All Lines In Service	2100 MW	1350 MW
<hr/>						FWD	REV	
MARCY_SO_SERIES_COMP_I/S						(Import)	(Export)	
Thu 08/31/2017	to	Mon 10/02/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>07/26/2017</u>	CENTRAL EAST - VC	2740 MW	
1600	Continuous	0659				Impacts Total Transfer Capability	235 MW	
Work scheduled by: NYISO						TTC with All Lines In Service	2975 MW	
<hr/>						FWD	REV	
SPRNBRK_-TREMONT__345_X28						(Import)	(Export)	
Sat 09/02/2017	to	Sun 09/03/2017				SPR/DUN-SOUTH	4200 MW	
0001	Continuous	0100				Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 09/05/2017 to Sun 09/10/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

E13THSTA-FARRAGUT_345_46

Sat 09/09/2017 to Sat 09/09/2017
0001 Continuous 0145

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Sat 09/09/2017 to Sat 09/09/2017
0200 Continuous 0230

Work scheduled by: ConEd

UPDATED by CE 07/26/2017

FWD
(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

W49TH_ST-E13THSTA_345_M55

Sat 09/09/2017 to Sat 09/09/2017
0200 Continuous 0359

Work scheduled by: ConEd

UPDATED by CE 07/26/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Sat 09/09/2017 to Sat 09/09/2017
0345 Continuous 0359

Work scheduled by: ConEd

UPDATED by CE 07/26/2017

FWD
(Import)
SCH - PJM_HTP **320 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 660 MW

DUNWODIE_345KV_5

Sat 09/09/2017 to Sun 09/10/2017
2200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/20/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_7

Sat 09/09/2017 to Sun 09/10/2017
2200 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/20/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-DUNWODIE_345_W75					FWD	
Sat 09/09/2017	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CE</u>	<u>06/20/2017</u>	(Import)
2200	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SPRNBRK_345KV_RNS3					FWD	
Sat 09/09/2017	to	Sun 09/10/2017	<u>UPDATED</u>	<u>by CE</u>	<u>06/20/2017</u>	(Import)
2200	Continuous	0200				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
MOSES_-ADIRNDCK_230_MA1					FWD	
Mon 09/11/2017	to	Sat 09/16/2017	<u>EXTENDED</u>	<u>by NYPA</u>	<u>08/14/2017</u>	(Import)
0700	Continuous	1730				MOSES SOUTH 2100 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW
CANANDGA-STONYRDG_230_68					FWD	
Mon 09/11/2017	to	Mon 09/11/2017				(Import)
0800	Continuous	1600				DYSINGER EAST 2850 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 09/11/2017	to	Fri 09/29/2017				(Import)
0800	Continuous	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
STONYRDG-HILLSIDE_230_72					FWD	
Wed 09/13/2017	to	Wed 09/13/2017				(Import)
0800	Continuous	1600				DYSINGER EAST 2850 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
SPRNBRK_345KV_RNS5					FWD	
Sat 09/16/2017	to	Sat 09/16/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-W49TH_ST_345_M51					FWD	
Sat 09/16/2017	to	Tue 09/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
MARCY_-N.SCTLND_345_18					FWD	
Sat 09/16/2017	to	Sun 09/17/2017				(Import)
0800	Continuous	1700				CENTRAL EAST - VC 2090 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability 885 MW
						TTC with All Lines In Service 2975 MW
MARCY_-N.SCTLND_345_18 & MARCY_SO_SERIES_COMP_I/S					FWD	
Sat 09/16/2017	to	Sun 09/17/2017				(Import)
0800		1700				CENTRAL EAST - VC 1855 MW
Work scheduled by:						Impacts Total Transfer Capability 1120 MW
						TTC with All Lines In Service 2975 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD	
Mon 09/18/2017	to	Fri 10/13/2017	<u>EXTENDED</u>	<u>by NYPA</u>	<u>06/09/2017</u>	(Import)
0630	Continuous	1700				CENTRAL EAST - VC 2520 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 455 MW
						TTC with All Lines In Service 2975 MW
NIAGARA_345_230_AT4					FWD	REV
Mon 09/18/2017	to	Tue 09/19/2017				(Import) (Export)
0700	Continuous	1530				SCH - OH - NY 2000 MW 1400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 0 MW 200 MW
						TTC with All Lines In Service 2000 MW 1600 MW
MOSES_-ADIRNDCK_230_MA1					FWD	
Mon 09/18/2017	to	Sat 09/23/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/15/2017</u>	(Import)
0700	Continuous	1730				MOSES SOUTH 2100 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 3150 MW
ROCHESTR-PANNELL_345_RP1					FWD	
Mon 09/18/2017	to	Fri 09/22/2017	<u>UPDATED</u>	<u>by PA</u>	<u>07/21/2017</u>	(Import)
0730	Continuous	1530				DYSINGER EAST 2300 MW
Work scheduled by: RGE						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_140					FWD	
Mon 09/18/2017	to	Fri 09/29/2017			(Import)	
0800	Continuous	1700		SCH - HQ_CEDARS	140 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	50 MW
					TTC with All Lines In Service	190 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Mon 09/18/2017	to	Fri 09/29/2017			(Export)	
0800	Continuous	1700		SCH - HQ_CEDARS	0 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	40 MW
					TTC with All Lines In Service	40 MW
PLSNTVLY_345KV_RNS5					FWD	
Tue 09/19/2017	to	Tue 09/19/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	
0001	Continuous	0100		UPNY CONED	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
PLSNTVLY-WOOD_ST_345_F30					FWD	
Tue 09/19/2017	to	Wed 09/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	
0001	Continuous	2359		UPNY CONED	4000 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
LINDEN_-GOETHALS_230_A2253					FWD	REV
Tue 09/19/2017	to	Sun 10/01/2017	<u>EXTENDED</u>	<u>by PJM</u>	<u>07/28/2017</u>	
0200	Continuous	0100		SCH - PJ - NY	2100 MW	1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2100 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 09/20/2017	to	Wed 09/20/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>08/10/2017</u>	
2330	Continuous	2359		UPNY CONED	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
MOSES_-ADIRNDCK_230_MAL					FWD	
Mon 09/25/2017	to	Sat 09/30/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/15/2017</u>	
0700	Continuous	1730		MOSES SOUTH	2100 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-STOLLERD_345_29					FWD	REV
					(Import)	(Export)
Mon 09/25/2017	to	Mon 10/16/2017			SCH - PJ - NY	2100 MW 1350 MW
0800	Continuous	1400			Impacts Total Transfer Capability	0 MW 0 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2100 MW 1350 MW
SPRNBRK_345KV_RNS5					FWD	
					(Import)	
Tue 09/26/2017	to	Tue 09/26/2017	<u>UPDATED</u>	<u>by CE</u>	<u>08/01/2017</u>	
0230	Continuous	0300			SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
PANNELL_-CLAY_345_2					FWD	
					(Import)	
Tue 09/26/2017	to	Wed 09/27/2017			WEST CENTRAL	1300 MW
0730	Continuous	1500			Impacts Total Transfer Capability	950 MW
Work scheduled by: RGE					TTC with All Lines In Service	2250 MW
E13THSTA-FARRAGUT_345_46					FWD	
					(Import)	
Wed 09/27/2017	to	Wed 09/27/2017			SPR/DUN-SOUTH	3800 MW
0001	Continuous	0030			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_46					FWD	
					(Import)	
Wed 09/27/2017	to	Wed 09/27/2017	<u>CANCELLED</u>	<u>by NYISO</u>	<u>08/16/2017</u>	
0001	Continuous	0100			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
SCH-NYISO-NE_LIMIT_800						REV
						(Export)
Wed 09/27/2017	to	Wed 09/27/2017			SCH - NE - NY	1000 MW
0600	Continuous	1600			Impacts Total Transfer Capability	600 MW
Work scheduled by: ISONE					TTC with All Lines In Service	1600 MW
SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4					FWD	
					(Import)	
Sun 10/01/2017	to	Tue 10/03/2017			SPR/DUN-SOUTH	3200 MW
0001		0300			Impacts Total Transfer Capability	1400 MW
Work scheduled by:					TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work ID	Start Date	End Date	Time	Work Type	Scheduled By	Zone	Capacity (MW)	Impacts	TTC
SPRNBRK__345KV_RNS4	Mon 10/02/2017	Mon 10/02/2017	0001	Continuous	1900	SPR/DUN-SOUTH	3200 MW	1400 MW	4600 MW
Work scheduled by: ConEd									
W49TH_ST_345KV_5	Mon 10/02/2017	Tue 10/03/2017	0001	Continuous	0300	SCH - PJM_HTP	315 MW	345 MW	660 MW
Work scheduled by: ConEd									
PLSNTVLY-EFISHKIL_345_F36	Mon 10/02/2017	Mon 10/16/2017	0001	Continuous	0300	UPNY CONED	4000 MW	1100 MW	5100 MW
Work scheduled by: ConEd									
SPRNBRK_-W49TH_ST_345_M52	Mon 10/02/2017	Wed 11/01/2017	0001	Continuous	0300	SPR/DUN-SOUTH	3200 MW	1400 MW	4600 MW
Work scheduled by: ConEd									
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/02/2017	Sat 10/07/2017	0600	Continuous	1400	SCH - NPX_CSC	0 MW	330 MW	330 MW
Work scheduled by: LI									
NIAGARA_-ROCHESTR_345_NR2	Mon 10/02/2017	Fri 10/06/2017	0700	Continuous	1530	DYSINGER EAST	1700 MW	1450 MW	3150 MW
Work scheduled by: NYPA									
FRASER_-COOPERS__345_33	Mon 10/02/2017	Fri 10/13/2017	0700	Continuous	1900	CENTRAL EAST - VC	2395 MW	580 MW	2975 MW
Work scheduled by: NYSEG									

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47

Mon 10/02/2017 to Fri 10/27/2017
 0700 Continuous 1730
 Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2100 MW	1350 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

ROTTDAM-EASTOVER_230_38

Mon 10/02/2017 to Wed 10/04/2017
 0800 Continuous 1200
 Work scheduled by: NGrid

ARR: 77

	REV
	(Export)
SCH - NE - NY	1400 MW
Impacts Total Transfer Capability	200 MW
TTC with All Lines In Service	1600 MW

SPRNBRK_345KV_RNS4

Mon 10/02/2017 to Fri 10/06/2017
 1901 Continuous 0300
 Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	3200 MW
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

W49TH_ST_345KV_5

Tue 10/03/2017 to Fri 10/06/2017
 0301 Continuous 2100
 Work scheduled by: ConEd

	FWD
	(Import)
SCH - PJM_HTP	315 MW
Impacts Total Transfer Capability	345 MW
TTC with All Lines In Service	660 MW

BECK___-NIAGARA_345_PA302

Wed 10/04/2017 to Thu 10/05/2017
 0600 Continuous 1700
 Work scheduled by: NYPA

UPDATED by PA 08/11/2017

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Fri 10/06/2017
 0700 Daily(No Weekends) 0800
 Work scheduled by: NGrid

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	950 MW	1000 MW
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	1400 MW	1600 MW

BERKSHIR-ALPS_____345_393

Fri 10/06/2017 to Fri 10/06/2017
 0700 Daily(No Weekends) 0800
 Work scheduled by: NGrid

ARR: 78

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
Fri 10/06/2017 to Fri 10/06/2017		(Import) (Export)	
0700	0800	SCH - NE - NY	950 MW 1000 MW
Work scheduled by:		Impacts Total Transfer Capability	450 MW 600 MW
ARR: 78		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
BERKSHIR-NORTHFLD_345_312		FWD	REV
Fri 10/06/2017 to Sat 10/28/2017		(Import) (Export)	
0700	Continuous 1600	SCH - NE - NY	900 MW 1200 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	500 MW 400 MW
		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
BERKSHIR-NORTHFLD_345_312		FWD	REV
Fri 10/06/2017 to Sat 10/28/2017		(Import) (Export)	
0700	Continuous 1600	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393		FWD	REV
Fri 10/06/2017 to Thu 10/12/2017		(Import) (Export)	
0800	Continuous 1700	SCH - NE - NY	950 MW 1000 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	450 MW 600 MW
ARR: 78		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393		FWD	REV
Fri 10/06/2017 to Thu 10/12/2017		(Import) (Export)	
0800	Continuous 1700	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 100 MW
ARR: 78		TTC with All Lines In Service	200 MW 200 MW
<hr/>			
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312		FWD	REV
Fri 10/06/2017 to Thu 10/12/2017		(Import) (Export)	
0800	1700	SCH - NE - NY	950 MW 1000 MW
Work scheduled by:		Impacts Total Transfer Capability	450 MW 600 MW
ARR: 78		TTC with All Lines In Service	1400 MW 1600 MW
<hr/>			
SCH-NE-NYISO_LIMIT_800		FWD	
Mon 10/09/2017 to Thu 10/12/2017		(Import)	
0700	Continuous 1700	SCH - NE - NY	1000 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WETHSRFD-MEYER 230_85/87				FWD	
Mon 10/09/2017	to	Fri 10/20/2017		(Import)	
0700	Continuous	1400		DYSINGER EAST	2850 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
MARCY_SO_SERIES_COMP_I/S				FWD	
Fri 10/13/2017	to	Tue 10/31/2017		(Import)	
1900	Continuous	2359		CENTRAL EAST - VC	2740 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	2975 MW
CHATGUAY-MASSENA 765_7040				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)	
0700	Continuous	1530		MOSES SOUTH	1550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)	(Export)
0700	Continuous	1530		SCH - HQ - NY	0 MW 0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MARCY 765_345_AT1				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)	
0700	Continuous	1530		MOSES SOUTH	1750 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MARCY 765_345_AT2				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)	
0700	Continuous	1530		MOSES SOUTH	1700 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
					ARR: 19
MASSENA -MARC 765_MSU1				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED by NYISO 03/24/2017	(Import)	
0700	Continuous	1530		CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	710 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_765_MSU1				FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)	
0700	Continuous	1530		MOSES SOUTH	500 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY_765_MSU1				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>03/24/2017</u>	(Import)	(Export)
0700	Continuous	1530		SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1025 MW 0 MW
				TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY_765_MSU1 & CHATGUAY-MASSENA_765_7040				FWD	
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	
0700		1530		MOSES SOUTH	500 MW
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY_765_MSU1 & MARCY_SO_SERIES_COMP_I/S				FWD	
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	
0700		1530		CENTRAL EAST - VC	2080 MW
Work scheduled by:				Impacts Total Transfer Capability	895 MW
				TTC with All Lines In Service	2975 MW
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2				FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017		(Import)	(Export)
0700		1530		SCH - HQ - NY	850 MW 0 MW
Work scheduled by:				Impacts Total Transfer Capability	650 MW 1000 MW
				TTC with All Lines In Service	1500 MW 1000 MW
COOPERS_-MIDDLETP_345_CCRT34				FWD	
Mon 10/16/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by NYISO</u> <u>06/21/2017</u>	(Import)	
0700	Continuous	1500		CENTRAL EAST - VC	2720 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	255 MW
				TTC with All Lines In Service	2975 MW
HURLYAVE-ROSETON_345_303				FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u> <u>by CH</u> <u>06/07/2017</u>	(Import)	
0800	Continuous	1600		UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS -HURLYAVE_345_301				FWD	
Mon 10/16/2017	to	Fri 11/03/2017		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	
SPRNBRK_345KV_RNS4				FWD	
Tue 10/17/2017	to	Sat 10/28/2017		(Import)	
0301	Continuous	0300	SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
BERKSHIR-ALPS_345_393				FWD	REV
Wed 10/18/2017	to	Wed 10/18/2017		(Import)	(Export)
0700	Continuous	1700	SCH - NE - NY	950 MW	1000 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW
BERKSHIR-ALPS_345_393				FWD	REV
Wed 10/18/2017	to	Wed 10/18/2017		(Import)	(Export)
0700	Continuous	1700	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS_345_393 & BERKSHIR-NORTHFLD_345_312				FWD	REV
Wed 10/18/2017	to	Wed 10/18/2017		(Import)	(Export)
0700		1700	SCH - NE - NY	950 MW	1000 MW
Work scheduled by:			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW
S.RIPLEY-DUNKIRK_230_68				FWD	REV
Mon 10/23/2017	to	Thu 10/26/2017	UPDATED by NYISO 08/01/2017	(Import)	(Export)
0800	Continuous	1500	SCH - PJ - NY	1950 MW	1350 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	150 MW	0 MW
			TTC with All Lines In Service	2100 MW	1350 MW
BERKSHIR-ALPS_345_393				FWD	REV
Wed 10/25/2017	to	Wed 10/25/2017		(Import)	(Export)
0700	Continuous	1700	SCH - NE - NY	950 MW	1000 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BERKSHIR-ALPS 345_393					
Wed 10/25/2017	to	Wed 10/25/2017			
0700	Continuous	1700			
Work scheduled by: NGrid			ARR: 78		
				SCH - NPX_1385	100 MW 100 MW
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD 345_312					
Wed 10/25/2017	to	Wed 10/25/2017			
0700		1700			
Work scheduled by:			ARR: 78		
				SCH - NE - NY	950 MW 1000 MW
				Impacts Total Transfer Capability	450 MW 600 MW
				TTC with All Lines In Service	1400 MW 1600 MW
S.RIPLEY-DUNKIRK 230_68					
Thu 10/26/2017	to	Sat 02/01/2020	UPDATED by NYISO 05/17/2017		
1501	Continuous	0000			
Work scheduled by: NYISO					
				SCH - PJ - NY	1950 MW 1350 MW
				Impacts Total Transfer Capability	150 MW 0 MW
				TTC with All Lines In Service	2100 MW 1350 MW
W49TH_ST_345KV_5					
Fri 10/27/2017	to	Wed 11/01/2017			
0001	Continuous	0300			
Work scheduled by: ConEd					
				SCH - PJM_HTP	315 MW
				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
SPRNBRK 345KV_RNS4					
Sat 10/28/2017	to	Wed 11/01/2017			
0301	Continuous	0300			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3200 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
BERKSHIR-ALPS 345_393					
Sat 10/28/2017	to	Sat 10/28/2017			
1500	Daily	1600			
Work scheduled by: NGrid			ARR: 78		
				SCH - NE - NY	950 MW 1000 MW
				Impacts Total Transfer Capability	450 MW 600 MW
				TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS 345_393					
Sat 10/28/2017	to	Sat 10/28/2017			
1500	Daily	1600			
Work scheduled by: NGrid			ARR: 78		
				SCH - NPX_1385	100 MW 100 MW
				Impacts Total Transfer Capability	100 MW 100 MW
				TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			FWD	REV
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312			(Import)	(Export)
Sat 10/28/2017	to Sat 10/28/2017			
1500	1600	SCH - NE - NY	950 MW	1000 MW
Work scheduled by:		Impacts Total Transfer Capability	450 MW	600 MW
	ARR: 78	TTC with All Lines In Service	1400 MW	1600 MW
<hr/>			FWD	
MOSES _____ -ADIRNDCK_230_MA2			(Import)	
Mon 10/30/2017	to Fri 11/03/2017	MOSES SOUTH	2100 MW	
0700	Continuous 1530	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NYPA		TTC with All Lines In Service	3150 MW	
<hr/>			FWD	
PLSNTVLY-EFISHKIL_345_F36			(Import)	
Wed 11/01/2017	to Sat 11/04/2017	UPNY CONED	4000 MW	
0001	Continuous 0300	Impacts Total Transfer Capability	1100 MW	
Work scheduled by: ConEd		TTC with All Lines In Service	5100 MW	
<hr/>			FWD	
E13THSTA-FARRAGUT_345_46			(Import)	
Thu 11/02/2017	to Thu 11/02/2017	CANCELLED by NYISO 08/16/2017		
0200	Continuous 0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd		Impacts Total Transfer Capability	800 MW	
		TTC with All Lines In Service	4600 MW	
<hr/>			FWD	REV
MARION _____ -FARRAGUT_345_C3403			(Import)	(Export)
Thu 11/02/2017	to Fri 11/03/2017	SCH - PJ - NY	2300 MW	1450 MW
0200	Continuous 0100	Impacts Total Transfer Capability	0 MW	0 MW
Work scheduled by: ConEd		TTC with All Lines In Service	2300 MW	1450 MW
<hr/>			FWD	
E13THSTA-FARRAGUT_345_46			(Import)	
Thu 11/02/2017	to Thu 11/02/2017	SPR/DUN-SOUTH	3800 MW	
0230	Continuous 0300	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd		TTC with All Lines In Service	4600 MW	
<hr/>			FWD	REV
BERKSHIR-ALPS _____ 345_393			(Import)	(Export)
Thu 11/02/2017	to Sat 11/04/2017	UPDATED by NE 08/02/2017		
0700	Continuous 1700	SCH - NE - NY	1300 MW	1300 MW
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW	300 MW
	ARR: 78	TTC with All Lines In Service	1400 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
BERKSHIR-ALPS 345_393							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>08/02/2017</u>		
0700	Continuous	1700				SCH - NPX_1385	100 MW
Work scheduled by: NGrid							100 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
						ARR: 78	
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312							
Thu 11/02/2017	to	Sat 11/04/2017				SCH - NE - NY	1300 MW
0700		1700				Impacts Total Transfer Capability	100 MW
Work scheduled by:						TTC with All Lines In Service	1400 MW
						ARR: 78	
BERKSHIR-NORTHFLD_345_312							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>08/02/2017</u>	SCH - NE - NY	1400 MW
0700	Continuous	1700				Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312							
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>08/02/2017</u>	SCH - NPX_1385	100 MW
0700	Continuous	1700				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
PLSNTVLY-EFISHKIL_345_F36							
Mon 11/06/2017	to	Wed 11/08/2017				UPNY CONED	4000 MW
0001	Continuous	0300				Impacts Total Transfer Capability	1100 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5100 MW
FRASANX-COOPERS 345_UCC2-41							
Mon 11/06/2017	to	Fri 11/17/2017				CENTRAL EAST - VC	2500 MW
0600	Continuous	1700				Impacts Total Transfer Capability	475 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
MARCY -FRASANX_345_UCC2-41							
Mon 11/06/2017	to	Fri 11/17/2017				CENTRAL EAST - VC	2500 MW
0600	Continuous	1700				Impacts Total Transfer Capability	475 MW
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW
						ARR: 19	

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

LINDN_CG-LNDVFT___345_V-3022

Mon 11/06/2017 to Thu 11/09/2017
0800 Continuous 1500

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJM_VFT **0 MW 0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

W49TH_ST_345KV_5

Fri 11/10/2017 to Fri 11/10/2017
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

SPRNBRK_-W49TH_ST_345_M52

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS4

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4

Sun 11/12/2017 to Wed 11/15/2017
0001 0300

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_5

Mon 11/13/2017 to Mon 11/13/2017
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

SPRNBRK_345KV_RNS4

Wed 11/15/2017 to Fri 11/17/2017
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3200 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

EGRDNCTY_345_138_AT1

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED by LI 08/01/2017**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED by LI 08/01/2017**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **1250 MW**
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Sun 11/19/2017 to Sat 12/23/2017 **UPDATED by LI 08/01/2017**
 0001 Continuous 2359
 Work scheduled by: LI

FWD
 (Import)
 CONED - LIPA **775 MW**
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Mon 11/27/2017 to Fri 12/01/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

ROTTDAM-EASTOVER_230_38

Mon 11/27/2017 to Thu 11/30/2017
 0900 Continuous 1500
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
 SCH - NE - NY **1400 MW 1400 MW**
 Impacts Total Transfer Capability 0 MW 200 MW
 TTC with All Lines In Service 1400 MW 1600 MW

ARR: 77

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sun 12/03/2017 to Tue 12/05/2017
 0001 0300
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

LEEDS_-PLSNTVLY_345_92

Mon 12/04/2017 to Mon 12/18/2017
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Mon 12/04/2017 to Mon 12/18/2017
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

MARCY_765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

MOSES_-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY 765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

LEEDS -PLSNTVLY_345_92

Wed 01/03/2018 to Sat 01/06/2018
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Wed 01/03/2018 to Sat 01/06/2018
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 01/05/2018 to Mon 01/08/2018
0001 0300

Work scheduled by:

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Mon 01/08/2018 to Wed 01/10/2018
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

MARCY 765_345_AT2

Sat 01/20/2018 to Sat 01/20/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2		FWD
Sat 02/03/2018	to Sat 02/03/2018	(Import)
0500	Continuous 1730	MOSES SOUTH 1700 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2		FWD
Mon 02/05/2018	to Fri 02/09/2018	(Import)
0500	Continuous 1730	MOSES SOUTH 1700 MW
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
HUDSONP_-FARRAGUT_345_B3402		FWD REV
Sun 02/18/2018	to Sun 04/01/2018	(Import) (Export)
0001	Continuous 2359	SCH - PJ - NY 2300 MW 1450 MW
Work scheduled by: PJM		Impacts Total Transfer Capability 0 MW 0 MW
		TTC with All Lines In Service 2300 MW 1450 MW
MARCY___-EDIC___345_UE1-7		FWD
Tue 02/20/2018	to Fri 02/23/2018	(Import)
0500	Continuous 1730	OSWEGO EXPORT 5250 MW
Work scheduled by: NYPA	ARR: 19&16	Impacts Total Transfer Capability 0 MW
		TTC with All Lines In Service 5250 MW
S.RIPLEY-DUNKIRK__230_68		FWD REV
Mon 03/19/2018	to Fri 04/20/2018	(Import) (Export)
1000	Continuous 1559	SCH - PJ - NY 1950 MW 1350 MW
Work scheduled by: PJM		Impacts Total Transfer Capability 350 MW 100 MW
		TTC with All Lines In Service 2300 MW 1450 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE		FWD
Mon 04/16/2018	to Tue 05/01/2018	(Import)
0001	Continuous 1800	SCH - PJM_NEPTUNE 0 MW
Work scheduled by: PJM		Impacts Total Transfer Capability 660 MW
		TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501		FWD
Mon 04/16/2018	to Tue 05/01/2018	(Import)
0001	Continuous 1800	SCH - PJM_NEPTUNE 0 MW
Work scheduled by: PJM		Impacts Total Transfer Capability 660 MW
		TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
MARCY___765_345_AT1			FWD
Mon 04/23/2018	to	Mon 04/23/2018	(Import)
0500	Continuous	1730	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
			ARR: 19
ROSETON_-ROCKTVRN_345_311			FWD
Mon 04/30/2018	to	Fri 05/18/2018	(Import)
0800	Continuous	1600	UPNY CONED 4400 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability 700 MW
			TTC with All Lines In Service 5100 MW
MARCY_SO_SERIES_COMP_I/S			FWD
Tue 05/01/2018	to	Wed 10/31/2018	(Import)
0001	Continuous	2359	CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability 235 MW
			TTC with All Lines In Service 2975 MW
MARCY___765_345_AT2			FWD
Mon 05/21/2018	to	Fri 05/25/2018	(Import)
0500	Continuous	1730	MOSES SOUTH 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
			ARR: 19
MARCY___765_345_AT1			FWD
Sat 08/04/2018	to	Sun 08/05/2018	(Import)
0500	Continuous	1730	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
			ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 09/10/2018 to Fri 10/05/2018
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4100 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, August 16, 2017 to Friday, February 15, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

FWD

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

FWD

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW