

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
Thu 11/24/2016	to	Wed 11/01/2017	<u>EXT FORCE</u>	<u>by PJM</u>	<u>10/10/2017</u>	(Import)
1500	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>					FWD	REV
Tue 05/02/2017	to	Tue 10/10/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import) (Export)
1710	Continuous	0759				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2100 MW 1350 MW
					TTC with All Lines In Service	
<b>SCH-NYISO-HQ_LIMIT_800</b>						REV
Thu 06/08/2017	to	Fri 12/15/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>08/03/2017</u>	(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					SCH - HQ - NY	200 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	
<b>SCH-HQ-NYISO_LIMIT_1450</b>					FWD	
Tue 08/01/2017	to	Fri 12/15/2017				(Import)
2100	Continuous	1600				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	50 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	
<b>SCH-IMO-NYISO_LIMIT_1450</b>					FWD	
Tue 08/29/2017	to	Tue 10/31/2017	<u>EXTENDED</u>	<u>by NYISO</u>	<u>07/28/2017</u>	(Import)
1230	Continuous	2359				1750 MW
Work scheduled by: NYISO					SCH - OH - NY	250 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	
<b>SCH-IMO-NYISO_LIMIT_1150</b>					FWD	
Sat 09/09/2017	to	Fri 10/13/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/09/2017</u>	(Import)
0500	Continuous	2100				1450 MW
Work scheduled by: NGrid					SCH - OH - NY	550 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	
<b>GILBOA_-N.SCTLND_345_GNS-1</b>					FWD	
Mon 09/18/2017	to	Wed 10/11/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/07/2017</u>	(Import)
0630	Continuous	1900				2520 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	455 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FIVEMILE-STOLLERD_345_29</b>				FWD	REV
Thu 09/28/2017	to	Tue 10/17/2017	<b>UPDATED by NYISO 09/25/2017</b>	(Import)	(Export)
0700	Continuous	1400		<b>2100 MW</b>	<b>1350 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	2100 MW
				1350 MW	
<b>SPRNBRK_-W49TH_ST_345_M52</b>				FWD	
Sun 10/01/2017	to	Sat 11/04/2017		(Import)	
0001	Continuous	2359		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>				FWD	
Mon 10/02/2017	to	Mon 10/16/2017		(Import)	
0001	Continuous	0300		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	5100 MW
<b>SCH-NYISO-IMO_NIAGARA_SOUTH_BUS</b>				FWD	REV
Mon 10/02/2017	to	Fri 10/06/2017	<b>UPDATED by NYISO 09/22/2017</b>	(Import)	(Export)
0500	Continuous	1630		<b>900 MW</b>	<b>800 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	1100 MW
				TTC with All Lines In Service	2000 MW
				1600 MW	
<b>CHAT_DC_GC2</b>				FWD	
Mon 10/02/2017	to	Wed 11/15/2017		(Import)	
0500	Continuous	2000		MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>					REV
Mon 10/02/2017	to	Wed 11/15/2017			(Export)
0500	Continuous	2000		SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD	
Mon 10/02/2017	to	Wed 11/15/2017		(Import)	
0500	Continuous	2000		SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start	End	Status	By	Effective Date	Zone	FWD	REV
SHOR_NPX-SHOREHAM_138_CSC	Mon 10/02/2017	Sun 10/08/2017	<u>EXTENDED</u>	<u>by LI</u>	<u>10/07/2017</u>	SCH - NPX_CSC	0 MW	0 MW
	0600	Continuous				Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
Work scheduled by: LI								
NIAGARA -ROCHESTR_345_NR2	Mon 10/02/2017	Fri 10/06/2017				DYSINGER EAST	1700 MW	
	0700	Continuous				Impacts Total Transfer Capability	1450 MW	
						TTC with All Lines In Service	3150 MW	
Work scheduled by: NYPA								
FRASER -COOPERS_345_33	Mon 10/02/2017	Fri 10/13/2017				CENTRAL EAST - VC	2395 MW	
	0700	Continuous				Impacts Total Transfer Capability	580 MW	
						TTC with All Lines In Service	2975 MW	
Work scheduled by: NYSEG								
BECK -NIAGARA_345_PA302	Mon 10/02/2017	Fri 10/06/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/27/2017</u>	SCH - OH - NY	900 MW	800 MW
	0800	Continuous				Impacts Total Transfer Capability	1100 MW	800 MW
						TTC with All Lines In Service	2000 MW	1600 MW
Work scheduled by: IESO								
SCH-NYISO-PJM_LIMIT_100	Mon 10/02/2017	Fri 10/06/2017	<u>UPDATED</u>	<u>by PJM</u>	<u>09/25/2017</u>	SCH - PJ - NY		400 MW
	0800	Continuous				Impacts Total Transfer Capability		950 MW
						TTC with All Lines In Service		1350 MW
Work scheduled by: PJM								
SPRNBRK_345KV_RNS4	Mon 10/02/2017	Sat 10/28/2017	<u>UPDATED</u>	<u>by CONED</u>	<u>10/03/2017</u>	SPR/DUN-SOUTH	3200 MW	
	1901	Continuous				Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	4600 MW	
Work scheduled by: ConEd								
SCH-NYISO-NE_LIMIT_700	Fri 10/06/2017	Sat 10/07/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/10/2017</u>	SCH - NE - NY		900 MW
	0700	Continuous				Impacts Total Transfer Capability		700 MW
						TTC with All Lines In Service		1600 MW
Work scheduled by: ISONE								

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Fri 10/06/2017	to	Tue 10/10/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import)
0700	Continuous	1600				<b>700 MW</b>
Work scheduled by: ISONE					SCH - NE - NY	700 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
<hr/>						
<b>BERKSHIR-ALPS 345_393</b>					FWD	REV
Fri 10/06/2017	to	Sat 10/28/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import) (Export)
0700	Continuous	1600				<b>950 MW 1000 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NE - NY	<b>950 MW 1000 MW</b>
					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-ALPS 345_393</b>					FWD	REV
Fri 10/06/2017	to	Sat 10/28/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import) (Export)
0700	Continuous	1600				<b>100 MW 100 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>						
<b>BERKSHIR-ALPS 345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 10/06/2017	to	Sat 10/28/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import) (Export)
0700		1600				<b>950 MW 1000 MW</b>
Work scheduled by:					<b>ARR: 78</b>	
					SCH - NE - NY	<b>950 MW 1000 MW</b>
					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 10/06/2017	to	Sat 10/28/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import) (Export)
0700	Continuous	1600				<b>900 MW 1200 MW</b>
Work scheduled by: ISONE						
					SCH - NE - NY	<b>900 MW 1200 MW</b>
					Impacts Total Transfer Capability	500 MW 400 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<hr/>						
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Fri 10/06/2017	to	Sat 10/28/2017	<b>UPDATED</b>	<b>by ISONE</b>	<b>10/10/2017</b>	(Import) (Export)
0700	Continuous	1600				<b>100 MW 100 MW</b>
Work scheduled by: ISONE						
					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<hr/>						
<b>BERKSHIR-ALPS 345_393</b>					FWD	REV
Fri 10/06/2017	to	Tue 10/31/2017	<b>CANCELLED</b>	<b>by NYISO</b>	<b>10/06/2017</b>	(Import) (Export)
0700	Daily(No Weekends)	0700				<b>950 MW 1000 MW</b>
Work scheduled by: NGrid					<b>ARR: 78</b>	
					SCH - NE - NY	<b>950 MW 1000 MW</b>
					Impacts Total Transfer Capability	450 MW 600 MW
					TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

		FWD	REV
		(Import)	(Export)
<b>BERKSHIR-ALPS</b> _____ <b>345_393</b>			
Fri 10/06/2017	to Tue 10/31/2017	<b>CANCELLED by NYISO 10/06/2017</b>	
0700	Daily(No Weekends) 0700	SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: NGrid		Impacts Total Transfer Capability	100 MW 100 MW
		TTC with All Lines In Service	200 MW 200 MW
		<b>ARR: 78</b>	
<b>CHAT_DC_GC1</b>			
Sun 10/08/2017	to Sun 10/08/2017	FWD (Import)	
0001	Continuous 0200	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	300 MW
		TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>			
Sun 10/08/2017	to Sun 10/08/2017	REV (Export)	
0001	Continuous 0200	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	500 MW
		TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			
Sun 10/08/2017	to Sun 10/08/2017	FWD (Import)	
0001	0200	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	600 MW
		TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>			
Sun 10/08/2017	to Sun 10/08/2017	FWD (Import) REV (Export)	
0001	0200	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	130 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>			
Sun 10/08/2017	to Sun 10/08/2017	FWD (Import)	
0001	Continuous 0200	SCH - HQ - NY	<b>700 MW</b>
Work scheduled by: HQ		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1500 MW
<b>SCH-NYISO-NE_LIMIT_600</b>			
Sun 10/08/2017	to Sat 10/28/2017	<b>UPDATED by ISONE 10/10/2017</b>	
0001	Continuous 1600	SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE		Impacts Total Transfer Capability	800 MW
		TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_800</b>				FWD	
Mon 10/09/2017	to	Thu 10/12/2017		(Import)	
0700	Continuous	1700	SCH - NE - NY	<b>1000 MW</b>	
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	1400 MW	
<b>CLAY -EDIC 345_1-16</b>				FWD	
Wed 10/11/2017	to	Wed 10/11/2017		(Import)	
0700	Continuous	1700	OSWEGO EXPORT	<b>4850 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>				FWD	
Thu 10/12/2017	to	Thu 10/12/2017	<b>UPDATED by ISONE 10/06/2017</b>	(Import)	
0700	Continuous	0759	SCH - NE - NY	<b>800 MW</b>	
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW	
			TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_500</b>					REV
Thu 10/12/2017	to	Thu 10/12/2017	<b>UPDATED by ISONE 10/06/2017</b>		(Export)
0700	Continuous	0759	SCH - NE - NY		<b>700 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability		900 MW
			TTC with All Lines In Service		1600 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
Fri 10/13/2017	to	Mon 10/23/2017	<b>UPDATED by NYISO 10/09/2017</b>	(Import)	(Export)
1500	Continuous	0759	SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	150 MW	0 MW
			TTC with All Lines In Service	2100 MW	1350 MW
<b>BERKSHIR-ALPS 345_393</b>				FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<b>CANCELLED by NYISO 10/06/2017</b>	(Import)	(Export)
1800	Daily(No Weekends)	1600	SCH - NE - NY	<b>950 MW</b>	<b>1000 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-ALPS 345_393</b>				FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<b>CANCELLED by NYISO 10/06/2017</b>	(Import)	(Export)
1800	Daily(No Weekends)	1600	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHATGUAY-MASSENA__765_7040</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
<b>CHATGUAY-MASSENA__765_7040</b>						FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)	(Export)
0100	Continuous	2000				SCH - HQ - NY	<b>0 MW 0 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2 &amp; MOSES__-MASSENA_230_MMS1 &amp; MOSES__-MASSENA_230_MMS2</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017				(Import)	
0100		2000				MOSES SOUTH	<b>1950 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	1200 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT1</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW
<b>MARCY__765_345_AT2</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)	
0100	Continuous	2000				CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW
						TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY__765_MSU1</b>						FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)	
0100	Continuous	2000				MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW
						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>					FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import) (Export)
0100	Continuous	2000				
Work scheduled by: NYPA					SCH - HQ - NY	<b>475 MW 1000 MW</b>
					Impacts Total Transfer Capability	1025 MW 0 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>					FWD	
Sat 10/14/2017	to	Sat 10/21/2017				(Import)
0100		2000				
Work scheduled by:					MOSES SOUTH	<b>500 MW</b>
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>					FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017				(Import) (Export)
0100		2000				
Work scheduled by:					SCH - HQ - NY	<b>850 MW 0 MW</b>
					Impacts Total Transfer Capability	650 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC1</b>					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)
0100	Continuous	2000				
Work scheduled by: HQ					MOSES SOUTH	<b>2850 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>						REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Export)
0100	Continuous	2000				
Work scheduled by: HQ					SCH - HQ - NY	<b>500 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sat 10/14/2017	to	Sat 10/28/2017				(Import)
0100		2000				
Work scheduled by:					MOSES SOUTH	<b>2550 MW</b>
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017				(Import) (Export)
0100		2000				
Work scheduled by:					SCH - HQ - NY	<b>1370 MW 0 MW</b>
					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Status	By	Effective Date	Zone	Impact	TTC
SCH-HQ-NYISO_LIMIT_700	Sat 10/14/2017	Sat 10/28/2017	UPDATED	by HQ	10/11/2017	SCH - HQ - NY	700 MW	1500 MW
	0100	Continuous				Impacts Total Transfer Capability	800 MW	
	Work scheduled by: HQ					TTC with All Lines In Service		1500 MW
HOMRC_NY-MAINS_NY_345_47	Sat 10/14/2017	Fri 10/27/2017	UPDATED	by NYSEG	10/11/2017	SCH - PJ - NY	2100 MW	1350 MW
	0700	Continuous				Impacts Total Transfer Capability	0 MW	0 MW
	Work scheduled by: NYSEG					TTC with All Lines In Service	2100 MW	1350 MW
SCH-IMO_NY_NIAG_NRTH_BUS_W/BB	Mon 10/16/2017	Fri 10/20/2017				SCH - OH - NY	1000 MW	1150 MW
	0500	Continuous				Impacts Total Transfer Capability	1000 MW	450 MW
	Work scheduled by: NYPA					TTC with All Lines In Service	2000 MW	1600 MW
COOPERS_-MIDDLETP_345_CCRT34	Mon 10/16/2017	Sat 10/28/2017	UPDATED	by NYISO	06/21/2017	CENTRAL EAST - VC	2720 MW	
	0700	Continuous				Impacts Total Transfer Capability	255 MW	
	Work scheduled by: NYSEG					TTC with All Lines In Service		2975 MW
HURLYAVE-ROSETON__345_303	Mon 10/16/2017	Fri 11/03/2017	UPDATED	by CH	06/07/2017	UPNY CONED	4100 MW	
	0800	Continuous				Impacts Total Transfer Capability	1000 MW	
	Work scheduled by: CHGE					TTC with All Lines In Service		5100 MW
LEEDS_-HURLYAVE_345_301	Mon 10/16/2017	Fri 11/03/2017				UPNY CONED	4100 MW	
	0800	Continuous				Impacts Total Transfer Capability	1000 MW	
	Work scheduled by: CHGE					TTC with All Lines In Service		5100 MW
MARCY_SO_SERIES_COMP_I/S	Sat 10/21/2017	Tue 10/31/2017	UPDATED	by NYISO	10/11/2017	CENTRAL EAST - VC	2740 MW	
	2000	Continuous				Impacts Total Transfer Capability	235 MW	
	Work scheduled by: NYISO					TTC with All Lines In Service		2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD	
Mon 10/23/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import)
0600	Continuous	1559				DYSINGER EAST <b>1700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Mon 10/23/2017	to	Thu 10/26/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/01/2017</u>	(Import) (Export)
0800	Continuous	1500				SCH - PJ - NY <b>1950 MW 1350 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<b>BECK_-NIAGARA__345_PA301</b>					FWD	REV
Tue 10/24/2017	to	Wed 10/25/2017				(Import) (Export)
0500	Continuous	1700				SCH - OH - NY <b>900 MW 800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1100 MW 800 MW
					TTC with All Lines In Service	2000 MW 1600 MW
<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD	
Wed 10/25/2017	to	Thu 11/09/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import)
1600	Continuous	1600				DYSINGER EAST <b>1700 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV
Thu 10/26/2017	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import) (Export)
1501	Continuous	0959				SCH - PJ - NY <b>1950 MW 1350 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<b>W49TH_ST_345KV_5</b>					FWD	
Fri 10/27/2017	to	Sat 11/04/2017				(Import)
0001	Continuous	2359				SCH - PJM_HTP <b>315 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	345 MW
					TTC with All Lines In Service	660 MW
<b>SPRNBRK__345KV_RNS4</b>					FWD	
Sat 10/28/2017	to	Sat 11/04/2017				(Import)
0301	Continuous	2359				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Mon 10/30/2017 to Sat 11/04/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**EXTENDED by NYPA 10/02/2017**

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE-DUFFYAVE\_345\_501**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE\_345\_138\_BK\_1**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE\_345\_138\_BK\_2**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**PLSNTVLY-EFISHKIL\_345\_F36**

Wed 11/01/2017 to Sat 11/04/2017  
0001 Continuous 0300

Work scheduled by: ConEd

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 5100 MW

FWD  
(Import)

**LAFAYTTE-CLRKSCRN\_345\_4-46**

Wed 11/01/2017 to Thu 11/02/2017  
0630 Continuous 1630

Work scheduled by: NGrid

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD	
Wed 11/01/2017	to	Sat 11/04/2017			(Import)	
0830	Continuous	1800		CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Thu 11/02/2017	to	Sat 12/02/2017	<u>UPDATED</u>	<u>by CE</u>	<u>09/29/2017</u>	(Import) (Export)
0001	Continuous	0100				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2300 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	<b>1300 MW 1300 MW</b>
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-ALPS_____345_393 &amp; BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017				(Import) (Export)
0700		1900				
Work scheduled by:					SCH - NE - NY	<b>1300 MW 1300 MW</b>
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	<b>1400 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_500</b>					FWD	
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import)
0700	Continuous	1900				<b>700 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	700 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_700</b>					REV	
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Export)
0700	Continuous	1900				<b>900 MW</b>
Work scheduled by: NGrid					SCH - NE - NY	900 MW
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1600 MW
<b>E13THSTA-FARRAGUT_345_46</b>					FWD	
Sat 11/04/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2017</u>	(Import)
0230	Continuous	0300				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>					FWD	
Mon 11/06/2017	to	Wed 11/08/2017				(Import)
0001	Continuous	0300				<b>4000 MW</b>
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD	
Mon 11/06/2017	to	Thu 11/09/2017				(Import)
0700	Continuous	1530				<b>2300 MW</b>
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>FRASANX-COOPERS__345_UCC2-41</b>					FWD	
Mon 11/06/2017	to	Fri 11/17/2017				(Import)
0700	Continuous	1530				<b>2500 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	2500 MW
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>					FWD	
Mon 11/06/2017	to	Fri 11/17/2017				(Import)
0700	Continuous	1530				<b>2500 MW</b>
Work scheduled by: NYPA					CENTRAL EAST - VC	2500 MW
					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work by	Notes	FWD	REV
LINDN_CG-LNDVFT_345_V-3022	Mon 11/06/2017	Thu 11/09/2017	0800 Continuous 1500	PJM		(Import)	(Export)
					SCH - PJM_VFT	0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
SCRIBA-VOLNEY_345_20	Mon 11/06/2017	Fri 11/17/2017	0800 Continuous 1630	NGrid		(Import)	
					OSWEGO EXPORT	5250 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	
W49TH_ST_345KV_5	Fri 11/10/2017	Fri 11/10/2017	0001 Continuous 0030	ConEd	<u>UPDATED by CONED 10/03/2017</u>	(Import)	
					SCH - PJM_HTP	315 MW	
					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	
SPRNBRK-W49TH_ST_345_M52	Fri 11/10/2017	Mon 11/13/2017	0001 Continuous 0300	ConEd	<u>UPDATED by CONED 10/03/2017</u>	(Import)	
					SPR/DUN-SOUTH	3200 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBRK_345KV_RNS4	Fri 11/10/2017	Mon 11/13/2017	0001 Continuous 0300	ConEd	<u>UPDATED by CONED 10/03/2017</u>	(Import)	
					SPR/DUN-SOUTH	3200 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4	Sun 11/12/2017	Wed 11/15/2017	0001 Continuous 0300			(Import)	
					SPR/DUN-SOUTH	3800 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_5	Mon 11/13/2017	Mon 11/13/2017	0230 Continuous 0300	ConEd	<u>UPDATED by CONED 10/03/2017</u>	(Import)	
					SCH - PJM_HTP	315 MW	
					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA2**

Mon 11/13/2017 to Fri 11/17/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SPRNBRK\_345KV\_RNS4**

Wed 11/15/2017 to Fri 11/17/2017 **UPDATED by CONED 10/03/2017**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**E13THSTA-FARRAGUT\_345\_45**

Sat 11/18/2017 to Tue 05/15/2018  
 0000 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sat 11/18/2017 to Tue 05/15/2018  
 0000 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EGRDNCTY\_345\_138\_AT1**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**SPRNBRK\_-EGRDNCTR\_345\_Y49**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
**CONED - LIPA 775 MW**  
 Impacts Total Transfer Capability 725 MW  
 TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES -ADIRNDCK\_230\_MA1**

Mon 11/20/2017 to Wed 11/22/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**WETHSRFD-MEYER\_230\_85/87**

Mon 11/20/2017 to Fri 12/01/2017 **UPDATED by NYSEG 09/13/2017**  
 1630 Continuous 1400  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**DYSINGER EAST 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**N. SCTLND-LEEDS\_345\_93**

Tue 11/21/2017 to Wed 11/22/2017 **UPDATED by NGRID 10/09/2017**  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD  
 (Import)  
**CENTRAL EAST - VC 2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**MOSES -ADIRNDCK\_230\_MA1**

Mon 11/27/2017 to Fri 12/01/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**ROSETON -EFISHKIL\_345\_RFK305**

Mon 11/27/2017 to Fri 12/01/2017  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4800 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 5100 MW

**ROTTDAM-EASTOVER\_230\_38**

Mon 11/27/2017 to Thu 11/30/2017  
 0900 Continuous 1500  
 Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
**SCH - NE - NY 1400 MW 1400 MW**  
 Impacts Total Transfer Capability 0 MW 200 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

**ARR: 77**

**ROSETON -EFISHKIL\_345\_RFK305**

Sat 12/02/2017 to Sat 12/02/2017  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
**UPNY CONED 4800 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 5100 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Sun 12/03/2017 to Tue 12/05/2017  
 0001 0300

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

-----  
**LEEDS -PLSNTVLY\_345\_92**

Mon 12/04/2017 to Mon 12/18/2017  
 0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED by NYISO 09/12/2017**

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

-----  
**PLSNTVLY\_345KV\_RNS5**

Mon 12/04/2017 to Mon 12/18/2017  
 0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED by NYISO 09/12/2017**

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MARCY 765\_345\_AT2**

Mon 12/04/2017 to Fri 12/08/2017  
 0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA2**

Mon 12/11/2017 to Fri 12/15/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA2**

Mon 12/18/2017 to Fri 12/22/2017  
 0700 Continuous 1530

Work scheduled by: NYPA

**UPDATED by NYPA 10/23/2016**

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**N. SCTLND-LEEDS 345\_94**

Tue 12/19/2017 to Wed 12/20/2017  
 0800 Continuous 1500

Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Wed 12/27/2017 to Thu 12/28/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**DUNWODIE-SHORE\_RD\_345\_Y50**

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by LI 09/22/2017**

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by LI 09/22/2017**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by LI 09/22/2017**

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by LI 09/22/2017**

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

Work scheduled by: ConEd

**EXTENDED by LI 09/22/2017**

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Tue 01/02/2018 to Fri 01/05/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_\_\_-PLSNTVLY\_345\_92**

Wed 01/03/2018 to Sat 01/06/2018  
0001 Continuous 0300

**UPDATED by NYISO 09/12/2017**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

Wed 01/03/2018 to Sat 01/06/2018  
0001 Continuous 0300

**UPDATED by NYISO 09/12/2017**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Fri 01/05/2018 to Sun 01/07/2018  
0001 2359

Work scheduled by:

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**PLSNTVLY\_345KV\_RNS5**

Mon 01/08/2018 to Wed 01/10/2018  
0001 Continuous 0300

**UPDATED by NYISO 09/12/2017**

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 01/08/2018 to Fri 01/12/2018  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 01/15/2018 to Fri 01/19/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**2300 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2**

Sat 01/20/2018 to Sat 01/20/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
**1700 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>			FWD	
Mon 01/22/2018	to	Fri 01/26/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK_230_MA1</b>			FWD	
Mon 01/29/2018	to	Fri 02/02/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>MARCY 765_345_AT2</b>			FWD	
Sat 02/03/2018	to	Sat 02/03/2018	(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
			<b>ARR: 19</b>	
<b>MARCY 765_345_AT2</b>			FWD	
Mon 02/05/2018	to	Fri 02/09/2018	(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
			<b>ARR: 19</b>	
<b>MOSES -ADIRNDCK_230_MA2</b>			FWD	
Mon 02/12/2018	to	Fri 02/16/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>HUDSONP -FARRAGUT_345_B3402</b>			FWD	REV
Sun 02/18/2018	to	Sun 04/01/2018	(Import)	(Export)
0001	Continuous	2359	SCH - PJ - NY	<b>2300 MW 1450 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2300 MW 1450 MW
<b>MARCY -EDIC 345_UE1-7</b>			FWD	
Tue 02/20/2018	to	Fri 02/23/2018	(Import)	
0500	Continuous	1730	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
			<b>ARR: 19&amp;16</b>	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>					FWD
Tue 02/20/2018	to	Fri 02/23/2018			(Import)
0700	Continuous	1730		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
<b>DUNWODIE_345KV_7</b>					FWD
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE_345KV_8</b>					FWD
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>
0001	Continuous	0030		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>
0001	Continuous	0300		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD      REV
Mon 02/26/2018	to	Wed 05/02/2018			(Import) (Export)
0001	Continuous	0300		SCH - NE - NY	<b>700 MW    1300 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW    300 MW
					TTC with All Lines In Service 1400 MW    1600 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD      REV
Mon 02/26/2018	to	Wed 05/02/2018			(Import) (Export)
0001	Continuous	0300		SCH - NPX_1385	<b>100 MW    100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 100 MW    100 MW
					TTC with All Lines In Service 200 MW    200 MW
<b>MOSES -ADIRNDCK_230_MA1</b>					FWD
Mon 02/26/2018	to	Fri 03/02/2018			(Import)
0700	Continuous	1730		MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>				FWD	
Mon 03/05/2018	to	Fri 03/09/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>MARCY -N.SCTLND_345_18</b>				FWD	
Tue 03/06/2018	to	Wed 03/07/2018		(Import)	
0600	Continuous	1530	CENTRAL EAST - VC	<b>2090 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW	
			TTC with All Lines In Service	2975 MW	
<b>MOSES -ADIRNDCK_230_MA1</b>				FWD	
Mon 03/12/2018	to	Fri 03/16/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
Mon 03/19/2018	to	Fri 04/20/2018		(Import)	(Export)
1000	Continuous	1559	SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW	100 MW
			TTC with All Lines In Service	2300 MW	1450 MW
<b>MOSES -ADIRNDCK_230_MA2</b>				FWD	
Mon 03/26/2018	to	Thu 03/29/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>DUNWODIE_345KV_7</b>				FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	<b>by CE</b>	<b>09/22/2017</b>
0230	Continuous	0300			
Work scheduled by: ConEd			SPR/DUN-SOUTH	<b>3800 MW</b>	
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
<b>DUNWODIE_345KV_8</b>				FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	<b>by CE</b>	<b>09/22/2017</b>
0230	Continuous	0300			
Work scheduled by: ConEd			SPR/DUN-SOUTH	<b>3800 MW</b>	
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>LINDN_CG-LNDVFT_345_V-3022</b>					
Sun 04/08/2018	to	Fri 04/13/2018			
1400	Continuous	1800	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW 315 MW
				TTC with All Lines In Service	315 MW 315 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD	
				(Import)	
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD	
				(Import)	
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>				FWD	
				(Import)	
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>				FWD	
				(Import)	
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: PJM				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
				(Import)	(Export)
Fri 04/20/2018	to	Sat 02/01/2020	<b>UPDATED by NYISO 10/09/2017</b>		
1600	Continuous	0000	SCH - PJ - NY	1950 MW	1350 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	350 MW 100 MW
				TTC with All Lines In Service	2300 MW 1450 MW
<b>MARCY_765_345_AT1</b>				FWD	
				(Import)	
Mon 04/23/2018	to	Mon 04/23/2018			
0500	Continuous	1730	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WETHSRFD-MEYER** 230\_85/87

Mon 04/23/2018 to Fri 05/11/2018  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

FWD  
 (Import)  
**DYSINGER EAST 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**HURLYAVE-ROSETON** 345\_303

Mon 04/30/2018 to Fri 05/25/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

Tue 05/01/2018 to Wed 10/31/2018  
 0001 Continuous 2359  
 Work scheduled by: NYISO

FWD  
 (Import)  
**CENTRAL EAST - VC 2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

**MARCY** 765\_345\_AT2

Mon 05/21/2018 to Fri 05/25/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MARCY** 765\_345\_AT1

Sat 08/04/2018 to Sun 08/05/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH 1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY** 765\_345\_AT2

Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**ROSETON-ROCKTVRN** 345\_311

Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

MARCY\_\_\_765\_345\_AT2

Thu 10/04/2018 to Fri 10/05/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 10/22/2018 to Fri 11/16/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

MARCY\_\_\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, October 11, 2017 to Friday, April 12, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_\_765\_345\_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018  
 0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH 1700 MW  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW