

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 11/24/2016	to	Wed 11/01/2017	EXT FORCE	by PJM	10/10/2017	(Import)
1500	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Tue 05/02/2017	to	Tue 10/10/2017	UPDATED	by NYISO	10/09/2017	(Import) (Export)
1710	Continuous	0759				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	Impacts Total Transfer Capability 150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
SCH-NYISO-HQ_LIMIT_800						REV
Thu 06/08/2017	to	Fri 12/15/2017	UPDATED	by HQ	08/03/2017	(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1450					FWD	
Tue 08/01/2017	to	Fri 12/15/2017				(Import)
2100	Continuous	1600				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	1500 MW
SCH-IMO-NYISO_LIMIT_1450					FWD	
Tue 08/29/2017	to	Tue 10/31/2017	EXTENDED	by NYISO	07/28/2017	(Import)
1230	Continuous	2359				1750 MW
Work scheduled by: NYISO					SCH - OH - NY	Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service	2000 MW
SCH-IMO-NYISO_LIMIT_1150					FWD	
Sat 09/09/2017	to	Fri 10/13/2017	UPDATED	by NGRID	10/12/2017	(Import)
0500	Continuous	1330				1450 MW
Work scheduled by: NGrid					SCH - OH - NY	Impacts Total Transfer Capability 550 MW
					TTC with All Lines In Service	2000 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD	
Mon 09/18/2017	to	Wed 10/11/2017	UPDATED	by NYPA	10/07/2017	(Import)
0630	Continuous	1900				2520 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 455 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
FIVEMILE-STOLLERD_345_29						
Thu 09/28/2017	to	Thu 10/19/2017	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>10/12/2017</u>	
0700	Continuous	1400				
Work scheduled by: NYSEG					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2100 MW
SPRNBRK_-W49TH_ST_345_M52						
Sun 10/01/2017	to	Sat 11/04/2017				
0001	Continuous	2359				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
PLSNTVLY-EFISHKIL_345_F36						
Mon 10/02/2017	to	Mon 10/16/2017				
0001	Continuous	0300				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
CHAT_DC_GC2						
Mon 10/02/2017	to	Wed 11/15/2017				
0500	Continuous	2000				
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC2						
Mon 10/02/2017	to	Wed 11/15/2017				REV
0500	Continuous	2000				(Export)
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1150						
Mon 10/02/2017	to	Wed 11/15/2017				
0500	Continuous	2000				
Work scheduled by: HQ					SCH - HQ - NY	1150 MW
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
SHOR_NPX-SHOREHAM_138_CSC						
Mon 10/02/2017	to	Sun 10/08/2017	<u>EXTENDED</u>	<u>by LI</u>	<u>10/07/2017</u>	
0600	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER -COOPERS 345_33					FWD
Mon 10/02/2017	to	Fri 10/13/2017			(Import)
0700	Continuous	1900			CENTRAL EAST - VC 2395 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability 580 MW
					TTC with All Lines In Service 2975 MW
SPRNBRK 345KV_RNS4					FWD
Mon 10/02/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by CONED 10/03/2017</u>	(Import)
1901	Continuous	0300			SPR/DUN-SOUTH 3200 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
SCH-NYISO-NE_LIMIT_700					REV
Fri 10/06/2017	to	Sat 10/07/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>	(Export)
0700	Continuous	2359			SCH - NE - NY 900 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1600 MW
SCH-NE-NYISO_LIMIT_500					FWD
Fri 10/06/2017	to	Tue 10/10/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>	(Import)
0700	Continuous	1600			SCH - NE - NY 700 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1400 MW
BERKSHIR-ALPS 345_393					FWD REV
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>	(Import) (Export)
0700	Continuous	1600			SCH - NE - NY 950 MW 1000 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 450 MW 600 MW
					TTC with All Lines In Service 1400 MW 1600 MW
BERKSHIR-ALPS 345_393					FWD REV
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>	(Import) (Export)
0700	Continuous	1600			SCH - NPX_1385 100 MW 100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD_345_312					FWD REV
Fri 10/06/2017	to	Sat 10/28/2017			(Import) (Export)
0700		1600			SCH - NE - NY 950 MW 1000 MW
Work scheduled by:					Impacts Total Transfer Capability 450 MW 600 MW
					TTC with All Lines In Service 1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
BERKSHIR-NORTHFLD_345_312						
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/10/2017</u>	
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NE - NY	900 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
BERKSHIR-NORTHFLD_345_312						
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/10/2017</u>	
0700	Continuous	1600				
Work scheduled by: ISONE					SCH - NPX_1385	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
CHAT_DC_GC1						
Sun 10/08/2017	to	Sun 10/08/2017				
0001	Continuous	0200				
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						
Sun 10/08/2017	to	Sun 10/08/2017				
0001	Continuous	0200				
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2						
Sun 10/08/2017	to	Sun 10/08/2017				
0001		0200				
Work scheduled by:					MOSES SOUTH	2550 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2						
Sun 10/08/2017	to	Sun 10/08/2017				
0001		0200				
Work scheduled by:					SCH - HQ - NY	1370 MW
					Impacts Total Transfer Capability	130 MW
					TTC with All Lines In Service	1500 MW
SCH-HQ-NYISO_LIMIT_700						
Sun 10/08/2017	to	Sun 10/08/2017				
0001	Continuous	0200				
Work scheduled by: HQ					SCH - HQ - NY	700 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600					REV	
Sun 10/08/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/10/2017</u>	(Export)
0001	Continuous	1600				800 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
SCH-NE-NYISO_LIMIT_800					FWD	
Mon 10/09/2017	to	Thu 10/12/2017				(Import)
0700	Continuous	1700				1000 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW
CLAY -EDIC 345_1-16					FWD	
Wed 10/11/2017	to	Wed 10/11/2017				(Import)
0700	Continuous	1700				4850 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
SCH-NE-NYISO_LIMIT_600					FWD	
Thu 10/12/2017	to	Thu 10/12/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/06/2017</u>	(Import)
0700	Continuous	0759				800 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	1400 MW
SCH-NYISO-NE_LIMIT_500					REV	
Thu 10/12/2017	to	Thu 10/12/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/06/2017</u>	(Export)
0700	Continuous	0759				700 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	1600 MW
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Fri 10/13/2017	to	Mon 10/23/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import) (Export)
1500	Continuous	0759				1950 MW 1350 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
CHATGUAY-MASSENA_765_7040					FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)
0100	Continuous	2000				1550 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	1600 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							FWD	REV
CHATGUAY-MASSENA__765_7040							(Import)	(Export)
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	SCH - HQ - NY	0 MW	0 MW
0100	Continuous	2000				Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: HQ						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>							FWD	
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES__-MASSENA_230_MMS1 & MOSES__-MASSENA_230_MMS2							(Import)	
Sat 10/14/2017	to	Sat 10/21/2017				MOSES SOUTH	1950 MW	
0100		2000				Impacts Total Transfer Capability	1200 MW	
Work scheduled by:						TTC with All Lines In Service	3150 MW	
<hr/>							FWD	
MARCY__765_345_AT1							(Import)	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	MOSES SOUTH	1750 MW	
0100	Continuous	2000				Impacts Total Transfer Capability	1400 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
<hr/>							FWD	
MARCY__765_345_AT2							(Import)	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	MOSES SOUTH	1700 MW	
0100	Continuous	2000				Impacts Total Transfer Capability	1450 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
<hr/>							FWD	
MASSENA_-MARCY__765_MSU1							(Import)	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	CENTRAL EAST - VC	2265 MW	
0100	Continuous	2000				Impacts Total Transfer Capability	710 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW	
<hr/>							FWD	
MASSENA_-MARCY__765_MSU1							(Import)	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	MOSES SOUTH	500 MW	
0100	Continuous	2000				Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
<hr/>							FWD	REV
MASSENA_-MARCY__765_MSU1							(Import)	(Export)
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	SCH - HQ - NY	475 MW	1000 MW
0100	Continuous	2000				Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA						TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY_ 765_MSU1 & CHATGUAY-MASSENA_ 765_7040

Sat 10/14/2017 to Sat 10/21/2017
0100 2000

Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_ 230_MMS1 & MOSES_-MASSENA_ 230_MMS2

Sat 10/14/2017 to Sat 10/21/2017
0100 2000

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **850 MW 0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by HQ 10/11/2017**
0100 Continuous 2000

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by HQ 10/11/2017**
0100 Continuous 2000

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sat 10/14/2017 to Sat 10/28/2017
0100 2000

Work scheduled by:

FWD
(Import)
MOSES SOUTH **2550 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sat 10/14/2017 to Sat 10/28/2017
0100 2000

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **1370 MW 0 MW**
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

SCH-HQ-NYISO_LIMIT_700

Sat 10/14/2017 to Sat 10/28/2017 **UPDATED by HQ 10/11/2017**
0100 Continuous 2000

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **700 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMRC_NY-MAINS_NY_345_47			
Sat 10/14/2017 to Fri 10/27/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>10/11/2017</u>
0700 Continuous 1730			
Work scheduled by: NYSEG			
		SCH - PJ - NY	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	2100 MW 1350 MW
		TTC with All Lines In Service	2100 MW 1350 MW
SCH-IMO-NYISO_LIMIT_600			
Mon 10/16/2017 to Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>
0500 Continuous 1700			
Work scheduled by: NYPA			
		SCH - OH - NY	FWD (Import)
		Impacts Total Transfer Capability	900 MW 1100 MW
		TTC with All Lines In Service	2000 MW
SCH-IMO_NY_NIAG_NRTH_BUS_W/BB			
Mon 10/16/2017 to Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>
0500 Continuous 1700			
Work scheduled by: NYPA			
		SCH - OH - NY	FWD (Import) REV (Export)
		Impacts Total Transfer Capability	1000 MW 1150 MW 450 MW
		TTC with All Lines In Service	2000 MW 1600 MW
COOPERS_-MIDDLETP_345_CCRT34			
Mon 10/16/2017 to Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/21/2017</u>
0700 Continuous 1500			
Work scheduled by: NYSEG			
		CENTRAL EAST - VC	FWD (Import)
		Impacts Total Transfer Capability	2720 MW 255 MW
		TTC with All Lines In Service	2975 MW
HURLYAVE-ROSETON__345_303			
Mon 10/16/2017 to Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>
0800 Continuous 1600			
Work scheduled by: CHGE			
		UPNY CONED	FWD (Import)
		Impacts Total Transfer Capability	4100 MW 1000 MW
		TTC with All Lines In Service	5100 MW
LEEDS_-HURLYAVE_345_301			
Mon 10/16/2017 to Fri 11/03/2017			
0800 Continuous 1600			
Work scheduled by: CHGE			
		UPNY CONED	FWD (Import)
		Impacts Total Transfer Capability	4100 MW 1000 MW
		TTC with All Lines In Service	5100 MW
MARCY_SO_SERIES_COMP_I/S			
Sat 10/21/2017 to Tue 10/31/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/11/2017</u>
2000 Continuous 2359			
Work scheduled by: NYISO			
		CENTRAL EAST - VC	FWD (Import)
		Impacts Total Transfer Capability	2740 MW 235 MW
		TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38					FWD
Mon 10/23/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYISO</u>	(Import)
0600	Continuous	1559		<u>10/09/2017</u>	1700 MW
Work scheduled by: NYPA					DYSINGER EAST
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
S.RIPLEY-DUNKIRK__230_68					FWD
Mon 10/23/2017	to	Thu 10/26/2017	<u>UPDATED</u>	<u>by NYISO</u>	(Import) (Export)
0800	Continuous	1500		<u>08/01/2017</u>	1950 MW 1350 MW
Work scheduled by: PJM					SCH - PJ - NY
					Impacts Total Transfer Capability 150 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					
BECK__-NIAGARA__345_PA301					FWD
Tue 10/24/2017	to	Wed 10/25/2017			(Import) (Export)
0500	Continuous	1700			900 MW 800 MW
Work scheduled by: NYPA					SCH - OH - NY
					Impacts Total Transfer Capability 1100 MW 800 MW
					TTC with All Lines In Service 2000 MW 1600 MW
<hr/>					
NIAGARA_-KINTIGH__345_NS1-38					FWD
Wed 10/25/2017	to	Thu 11/09/2017	<u>UPDATED</u>	<u>by NYISO</u>	(Import)
1600	Continuous	1600		<u>10/09/2017</u>	1700 MW
Work scheduled by: NYSEG					DYSINGER EAST
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<hr/>					
S.RIPLEY-DUNKIRK__230_68					FWD
Thu 10/26/2017	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by NYISO</u>	(Import) (Export)
1501	Continuous	0959		<u>10/09/2017</u>	1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY
					Impacts Total Transfer Capability 150 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					
W49TH_ST_345KV_5					FWD
Fri 10/27/2017	to	Sat 11/04/2017			(Import)
0001	Continuous	2359			315 MW
Work scheduled by: ConEd					SCH - PJM_HTP
					Impacts Total Transfer Capability 345 MW
					TTC with All Lines In Service 660 MW
<hr/>					
SPRNBRK__345KV_RNS4					FWD
Sat 10/28/2017	to	Sat 11/04/2017			(Import)
0301	Continuous	2359			3200 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH
					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 10/30/2017 to Sat 11/04/2017
0700 Continuous 1530

Work scheduled by: NYPA

EXTENDED by NYPA 10/02/2017

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

NEPTUNE -DUFFYAVE_345_NEPTUNE

Tue 10/31/2017 to Thu 11/02/2017
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 10/31/2017 to Thu 11/02/2017
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 10/31/2017 to Thu 11/02/2017
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Tue 10/31/2017 to Thu 11/02/2017
0001 Continuous 2359

Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

PLSNTVLY-EFISHKIL_345_F36

Wed 11/01/2017 to Sat 11/04/2017
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

LAFAYTTE-CLRKSCRN_345_4-46

Wed 11/01/2017 to Thu 11/02/2017
0630 Continuous 1630

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42					FWD	
Wed 11/01/2017	to	Sat 11/04/2017			(Import)	
0830	Continuous	1800		CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
MARION_-FARRAGUT_345_C3403					FWD	REV
Thu 11/02/2017	to	Sat 12/02/2017	<u>UPDATED</u>	<u>by CE</u>	<u>09/29/2017</u>	(Import) (Export)
0001	Continuous	0100				
Work scheduled by: ConEd					SCH - PJ - NY	2300 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	1300 MW 1300 MW
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-ALPS_____345_393					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-ALPS_____345_393 & BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017				(Import) (Export)
0700		1900				
Work scheduled by:					SCH - NE - NY	1300 MW 1300 MW
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	1400 MW 1450 MW
					Impacts Total Transfer Capability	0 MW 150 MW
					TTC with All Lines In Service	1400 MW 1600 MW
BERKSHIR-NORTHFLD_345_312					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by NE</u>	<u>10/10/2017</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500

Thu 11/02/2017 to Sat 11/04/2017
0700 Continuous 1900

UPDATED by NE 10/10/2017

Work scheduled by: NGrid

FWD
(Import)
700 MW
SCH - NE - NY
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_700

Thu 11/02/2017 to Sat 11/04/2017
0700 Continuous 1900

UPDATED by NE 10/10/2017

Work scheduled by: NGrid

REV
(Export)
900 MW
SCH - NE - NY
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1600 MW

E13THSTA-FARRAGUT_345_46

Sat 11/04/2017 to Sat 11/04/2017
0230 Continuous 0300

UPDATED by CE 10/04/2017

Work scheduled by: ConEd

FWD
(Import)
3800 MW
SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

PLSNTVLY-EFISHKIL_345_F36

Mon 11/06/2017 to Wed 11/08/2017
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
4000 MW
UPNY CONED
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 5100 MW

MOSES__-ADIRNDCK_230_MA2

Mon 11/06/2017 to Thu 11/09/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
2300 MW
MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASANX-COOPERS__345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
2500 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY__-FRASANX_345_UCC2-41

Mon 11/06/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
2500 MW
CENTRAL EAST - VC
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work by	SCH	FWD	REV
LINDN_CG-LNDVFT_345_V-3022	Mon 11/06/2017	Thu 11/09/2017	0800 Continuous 1500	PJM	SCH - PJM_VFT	0 MW	0 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
SCRIBA -VOLNEY_345_20	Mon 11/06/2017	Fri 11/17/2017	0800 Continuous 1630	NGrid	OSWEGO EXPORT	5250 MW	
					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	
W49TH_ST_345KV_5	Fri 11/10/2017	Fri 11/10/2017	0001 Continuous 0030	ConEd	SCH - PJM_HTP	315 MW	
					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	
SPRNBRK -W49TH_ST_345_M52	Fri 11/10/2017	Mon 11/13/2017	0001 Continuous 0300	ConEd	SPR/DUN-SOUTH	3200 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBRK_345KV_RNS4	Fri 11/10/2017	Mon 11/13/2017	0001 Continuous 0300	ConEd	SPR/DUN-SOUTH	3200 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service	4600 MW	
SPRNBRK_345KV_RS3 & SPRNBRK_345KV_RS4	Sun 11/12/2017	Wed 11/15/2017	0001 Continuous 0300		SPR/DUN-SOUTH	3800 MW	
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_5	Mon 11/13/2017	Mon 11/13/2017	0230 Continuous 0300	ConEd	SCH - PJM_HTP	315 MW	
					Impacts Total Transfer Capability	345 MW	
					TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SPRNBRK_345KV_RNS4

Wed 11/15/2017 to Fri 11/17/2017 **UPDATED by CONED 10/03/2017**
0001 Continuous 0100

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

E13THSTA-FARRAGUT_345_45

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Sat 11/18/2017 to Tue 05/15/2018
0000 Continuous 2359

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

EGRDNCTY_345_138_AT1

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**
0001 Continuous 0300

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**
0001 Continuous 0300

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **1250 MW**
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

SPRNBRK_-EGRDNCTR_345_Y49

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**
0001 Continuous 0300

Work scheduled by: LI

FWD
(Import)
CONED - LIPA **775 MW**
Impacts Total Transfer Capability 725 MW
TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Mon 11/20/2017 to Wed 11/22/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

WETHSRFD-MEYER_230_85/87

Mon 11/20/2017 to Fri 12/01/2017 **UPDATED by NYSEG 09/13/2017**
 1630 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
DYSINGER EAST 2850 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

N. SCTLND-LEEDS_345_93

Tue 11/21/2017 to Wed 11/22/2017 **UPDATED by NGRID 10/09/2017**
 0800 Continuous 1500
 Work scheduled by: NGrid

FWD
 (Import)
CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

MOSES -ADIRNDCK_230_MA1

Mon 11/27/2017 to Fri 12/01/2017
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

ROSETON -EFISHKIL_345_RFK305

Mon 11/27/2017 to Fri 12/01/2017
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4800 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 5100 MW

ROTTDAM-EASTOVER_230_38

Mon 11/27/2017 to Thu 11/30/2017
 0900 Continuous 1500
 Work scheduled by: NGrid

FWD REV
 (Import) (Export)
SCH - NE - NY 1400 MW 1400 MW
 Impacts Total Transfer Capability 0 MW 200 MW
 TTC with All Lines In Service 1400 MW 1600 MW

ARR: 77

ROSETON -EFISHKIL_345_RFK305

Sat 12/02/2017 to Sat 12/02/2017
 0001 Continuous 2359
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4800 MW
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Sun 12/03/2017 to Tue 12/05/2017
0001 0300

Work scheduled by:

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

LEEDS -PLSNTVLY_345_92

Mon 12/04/2017 to Mon 12/18/2017
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Mon 12/04/2017 to Mon 12/18/2017
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

MARCY 765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA2

Mon 12/18/2017 to Fri 12/22/2017
0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 10/23/2016

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

N. SCTLND-LEEDS 345_94

Tue 12/19/2017 to Wed 12/20/2017
0800 Continuous 1500

Work scheduled by: NGrid

FWD
(Import)
CENTRAL EAST - VC 2650 MW
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Wed 12/27/2017 to Thu 12/28/2017
0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

DUNWODIE-SHORE_RD_345_Y50

Tue 01/02/2018 to Thu 01/04/2018
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
(Import)
CONED - LIPA **800 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1500 MW

DUNWODIE_345KV_4

Tue 01/02/2018 to Thu 01/04/2018
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Tue 01/02/2018 to Thu 01/04/2018
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SHORE_RD_345_138_BK 1

Tue 01/02/2018 to Thu 01/04/2018
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Tue 01/02/2018 to Thu 01/04/2018
0001 Continuous 2359

Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
(Import)
CONED - LIPA **1350 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

MOSES___-ADIRNDCK_230_MAL

Tue 01/02/2018 to Fri 01/05/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92

Wed 01/03/2018 to Sat 01/06/2018
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Wed 01/03/2018 to Sat 01/06/2018
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 01/05/2018 to Sun 01/07/2018
 0001 2359
 Work scheduled by:

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Mon 01/08/2018 to Wed 01/10/2018
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

MOSES___-ADIRNDCK_230_MAI

Mon 01/08/2018 to Fri 01/12/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 01/15/2018 to Fri 01/19/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Sat 01/20/2018 to Sat 01/20/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MAI			FWD	
Mon 01/22/2018	to	Fri 01/26/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MAI			FWD	
Mon 01/29/2018	to	Fri 02/02/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2			FWD	
Sat 02/03/2018	to	Sat 02/03/2018	(Import)	
0500	Continuous	1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
			ARR: 19	
MARCY___765_345_AT2			FWD	
Mon 02/05/2018	to	Fri 02/09/2018	(Import)	
0500	Continuous	1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
			ARR: 19	
MOSES___-ADIRNDCK_230_MA2			FWD	
Mon 02/12/2018	to	Fri 02/16/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
HUDSONP_-FARRAGUT_345_B3402			FWD	REV
Sun 02/18/2018	to	Sun 04/01/2018	(Import)	(Export)
0001	Continuous	2359	SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2300 MW 1450 MW
MARCY___-EDIC___345_UE1-7			FWD	
Tue 02/20/2018	to	Fri 02/23/2018	(Import)	
0500	Continuous	1730	OSWEGO EXPORT	5250 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW
			TTC with All Lines In Service	5250 MW
			ARR: 19&16	

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MAL					FWD	
Tue 02/20/2018	to	Fri 02/23/2018			(Import)	
0700	Continuous	1730		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
DUNWODIE_345KV_7					FWD	
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_8					FWD	
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	0030				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
DUNWODIE-MOTTHAVN_345_72					FWD	
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	0300				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3800 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
LONG_MTN-PLSNTVLY_345_398					FWD	REV
Mon 02/26/2018	to	Wed 05/02/2018			(Import)	(Export)
0001	Continuous	0300				
Work scheduled by: ConEd					SCH - NE - NY	700 MW 1300 MW
					Impacts Total Transfer Capability	700 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW
LONG_MTN-PLSNTVLY_345_398					FWD	REV
Mon 02/26/2018	to	Wed 05/02/2018			(Import)	(Export)
0001	Continuous	0300				
Work scheduled by: ConEd					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
MOSES___-ADIRNDCK_230_MAL					FWD	
Mon 02/26/2018	to	Fri 03/02/2018			(Import)	
0700	Continuous	1730				
Work scheduled by: NYPA					MOSES SOUTH	2300 MW
					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1				FWD
Mon 03/05/2018	to	Fri 03/09/2018		(Import)
0700	Continuous	1730		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
MARCY___-N.SCTLND_345_18				FWD
Tue 03/06/2018	to	Wed 03/07/2018		(Import)
0600	Continuous	1530		CENTRAL EAST - VC 2090 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 885 MW
ARR: 19				TTC with All Lines In Service 2975 MW
MOSES___-ADIRNDCK_230_MA1				FWD
Mon 03/12/2018	to	Fri 03/16/2018		(Import)
0700	Continuous	1730		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
S.RIPLEY-DUNKIRK__230_68				FWD REV
Mon 03/19/2018	to	Fri 04/20/2018		(Import) (Export)
1000	Continuous	1559		SCH - PJ - NY 1950 MW 1350 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 350 MW 100 MW
				TTC with All Lines In Service 2300 MW 1450 MW
MOSES___-ADIRNDCK_230_MA2				FWD
Mon 03/26/2018	to	Thu 03/29/2018		(Import)
0700	Continuous	1530		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
DUNWODIE_345KV_7				FWD
Sat 03/31/2018	to	Sat 03/31/2018	UPDATED by CE 09/22/2017	(Import)
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8				FWD
Sat 03/31/2018	to	Sat 03/31/2018	UPDATED by CE 09/22/2017	(Import)
0230	Continuous	0300		SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LINDN_CG-LNDVFT_345_V-3022					
Sun 04/08/2018	to	Fri 04/13/2018			
1400	Continuous	1800			
Work scheduled by: PJM				SCH - PJM_VFT	0 MW
				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800			
Work scheduled by: PJM				SCH - PJM_NEPTUNE	0 MW
				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800			
Work scheduled by: PJM				SCH - PJM_NEPTUNE	0 MW
				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800			
Work scheduled by: PJM				SCH - PJM_NEPTUNE	375 MW
				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					
Mon 04/16/2018	to	Tue 05/01/2018			
0001	Continuous	1800			
Work scheduled by: PJM				SCH - PJM_NEPTUNE	375 MW
				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK_230_68					
Fri 04/20/2018	to	Sat 02/01/2020	UPDATED	by NYISO	10/09/2017
1600	Continuous	0000			
Work scheduled by: NYISO				SCH - PJ - NY	1950 MW
				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	2300 MW
MARCY_765_345_AT1					
Mon 04/23/2018	to	Mon 04/23/2018			
0500	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	1750 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WETHSRFD-MEYER___230_85/87

Mon 04/23/2018 to Fri 05/11/2018
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 04/30/2018 to Fri 05/25/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
 0001 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
 0500 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2690 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Thursday ,October 12, 2017 to Saturday ,April 13, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY____765_345_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW