

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56					FWD	
Thu 11/24/2016	to	Wed 11/01/2017	EXT FORCE	by PJM	10/10/2017	(Import)
1500	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Tue 05/02/2017	to	Tue 10/10/2017	UPDATED	by NYISO	10/09/2017	(Import) (Export)
1710	Continuous	0759				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	Impacts Total Transfer Capability 150 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
SCH-NYISO-HQ_LIMIT_800						REV
Thu 06/08/2017	to	Fri 12/15/2017	UPDATED	by HQ	08/03/2017	(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1450					FWD	
Tue 08/01/2017	to	Fri 12/15/2017				(Import)
2100	Continuous	1600				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service	1500 MW
SCH-IMO-NYISO_LIMIT_1450					FWD	
Tue 08/29/2017	to	Tue 10/31/2017	EXTENDED	by NYISO	07/28/2017	(Import)
1230	Continuous	2359				1750 MW
Work scheduled by: NYISO					SCH - OH - NY	Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service	2000 MW
SCH-IMO-NYISO_LIMIT_1150					FWD	
Sat 09/09/2017	to	Fri 10/13/2017	UPDATED	by NGRID	10/12/2017	(Import)
0500	Continuous	1330				1450 MW
Work scheduled by: NGrid					SCH - OH - NY	Impacts Total Transfer Capability 550 MW
					TTC with All Lines In Service	2000 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD	
Mon 09/18/2017	to	Wed 10/11/2017	UPDATED	by NYPA	10/07/2017	(Import)
0630	Continuous	1900				2520 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	Impacts Total Transfer Capability 455 MW
					TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
FIVEMILE-STOLLERD_345_29					(Import)	(Export)
Thu 09/28/2017	to	Thu 10/19/2017	<u>UPDATED</u>	<u>by NGRID</u>	<u>10/13/2017</u>	
0700	Continuous	1500				
Work scheduled by: NYSEG					SCH - PJ - NY	2100 MW
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2100 MW
<hr/>					FWD	REV
SPRNBRK_-W49TH_ST_345_M52					(Import)	(Export)
Sun 10/01/2017	to	Sat 11/04/2017				
0001	Continuous	2359				
Work scheduled by: ConEd					SPR/DUN-SOUTH	3200 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<hr/>					FWD	REV
PLSNTVLY-EFISHKIL_345_F36					(Import)	(Export)
Mon 10/02/2017	to	Mon 10/16/2017				
0001	Continuous	0300				
Work scheduled by: ConEd					UPNY CONED	4000 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<hr/>					FWD	REV
CHAT_DC_GC2					(Import)	(Export)
Mon 10/02/2017	to	Wed 11/15/2017				
0500	Continuous	2000				
Work scheduled by: HQ					MOSES SOUTH	2850 MW
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
<hr/>					FWD	REV
CHAT_DC_GC2					(Import)	(Export)
Mon 10/02/2017	to	Wed 11/15/2017				
0500	Continuous	2000				
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<hr/>					FWD	REV
SCH-HQ-NYISO_LIMIT_1150					(Import)	(Export)
Mon 10/02/2017	to	Wed 11/15/2017				
0500	Continuous	2000				
Work scheduled by: HQ					SCH - HQ - NY	1150 MW
					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
<hr/>					FWD	REV
SHOR_NPX-SHOREHAM_138_CSC					(Import)	(Export)
Mon 10/02/2017	to	Sun 10/08/2017	<u>EXTENDED</u>	<u>by LI</u>	<u>10/07/2017</u>	
0600	Continuous	1600				
Work scheduled by: LI					SCH - NPX_CSC	0 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Type	Impact	TTC	FWD	REV
FRASER - COOPERS 345_33	Mon 10/02/2017	Fri 10/13/2017	0700	Continuous	1900	NYSEG	CENTRAL EAST - VC	2395 MW	2395 MW	
							Impacts Total Transfer Capability	580 MW		
							TTC with All Lines In Service	2975 MW		
SPRNBRK 345KV_RNS4	Mon 10/02/2017	Sat 10/28/2017	1901	Continuous	0300	ConEd	SPR/DUN-SOUTH	3200 MW		
							Impacts Total Transfer Capability	1400 MW		
							TTC with All Lines In Service	4600 MW		
SCH-NE-NYISO_LIMIT_500	Fri 10/06/2017	Tue 10/10/2017	0700	Continuous	1600	ISONE	SCH - NE - NY	700 MW		
							Impacts Total Transfer Capability	700 MW		
							TTC with All Lines In Service	1400 MW		
BERKSHIR-ALPS 345_393	Fri 10/06/2017	Fri 10/13/2017	0700	Continuous	1359	NGrid	SCH - NE - NY	950 MW	1000 MW	
							Impacts Total Transfer Capability	450 MW	600 MW	
							TTC with All Lines In Service	1400 MW	1600 MW	
										ARR: 78
BERKSHIR-ALPS 345_393	Fri 10/06/2017	Fri 10/13/2017	0700	Continuous	1359	NGrid	SCH - NPX_1385	100 MW	100 MW	
							Impacts Total Transfer Capability	100 MW	100 MW	
							TTC with All Lines In Service	200 MW	200 MW	
										ARR: 78
BERKSHIR-ALPS 345_393 & BERKSHIR-NORTHFLD 345_312	Fri 10/06/2017	Fri 10/13/2017	0700		1359		SCH - NE - NY	950 MW	1000 MW	
							Impacts Total Transfer Capability	450 MW	600 MW	
							TTC with All Lines In Service	1400 MW	1600 MW	
										ARR: 78
BERKSHIR-NORTHFLD 345_312	Fri 10/06/2017	Sat 10/28/2017	0700	Continuous	1600	ISONE	SCH - NE - NY	900 MW	1200 MW	
							Impacts Total Transfer Capability	500 MW	400 MW	
							TTC with All Lines In Service	1400 MW	1600 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312				FWD	REV
				(Import)	(Export)
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by ISONE</u> <u>10/10/2017</u>	SCH - NPX_1385	100 MW 100 MW
0700	Continuous	1600		Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: ISONE				TTC with All Lines In Service	200 MW 200 MW
CHAT_DC_GC1				FWD	
				(Import)	
Sun 10/08/2017	to	Sun 10/08/2017		MOSES SOUTH	2850 MW
0001	Continuous	0200		Impacts Total Transfer Capability	300 MW
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					REV
					(Export)
Sun 10/08/2017	to	Sun 10/08/2017		SCH - HQ - NY	500 MW
0001	Continuous	0200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	
				(Import)	
Sun 10/08/2017	to	Sun 10/08/2017		MOSES SOUTH	2550 MW
0001		0200		Impacts Total Transfer Capability	600 MW
Work scheduled by:				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2				FWD	REV
				(Import)	(Export)
Sun 10/08/2017	to	Sun 10/08/2017		SCH - HQ - NY	1370 MW 0 MW
0001		0200		Impacts Total Transfer Capability	130 MW 1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW 1000 MW
SCH-HQ-NYISO_LIMIT_700				FWD	
				(Import)	
Sun 10/08/2017	to	Sun 10/08/2017		SCH - HQ - NY	700 MW
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: HQ				TTC with All Lines In Service	1500 MW
SCH-NYISO-NE_LIMIT_600					REV
					(Export)
Sun 10/08/2017	to	Sat 10/28/2017	<u>UPDATED</u> <u>by ISONE</u> <u>10/10/2017</u>	SCH - NE - NY	800 MW
0001	Continuous	1600		Impacts Total Transfer Capability	800 MW
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800				FWD	
Mon 10/09/2017	to	Thu 10/12/2017		(Import)	
0700	Continuous	1700	SCH - NE - NY	1000 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	1400 MW	
CLAY -EDIC 345_1-16				FWD	
Wed 10/11/2017	to	Wed 10/11/2017		(Import)	
0700	Continuous	1700	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
SCH-NE-NYISO_LIMIT_600				FWD	
Thu 10/12/2017	to	Thu 10/12/2017	UPDATED by ISONE 10/06/2017	(Import)	
0700	Continuous	0759	SCH - NE - NY	800 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW	
			TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_500				REV	
Thu 10/12/2017	to	Thu 10/12/2017	UPDATED by ISONE 10/06/2017	(Export)	
0700	Continuous	0759	SCH - NE - NY	700 MW	
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	1600 MW	
FRASER 345_FRASER SVC				FWD	
Fri 10/13/2017	to	Sat 10/14/2017	FORCED by NYSEG 10/13/2017	(Import)	
1219	Continuous	2359	CENTRAL EAST - VC	2935 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
S.RIPLEY-DUNKIRK 230_68				FWD	REV
Fri 10/13/2017	to	Mon 10/23/2017	UPDATED by NYISO 10/09/2017	(Import)	(Export)
1500	Continuous	0759	SCH - PJ - NY	1950 MW	1350 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	150 MW	0 MW
			TTC with All Lines In Service	2100 MW	1350 MW
BERKSHIR-ALPS 345_393				FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	UPDATED by ISONE 10/13/2017	(Import)	(Export)
1516	Continuous	1600	SCH - NE - NY	950 MW	1000 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW

ARR: 78

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
BERKSHIR-ALPS _____	345_393						
Fri 10/13/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/13/2017</u>		
1516	Continuous	1600				SCH - NPX_1385	100 MW
Work scheduled by: NGrid							100 MW
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
							ARR: 78
BERKSHIR-ALPS _____	345_393	& BERKSHIR-NORTHFLD _____	345_312				
Fri 10/13/2017	to	Sat 10/28/2017					
1516		1600				SCH - NE - NY	950 MW
Work scheduled by:							1000 MW
						Impacts Total Transfer Capability	450 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
							ARR: 78
W49TH_ST_345KV_8							
Sat 10/14/2017	to	Wed 10/18/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/13/2017</u>		
0001	Continuous	2200				SCH - PJM_HTP	315 MW
Work scheduled by: ConEd							
						Impacts Total Transfer Capability	345 MW
						TTC with All Lines In Service	660 MW
CHATGUAY-MASSENA _____	765_7040						
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>		
0100	Continuous	2000				MOSES SOUTH	1550 MW
Work scheduled by: HQ							
						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA _____	765_7040						
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>		
0100	Continuous	2000				SCH - HQ - NY	0 MW
Work scheduled by: HQ							0 MW
						Impacts Total Transfer Capability	1500 MW
						TTC with All Lines In Service	1500 MW
							1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES _____	-MASSENA _____	230_MMS1	& MOSES _____	-	MASSENA _____	230_MMS2	
Sat 10/14/2017	to	Sat 10/21/2017					
0100		2000				MOSES SOUTH	1950 MW
Work scheduled by:							
						Impacts Total Transfer Capability	1200 MW
						TTC with All Lines In Service	3150 MW
MARCY _____	765_345_AT1						
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>		
0100	Continuous	2000				MOSES SOUTH	1750 MW
Work scheduled by: NYPA							
						Impacts Total Transfer Capability	1400 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2					FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)
0100	Continuous	2000				1700 MW
Work scheduled by: NYPA					ARR: 19	MOSES SOUTH Impacts Total Transfer Capability 1450 MW TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)
0100	Continuous	2000				2265 MW
Work scheduled by: NYPA					CENTRAL EAST - VC Impacts Total Transfer Capability 710 MW TTC with All Lines In Service 2975 MW	
MASSENA_-MARCY___765_MSU1					FWD	
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)
0100	Continuous	2000				500 MW
Work scheduled by: NYPA					MOSES SOUTH Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW	
MASSENA_-MARCY___765_MSU1					FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import) (Export)
0100	Continuous	2000				475 MW 1000 MW
Work scheduled by: NYPA					SCH - HQ - NY Impacts Total Transfer Capability 1025 MW 0 MW TTC with All Lines In Service 1500 MW 1000 MW	
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040					FWD	
Sat 10/14/2017	to	Sat 10/21/2017				(Import)
0100		2000				500 MW
Work scheduled by:					MOSES SOUTH Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW	
MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2					FWD	REV
Sat 10/14/2017	to	Sat 10/21/2017				(Import) (Export)
0100		2000				850 MW 0 MW
Work scheduled by:					SCH - HQ - NY Impacts Total Transfer Capability 650 MW 1000 MW TTC with All Lines In Service 1500 MW 1000 MW	
CHAT_DC_GC1					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)
0100	Continuous	2000				2850 MW
Work scheduled by: HQ					MOSES SOUTH Impacts Total Transfer Capability 300 MW TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					REV	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by HQ	10/11/2017	(Export)
0100	Continuous	2000				500 MW
Work scheduled by: HQ					SCH - HQ - NY	500 MW
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sat 10/14/2017	to	Sat 10/28/2017				(Import)
0100		2000				2550 MW
Work scheduled by:					MOSES SOUTH	2550 MW
					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017				(Import) (Export)
0100		2000				1370 MW 0 MW
Work scheduled by:					SCH - HQ - NY	1370 MW 0 MW
					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
SCH-HQ-NYISO_LIMIT_700					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	UPDATED	by HQ	10/11/2017	(Import)
0100	Continuous	2000				700 MW
Work scheduled by: HQ					SCH - HQ - NY	700 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1500 MW
HOMRC_NY-MAINS_NY_345_47					FWD	REV
Sat 10/14/2017	to	Fri 10/27/2017	UPDATED	by NYSEG	10/11/2017	(Import) (Export)
0700	Continuous	1730				2100 MW 1350 MW
Work scheduled by: NYSEG					SCH - PJ - NY	2100 MW 1350 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
W49TH_ST_345KV_7					FWD	
Sun 10/15/2017	to	Sun 10/15/2017	UPDATED	by CE	10/13/2017	(Import)
0001	Continuous	2100				350 MW
Work scheduled by: ConEd					SCH - PJM_HTP	350 MW
					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
SCH-IMO-NYISO_LIMIT_600					FWD	
Mon 10/16/2017	to	Fri 10/20/2017	UPDATED	by NYISO	10/12/2017	(Import)
0500	Continuous	1700				900 MW
Work scheduled by: NYPA					SCH - OH - NY	900 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SCH-IMO_NY_NIAG_NRTH_BUS_W/BB						
Mon 10/16/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1000 MW
					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	2000 MW
						1600 MW
COOPERS_-MIDDLETP_345_CCRT34					FWD	
Mon 10/16/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>06/21/2017</u>	
0700	Continuous	1500				
Work scheduled by: NYSEG					CENTRAL EAST - VC	2720 MW
					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
HURLYAVE-ROSETON_345_303					FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	4100 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
LEEDS_-HURLYAVE_345_301					FWD	
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	4100 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
MARCY_SO_SERIES_COMP_I/S					FWD	
Sat 10/21/2017	to	Tue 10/31/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/11/2017</u>	
2000	Continuous	2359				
Work scheduled by: NYISO					CENTRAL EAST - VC	2740 MW
					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
NIAGARA_-KINTIGH_345_NS1-38					FWD	
Mon 10/23/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	
0600	Continuous	1559				
Work scheduled by: NYPA					DYSINGER EAST	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Mon 10/23/2017	to	Thu 10/26/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/01/2017</u>	
0800	Continuous	1500				
Work scheduled by: PJM					SCH - PJ - NY	1950 MW
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2100 MW
						1350 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK -NIAGARA 345_PA301				FWD	REV
Tue 10/24/2017 to Wed 10/25/2017				(Import) (Export)	
0500	Continuous	1700		SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1100 MW 800 MW
				TTC with All Lines In Service	2000 MW 1600 MW
NIAGARA -KINTIGH 345_NS1-38				FWD	
Wed 10/25/2017 to Thu 11/09/2017				(Import)	
1600	Continuous	1600	UPDATED by NYISO 10/09/2017	DYSINGER EAST	1700 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
S.RIPLEY-DUNKIRK 230_68				FWD	REV
Thu 10/26/2017 to Mon 03/19/2018				(Import) (Export)	
1501	Continuous	0959	UPDATED by NYISO 10/09/2017	SCH - PJ - NY	1950 MW 1350 MW
Work scheduled by: NYISO				Impacts Total Transfer Capability	150 MW 0 MW
				TTC with All Lines In Service	2100 MW 1350 MW
W49TH_ST_345KV_5				FWD	
Fri 10/27/2017 to Sat 11/04/2017				(Import)	
0001	Continuous	2359		SCH - PJM_HTP	315 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	345 MW
				TTC with All Lines In Service	660 MW
SPRNBK 345KV_RNS4				FWD	
Sat 10/28/2017 to Sat 11/04/2017				(Import)	
0301	Continuous	2359		SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	4600 MW
MOSES -ADIRNDCK 230_MA2				FWD	
Mon 10/30/2017 to Sat 11/04/2017				(Import)	
0700	Continuous	1530	EXTENDED by NYPA 10/02/2017	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
NEPTUNE -DUFFYAVE 345_NEPTUNE				FWD	
Tue 10/31/2017 to Thu 11/02/2017				(Import)	
0001	Continuous	2359		SCH - PJM_NEPTUNE	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501				FWD	
Tue 10/31/2017	to	Thu 11/02/2017		(Import)	
0001	Continuous	2359	SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD	
Tue 10/31/2017	to	Thu 11/02/2017		(Import)	
0001	Continuous	2359	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	
Tue 10/31/2017	to	Thu 11/02/2017		(Import)	
0001	Continuous	2359	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
PLSNTVLY-EFISHKIL_345_F36				FWD	
Wed 11/01/2017	to	Sat 11/04/2017		(Import)	
0001	Continuous	0300	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1100 MW	
			TTC with All Lines In Service	5100 MW	
LAFAYTTE-CLRKSCRN_345_4-46				FWD	
Wed 11/01/2017	to	Thu 11/02/2017		(Import)	
0630	Continuous	1630	CENTRAL EAST - VC	2650 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW	
			TTC with All Lines In Service	2975 MW	
COOPERS_-DOLSONAV_345_CCDA42				FWD	
Wed 11/01/2017	to	Sat 11/04/2017		(Import)	
0830	Continuous	1800	CENTRAL EAST - VC	2720 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	255 MW	
			TTC with All Lines In Service	2975 MW	
MARION_-FARRAGUT_345_C3403				FWD	REV
Thu 11/02/2017	to	Sat 12/02/2017	UPDATED	by CE	09/29/2017
0001	Continuous	0100	SCH - PJ - NY	2300 MW	1450 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2300 MW	1450 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
BERKSHIR-ALPS _____ 345_393						(Import)	(Export)
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NE - NY	1300 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<hr/>							
BERKSHIR-ALPS _____ 345_393						FWD	REV
						(Import)	(Export)
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NPX_1385	100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<hr/>							
BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312						FWD	REV
						(Import)	(Export)
Thu 11/02/2017	to	Sat 11/04/2017					
0700		1900				SCH - NE - NY	1300 MW
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<hr/>							
BERKSHIR-NORTHFLD_345_312						FWD	REV
						(Import)	(Export)
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NE - NY	1400 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<hr/>							
BERKSHIR-NORTHFLD_345_312						FWD	REV
						(Import)	(Export)
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NPX_1385	100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<hr/>							
SCH-NE-NYISO_LIMIT_500						FWD	
						(Import)	
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NE - NY	700 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1400 MW
<hr/>							
SCH-NYISO-NE_LIMIT_700							REV
							(Export)
Thu 11/02/2017	to	Sat 11/04/2017	UPDATED	by NE	<u>10/10/2017</u>		
0700	Continuous	1900				SCH - NE - NY	900 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46					FWD		
Sat 11/04/2017	to	Sat 11/04/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/04/2017</u>	(Import)	
0230	Continuous	0300				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service	4600 MW	
PLSNTVLY-EFISHKIL_345_F36					FWD		
Mon 11/06/2017	to	Wed 11/08/2017				(Import)	
0001	Continuous	0300				4000 MW	
Work scheduled by: ConEd					UPNY CONED	1100 MW	
					Impacts Total Transfer Capability	5100 MW	
					TTC with All Lines In Service	5100 MW	
MOSES__-ADIRNDCK_230_MA2					FWD		
Mon 11/06/2017	to	Thu 11/09/2017				(Import)	
0700	Continuous	1530				2300 MW	
Work scheduled by: NYPA					MOSES SOUTH	850 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service	3150 MW	
FRASANX-COOPERS__345_UCC2-41					FWD		
Mon 11/06/2017	to	Fri 11/17/2017				(Import)	
0700	Continuous	1530				2500 MW	
Work scheduled by: NYPA					CENTRAL EAST - VC	475 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service	2975 MW	
MARCY__-FRASANX_345_UCC2-41					FWD		
Mon 11/06/2017	to	Fri 11/17/2017				(Import)	
0700	Continuous	1530				2500 MW	
Work scheduled by: NYPA					CENTRAL EAST - VC	475 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service	2975 MW	
LINDN_CG-LNDVFT__345_V-3022					FWD	REV	
Mon 11/06/2017	to	Thu 11/09/2017				(Import)	(Export)
0800	Continuous	1500				0 MW	0 MW
Work scheduled by: PJM					SCH - PJM_VFT	315 MW	315 MW
					Impacts Total Transfer Capability	315 MW	315 MW
					TTC with All Lines In Service	315 MW	315 MW
SCRIBA__-VOLNEY__345_20					FWD		
Mon 11/06/2017	to	Fri 11/17/2017				(Import)	
0800	Continuous	1630				5250 MW	
Work scheduled by: NGrid					OSWEGO EXPORT	0 MW	
					Impacts Total Transfer Capability	5250 MW	
					TTC with All Lines In Service	5250 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Fri 11/10/2017 to Fri 11/10/2017
0001 Continuous 0030

UPDATED by CONED 10/03/2017

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

SPRNBRK_-W49TH_ST_345_M52

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300

UPDATED by CONED 10/03/2017

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RNS4

Fri 11/10/2017 to Mon 11/13/2017
0001 Continuous 0300

UPDATED by CONED 10/03/2017

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SPRNBRK__345KV_RS3 & SPRNBRK__345KV_RS4

Sun 11/12/2017 to Wed 11/15/2017
0001 0300

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_5

Mon 11/13/2017 to Mon 11/13/2017
0230 Continuous 0300

UPDATED by CONED 10/03/2017

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **315 MW**
Impacts Total Transfer Capability 345 MW
TTC with All Lines In Service 660 MW

MOSES__-ADIRNDCK_230_MA2

Mon 11/13/2017 to Fri 11/17/2017
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SPRNBRK__345KV_RNS4

Wed 11/15/2017 to Fri 11/17/2017
0001 Continuous 0100

UPDATED by CONED 10/03/2017

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45						FWD
Sat 11/18/2017	to	Tue 05/15/2018				(Import)
0000	Continuous	2359			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M54						FWD
Sat 11/18/2017	to	Tue 05/15/2018				(Import)
0000	Continuous	2359			SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
EGRDNCTY_345_138_AT1						FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>UPDATED</u>	<u>by LI</u>	<u>08/01/2017</u>	(Import)
0001	Continuous	0300			CONED - LIPA	1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2						FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>UPDATED</u>	<u>by LI</u>	<u>08/01/2017</u>	(Import)
0001	Continuous	0300			CONED - LIPA	1250 MW
Work scheduled by: LI						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1500 MW
SPRNBK_-EGRDNCTR_345_Y49						FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>UPDATED</u>	<u>by LI</u>	<u>08/01/2017</u>	(Import)
0001	Continuous	0300			CONED - LIPA	775 MW
Work scheduled by: LI						Impacts Total Transfer Capability 725 MW
						TTC with All Lines In Service 1500 MW
MOSES_-ADIRNDCK_230_MA1						FWD
Mon 11/20/2017	to	Wed 11/22/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/13/2017</u>	(Import)
0700	Continuous	1730			MOSES SOUTH	2300 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
WETHSRFD-MEYER_230_85/87						FWD
Mon 11/20/2017	to	Fri 12/01/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>09/13/2017</u>	(Import)
1630	Continuous	1400			DYSINGER EAST	2850 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-LEEDS _____345_93				FWD
Tue 11/21/2017	to	Wed 11/22/2017	UPDATED by NGRID 10/09/2017	(Import)
0800	Continuous	1500		CENTRAL EAST - VC 2650 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW
MOSES _____ADIRNDCK_230_MAI				FWD
Mon 11/27/2017	to	Fri 12/01/2017		(Import)
0700	Continuous	1530		MOSES SOUTH 2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
ROSETON _____EFISHKIL_345_RFK305				FWD
Mon 11/27/2017	to	Fri 12/01/2017		(Import)
0800	Continuous	1600		UPNY CONED 4800 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 5100 MW
ROTTDAM-EASTOVER _____230_38				FWD REV
Mon 11/27/2017	to	Thu 11/30/2017		(Import) (Export)
0900	Continuous	1500		SCH - NE - NY 1400 MW 1400 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW 200 MW
ARR: 77				TTC with All Lines In Service 1400 MW 1600 MW
ROSETON _____EFISHKIL_345_RFK305				FWD
Sat 12/02/2017	to	Sat 12/02/2017		(Import)
0001	Continuous	2359		UPNY CONED 4800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 5100 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Sun 12/03/2017	to	Tue 12/05/2017		(Import)
0001		0300		UPNY CONED 3800 MW
Work scheduled by:				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
LEEDS _____PLSNTVLY_345_92				FWD
Mon 12/04/2017	to	Mon 12/18/2017	UPDATED by NYISO 09/12/2017	(Import)
0001	Continuous	0300		UPNY CONED 3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

FWD

Mon 12/04/2017 to Mon 12/18/2017
 0001 Continuous 0300

UPDATED by NYISO 09/12/2017

Work scheduled by: ConEd

UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

MARCY_765_345_AT2

FWD

Mon 12/04/2017 to Fri 12/08/2017
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

(Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 12/11/2017 to Fri 12/15/2017
 0700 Continuous 1530

Work scheduled by: NYPA

(Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017
 0700 Continuous 1530

UPDATED by NYPA 10/23/2016

Work scheduled by: NYPA

(Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

N.SCTLND-LEEDS_345_94

FWD

Tue 12/19/2017 to Wed 12/20/2017
 0800 Continuous 1500

Work scheduled by: NGrid

(Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

MARCY_765_345_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017
 0500 Continuous 1630

Work scheduled by: NYPA

ARR: 19

(Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

DUNWODIE-SHORE_RD_345_Y50

FWD

Tue 01/02/2018 to Thu 01/04/2018
 0001 Continuous 2359

EXTENDED by LI 09/22/2017

Work scheduled by: ConEd

(Import)
 CONED - LIPA **800 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_6					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	TTC with All Lines In Service 4600 MW
SHORE_RD_345_138_BK 1					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	TTC with All Lines In Service 1500 MW
SHORE_RD_345_138_BK 2					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	TTC with All Lines In Service 1500 MW
MOSES__-ADIRNDCK_230_MAI					FWD	
Tue 01/02/2018	to	Fri 01/05/2018				(Import)
0700	Continuous	1730				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	TTC with All Lines In Service 3150 MW
LEEDS__-PLSNTVLY_345_92					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	UPDATED	by NYISO	09/12/2017	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	UPDATED	by NYISO	09/12/2017	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

Fri 01/05/2018 to Sun 01/07/2018
0001 2359

Work scheduled by:

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Mon 01/08/2018 to Wed 01/10/2018 **UPDATED by NYISO 09/12/2017**
0001 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 3800 MW
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBK_345_W64

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W99

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED 4350 MW
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK_345KV_RNS5

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH 3200 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MOSES -ADIRNDCK_230_MA1

Mon 01/08/2018 to Fri 01/12/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA1

Mon 01/15/2018 to Fri 01/19/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2		FWD	
Sat 01/20/2018	to Sat 01/20/2018	(Import)	
0500	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
ARR: 19		TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MAI		FWD	
Mon 01/22/2018	to Fri 01/26/2018	(Import)	
0700	Continuous 1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MAI		FWD	
Mon 01/29/2018	to Fri 02/02/2018	(Import)	
0700	Continuous 1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2		FWD	
Sat 02/03/2018	to Sat 02/03/2018	(Import)	
0500	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
ARR: 19		TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2		FWD	
Mon 02/05/2018	to Fri 02/09/2018	(Import)	
0500	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
ARR: 19		TTC with All Lines In Service	3150 MW
MOSES___-ADIRNDCK_230_MA2		FWD	
Mon 02/12/2018	to Fri 02/16/2018	(Import)	
0700	Continuous 1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
HUDSONP_-FARRAGUT_345_B3402		FWD	REV
Sun 02/18/2018	to Sun 04/01/2018	(Import) (Export)	
0001	Continuous 2359	SCH - PJ - NY	2300 MW 1450 MW
Work scheduled by: PJM		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7					FWD		
Tue 02/20/2018	to	Fri 02/23/2018			(Import)		
0500	Continuous	1730			OSWEGO EXPORT	5250 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW	
					TTC with All Lines In Service	5250 MW	
MOSES -ADIRNDCK 230 MA1					FWD		
Tue 02/20/2018	to	Fri 02/23/2018			(Import)		
0700	Continuous	1730			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW	
					TTC with All Lines In Service	3150 MW	
DUNWODIE 345KV 7					FWD		
Sat 02/24/2018	to	Sat 02/24/2018	UPDATED	by CE	09/22/2017		
0001	Continuous	0030			SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
DUNWODIE 345KV 8					FWD		
Sat 02/24/2018	to	Sat 02/24/2018	UPDATED	by CE	09/22/2017		
0001	Continuous	0030			SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
DUNWODIE-MOTTHAVN 345 72					FWD		
Sat 02/24/2018	to	Sat 03/31/2018	UPDATED	by CE	09/22/2017		
0001	Continuous	0300			SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
LONG MTN-PLSNTVLY 345 398					FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018			(Import)	(Export)	
0001	Continuous	0300			SCH - NE - NY	700 MW	1300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	700 MW	300 MW
					TTC with All Lines In Service	1400 MW	1600 MW
LONG MTN-PLSNTVLY 345 398					FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018			(Import)	(Export)	
0001	Continuous	0300			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW	100 MW
					TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1				FWD	
Mon 02/26/2018	to	Fri 03/02/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
MOSES___-ADIRNDCK_230_MA1				FWD	
Mon 03/05/2018	to	Fri 03/09/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
MARCY___-N.SCTLND_345_18				FWD	
Tue 03/06/2018	to	Wed 03/07/2018		(Import)	
0600	Continuous	1530	CENTRAL EAST - VC	2090 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	885 MW	
			TTC with All Lines In Service	2975 MW	
MOSES___-ADIRNDCK_230_MA1				FWD	
Mon 03/12/2018	to	Fri 03/16/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
S.RIPLEY-DUNKIRK__230_68				FWD	REV
Mon 03/19/2018	to	Fri 04/20/2018		(Import)	(Export)
1000	Continuous	1559	SCH - PJ - NY	1950 MW	1350 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	350 MW	100 MW
			TTC with All Lines In Service	2300 MW	1450 MW
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 03/26/2018	to	Thu 03/29/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
DUNWODIE_345KV_7				FWD	
Sat 03/31/2018	to	Sat 03/31/2018	UPDATED	by CE	09/22/2017
0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8					FWD	
Sat 03/31/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0230	Continuous	0300				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
LINDN_CG-LNDVFT_345_V-3022					FWD	REV
Sun 04/08/2018	to	Fri 04/13/2018				(Import) (Export)
1400	Continuous	1800				0 MW 0 MW
Work scheduled by: PJM					SCH - PJM_VFT	
					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					FWD	
Mon 04/16/2018	to	Tue 05/01/2018				(Import)
0001	Continuous	1800				0 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					FWD	
Mon 04/16/2018	to	Tue 05/01/2018				(Import)
0001	Continuous	1800				0 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					FWD	
Mon 04/16/2018	to	Tue 05/01/2018				(Import)
0001	Continuous	1800				375 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					FWD	
Mon 04/16/2018	to	Tue 05/01/2018				(Import)
0001	Continuous	1800				375 MW
Work scheduled by: PJM					SCH - PJM_NEPTUNE	
					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Fri 04/20/2018	to	Sat 02/01/2020	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import) (Export)
1600	Continuous	0000				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	
					Impacts Total Transfer Capability	350 MW 100 MW
					TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 04/23/2018 to Mon 04/23/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

WETHSRFD-MEYER___230_85/87

Mon 04/23/2018 to Fri 05/11/2018
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 04/30/2018 to Fri 05/25/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
 0001 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4400 MW**
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
 0500 1730
 Work scheduled by:

FWD
 (Import)
 CENTRAL EAST - VC **2690 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,October 13, 2017 to Sunday ,April 14, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW