

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONTP-W49TH_ST_345_Y56</b>					FWD	
Thu 11/24/2016	to	Wed 11/01/2017	<b>EXT FORCE</b>	<b>by PJM</b>	<b>10/10/2017</b>	(Import)
1500	Continuous	2359				0 MW
Work scheduled by: ConEd					SCH - PJM_HTP	660 MW
					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>SCH-NYISO-HQ_LIMIT_800</b>						REV
Thu 06/08/2017	to	Fri 12/15/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>08/03/2017</b>	(Export)
0600	Continuous	1700				800 MW
Work scheduled by: HQ					SCH - HQ - NY	200 MW
					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1000 MW
<b>SCH-HQ-NYISO_LIMIT_1450</b>						FWD
Tue 08/01/2017	to	Fri 12/15/2017				(Import)
2100	Continuous	1600				1450 MW
Work scheduled by: HQ					SCH - HQ - NY	50 MW
					Impacts Total Transfer Capability	1500 MW
					TTC with All Lines In Service	1500 MW
<b>SCH-IMO-NYISO_LIMIT_1450</b>						FWD
Tue 08/29/2017	to	Tue 10/31/2017	<b>EXTENDED</b>	<b>by NYISO</b>	<b>07/28/2017</b>	(Import)
1230	Continuous	2359				1750 MW
Work scheduled by: NYISO					SCH - OH - NY	250 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	2000 MW
<b>SCH-IMO-NYISO_LIMIT_1150</b>						FWD
Sat 09/09/2017	to	Fri 10/13/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>10/12/2017</b>	(Import)
0500	Continuous	1330				1450 MW
Work scheduled by: NGrid					SCH - OH - NY	550 MW
					Impacts Total Transfer Capability	2000 MW
					TTC with All Lines In Service	2000 MW
<b>GILBOA__-N.SCTLND_345_GNS-1</b>						FWD
Mon 09/18/2017	to	Wed 10/11/2017	<b>UPDATED</b>	<b>by NYPA</b>	<b>10/07/2017</b>	(Import)
0630	Continuous	1900				2520 MW
Work scheduled by: NYPA					CENTRAL EAST - VC	455 MW
					Impacts Total Transfer Capability	2975 MW
					TTC with All Lines In Service	2975 MW
<b>FIVEMILE-STOLLERD_345_29</b>						FWD
Thu 09/28/2017	to	Thu 10/19/2017	<b>UPDATED</b>	<b>by NGRID</b>	<b>10/13/2017</b>	(Import)
0700	Continuous	1500				2100 MW
Work scheduled by: NYSEG					SCH - PJ - NY	0 MW
					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	2100 MW
						1350 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK_-W49TH_ST_345_M52</b>				FWD
Sun 10/01/2017	to	Sat 11/04/2017		(Import)
0001	Continuous	2359	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>				FWD
Mon 10/02/2017	to	Mon 10/16/2017		(Import)
0001	Continuous	0300	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1100 MW
				TTC with All Lines In Service 5100 MW
<b>CHAT_DC_GC2</b>				FWD
Mon 10/02/2017	to	Wed 11/15/2017		(Import)
0500	Continuous	2000	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>				REV
Mon 10/02/2017	to	Wed 11/15/2017		(Export)
0500	Continuous	2000	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>				FWD
Mon 10/02/2017	to	Wed 11/15/2017		(Import)
0500	Continuous	2000	SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 350 MW
				TTC with All Lines In Service 1500 MW
<b>FRASER_-COOPERS_345_33</b>				FWD
Mon 10/02/2017	to	Fri 10/13/2017		(Import)
0700	Continuous	1900	CENTRAL EAST - VC	<b>2395 MW</b>
Work scheduled by: NYSEG				Impacts Total Transfer Capability 580 MW
				TTC with All Lines In Service 2975 MW
<b>SPRNBK_345KV_RNS4</b>				FWD
Mon 10/02/2017	to	Sat 10/28/2017	<b>UPDATED by CONED 10/03/2017</b>	(Import)
1901	Continuous	0300	SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1400 MW
				TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>BERKSHIR-ALPS 345_393</b>						
Fri 10/06/2017	to	Fri 10/13/2017	<u>UPDATED</u>	<u>by ISONE 10/13/2017</u>		
0700	Continuous	1359			SCH - NE - NY	<b>950 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1400 MW
					ARR: 78	1000 MW
					600 MW	600 MW
					1600 MW	1600 MW
<b>BERKSHIR-ALPS 345_393</b>						
Fri 10/06/2017	to	Fri 10/13/2017	<u>UPDATED</u>	<u>by ISONE 10/13/2017</u>		
0700	Continuous	1359			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
					ARR: 78	100 MW
					200 MW	200 MW
<b>BERKSHIR-ALPS 345_393 &amp; BERKSHIR-NORTHFLD 345_312</b>						
Fri 10/06/2017	to	Fri 10/13/2017				
0700		1359			SCH - NE - NY	<b>950 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	1400 MW
					ARR: 78	1000 MW
					600 MW	600 MW
					1600 MW	1600 MW
<b>BERKSHIR-NORTHFLD 345_312</b>						
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>		
0700	Continuous	1600			SCH - NE - NY	<b>900 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1400 MW
						400 MW
						1600 MW
<b>BERKSHIR-NORTHFLD 345_312</b>						
Fri 10/06/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>		
0700	Continuous	1600			SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
						100 MW
						200 MW
<b>SCH-NYISO-NE LIMIT 600</b>						
Sun 10/08/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE 10/10/2017</u>		
0001	Continuous	1600			SCH - NE - NY	<b>800 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1600 MW
<b>SCH-NE-NYISO LIMIT 800</b>						
Mon 10/09/2017	to	Thu 10/12/2017				
0700	Continuous	1700			SCH - NE - NY	<b>1000 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY -EDIC 345_1-16</b>				FWD	
Wed 10/11/2017	to	Wed 10/11/2017		(Import)	
0700	Continuous	1700	OSWEGO EXPORT	<b>4850 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>				FWD	
Thu 10/12/2017	to	Thu 10/12/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/06/2017</u>
0700	Continuous	0759	SCH - NE - NY		
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW	
			TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_500</b>				REV	
Thu 10/12/2017	to	Thu 10/12/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/06/2017</u>
0700	Continuous	0759	SCH - NE - NY		
Work scheduled by: ISONE			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	1600 MW	
<b>FRASER 345_FRASER SVC</b>				FWD	
Fri 10/13/2017	to	Mon 10/16/2017	<u>EXT FORCE</u>	<u>by NYSEG</u>	<u>10/14/2017</u>
1219	Continuous	2359	CENTRAL EAST - VC		
Work scheduled by: NYSEG			Impacts Total Transfer Capability	40 MW	
			TTC with All Lines In Service	2975 MW	
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
Fri 10/13/2017	to	Mon 10/23/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>
1500	Continuous	0759	SCH - PJ - NY		
Work scheduled by: NYISO			Impacts Total Transfer Capability	150 MW	0 MW
			TTC with All Lines In Service	2100 MW	1350 MW
<b>BERKSHIR-ALPS 345_393</b>				FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/13/2017</u>
1516	Continuous	1600	SCH - NE - NY		
Work scheduled by: NGrid			Impacts Total Transfer Capability	450 MW	600 MW
			TTC with All Lines In Service	1400 MW	1600 MW
<b>BERKSHIR-ALPS 345_393</b>				FWD	REV
Fri 10/13/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by ISONE</u>	<u>10/13/2017</u>
1516	Continuous	1600	SCH - NPX_1385		
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS _____ 345_393 & BERKSHIR-NORTHFLD_345_312						FWD	REV	
Fri 10/13/2017 to Sat 10/28/2017						(Import)	(Export)	
1516		1600				SCH - NE - NY	950 MW	1000 MW
Work scheduled by:						Impacts Total Transfer Capability	450 MW	600 MW
ARR: 78						TTC with All Lines In Service	1400 MW	1600 MW
W49TH_ST_345KV_8						FWD		
Sat 10/14/2017 to Wed 10/18/2017						(Import)		
0001	Continuous	2200	<u>UPDATED</u>	<u>by CE</u>	<u>10/13/2017</u>	SCH - PJM_HTP	315 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	345 MW	
						TTC with All Lines In Service	660 MW	
CHATGUAY-MASSENA__765_7040						FWD		
Sat 10/14/2017 to Sat 10/21/2017						(Import)		
0100	Continuous	2000	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	MOSES SOUTH	1550 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA__765_7040						FWD	REV	
Sat 10/14/2017 to Sat 10/21/2017						(Import)	(Export)	
0100	Continuous	2000	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2 & MOSES__-MASSENA__230_MMS1 & MOSES__-MASSENA__230_MMS2						FWD		
Sat 10/14/2017 to Sat 10/21/2017						(Import)		
0100		2000				MOSES SOUTH	1950 MW	
Work scheduled by:						Impacts Total Transfer Capability	1200 MW	
						TTC with All Lines In Service	3150 MW	
MARCY__765_345_AT1						FWD		
Sat 10/14/2017 to Sat 10/21/2017						(Import)		
0100	Continuous	2000	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW	
ARR: 19						TTC with All Lines In Service	3150 MW	
MARCY__765_345_AT2						FWD		
Sat 10/14/2017 to Sat 10/21/2017						(Import)		
0100	Continuous	2000	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW	
ARR: 19						TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA -MARCY 765_MSU1</b>						FWD
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)
0100	Continuous	2000				<b>CENTRAL EAST - VC</b> <b>2265 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 710 MW TTC with All Lines In Service 2975 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import)
0100	Continuous	2000				<b>MOSES SOUTH</b> <b>500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW
<b>MASSENA -MARCY 765_MSU1</b>						FWD
Sat 10/14/2017	to	Sat 10/21/2017	<u>UPDATED</u>	<u>by PA</u>	<u>09/22/2017</u>	(Import) (Export)
0100	Continuous	2000				<b>SCH - HQ - NY</b> <b>475 MW 1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 1025 MW 0 MW TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA -MARCY 765_MSU1 &amp; CHATGUAY-MASSENA 765_7040</b>						FWD
Sat 10/14/2017	to	Sat 10/21/2017				(Import)
0100		2000				<b>MOSES SOUTH</b> <b>500 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 2650 MW TTC with All Lines In Service 3150 MW
<b>MOSES -MASSENA 230_MMS1 &amp; MOSES -MASSENA 230_MMS2</b>						FWD
Sat 10/14/2017	to	Sat 10/21/2017				(Import) (Export)
0100		2000				<b>SCH - HQ - NY</b> <b>850 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 650 MW 1000 MW TTC with All Lines In Service 1500 MW 1000 MW
<b>CHAT_DC_GC1</b>						FWD
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Import)
0100	Continuous	2000				<b>MOSES SOUTH</b> <b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC1</b>						REV
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	(Export)
0100	Continuous	2000				<b>SCH - HQ - NY</b> <b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	
Sat 10/14/2017	to	Sat 10/28/2017			(Import)	
0100		2000		MOSES SOUTH		
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>					FWD	REV
Sat 10/14/2017	to	Sat 10/28/2017			(Import)	(Export)
0100		2000		SCH - HQ - NY		
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>					FWD	
Sat 10/14/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>10/11/2017</u>	
0100	Continuous	2000				
Work scheduled by: HQ					SCH - HQ - NY	700 MW
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1500 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>					FWD	REV
Sat 10/14/2017	to	Fri 10/27/2017	<u>UPDATED</u>	<u>by NYSEG</u>	<u>10/11/2017</u>	
0700	Continuous	1730				
Work scheduled by: NYSEG					SCH - PJ - NY	2100 MW 1350 MW
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2100 MW 1350 MW
<b>W49TH_ST_345KV_7</b>					FWD	
Sun 10/15/2017	to	Sun 10/15/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/13/2017</u>	
0001	Continuous	2100				
Work scheduled by: ConEd					SCH - PJM_HTP	350 MW
					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
<b>SCH-IMO-NYISO_LIMIT_600</b>					FWD	
Mon 10/16/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	900 MW
					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	2000 MW
<b>SCH-IMO_NY_NIAG_NRTH_BUS_W/BB</b>					FWD	REV
Mon 10/16/2017	to	Fri 10/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/12/2017</u>	
0500	Continuous	1700				
Work scheduled by: NYPA					SCH - OH - NY	1000 MW 1150 MW
					Impacts Total Transfer Capability	1000 MW 450 MW
					TTC with All Lines In Service	2000 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HURLYAVE-ROSETON__345_303</b>					FWD		
Mon 10/16/2017	to	Fri 11/03/2017	<u>UPDATED</u>	<u>by CH</u>	<u>06/07/2017</u>	(Import)	
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>	
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW	
					TTC with All Lines In Service	5100 MW	
<b>LEEDS__-HURLYAVE_345_301</b>					FWD		
Mon 10/16/2017	to	Fri 11/03/2017				(Import)	
0800	Continuous	1600				UPNY CONED <b>4100 MW</b>	
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW	
					TTC with All Lines In Service	5100 MW	
<b>COOPERS_-MIDDLETP_345_CCRT34</b>					FWD		
Tue 10/17/2017	to	Sat 10/28/2017	<u>UPDATED</u>	<u>by NY</u>	<u>10/16/2017</u>	(Import)	
0700	Continuous	1500				CENTRAL EAST - VC <b>2720 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	255 MW	
					TTC with All Lines In Service	2975 MW	
<b>MARCY_SO_SERIES_COMP_I/S</b>					FWD		
Sat 10/21/2017	to	Tue 10/31/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/11/2017</u>	(Import)	
2000	Continuous	2359				CENTRAL EAST - VC <b>2740 MW</b>	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
<b>NIAGARA_-KINTIGH__345_NS1-38</b>					FWD		
Mon 10/23/2017	to	Wed 10/25/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/09/2017</u>	(Import)	
0600	Continuous	1559				DYSINGER EAST <b>1700 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW	
					TTC with All Lines In Service	3150 MW	
<b>S.RIPLEY-DUNKIRK__230_68</b>					FWD	REV	
Mon 10/23/2017	to	Thu 10/26/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>08/01/2017</u>	(Import)	(Export)
0800	Continuous	1500				SCH - PJ - NY <b>1950 MW</b>	<b>1350 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	150 MW	0 MW
					TTC with All Lines In Service	2100 MW	1350 MW
<b>BECK__-NIAGARA__345_PA301</b>					FWD	REV	
Tue 10/24/2017	to	Wed 10/25/2017				(Import)	(Export)
0500	Continuous	1700				SCH - OH - NY <b>900 MW</b>	<b>800 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1100 MW	800 MW
					TTC with All Lines In Service	2000 MW	1600 MW



# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-KINTIGH\_345\_NS1-38**

Wed 10/25/2017 to Thu 11/09/2017  
1600 Continuous 1600

Work scheduled by: NYSEG

**UPDATED by NYISO 10/09/2017**

DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**S.RIPLEY-DUNKIRK\_230\_68**

Thu 10/26/2017 to Mon 03/19/2018  
1501 Continuous 0959

Work scheduled by: NYISO

**UPDATED by NYISO 10/09/2017**

SCH - PJ - NY **1950 MW 1350 MW**  
Impacts Total Transfer Capability 150 MW 0 MW  
TTC with All Lines In Service 2100 MW 1350 MW

FWD REV  
(Import) (Export)

**W49TH\_ST\_345KV\_5**

Fri 10/27/2017 to Sat 11/04/2017  
0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP **315 MW**  
Impacts Total Transfer Capability 345 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**SPRNBRK\_345KV\_RNS4**

Sat 10/28/2017 to Sat 11/04/2017  
0301 Continuous 2359

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 10/30/2017 to Sat 11/04/2017  
0700 Continuous 1530

Work scheduled by: NYPA

**EXTENDED by NYPA 10/02/2017**

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE-DUFFYAVE\_345\_501**

Tue 10/31/2017 to Thu 11/02/2017  
0001 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE_345_138_BK_1</b>					FWD	
Tue 10/31/2017	to	Thu 11/02/2017			(Import)	
0001	Continuous	2359		SCH - PJM_NEPTUNE	<b>375 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>					FWD	
Tue 10/31/2017	to	Thu 11/02/2017			(Import)	
0001	Continuous	2359		SCH - PJM_NEPTUNE	<b>375 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
<b>PLSNTVLY-EFISHKIL_345_F36</b>					FWD	
Wed 11/01/2017	to	Sat 11/04/2017			(Import)	
0001	Continuous	0300		UPNY CONED	<b>4000 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1100 MW
					TTC with All Lines In Service	5100 MW
<b>LAFAYTTE-CLRKSCRN_345_4-46</b>					FWD	
Wed 11/01/2017	to	Thu 11/02/2017			(Import)	
0630	Continuous	1630		CENTRAL EAST - VC	<b>2650 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
<b>COOPERS_-DOLSONAV_345_CCDA42</b>					FWD	
Wed 11/01/2017	to	Sat 11/04/2017			(Import)	
0830	Continuous	1800		CENTRAL EAST - VC	<b>2720 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	255 MW
					TTC with All Lines In Service	2975 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Thu 11/02/2017	to	Sat 12/02/2017	<b>UPDATED</b>	<b>by CE</b>	<b>09/29/2017</b>	(Import) (Export)
0001	Continuous	0100				
Work scheduled by: ConEd					SCH - PJ - NY	<b>2300 MW 1450 MW</b>
					Impacts Total Transfer Capability	0 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<b>BERKSHIR-ALPS_____345_393</b>					FWD	REV
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	<b>1300 MW 1300 MW</b>
					Impacts Total Transfer Capability	100 MW 300 MW
					TTC with All Lines In Service	1400 MW 1600 MW

ARR: 78

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BERKSHIR-ALPS</b>	<b>345_393</b>						
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>		
0700	Continuous	1900				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
						ARR: 78	
<b>BERKSHIR-ALPS</b>	<b>345_393</b>	<b>&amp; BERKSHIR-NORTHFLD</b>	<b>345_312</b>				
Thu 11/02/2017	to	Sat 11/04/2017					
0700		1900				SCH - NE - NY	<b>1300 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
						ARR: 78	
<b>BERKSHIR-NORTHFLD</b>	<b>345_312</b>						
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>		
0700	Continuous	1900				SCH - NE - NY	<b>1400 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	1400 MW
							1600 MW
<b>BERKSHIR-NORTHFLD</b>	<b>345_312</b>						
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>		
0700	Continuous	1900				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
							200 MW
<b>SCH-NE-NYISO_LIMIT</b>	<b>500</b>						
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>		
0700	Continuous	1900				SCH - NE - NY	<b>700 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT</b>	<b>700</b>						
Thu 11/02/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by NE</b>	<b>10/10/2017</b>		
0700	Continuous	1900				SCH - NE - NY	<b>900 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1600 MW
<b>E13THSTA-FARRAGUT</b>	<b>345_46</b>						
Sat 11/04/2017	to	Sat 11/04/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/04/2017</b>		
0230	Continuous	0300				SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY-EFISHKIL\_345\_F36**

Mon 11/06/2017 to Wed 11/08/2017  
 0001 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1100 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MOSES -ADIRNDCK\_230\_MA2**

Mon 11/06/2017 to Thu 11/09/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASANX-COOPERS\_345\_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MARCY -FRASANX\_345\_UCC2-41**

Mon 11/06/2017 to Fri 11/17/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **2500 MW**  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

-----  
**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 11/06/2017 to Thu 11/09/2017  
 0800 Continuous 1500  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJM\_VFT **0 MW 0 MW**  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

-----  
**SCRIBA -VOLNEY\_345\_20**

Mon 11/06/2017 to Fri 11/17/2017  
 0800 Continuous 1630  
 Work scheduled by: NGrid

FWD  
 (Import)  
 OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

-----  
**ROCHESTR-PANNELL\_345\_RP1**

Mon 11/06/2017 to Tue 11/07/2017  
 0900 Continuous 1500  
 Work scheduled by: RGE

FWD  
 (Import)  
 DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_5**

Fri 11/10/2017 to Fri 11/10/2017  
 0001 Continuous 0030  
 Work scheduled by: ConEd

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SCH - PJM\_HTP **315 MW**  
 Impacts Total Transfer Capability 345 MW  
 TTC with All Lines In Service 660 MW

**SPRNBRK\_-W49TH\_ST\_345\_M52**

Fri 11/10/2017 to Mon 11/13/2017  
 0001 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RNS4**

Fri 11/10/2017 to Mon 11/13/2017  
 0001 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**SPRNBRK\_\_345KV\_RS3 & SPRNBRK\_\_345KV\_RS4**

Sun 11/12/2017 to Wed 11/15/2017  
 0001 0300  
 Work scheduled by:

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_5**

Mon 11/13/2017 to Mon 11/13/2017  
 0230 Continuous 0300  
 Work scheduled by: ConEd

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SCH - PJM\_HTP **315 MW**  
 Impacts Total Transfer Capability 345 MW  
 TTC with All Lines In Service 660 MW

**MOSES\_-ADIRNDCK\_230\_MA2**

Mon 11/13/2017 to Fri 11/17/2017  
 0700 Continuous 1530  
 Work scheduled by: NYPA

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SPRNBRK\_\_345KV\_RNS4**

Wed 11/15/2017 to Fri 11/17/2017  
 0001 Continuous 0100  
 Work scheduled by: ConEd

**UPDATED by CONED 10/03/2017**

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**E13THSTA-FARRAGUT\_345\_45**

Sat 11/18/2017 to Tue 05/15/2018  
 0000 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**W49TH\_ST-E13THSTA\_345\_M54**

Sat 11/18/2017 to Tue 05/15/2018  
 0000 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**EGRDNCTY\_345\_138\_AT1**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **1250 MW**  
 Impacts Total Transfer Capability 250 MW  
 TTC with All Lines In Service 1500 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

Sun 11/19/2017 to Sun 12/24/2017 **UPDATED by LI 08/01/2017**  
 0001 Continuous 0300  
 Work scheduled by: LI

FWD  
 (Import)  
 CONED - LIPA **775 MW**  
 Impacts Total Transfer Capability 725 MW  
 TTC with All Lines In Service 1500 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Mon 11/20/2017 to Wed 11/22/2017 **UPDATED by NYPA 10/13/2017**  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**WETHSRFD-MEYER\_230\_85/87**

Mon 11/20/2017 to Fri 12/01/2017 **UPDATED by NYSEG 09/13/2017**  
 1630 Continuous 1400  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-LEEDS</b> _____345_93				FWD
Tue 11/21/2017	to	Wed 11/22/2017	<b>UPDATED</b>	(Import)
0800	Continuous	1500	<b>by NGRID</b>	<b>10/09/2017</b>
Work scheduled by: NGrid				CENTRAL EAST - VC <b>2650 MW</b>
				Impacts Total Transfer Capability 325 MW
				TTC with All Lines In Service 2975 MW
<b>MOSES</b> ____-ADIRNDCK_230_MAI				FWD
Mon 11/27/2017	to	Fri 12/01/2017		(Import)
0700	Continuous	1530		MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW
<b>ROSETON</b> ____-EFISHKIL_345_RFK305				FWD
Mon 11/27/2017	to	Fri 12/01/2017		(Import)
0800	Continuous	1600		UPNY CONED <b>4800 MW</b>
Work scheduled by: CHGE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 5100 MW
<b>ROTTDAM-EASTOVER</b> _230_38				FWD
Mon 11/27/2017	to	Thu 11/30/2017		(Import) (Export)
0900	Continuous	1500		SCH - NE - NY <b>1400 MW 1400 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW 200 MW
				TTC with All Lines In Service 1400 MW 1600 MW
				<b>ARR: 77</b>
<b>ROSETON</b> ____-EFISHKIL_345_RFK305				FWD
Sat 12/02/2017	to	Sat 12/02/2017		(Import)
0001	Continuous	2359		UPNY CONED <b>4800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 5100 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>				FWD
Sun 12/03/2017	to	Tue 12/05/2017		(Import)
0001		0300		UPNY CONED <b>3800 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
<b>LEEDS</b> ____-PLSNTVLY_345_92				FWD
Mon 12/04/2017	to	Mon 12/18/2017	<b>UPDATED</b>	(Import)
0001	Continuous	0300	<b>by NYISO</b>	<b>09/12/2017</b>
Work scheduled by: ConEd				UPNY CONED <b>3800 MW</b>
				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY\_345KV\_RNS5

FWD

Mon 12/04/2017 to Mon 12/18/2017  
0001 Continuous 0300

UPDATED by NYISO 09/12/2017

Work scheduled by: ConEd

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 5100 MW

MARCY\_765\_345\_AT2

FWD

Mon 12/04/2017 to Fri 12/08/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/11/2017 to Fri 12/15/2017  
0700 Continuous 1530

Work scheduled by: NYPA

(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_-ADIRNDCK\_230\_MA2

FWD

Mon 12/18/2017 to Fri 12/22/2017  
0700 Continuous 1530

UPDATED by NYPA 10/23/2016

Work scheduled by: NYPA

(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

N.SCTLND-LEEDS\_345\_94

FWD

Tue 12/19/2017 to Wed 12/20/2017  
0800 Continuous 1500

Work scheduled by: NGrid

(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

MARCY\_765\_345\_AT2

FWD

Wed 12/27/2017 to Thu 12/28/2017  
0500 Continuous 1630

Work scheduled by: NYPA

**ARR: 19**

(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

DUNWODIE-SHORE\_RD\_345\_Y50

FWD

Tue 01/02/2018 to Thu 01/04/2018  
0001 Continuous 2359

EXTENDED by LI 09/22/2017

Work scheduled by: ConEd

(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW



# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_4</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_6</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>SHORE_RD_345_138_BK 1</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				CONED - LIPA <b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				CONED - LIPA <b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>MOSES__-ADIRNDCK_230_MAI</b>					FWD	
Tue 01/02/2018	to	Fri 01/05/2018				(Import)
0700	Continuous	1730				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>LEEDS__-PLSNTVLY_345_92</b>					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/12/2017</b>	(Import)
0001	Continuous	0300				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/12/2017</b>	(Import)
0001	Continuous	0300				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4**

Fri 01/05/2018 to Sun 01/07/2018  
 0001 2359

Work scheduled by:

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

-----  
**PLSNTVLY\_345KV\_RNS5**

Mon 01/08/2018 to Wed 01/10/2018  
 0001 Continuous 0300

Work scheduled by: ConEd

**UPDATED by NYISO 09/12/2017**

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5100 MW

-----  
**EASTVIEW-SPRNBK\_\_345\_W64**

Mon 01/08/2018 to Fri 02/23/2018  
 0001 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MILLWOOD-EASTVIEW\_345\_W99**

Mon 01/08/2018 to Fri 02/23/2018  
 0001 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 750 MW  
 TTC with All Lines In Service 5100 MW

-----  
**SPRNBK\_\_345KV\_RNS5**

Mon 01/08/2018 to Fri 02/23/2018  
 0001 Continuous 0200

Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

-----  
**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 01/08/2018 to Fri 01/12/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASER\_\_-COOPERS\_\_345\_33**

Mon 01/08/2018 to Thu 01/11/2018  
 0800 Continuous 1500

Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2395 MW**  
 Impacts Total Transfer Capability 580 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 01/15/2018 to Fri 01/19/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Sat 01/20/2018 to Sat 01/20/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 01/22/2018 to Fri 01/26/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 01/29/2018 to Fri 02/02/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Sat 02/03/2018 to Sat 02/03/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Mon 02/05/2018 to Fri 02/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 02/12/2018 to Fri 02/16/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Work Scheduled by	Transfer Type	Impact	FWD (Import)	REV (Export)
<b>HUDSONP_-FARRAGUT_345_B3402</b>	Sun 02/18/2018	Sun 04/01/2018	0001 Continuous 2359	PJM	SCH - PJ - NY	Impacts Total Transfer Capability	2300 MW	1450 MW
					TTC with All Lines In Service		2300 MW	1450 MW
<b>MARCY_-EDIC_345_UE1-7</b>	Tue 02/20/2018	Fri 02/23/2018	0500 Continuous 1730	NYPA	OSWEGO EXPORT	Impacts Total Transfer Capability	5250 MW	
					TTC with All Lines In Service		5250 MW	
					<b>ARR: 19&amp;16</b>			
<b>MOSES_-ADIRNDCK_230_MA1</b>	Tue 02/20/2018	Fri 02/23/2018	0700 Continuous 1730	NYPA	MOSES SOUTH	Impacts Total Transfer Capability	2300 MW	
					TTC with All Lines In Service		850 MW	3150 MW
<b>DUNWODIE_345KV_7</b>	Sat 02/24/2018	Sat 02/24/2018	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	Impacts Total Transfer Capability	800 MW	3800 MW
					TTC with All Lines In Service		4600 MW	
<b>DUNWODIE_345KV_8</b>	Sat 02/24/2018	Sat 02/24/2018	0001 Continuous 0030	ConEd	SPR/DUN-SOUTH	Impacts Total Transfer Capability	800 MW	3800 MW
					TTC with All Lines In Service		4600 MW	
<b>DUNWODIE-MOTTHAVN_345_72</b>	Sat 02/24/2018	Sat 03/31/2018	0001 Continuous 0300	ConEd	SPR/DUN-SOUTH	Impacts Total Transfer Capability	800 MW	3800 MW
					TTC with All Lines In Service		4600 MW	
<b>LONG_MTN-PLSNTVLY_345_398</b>	Mon 02/26/2018	Wed 05/02/2018	0001 Continuous 0300	ConEd	SCH - NE - NY	Impacts Total Transfer Capability	700 MW	1300 MW
					TTC with All Lines In Service		1400 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398			FWD	REV
			(Import)	(Export)
Mon 02/26/2018	to	Wed 05/02/2018		
0001	Continuous	0300	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
MOSES__-ADIRNDCK_230_MAI			FWD	
			(Import)	
Mon 02/26/2018	to	Fri 03/02/2018	MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1730	Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MAI			FWD	
			(Import)	
Mon 03/05/2018	to	Fri 03/09/2018	MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1730	Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW
MARCY__-N.SCTLND_345_18			FWD	
			(Import)	
Tue 03/06/2018	to	Wed 03/07/2018	CENTRAL EAST - VC	<b>2090 MW</b>
0600	Continuous	1530	Impacts Total Transfer Capability	885 MW
Work scheduled by: NYPA			TTC with All Lines In Service	2975 MW
			<b>ARR: 19</b>	
MOSES__-ADIRNDCK_230_MAI			FWD	
			(Import)	
Mon 03/12/2018	to	Fri 03/16/2018	MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1730	Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW
S.RIPLEY-DUNKIRK_230_68			FWD	REV
			(Import)	(Export)
Mon 03/19/2018	to	Fri 04/20/2018	SCH - PJ - NY	<b>1950 MW</b>
1000	Continuous	1559	Impacts Total Transfer Capability	350 MW
Work scheduled by: PJM			TTC with All Lines In Service	2300 MW
				1450 MW
MOSES__-ADIRNDCK_230_MA2			FWD	
			(Import)	
Mon 03/26/2018	to	Thu 03/29/2018	MOSES SOUTH	<b>2300 MW</b>
0700	Continuous	1530	Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
<b>DUNWODIE_345KV_7</b>				FWD
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	(Import)
0230	Continuous	0300	<b>by CE</b>	<b>3800 MW</b>
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>DUNWODIE_345KV_8</b>				FWD
Sat 03/31/2018	to	Sat 03/31/2018	<b>UPDATED</b>	(Import)
0230	Continuous	0300	<b>by CE</b>	<b>3800 MW</b>
Work scheduled by: ConEd				SPR/DUN-SOUTH
				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<hr/>				
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD
Sun 04/08/2018	to	Fri 04/13/2018		(Import) (Export)
1400	Continuous	1800		<b>0 MW</b> <b>0 MW</b>
Work scheduled by: PJM				SCH - PJM_VFT
				Impacts Total Transfer Capability 315 MW 315 MW
				TTC with All Lines In Service 315 MW 315 MW
<hr/>				
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD
Mon 04/16/2018	to	Tue 05/01/2018		(Import)
0001	Continuous	1800		<b>0 MW</b>
Work scheduled by: PJM				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<hr/>				
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD
Mon 04/16/2018	to	Tue 05/01/2018		(Import)
0001	Continuous	1800		<b>0 MW</b>
Work scheduled by: PJM				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW
<hr/>				
<b>NEWBRDGE_345_138_BK_1</b>				FWD
Mon 04/16/2018	to	Tue 05/01/2018		(Import)
0001	Continuous	1800		<b>375 MW</b>
Work scheduled by: PJM				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW
<hr/>				
<b>NEWBRDGE_345_138_BK_2</b>				FWD
Mon 04/16/2018	to	Tue 05/01/2018		(Import)
0001	Continuous	1800		<b>375 MW</b>
Work scheduled by: PJM				SCH - PJM_NEPTUNE
				Impacts Total Transfer Capability 285 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Capability	FWD	REV
<b>S.RIPLEY-DUNKIRK__230_68</b>	Fri 04/20/2018	Sat 02/01/2020	1600	Continuous	0000	NYISO	1950 MW	1350 MW
						<b>UPDATED by NYISO 10/09/2017</b>	(Import)	(Export)
Work scheduled by: NYISO						SCH - PJ - NY	350 MW	100 MW
						Impacts Total Transfer Capability	2300 MW	1450 MW
						TTC with All Lines In Service		
<b>MARCY___765_345_AT1</b>	Mon 04/23/2018	Mon 04/23/2018	0500	Continuous	1730	NYPA	1750 MW	
Work scheduled by: NYPA						ARR: 19	MOSES SOUTH	1400 MW
						Impacts Total Transfer Capability	3150 MW	
						TTC with All Lines In Service		
<b>WETHSRFD-MEYER___230_85/87</b>	Mon 04/23/2018	Fri 05/11/2018	0700	Continuous	1500	NYSEG	2850 MW	
Work scheduled by: NYSEG						DYSINGER EAST	300 MW	
						Impacts Total Transfer Capability	3150 MW	
						TTC with All Lines In Service		
<b>HURLYAVE-ROSETON__345_303</b>	Mon 04/30/2018	Fri 05/25/2018	0800	Continuous	1600	CHGE	4100 MW	
Work scheduled by: CHGE						UPNY CONED	1000 MW	
						Impacts Total Transfer Capability	5100 MW	
						TTC with All Lines In Service		
<b>MARCY_SO_SERIES_COMP_I/S</b>	Tue 05/01/2018	Wed 10/31/2018	0001	Continuous	2359	NYISO	2740 MW	
Work scheduled by: NYISO						CENTRAL EAST - VC	235 MW	
						Impacts Total Transfer Capability	2975 MW	
						TTC with All Lines In Service		
<b>MARCY___765_345_AT2</b>	Mon 05/21/2018	Fri 05/25/2018	0500	Continuous	1730	NYPA	1700 MW	
Work scheduled by: NYPA						ARR: 19	MOSES SOUTH	1450 MW
						Impacts Total Transfer Capability	3150 MW	
						TTC with All Lines In Service		
<b>MARCY___765_345_AT1</b>	Sat 08/04/2018	Sun 08/05/2018	0500	Continuous	1730	NYPA	1750 MW	
Work scheduled by: NYPA						ARR: 19	MOSES SOUTH	1400 MW
						Impacts Total Transfer Capability	3150 MW	
						TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Tue 09/04/2018 to Sun 09/09/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/10/2018 to Fri 09/28/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 5100 MW

**MARCY\_\_\_345KV\_CSC**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S**

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

**MARCY\_\_\_765\_345\_AT2**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2**

Thu 10/04/2018 to Fri 10/05/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 5100 MW



# NYISO TRANSFER LIMITATIONS

Monday ,October 16, 2017 to Wednesday, April 17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MARCY\_\_\_765\_345\_AT2

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW