

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800

Thu 06/08/2017 to Fri 12/15/2017
 0600 Continuous 1700
 Work scheduled by: HQ

UPDATED by HQ 08/03/2017

SCH - HQ - NY
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1000 MW

REV
 (Export)
800 MW

S.RIPLEY-DUNKIRK_230_68

Sat 10/28/2017 to Mon 03/19/2018
 1501 Continuous 0959
 Work scheduled by: NYISO

UPDATED by NYISO 10/31/2017

SCH - PJ - NY
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 2300 MW

FWD REV
 (Import) (Export)
1950 MW 1350 MW

SCH-NYISO-IMO_LIMIT_1400

Wed 11/01/2017 to Mon 04/30/2018
 0001 Continuous 2359
 Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1900 MW

REV
 (Export)
1700 MW

MARION_-FARRAGUT_345_C3403

Fri 11/17/2017 to Sat 12/23/2017
 0801 Continuous 0100
 Work scheduled by: ConEd

EXTENDED by CE 11/28/2017

SCH - PJ - NY
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 2300 MW

FWD REV
 (Import) (Export)
2300 MW 1450 MW

EGRDNCTY_345_138_AT1

Sun 11/19/2017 to Sun 12/24/2017
 0001 Continuous 0300
 Work scheduled by: LI

by CE 11/23/2017

CONED - LIPA
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

FWD
 (Import)
1250 MW

EGRDNCTY_345_138_AT2

Sun 11/19/2017 to Sun 12/24/2017
 0001 Continuous 0300
 Work scheduled by: LI

by CE 11/23/2017

CONED - LIPA
 Impacts Total Transfer Capability 250 MW
 TTC with All Lines In Service 1500 MW

FWD
 (Import)
1250 MW

SPRNBRK_-EGRDNCTR_345_Y49

Sun 11/19/2017 to Sun 12/24/2017
 0001 Continuous 0300
 Work scheduled by: LI

by CE 11/23/2017

CONED - LIPA
 Impacts Total Transfer Capability 725 MW
 TTC with All Lines In Service 1500 MW

FWD
 (Import)
775 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2						FWD
Mon 11/20/2017	to	Wed 12/06/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/04/2017</u>	(Import)
1800	Continuous	0559				MOSES SOUTH 2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC2						REV
Mon 11/20/2017	to	Wed 12/06/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/04/2017</u>	(Export)
1800	Continuous	0559				SCH - HQ - NY 500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_1200						FWD
Mon 11/20/2017	to	Wed 12/06/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/04/2017</u>	(Import)
1800	Continuous	0559				SCH - HQ - NY 1200 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 1500 MW
E13THSTA-FARRAGUT_345_45						FWD
Sun 11/26/2017	to	Tue 05/15/2018		<u>by CE</u>	<u>12/06/2017</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
W49TH_ST-E13THSTA_345_M54						FWD
Sun 11/26/2017	to	Tue 05/15/2018		<u>by CE</u>	<u>12/06/2017</u>	(Import)
0001	Continuous	2359				SPR/DUN-SOUTH 3800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
SCH-IMO-NYISO_LIMIT_1200						FWD
Mon 11/27/2017	to	Fri 12/01/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/22/2017</u>	(Import)
0500	Continuous	1700				SCH - OH - NY 1500 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100						REV
Mon 11/27/2017	to	Fri 12/01/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>11/22/2017</u>	(Export)
0500	Continuous	1700				SCH - PJ - NY 400 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability 1050 MW
						TTC with All Lines In Service 1450 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305					FWD		
Mon 11/27/2017	to	Fri 12/01/2017	EXTENDED	by CHGE	12/01/2017	(Import)	
0700	Continuous	2359				UPNY CONED 4800 MW	
Work scheduled by: CHGE					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	5100 MW	
ERIE E_-S.RIPLEY_230_69 & WETHSRFD-MEYER_230_85/87					FWD		
Mon 11/27/2017	to	Sat 12/02/2017				(Import)	
0700		1600				DYSINGER EAST 2850 MW	
Work scheduled by:					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
WETHSRFD-MEYER_230_85/87					FWD		
Mon 11/27/2017	to	Sat 12/02/2017	EXTENDED	by NYSEG	11/30/2017	(Import)	
0700	Continuous	1600				DYSINGER EAST 2850 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
MARCY_SO_SERIES_COMP_I/S					FWD		
Mon 11/27/2017	to	Sat 12/02/2017				(Import)	
0700	Continuous	2359				CENTRAL EAST - VC 2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW	
					TTC with All Lines In Service	2975 MW	
CEDARS_-ROSEMNTB_115_2/22					FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	UPDATED	by HQ	11/22/2017	(Import)	(Export)
0700	Continuous	1600				SCH - HQ_CEDARS 95 MW	100 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	104 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW
							ARR: 38
DENNISON-ROSEMNTB_115_2/22					FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	UPDATED	by HQ	11/22/2017	(Import)	(Export)
0700	Continuous	1600				SCH - HQ_CEDARS 95 MW	100 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	104 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW
							ARR: 38
SCH-HQ_CEDARS-NYISO_LIMIT_100					FWD		
Mon 11/27/2017	to	Thu 12/07/2017	UPDATED	by HQ	11/22/2017	(Import)	
0700	Continuous	1600				SCH - HQ_CEDARS 100 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	99 MW	
					TTC with All Lines In Service	199 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305				FWD
Sat 12/02/2017	to	Sat 12/02/2017		(Import)
0001	Continuous	2359	UPNY CONED	4800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 5100 MW
SCH-IMO-NYISO_LIMIT_500				FWD
Sat 12/02/2017	to	Sat 12/02/2017		(Import)
0700	Continuous	1700	SCH - OH - NY	800 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability 950 MW
				TTC with All Lines In Service 1750 MW
SCH-NYISO-PJM_LIMIT_100				REV
Sat 12/02/2017	to	Sat 12/02/2017	UPDATED by NYISO 11/29/2017	(Export)
0800	Continuous	1600	SCH - PJ - NY	400 MW
Work scheduled by: PJM				Impacts Total Transfer Capability 1050 MW
				TTC with All Lines In Service 1450 MW
OSWEGO_COMPLEX_AVR_O/S				FWD
Sat 12/02/2017	to	Sat 12/02/2017	CANCELLED by Gen 12/02/2017	(Import)
0900	Continuous	1000	CENTRAL EAST - VC	2870 MW
Work scheduled by: Gen				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4				FWD
Sun 12/03/2017	to	Tue 12/05/2017		(Import)
0001		0300	UPNY CONED	3800 MW
Work scheduled by:				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW
OSWEGO_COMPLEX_AVR_O/S				FWD
Sun 12/03/2017	to	Sun 12/03/2017		(Import)
0900	Continuous	1000	CENTRAL EAST - VC	2870 MW
Work scheduled by: Gen				Impacts Total Transfer Capability 105 MW
				TTC with All Lines In Service 2975 MW
LEEDS___-PLSNTVLY_345_92				FWD
Mon 12/04/2017	to	Mon 12/18/2017	UPDATED by NYISO 09/12/2017	(Import)
0001	Continuous	0300	UPNY CONED	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1300 MW
				TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Mon 12/04/2017 to Mon 12/18/2017
 0001 Continuous 0300
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLY_345KV_RNS5

Mon 12/04/2017 to Mon 12/18/2017 **UPDATED by NYISO 09/12/2017**
 0001 Continuous 0300
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

MARCY_765_345_AT2

Mon 12/04/2017 to Fri 12/08/2017 **UPDATED by NYPA 11/13/2017**
 0500 Continuous 1700
 Work scheduled by: NYPA **ARR: 19**

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

NRTH1385-NOR HBR_138_601

Mon 12/04/2017 to Wed 12/13/2017 **UPDATED by NYISO 11/08/2017**
 0700 Continuous 2359
 Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_1385 100 MW	100 MW
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602

Mon 12/04/2017 to Wed 12/13/2017
 0700 2359
 Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NPX_1385 0 MW	0 MW
Impacts Total Transfer Capability 200 MW	200 MW
TTC with All Lines In Service 200 MW	200 MW

NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603

Mon 12/04/2017 to Wed 12/13/2017
 0700 2359
 Work scheduled by:

FWD	REV
(Import)	(Export)
SCH - NPX_1385 0 MW	0 MW
Impacts Total Transfer Capability 200 MW	200 MW
TTC with All Lines In Service 200 MW	200 MW

NRTH1385-NOR HBR_138_602

Mon 12/04/2017 to Wed 12/13/2017 **UPDATED by NYISO 11/08/2017**
 0700 Continuous 2359
 Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_1385 100 MW	100 MW
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603

Mon 12/04/2017 to Wed 12/13/2017
 0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 12/04/2017 to Wed 12/13/2017 **UPDATED by NYISO 11/08/2017**
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 12/04/2017 to Wed 12/13/2017 **UPDATED by NYISO 11/08/2017**
 0700 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

LEEDS__345_LEEDS SVC

Mon 12/04/2017 to Thu 12/07/2017 **EXTENDED by NGRID 12/06/2017**
 0800 Continuous 1500

Work scheduled by: NGrid

	FWD
	(Import)
CENTRAL EAST - VC	2950 MW
Impacts Total Transfer Capability	25 MW
TTC with All Lines In Service	2975 MW

LEEDS__345_LEEDS SVC & MARCY_SO_SERIES_COMP_I/S

Mon 12/04/2017 to Thu 12/07/2017
 0800 1500

Work scheduled by:

	FWD
	(Import)
CENTRAL EAST - VC	2715 MW
Impacts Total Transfer Capability	260 MW
TTC with All Lines In Service	2975 MW

CHAT_DC_GC1

Wed 12/06/2017 to Wed 12/06/2017 **UPDATED by HQ 12/05/2017**
 0600 Daily 2300

Work scheduled by: HQ

	FWD
	(Import)
MOSES SOUTH	2850 MW
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT_DC_GC1

Wed 12/06/2017 to Wed 12/06/2017 **UPDATED by HQ 12/05/2017**
 0600 Daily 2300

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	500 MW
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2

Wed 12/06/2017 to Wed 12/06/2017
0600 to 2300

Work scheduled by:

FWD
(Import)
MOSES SOUTH 2550 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Wed 12/06/2017 to Wed 12/06/2017
0600 to 2300

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY 1370 MW 0 MW
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Wed 12/06/2017 to Wed 12/06/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 2300

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH 2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Wed 12/06/2017 to Wed 12/06/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 2300

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY 500 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_700

Wed 12/06/2017 to Wed 12/06/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 2300

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY 700 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1500 MW

CHAT_DC_GC1

Thu 12/07/2017 to Sun 12/10/2017 **CANCELLED by HQ 12/04/2017**
0600 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH 2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Thu 12/07/2017 to Sun 12/10/2017 **CANCELLED by HQ 12/04/2017**
0600 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY 500 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Status	By	Effective Date	Location	Direction	Value
CHAT_DC_GC2	Thu 12/07/2017	Sun 12/10/2017	CANCELLED	HQ	12/04/2017	MOSES SOUTH	FWD (Import)	2850 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Thu 12/07/2017	Sun 12/10/2017	CANCELLED	HQ	12/04/2017	SCH - HQ - NY	REV (Export)	500 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_700	Thu 12/07/2017	Sun 12/10/2017	CANCELLED	HQ	12/04/2017	SCH - HQ - NY	FWD (Import)	700 MW
							Impacts Total Transfer Capability	800 MW
							TTC with All Lines In Service	1500 MW
CHAT_DC_GC1	Fri 12/08/2017	Fri 12/08/2017	UPDATED	HQ	12/05/2017	MOSES SOUTH	FWD (Import)	2850 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC1	Fri 12/08/2017	Fri 12/08/2017	UPDATED	HQ	12/05/2017	SCH - HQ - NY	REV (Export)	500 MW
							Impacts Total Transfer Capability	500 MW
							TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2	Fri 12/08/2017	Fri 12/08/2017				MOSES SOUTH	FWD (Import)	2550 MW
							Impacts Total Transfer Capability	600 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2	Fri 12/08/2017	Fri 12/08/2017				SCH - HQ - NY	FWD (Import) REV (Export)	1370 MW 0 MW
							Impacts Total Transfer Capability	130 MW 1000 MW
							TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Fri 12/08/2017 to Fri 12/08/2017
0500 Daily 2000

UPDATED by HQ 12/05/2017

Work scheduled by: HQ

FWD
(Import)
2850 MW
MOSES SOUTH
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Fri 12/08/2017 to Fri 12/08/2017
0500 Daily 2000

UPDATED by HQ 12/05/2017

Work scheduled by: HQ

REV
(Export)
500 MW
SCH - HQ - NY
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_700

Fri 12/08/2017 to Fri 12/08/2017
0500 Daily 2000

UPDATED by HQ 12/05/2017

Work scheduled by: HQ

FWD
(Import)
700 MW
SCH - HQ - NY
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_900

Fri 12/08/2017 to Fri 12/08/2017
0515 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
1200 MW
SCH - OH - NY
Impacts Total Transfer Capability 550 MW
TTC with All Lines In Service 1750 MW

CHAT_DC_GC1

Sat 12/09/2017 to Sat 12/09/2017
0600 Daily 2000

UPDATED by HQ 12/05/2017

Work scheduled by: HQ

FWD
(Import)
2850 MW
MOSES SOUTH
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sat 12/09/2017 to Sat 12/09/2017
0600 Daily 2000

UPDATED by HQ 12/05/2017

Work scheduled by: HQ

REV
(Export)
500 MW
SCH - HQ - NY
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sat 12/09/2017 to Sat 12/09/2017
0600 2000

Work scheduled by:

FWD
(Import)
2550 MW
MOSES SOUTH
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2						FWD	REV	
Sat 12/09/2017	to	Sat 12/09/2017				(Import)	(Export)	
0600		2000			SCH - HQ - NY	1370 MW	0 MW	
Work scheduled by:						Impacts Total Transfer Capability	130 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2						FWD		
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)		
0600	Daily	2000			MOSES SOUTH	2850 MW		
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2							REV	
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>		(Export)	
0600	Daily	2000			SCH - HQ - NY		500 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_700						FWD		
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)		
0600	Daily	2000			SCH - HQ - NY	700 MW		
Work scheduled by: HQ						Impacts Total Transfer Capability	800 MW	
						TTC with All Lines In Service	1500 MW	
SCH-HQ-NYISO_LIMIT_800						FWD		
Sat 12/09/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)		
2001	Daily	0559			SCH - HQ - NY	800 MW		
Work scheduled by: HQ						Impacts Total Transfer Capability	700 MW	
						TTC with All Lines In Service	1500 MW	
CHAT_DC_GC1						FWD		
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)		
0600	Daily	1800			MOSES SOUTH	2850 MW		
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW	
						TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1							REV	
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>		(Export)	
0600	Daily	1800			SCH - HQ - NY		500 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service	1000 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 12/10/2017 to Sun 12/10/2017
0600 1800

Work scheduled by:

FWD
(Import)
MOSES SOUTH **2550 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Sun 12/10/2017 to Sun 12/10/2017
0600 1800

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **1370 MW 0 MW**
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Sun 12/10/2017 to Sun 12/10/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 1800

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sun 12/10/2017 to Sun 12/10/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 1800

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_700

Sun 12/10/2017 to Sun 12/10/2017 **UPDATED by HQ 12/05/2017**
0600 Daily 1800

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **700 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1500 MW

SCH-IMO-NYISO_LIMIT_700

Mon 12/11/2017 to Thu 12/14/2017 **by NGRID 12/06/2017**
0630 Continuous 1430

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1000 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 1750 MW

MOSES__-ADIRNDCK_230_MA2

Mon 12/11/2017 to Fri 12/15/2017 **CANCELLED by NYPA 12/04/2017**
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-KINTIGH__345_NS1-38					FWD	
Mon 12/11/2017	to	Wed 12/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/20/2017</u>	(Import)
0800	Continuous	1600				DYSINGER EAST 1700 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
N. SCTLND-LEEDS__345_93					FWD	
Wed 12/13/2017	to	Fri 12/15/2017				(Import)
0800	Continuous	1500				CENTRAL EAST - VC 2650 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
MOSES_-ADIRNDCK_230_MA2					FWD	
Mon 12/18/2017	to	Fri 12/22/2017	<u>UPDATED</u>	<u>by NYPA</u>	<u>10/23/2016</u>	(Import)
0700	Continuous	1530				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON__345_303					FWD	
Tue 12/19/2017	to	Tue 12/19/2017				(Import)
0800	Daily	1600				UPNY CONED 4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO__500_5018					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import) (Export)
0200	Continuous	1700				SCH - PJ - NY 2100 MW 1000 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	200 MW 450 MW
					TTC with All Lines In Service	2300 MW 1450 MW
HOPATCON-RAMAPO__500_5018					FWD	
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import)
0200	Continuous	1700				UPNY CONED 5000 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO__500_5018 & S.RIPLEY-DUNKIRK__230_68					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import) (Export)
0200		1700				SCH - PJ - NY 1200 MW 1300 MW
Work scheduled by:					Impacts Total Transfer Capability	1100 MW 150 MW
					TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
RAMAPO___345_345_PAR3500							
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>		
0200	Continuous	1700				SCH - PJ - NY	2200 MW 1450 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO___345_345_PAR4500							
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>		
0200	Continuous	1700				SCH - PJ - NY	2200 MW 1450 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO___500_345_BK 1500							
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>		
0200	Continuous	1700				SCH - PJ - NY	2100 MW 1000 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	200 MW 450 MW
						TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO___500_345_BK 1500							
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>		
0200	Continuous	1700				UPNY CONED	5000 MW
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	5100 MW
S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR3500							
Tue 12/26/2017	to	Thu 12/28/2017					
0200		1700				SCH - PJ - NY	1450 MW 1250 MW
Work scheduled by:						Impacts Total Transfer Capability	850 MW 200 MW
						TTC with All Lines In Service	2300 MW 1450 MW
S.RIPLEY-DUNKIRK__230_68 & RAMAPO___345_345_PAR4500							
Tue 12/26/2017	to	Thu 12/28/2017					
0200		1700				SCH - PJ - NY	1450 MW 1250 MW
Work scheduled by:						Impacts Total Transfer Capability	850 MW 200 MW
						TTC with All Lines In Service	2300 MW 1450 MW
DUNWODIE-SHORE_RD_345_Y50							
Tue 01/02/2018	to	Thu 01/04/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>09/22/2017</u>		
0001	Continuous	2359				CONED - LIPA	800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	700 MW
						TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Tue 01/02/2018 to Thu 01/04/2018
 0001 Continuous 2359
 Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_6

Tue 01/02/2018 to Thu 01/04/2018
 0001 Continuous 2359
 Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

SHORE_RD_345_138_BK 1

Tue 01/02/2018 to Thu 01/04/2018
 0001 Continuous 2359
 Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Tue 01/02/2018 to Thu 01/04/2018
 0001 Continuous 2359
 Work scheduled by: ConEd

EXTENDED by LI 09/22/2017

FWD
 (Import)
 CONED - LIPA **1350 MW**
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1500 MW

MOSES__-ADIRNDCK_230_MA1

Tue 01/02/2018 to Fri 01/05/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

EXTENDED by LI 09/22/2017

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

LEEDS__-PLSNTVLY_345_92

Wed 01/03/2018 to Sat 01/06/2018
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

Wed 01/03/2018 to Sat 01/06/2018
 0001 Continuous 0300
 Work scheduled by: ConEd

UPDATED by NYISO 09/12/2017

FWD
 (Import)
 UPNY CONED **3800 MW**
 Impacts Total Transfer Capability 1300 MW
 TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

FWD

Fri 01/05/2018 to Sun 01/07/2018
0001 2359

(Import)

Work scheduled by:

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

PLSNTVLY_345KV_RNS5

FWD

Mon 01/08/2018 to Wed 01/10/2018 **UPDATED by NYISO 09/12/2017**
0001 Continuous 0300

(Import)

Work scheduled by: ConEd

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5100 MW

EASTVIEW-SPRNBK__345_W64

FWD

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

MILLWOOD-EASTVIEW_345_W99

FWD

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 750 MW
TTC with All Lines In Service 5100 MW

SPRNBK__345KV_RNS5

FWD

Mon 01/08/2018 to Fri 02/23/2018
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

MARCY___765_345_AT2

FWD

Mon 01/08/2018 to Sun 01/14/2018 **UPDATED by NYPA 11/20/2017**
0500 Continuous 2100

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASER_-COOPERS__345_33

FWD

Mon 01/08/2018 to Thu 01/11/2018
0800 Continuous 1500

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC **2395 MW**
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS _____ 345_2	FWD	REV
Mon 01/08/2018 to Fri 02/02/2018 UPDATED by NG 10/17/2017	(Import)	(Export)
0800 Continuous 1400		
Work scheduled by: NGrid	SCH - NE - NY 900 MW	1600 MW
	Impacts Total Transfer Capability	500 MW 0 MW
	TTC with All Lines In Service	1400 MW 1600 MW
<hr/>		
N. SCTLND-ALPS _____ 345_2	FWD	REV
Mon 01/08/2018 to Fri 02/02/2018 UPDATED by NG 10/17/2017	(Import)	(Export)
0800 Continuous 1400		
Work scheduled by: NGrid	SCH - NPX_1385 100 MW	100 MW
	Impacts Total Transfer Capability	100 MW 100 MW
	TTC with All Lines In Service	200 MW 200 MW
<hr/>		
PLSNTVLY-EFISHKIL_345_F37	FWD	
Thu 01/11/2018 to Fri 01/12/2018	(Import)	
0001 Continuous 0200		
Work scheduled by: ConEd	UPNY CONED 4000 MW	
	Impacts Total Transfer Capability	1100 MW
	TTC with All Lines In Service	5100 MW
<hr/>		
MOSES -ADIRNDCK_230_MA1	FWD	
Mon 01/15/2018 to Fri 01/19/2018	(Import)	
0700 Continuous 1530		
Work scheduled by: NYPA	MOSES SOUTH 2300 MW	
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
MARCY_765_345_AT2	FWD	
Sat 01/20/2018 to Sat 01/20/2018	(Import)	
0500 Continuous 1730		
Work scheduled by: NYPA	MOSES SOUTH 1700 MW	
	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
ARR: 19		
<hr/>		
MOSES -ADIRNDCK_230_MA1	FWD	
Mon 01/22/2018 to Fri 01/26/2018	(Import)	
0700 Continuous 1530		
Work scheduled by: NYPA	MOSES SOUTH 2300 MW	
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
MOSES -ADIRNDCK_230_MA1	FWD	
Mon 01/29/2018 to Fri 02/02/2018	(Import)	
0700 Continuous 1530		
Work scheduled by: NYPA	MOSES SOUTH 2300 MW	
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Sat 02/03/2018 to Sat 02/03/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH 1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/05/2018 to Fri 02/09/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 02/12/2018 to Fri 02/16/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

HUDSONP_-FARRAGUT_345_B3402

Sun 02/18/2018 to Sun 04/01/2018
0001 Continuous 2359

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJ - NY 2300 MW 1450 MW
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2300 MW 1450 MW

MARCY___-EDIC___345_UE1-7

Tue 02/20/2018 to Fri 02/23/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19&16

FWD
(Import)
OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MOSES___-ADIRNDCK_230_MA1

Tue 02/20/2018 to Fri 02/23/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH 2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_7

Sat 02/24/2018 to Sat 02/24/2018
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CE 09/22/2017

FWD
(Import)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8				FWD		
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u> <u>by CE</u> <u>09/22/2017</u>	(Import)		
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service	4600 MW	
DUNWODIE-MOTTHAVN_345_72				FWD		
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u> <u>by CE</u> <u>09/22/2017</u>	(Import)		
0001	Continuous	0300		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service	4600 MW	
LONG_MTN-PLSNTVLY_345_398				FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018		(Import) (Export)		
0001	Continuous	0300		SCH - NE - NY	700 MW	1300 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	700 MW	300 MW
				TTC with All Lines In Service	1400 MW	1600 MW
LONG_MTN-PLSNTVLY_345_398				FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018		(Import) (Export)		
0001	Continuous	0300		SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW	100 MW
				TTC with All Lines In Service	200 MW	200 MW
MOSES__-ADIRNDCK_230_MAI				FWD		
Mon 02/26/2018	to	Fri 03/02/2018		(Import)		
0700	Continuous	1730		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
MOSES__-ADIRNDCK_230_MAI				FWD		
Mon 03/05/2018	to	Fri 03/09/2018		(Import)		
0700	Continuous	1730		MOSES SOUTH	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW	
				TTC with All Lines In Service	3150 MW	
MARCY__-N.SCTLND_345_18				FWD		
Tue 03/06/2018	to	Wed 03/07/2018		(Import)		
0600	Continuous	1530		CENTRAL EAST - VC	2090 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	885 MW	
				TTC with All Lines In Service	2975 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 03/12/2018 to Fri 03/16/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

S.RIPLEY-DUNKIRK_230_68

Mon 03/19/2018 to Fri 04/20/2018
1000 Continuous 1559

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJ - NY **1950 MW 1350 MW**
Impacts Total Transfer Capability 350 MW 100 MW
TTC with All Lines In Service 2300 MW 1450 MW

MARCY___345KV_CSC

Mon 03/26/2018 to Fri 04/13/2018
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MA2

Mon 03/26/2018 to Thu 03/29/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

DUNWODIE_345KV_7

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED by CE 09/22/2017**
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED by CE 09/22/2017**
0230 Continuous 0300

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

MOSES___-ADIRNDCK_230_MA1

Mon 04/02/2018 to Fri 04/06/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Update	By	Date	Impact	FWD	REV
MALONE -WILLIS 115_1-910								
Tue 04/03/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>	SCH - HQ_CEDARS		REV
0700	Continuous	1530				Impacts Total Transfer Capability	60 MW	(Export)
Work scheduled by: NYPA						ARR: 38	TTC with All Lines In Service	100 MW
SHOR_NPX-SHOREHAM 138_CSC								
Wed 04/04/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by LI</u>	<u>11/08/2017</u>	SCH - NPX_CSC	0 MW	REV
0600	Continuous	1800				Impacts Total Transfer Capability	330 MW	(Import) (Export)
Work scheduled by: LI						TTC with All Lines In Service	330 MW	330 MW
LINDN_CG-LNDVFT 345_V-3022								
Sun 04/08/2018	to	Fri 04/13/2018				SCH - PJM_VFT	0 MW	REV
1400	Continuous	1800				Impacts Total Transfer Capability	315 MW	(Import) (Export)
Work scheduled by: PJM						TTC with All Lines In Service	315 MW	315 MW
MOSES -ADIRNDCK 230_MA1								
Mon 04/09/2018	to	Fri 04/13/2018				MOSES SOUTH	2300 MW	FWD
0700	Continuous	1730				Impacts Total Transfer Capability	850 MW	(Import)
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
FRASER -GILBOA 345_GF5-35								
Mon 04/09/2018	to	Fri 04/20/2018				CENTRAL EAST - VC	2650 MW	FWD
0700	Continuous	1730				Impacts Total Transfer Capability	325 MW	(Import)
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW	
NEPTUNE -DUFFYAVE 345_NEPTUNE								
Mon 04/16/2018	to	Tue 05/01/2018				SCH - PJM_NEPTUNE	0 MW	FWD
0001	Continuous	1800				Impacts Total Transfer Capability	660 MW	(Import)
Work scheduled by: PJM						TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE 345_501								
Mon 04/16/2018	to	Tue 05/01/2018				SCH - PJM_NEPTUNE	0 MW	FWD
0001	Continuous	1800				Impacts Total Transfer Capability	660 MW	(Import)
Work scheduled by: PJM						TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: PJM			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	375 MW	
Work scheduled by: PJM			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
MOSES__-ADIRNDCK_230_MA1				FWD	
Mon 04/16/2018	to	Fri 04/20/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
S.RIPLEY-DUNKIRK__230_68				FWD	REV
Fri 04/20/2018	to	Sat 02/01/2020	UPDATED	(Import)	(Export)
1600	Continuous	0000	by NYISO 10/31/2017	SCH - PJ - NY	1950 MW 1350 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	350 MW	100 MW
			TTC with All Lines In Service	2300 MW	1450 MW
MARCY__765_345_AT1				FWD	
Mon 04/23/2018	to	Mon 04/23/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
MOSES__-ADIRNDCK_230_MA2				FWD	
Mon 04/30/2018	to	Fri 05/04/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
HURLYAVE-ROSETON__345_303				FWD	
Mon 04/30/2018	to	Fri 05/25/2018		(Import)	
0800	Continuous	1600	UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
 0001 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_KINTIGH_345_NS1-38

Mon 05/07/2018 to Fri 05/11/2018
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES_ADIRNDCK_230_MA2

Mon 05/07/2018 to Fri 05/11/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MOSES_ADIRNDCK_230_MA2

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

CLAY_EDIC_345_1-16

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

WETHSRFD-MEYER_230_85/87

Tue 05/15/2018 to Fri 06/01/2018
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

MARCY_765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 2000

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1600 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2000 MW 1600 MW

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FRASER_-GILBOA___345_GF5-35

Mon 09/10/2018 to Fri 10/05/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S</p> <p>Tue 09/11/2018 to Tue 09/11/2018 0500 1730</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2690 MW</p> <p>Impacts Total Transfer Capability 285 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>MARCY___765_345_AT2</p> <p>Tue 09/11/2018 to Tue 09/11/2018 0500 Continuous 1730</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>NIAGARA__345_230_AT4</p> <p>Fri 09/14/2018 to Fri 09/14/2018 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - OH - NY 2000 MW 1400 MW</p> <p>Impacts Total Transfer Capability 0 MW 200 MW</p> <p>TTC with All Lines In Service 2000 MW 1600 MW</p>
<p>NIAGARA_-ROCHESTR_345_NR2</p> <p>Mon 09/17/2018 to Fri 09/21/2018 0500 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 1700 MW</p> <p>Impacts Total Transfer Capability 1450 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 09/17/2018 to Fri 09/21/2018 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2100 MW</p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES___-ADIRNDCK_230_MA1</p> <p>Mon 09/24/2018 to Fri 09/28/2018 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2100 MW</p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CLAY___-EDIC___345_2-15</p> <p>Mon 09/24/2018 to Fri 09/28/2018 0700 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK - NIAGARA 345_PA302	FWD	REV
Mon 10/01/2018 to Fri 10/05/2018	(Import)	(Export)
0500 Continuous 1700	SCH - OH - NY 900 MW	800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1100 MW
	TTC with All Lines In Service	2000 MW
		1600 MW
MOSES - ADIRNDCK 230_MA2	FWD	
Mon 10/01/2018 to Wed 10/03/2018	(Import)	
0700 Continuous 1530	MOSES SOUTH 2100 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
PANNELL - CLAY 345_1	FWD	
Mon 10/01/2018 to Fri 10/05/2018	(Import)	
0700 Continuous 1700	WEST CENTRAL 1300 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	950 MW
	TTC with All Lines In Service	2250 MW
MARCY 765_345_AT2	FWD	
Thu 10/04/2018 to Fri 10/05/2018	(Import)	
0500 Continuous 1730	MOSES SOUTH 1700 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
		ARR: 19
MOSES - ADIRNDCK 230_MA1	FWD	
Mon 10/08/2018 to Fri 10/12/2018	(Import)	
0700 Continuous 1530	MOSES SOUTH 2100 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040	FWD	
Sat 10/13/2018 to Sat 10/27/2018	(Import)	
0100 Continuous 1730	MOSES SOUTH 1550 MW	
Work scheduled by: NYPA	Impacts Total Transfer Capability	1600 MW
	TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA 765_7040	FWD	REV
Sat 10/13/2018 to Sat 10/27/2018	(Import)	(Export)
0100 Continuous 1730	SCH - HQ - NY 0 MW	0 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1500 MW
	TTC with All Lines In Service	1500 MW
		1000 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	1750 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
		TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	CENTRAL EAST - VC	2265 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	710 MW
		TTC with All Lines In Service	2975 MW
MASSENA_-MARCY___765_MSU1		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	500 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import) (Export)	
0100	Continuous 1730	SCH - HQ - NY	475 MW 1000 MW
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	MOSES SOUTH	500 MW
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
MASSENA_-MARCY___765_MSU1 & MARCY_SO_SERIES_COMP_I/S		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	CENTRAL EAST - VC	2080 MW
Work scheduled by:		Impacts Total Transfer Capability	895 MW
		TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2

Sat 10/13/2018 to Sat 10/27/2018
0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

LEEDS -HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

KINTIGH -ROCHESTR_345_SRI-39

Mon 10/29/2018 to Fri 11/02/2018
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES -ADIRNDCK_230_MAI

Mon 10/29/2018 to Fri 11/02/2018
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

MOSES -ADIRNDCK_230_MAI

Mon 11/05/2018 to Fri 11/09/2018
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY_345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2925 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MARCY_765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Wednesday, December 06, 2017 to Friday, June 07, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 11/19/2018 to Wed 11/21/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/10/2018 to Fri 12/14/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Wed 12/26/2018 to Fri 12/28/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW