

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800					REV
Thu 06/08/2017	to	Sun 12/10/2017	<u>by HQ</u>	<u>12/08/2017</u>	(Export)
0600	Continuous	1800			800 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1000 MW
S.RIPLEY-DUNKIRK_230_68					FWD REV
Sat 10/28/2017	to	Mon 12/11/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>12/08/2017</u>
1501	Continuous	0859			(Import) (Export)
Work scheduled by: NYISO					1950 MW 1350 MW
					Impacts Total Transfer Capability 350 MW 100 MW
					TTC with All Lines In Service 2300 MW 1450 MW
SCH-NYISO-IMO_LIMIT_1400					REV
Wed 11/01/2017	to	Mon 04/30/2018			(Export)
0001	Continuous	2359			1700 MW
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1900 MW
MARION_-FARRAGUT_345_C3403					FWD REV
Fri 11/17/2017	to	Sat 12/23/2017	<u>EXTENDED</u>	<u>by CE</u>	<u>11/28/2017</u>
0801	Continuous	0100			(Import) (Export)
Work scheduled by: ConEd					2300 MW 1450 MW
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW
EGRDNCTY_345_138_AT1					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
EGRDNCTY_345_138_AT2					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			1250 MW
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
SPRNBRK_-EGRDNCTR_345_Y49					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			775 MW
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW
					TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD		
CHAT_DC_GC2						(Import)		
Mon 11/20/2017	to	Wed 12/06/2017	<u>EXTENDED</u>	<u>by HQ</u>	<u>12/08/2017</u>	MOSES SOUTH	2850 MW	
1800	Continuous	0559				Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ						TTC with All Lines In Service	3150 MW	
<hr/>								
CHAT_DC_GC2						REV		
Mon 11/20/2017	to	Wed 12/06/2017	<u>EXTENDED</u>	<u>by HQ</u>	<u>12/08/2017</u>	SCH - HQ - NY	500 MW	
1800	Continuous	0559				Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ						TTC with All Lines In Service	1000 MW	
<hr/>								
SCH-HQ-NYISO_LIMIT_1200						FWD		
Mon 11/20/2017	to	Wed 12/06/2017	<u>EXTENDED</u>	<u>by HQ</u>	<u>12/08/2017</u>	SCH - HQ - NY	1200 MW	
1800	Continuous	0559				Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ						TTC with All Lines In Service	1500 MW	
<hr/>								
E13THSTA-FARRAGUT_345_45						FWD		
Sun 11/26/2017	to	Tue 05/15/2018		<u>by CE</u>	<u>12/06/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<hr/>								
W49TH_ST-E13THSTA_345_M54						FWD		
Sun 11/26/2017	to	Tue 05/15/2018		<u>by CE</u>	<u>12/06/2017</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	2359				Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd						TTC with All Lines In Service	4600 MW	
<hr/>								
CEDARS__-ROSEMNTB_115_2/22						FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>11/22/2017</u>	SCH - HQ_CEDARS	95 MW	100 MW
0700	Continuous	1600				Impacts Total Transfer Capability	104 MW	0 MW
Work scheduled by: HQ						TTC with All Lines In Service	199 MW	100 MW
<hr/>								
DENNISON-ROSEMNTB_115_2/22						FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>11/22/2017</u>	SCH - HQ_CEDARS	95 MW	100 MW
0700	Continuous	1600				Impacts Total Transfer Capability	104 MW	0 MW
Work scheduled by: HQ						TTC with All Lines In Service	199 MW	100 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_100					FWD	
Mon 11/27/2017	to	Thu 12/07/2017	UPDATED	by HQ	11/22/2017	(Import)
0700	Continuous	1600				SCH - HQ_CEDARS 100 MW
Work scheduled by: HQ					Impacts Total Transfer Capability	99 MW
					TTC with All Lines In Service	199 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Sun 12/03/2017	to	Tue 12/05/2017				(Import)
0001		0300				UPNY CONED 3800 MW
Work scheduled by:					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
OSWEGO_COMPLEX_AVR_O/S					FWD	
Sun 12/03/2017	to	Sun 12/03/2017				(Import)
0900	Continuous	1000				CENTRAL EAST - VC 2870 MW
Work scheduled by: Gen					Impacts Total Transfer Capability	105 MW
					TTC with All Lines In Service	2975 MW
MARCY_SO_SERIES_COMP_I/S					FWD	
Mon 12/04/2017	to	Fri 12/08/2017	UPDATED	by NYISO	12/08/2017	(Import)
0001	Continuous	0318				CENTRAL EAST - VC 2740 MW
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
LEEDS___-PLSNTVLY_345_92					FWD	
Mon 12/04/2017	to	Mon 12/18/2017	UPDATED	by NYISO	09/12/2017	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
PLSNTVLY_345KV_RNS5					FWD	
Mon 12/04/2017	to	Mon 12/18/2017	UPDATED	by NYISO	09/12/2017	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1300 MW
					TTC with All Lines In Service	5100 MW
MARCY___765_345_AT2					FWD	
Mon 12/04/2017	to	Fri 12/08/2017	UPDATED	by NYPA	11/13/2017	(Import)
0500	Continuous	1700				MOSES SOUTH 1700 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NOR HBR_138_601							
Mon 12/04/2017	to	Fri 02/02/2018	EXTENDED	by LI	12/07/2017		
0700	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602							
Mon 12/04/2017	to	Fri 02/02/2018				SCH - NPX_1385	0 MW
0700		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603							
Mon 12/04/2017	to	Fri 02/02/2018				SCH - NPX_1385	0 MW
0700		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602							
Mon 12/04/2017	to	Fri 02/02/2018	EXTENDED	by LI	12/07/2017		
0700	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603							
Mon 12/04/2017	to	Fri 02/02/2018				SCH - NPX_1385	0 MW
0700		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
NRTH1385-NOR HBR_138_603							
Mon 12/04/2017	to	Fri 02/02/2018	EXTENDED	by LI	12/07/2017		
0700	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC							
Mon 12/04/2017	to	Fri 02/02/2018	EXTENDED	by LI	12/07/2017		
0700	Continuous	2359				SCH - NPX_1385	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS 345 LEEDS SVC					FWD	
Mon 12/04/2017	to	Thu 12/07/2017	EXTENDED	by NGRID	12/06/2017	(Import)
0800	Continuous	1500				CENTRAL EAST - VC 2950 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability 25 MW	
					TTC with All Lines In Service 2975 MW	
LEEDS 345 LEEDS SVC & MARCY_SO_SERIES_COMP_I/S					FWD	
Mon 12/04/2017	to	Thu 12/07/2017				(Import)
0800		1500				CENTRAL EAST - VC 2715 MW
Work scheduled by:					Impacts Total Transfer Capability 260 MW	
					TTC with All Lines In Service 2975 MW	
CHAT_DC_GC1					FWD	
Wed 12/06/2017	to	Wed 12/06/2017	UPDATED	by HQ	12/05/2017	(Import)
0600	Daily	2300				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	
CHAT_DC_GC1					REV	
Wed 12/06/2017	to	Wed 12/06/2017	UPDATED	by HQ	12/05/2017	(Export)
0600	Daily	2300				SCH - HQ - NY 500 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW	
					TTC with All Lines In Service 1000 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Wed 12/06/2017	to	Wed 12/06/2017				(Import)
0600		2300				MOSES SOUTH 2550 MW
Work scheduled by:					Impacts Total Transfer Capability 600 MW	
					TTC with All Lines In Service 3150 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Wed 12/06/2017	to	Wed 12/06/2017				(Import) (Export)
0600		2300				SCH - HQ - NY 1370 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability 130 MW 1000 MW	
					TTC with All Lines In Service 1500 MW 1000 MW	
CHAT_DC_GC2					FWD	
Wed 12/06/2017	to	Wed 12/06/2017	UPDATED	by HQ	12/05/2017	(Import)
0600	Daily	2300				MOSES SOUTH 2850 MW
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2						REV
Wed 12/06/2017	to	Wed 12/06/2017	UPDATED	by HQ	12/05/2017	(Export)
0600	Daily	2300				500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_700						FWD
Wed 12/06/2017	to	Wed 12/06/2017	UPDATED	by HQ	12/05/2017	(Import)
0600	Daily	2300				700 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1500 MW
CHAT_DC_GC1						FWD
Thu 12/07/2017	to	Sun 12/10/2017	CANCELLED	by HQ	12/04/2017	(Import)
0600	Continuous	1700				2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC1						REV
Thu 12/07/2017	to	Sun 12/10/2017	CANCELLED	by HQ	12/04/2017	(Export)
0600	Continuous	1700				500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
CHAT_DC_GC2						FWD
Thu 12/07/2017	to	Sun 12/10/2017	CANCELLED	by HQ	12/04/2017	(Import)
0600	Continuous	1700				2850 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC2						REV
Thu 12/07/2017	to	Sun 12/10/2017	CANCELLED	by HQ	12/04/2017	(Export)
0600	Continuous	1700				500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_700						FWD
Thu 12/07/2017	to	Sun 12/10/2017	CANCELLED	by HQ	12/04/2017	(Import)
0600	Continuous	1700				700 MW
Work scheduled by: HQ						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1					FWD		
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				2850 MW	
Work scheduled by: HQ					MOSES SOUTH		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1					REV		
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)	
0500	Daily	2000				500 MW	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD		
Fri 12/08/2017	to	Fri 12/08/2017				(Import)	
0500		2000				2550 MW	
Work scheduled by:					MOSES SOUTH		
					Impacts Total Transfer Capability	600 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV	
Fri 12/08/2017	to	Fri 12/08/2017				(Import)	(Export)
0500		2000				1370 MW	0 MW
Work scheduled by:					SCH - HQ - NY		
					Impacts Total Transfer Capability	130 MW	1000 MW
					TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2					FWD		
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				2850 MW	
Work scheduled by: HQ					MOSES SOUTH		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2					REV		
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)	
0500	Daily	2000				500 MW	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_700					FWD		
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				700 MW	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_900					FWD	
Fri 12/08/2017	to	Fri 12/08/2017			(Import)	
0515	Continuous	1730		SCH - OH - NY	1200 MW	
Work scheduled by: NGrid					Impacts Total Transfer Capability	550 MW
					TTC with All Lines In Service	1750 MW
MARCY_SO_SERIES_COMP_I/S					FWD	
Fri 12/08/2017	to	Mon 12/18/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>12/08/2017</u>	(Import)
0942	Continuous	0300		CENTRAL EAST - VC	2740 MW	
Work scheduled by: NYISO					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
SCH-HQ-NYISO_LIMIT_1400					FWD	
Sat 12/09/2017	to	Sun 12/10/2017		<u>by HQ</u>	<u>12/08/2017</u>	(Import)
0001	Continuous	1800		SCH - HQ - NY	1400 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	1500 MW
CHAT_DC_GC1					FWD	
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	2000		MOSES SOUTH	2850 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1						REV
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)
0600	Daily	2000		SCH - HQ - NY	500 MW	
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	
Sat 12/09/2017	to	Sat 12/09/2017				(Import)
0600		2000		MOSES SOUTH	2550 MW	
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2					FWD	REV
Sat 12/09/2017	to	Sat 12/09/2017				(Import) (Export)
0600		2000		SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	130 MW
					TTC with All Lines In Service	1500 MW
						1000 MW
						1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2						FWD
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	2000				2850 MW
Work scheduled by: HQ						MOSES SOUTH
						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC2						REV
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)
0600	Daily	2000				500 MW
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
SCH-HQ-NYISO_LIMIT_700						FWD
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	2000				700 MW
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1500 MW
SCH-HQ-NYISO_LIMIT_800						FWD
Sat 12/09/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
2001	Daily	0559				800 MW
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 700 MW
						TTC with All Lines In Service 1500 MW
CHAT_DC_GC1						FWD
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	1800				2850 MW
Work scheduled by: HQ						MOSES SOUTH
						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
CHAT_DC_GC1						REV
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)
0600	Daily	1800				500 MW
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2						FWD
Sun 12/10/2017	to	Sun 12/10/2017				(Import)
0600		1800				2550 MW
Work scheduled by:						MOSES SOUTH
						Impacts Total Transfer Capability 600 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
CHAT_DC_GC1 & CHAT_DC_GC2							
Sun 12/10/2017	to	Sun 12/10/2017					
0600		1800			SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	130 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2						FWD	
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0600	Daily	1800			MOSES SOUTH	2850 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC2							REV
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>		(Export)
0600	Daily	1800			SCH - HQ - NY		500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_700						FWD	
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0600	Daily	1800			SCH - HQ - NY	700 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1500 MW
SCH-IMO-NYISO_LIMIT_700						FWD	
Mon 12/11/2017	to	Thu 12/14/2017		<u>by NGRID</u>	<u>12/06/2017</u>	(Import)	
0630	Continuous	1430			SCH - OH - NY	1000 MW	
Work scheduled by: NGrid						Impacts Total Transfer Capability	750 MW
						TTC with All Lines In Service	1750 MW
MOSES -ADIRNDCK_230_MA2						FWD	
Mon 12/11/2017	to	Fri 12/15/2017	<u>CANCELLED</u>	<u>by NYPA</u>	<u>12/04/2017</u>	(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
NIAGARA -KINTIGH_345_NS1-38						FWD	
Mon 12/11/2017	to	Wed 12/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/20/2017</u>	(Import)	
0800	Continuous	1600			DYSINGER EAST	1700 MW	
Work scheduled by: NYSEG						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-PJM_LIMIT_100				REV
Mon 12/11/2017	to	Fri 12/15/2017		(Export)
0900	Continuous	1400	SCH - PJ - NY	400 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	1450 MW
CHAT_DC_GC2				FWD
Tue 12/12/2017	to	Tue 12/12/2017		(Import)
0900	Continuous	1700	MOSES SOUTH	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC2				REV
Tue 12/12/2017	to	Tue 12/12/2017		(Export)
0900	Continuous	1700	SCH - HQ - NY	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
SCH-HQ-NYISO_LIMIT_1200				FWD
Tue 12/12/2017	to	Tue 12/12/2017		(Import)
0900	Continuous	1700	SCH - HQ - NY	1200 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	1500 MW
N.SCTLND-LEEDS___345_93				FWD
Wed 12/13/2017	to	Fri 12/15/2017		(Import)
0800	Continuous	1500	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
S.RIPLEY-DUNKIRK__230_68				FWD REV
Fri 12/15/2017	to	Mon 03/19/2018	UPDATED by NYISO 12/08/2017	(Import) (Export)
1400	Continuous	0959	SCH - PJ - NY	1950 MW 1350 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability	350 MW 100 MW
			TTC with All Lines In Service	2300 MW 1450 MW
MOSES___-ADIRNDCK_230_MA2				FWD
Mon 12/18/2017	to	Fri 12/22/2017	CANCELLED by NYPA 12/07/2017	(Import)
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON__345_303					FWD	
Tue 12/19/2017	to	Tue 12/19/2017			(Import)	
0800	Daily	1600		UPNY CONED	4100 MW	
Work scheduled by: CHGE					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO__500_5018					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import) (Export)
0200	Continuous	1700				
Work scheduled by: PJM					SCH - PJ - NY	2100 MW 1000 MW
					Impacts Total Transfer Capability	200 MW 450 MW
					TTC with All Lines In Service	2300 MW 1450 MW
HOPATCON-RAMAPO__500_5018					FWD	
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import)
0200	Continuous	1700				
Work scheduled by: PJM					UPNY CONED	5000 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5100 MW
HOPATCON-RAMAPO__500_5018 & S.RIPLEY-DUNKIRK__230_68					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017			(Import) (Export)	
0200		1700				
Work scheduled by:					SCH - PJ - NY	1200 MW 1300 MW
					Impacts Total Transfer Capability	1100 MW 150 MW
					TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO__345_345_PAR3500					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import) (Export)
0200	Continuous	1700				
Work scheduled by: PJM					SCH - PJ - NY	2200 MW 1450 MW
					Impacts Total Transfer Capability	100 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO__345_345_PAR4500					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import) (Export)
0200	Continuous	1700				
Work scheduled by: PJM					SCH - PJ - NY	2200 MW 1450 MW
					Impacts Total Transfer Capability	100 MW 0 MW
					TTC with All Lines In Service	2300 MW 1450 MW
RAMAPO__500_345_BK 1500					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017	<u>UPDATED</u>	<u>by CE</u>	<u>10/27/2017</u>	(Import) (Export)
0200	Continuous	1700				
Work scheduled by: PJM					SCH - PJ - NY	2100 MW 1000 MW
					Impacts Total Transfer Capability	200 MW 450 MW
					TTC with All Lines In Service	2300 MW 1450 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___500_345_BK 1500					FWD	
Tue 12/26/2017	to	Thu 12/28/2017	UPDATED	by CE	10/27/2017	(Import)
0200	Continuous	1700				5000 MW
Work scheduled by: PJM					UPNY CONED	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5100 MW
<hr/>						
S.RIPLEY-DUNKIRK_230_68 & RAMAPO___345_345_PAR3500					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import) (Export)
0200		1700				1450 MW 1250 MW
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	850 MW 200 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
S.RIPLEY-DUNKIRK_230_68 & RAMAPO___345_345_PAR4500					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import) (Export)
0200		1700				1450 MW 1250 MW
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	850 MW 200 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
DUNWODIE-SHORE_RD_345_Y50					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				800 MW
Work scheduled by: ConEd					CONED - LIPA	
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW
<hr/>						
DUNWODIE_345KV_4					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
DUNWODIE_345KV_6					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
SHORE_RD_345_138_BK 1					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	EXTENDED	by LI	09/22/2017	(Import)
0001	Continuous	2359				1350 MW
Work scheduled by: ConEd					CONED - LIPA	
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	2359				CONED - LIPA 1350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	TTC with All Lines In Service 1500 MW
MOSES -ADIRNDCK_230_MAI					FWD	
Tue 01/02/2018	to	Fri 01/05/2018				(Import)
0700	Continuous	1730				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	TTC with All Lines In Service 3150 MW
LEEDS -PLSNTVLY_345_92					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
PLSNTVLY_345KV_RNS5					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4					FWD	
Fri 01/05/2018	to	Sun 01/07/2018				(Import)
0001		2359				UPNY CONED 3800 MW
Work scheduled by:					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
PLSNTVLY_345KV_RNS5					FWD	
Mon 01/08/2018	to	Wed 01/10/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED 3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
EASTVIEW-SPRNBK_345_W64					FWD	
Mon 01/08/2018	to	Fri 02/23/2018				(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW	TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99					FWD	
Mon 01/08/2018	to	Fri 02/23/2018			(Import)	
0001	Continuous	0200		UPNY CONED	4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	750 MW
					TTC with All Lines In Service	5100 MW
SPRNBRK_345KV_RNS5					FWD	
Mon 01/08/2018	to	Fri 02/23/2018			(Import)	
0001	Continuous	0200		SPR/DUN-SOUTH	3200 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
MARCY_765_345_AT2					FWD	
Mon 01/08/2018	to	Sun 01/14/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>	
0500	Continuous	2100				
Work scheduled by: NYPA					MOSES SOUTH	1700 MW
					Impacts Total Transfer Capability	1450 MW
					TTC with All Lines In Service	3150 MW
FRASER-COOPERS_345_33					FWD	
Mon 01/08/2018	to	Thu 01/11/2018			(Import)	
0800	Continuous	1500		CENTRAL EAST - VC	2395 MW	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	580 MW
					TTC with All Lines In Service	2975 MW
N.SCTLND-ALPS_345_2					FWD	REV
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>	
0800	Continuous	1400				
Work scheduled by: NGrid					SCH - NE - NY	900 MW 1600 MW
					Impacts Total Transfer Capability	500 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
N.SCTLND-ALPS_345_2					FWD	REV
Mon 01/08/2018	to	Fri 02/02/2018	<u>UPDATED</u>	<u>by NG</u>	<u>10/17/2017</u>	
0800	Continuous	1400				
Work scheduled by: NGrid					SCH - NPX_1385	100 MW 100 MW
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
N.SCTLND-ALPS_345_2 & NRTH1385-NOR HBR_138_601					FWD	REV
Mon 01/08/2018	to	Fri 02/02/2018			(Import)	(Export)
0800		1400		SCH - NPX_1385	0 MW	0 MW
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_602

Mon 01/08/2018 to Fri 02/02/2018
0800 1400

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_603

Mon 01/08/2018 to Fri 02/02/2018
0800 1400

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

PLSNTVLY-EFISHKIL_345_F37

Thu 01/11/2018 to Fri 01/12/2018
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

MOSES___-ADIRNDCK_230_MAI

Mon 01/15/2018 to Fri 01/19/2018
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY___765_345_AT2

Sat 01/20/2018 to Sat 01/20/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 01/22/2018 to Fri 01/26/2018
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 01/29/2018 to Fri 02/02/2018
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2				FWD	
Sat 02/03/2018	to	Sat 02/03/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
ARR: 19					
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 02/05/2018	to	Fri 02/09/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
MOSES___-ADIRNDCK_230_MA2				FWD	
Mon 02/12/2018	to	Fri 02/16/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
HUDSONP_-FARRAGUT_345_B3402				FWD	REV
Sun 02/18/2018	to	Sun 04/01/2018		(Import)	(Export)
0001	Continuous	2359	SCH - PJ - NY	2300 MW	1450 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2300 MW	1450 MW
MARCY___-EDIC___345_UE1-7				FWD	
Tue 02/20/2018	to	Fri 02/23/2018		(Import)	
0500	Continuous	1730	OSWEGO EXPORT	5250 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
ARR: 19&16					
MOSES___-ADIRNDCK_230_MA1				FWD	
Tue 02/20/2018	to	Fri 02/23/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
DUNWODIE_345KV_7				FWD	
Sat 02/24/2018	to	Sat 02/24/2018	UPDATED		
0001	Continuous	0030	by CE		
Work scheduled by: ConEd			09/22/2017		
			SPR/DUN-SOUTH	3800 MW	
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8					FWD	
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	0030				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
DUNWODIE-MOTTHAVN_345_72					FWD	
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	0300				3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
LONG_MTN-PLSNTVLY_345_398					FWD	
Mon 02/26/2018	to	Wed 05/02/2018				(Import) (Export)
0001	Continuous	0300				700 MW 1300 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 700 MW 300 MW	
					TTC with All Lines In Service 1400 MW 1600 MW	
LONG_MTN-PLSNTVLY_345_398					FWD	
Mon 02/26/2018	to	Wed 05/02/2018				(Import) (Export)
0001	Continuous	0300				100 MW 100 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 100 MW 100 MW	
					TTC with All Lines In Service 200 MW 200 MW	
MOSES__-ADIRNDCK_230_MAI					FWD	
Mon 02/26/2018	to	Fri 03/02/2018				(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
MOSES__-ADIRNDCK_230_MAI					FWD	
Mon 03/05/2018	to	Fri 03/09/2018				(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	
					TTC with All Lines In Service 3150 MW	
MARCY__-N.SCTLND_345_18					FWD	
Tue 03/06/2018	to	Wed 03/07/2018				(Import)
0600	Continuous	1530				2090 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 885 MW	
					TTC with All Lines In Service 2975 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1					FWD
Mon 03/12/2018	to	Fri 03/16/2018			(Import)
0700	Continuous	1730		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
S.RIPLEY-DUNKIRK_230_68					FWD REV
Mon 03/19/2018	to	Fri 04/20/2018			(Import) (Export)
1000	Continuous	1559		SCH - PJ - NY	1950 MW 1350 MW
Work scheduled by: PJM					Impacts Total Transfer Capability 350 MW 100 MW
					TTC with All Lines In Service 2300 MW 1450 MW
MARCY_345KV_CSC					FWD
Mon 03/26/2018	to	Fri 04/13/2018			(Import)
0500	Continuous	1730		CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 50 MW
					TTC with All Lines In Service 2975 MW
MOSES -ADIRNDCK_230_MA2					FWD
Mon 03/26/2018	to	Thu 03/29/2018			(Import)
0700	Continuous	1530		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW
DUNWODIE_345KV_7					FWD
Sat 03/31/2018	to	Sat 03/31/2018	UPDATED	by CE	09/22/2017
0230	Continuous	0300			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH
					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
DUNWODIE_345KV_8					FWD
Sat 03/31/2018	to	Sat 03/31/2018	UPDATED	by CE	09/22/2017
0230	Continuous	0300			(Import)
Work scheduled by: ConEd					SPR/DUN-SOUTH
					3800 MW
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
MOSES -ADIRNDCK_230_MA1					FWD
Mon 04/02/2018	to	Fri 04/06/2018			(Import)
0700	Continuous	1730		MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
MALONE__-WILLIS__115_1-910								REV
Tue 04/03/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>			(Export)
0700	Continuous	1530				SCH - HQ_CEDARS		60 MW
Work scheduled by: NYPA								40 MW
								TTC with All Lines In Service
								100 MW
<hr/>								
SHOR_NPX-SHOREHAM_138_CSC							FWD	REV
Wed 04/04/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by LI</u>	<u>11/08/2017</u>			(Import) (Export)
0600	Continuous	1800				SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI								Impacts Total Transfer Capability
								330 MW 330 MW
								TTC with All Lines In Service
								330 MW 330 MW
<hr/>								
LINDN_CG-LNDVFT__345_V-3022							FWD	REV
Sun 04/08/2018	to	Fri 04/13/2018						(Import) (Export)
1400	Continuous	1800				SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM								Impacts Total Transfer Capability
								315 MW 315 MW
								TTC with All Lines In Service
								315 MW 315 MW
<hr/>								
MOSES__-ADIRNDCK_230_MA1							FWD	
Mon 04/09/2018	to	Fri 04/13/2018						(Import)
0700	Continuous	1730				MOSES SOUTH	2300 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability
								850 MW
								TTC with All Lines In Service
								3150 MW
<hr/>								
FRASER__-GILBOA__345_GF5-35							FWD	
Mon 04/09/2018	to	Fri 04/20/2018						(Import)
0700	Continuous	1730				CENTRAL EAST - VC	2650 MW	
Work scheduled by: NYPA								Impacts Total Transfer Capability
								325 MW
								TTC with All Lines In Service
								2975 MW
<hr/>								
NEPTUNE_-DUFFYAVE_345_NEPTUNE							FWD	
Mon 04/16/2018	to	Tue 05/01/2018						(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: PJM								Impacts Total Transfer Capability
								660 MW
								TTC with All Lines In Service
								660 MW
<hr/>								
NEWBRDGE-DUFFYAVE_345_501							FWD	
Mon 04/16/2018	to	Tue 05/01/2018						(Import)
0001	Continuous	1800				SCH - PJM_NEPTUNE	0 MW	
Work scheduled by: PJM								Impacts Total Transfer Capability
								660 MW
								TTC with All Lines In Service
								660 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
NEWBRDGE_345_138_BK_1			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<hr/>			
NEWBRDGE_345_138_BK_2			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<hr/>			
MOSES__-ADIRNDCK_230_MA1			FWD
Mon 04/16/2018	to	Fri 04/20/2018	(Import)
0700	Continuous	1730	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
S.RIPLEY-DUNKIRK__230_68			FWD REV
Fri 04/20/2018	to	Sat 02/01/2020	(Import) (Export)
1600	Continuous	0000	SCH - PJ - NY 1950 MW 1350 MW
Work scheduled by: NYISO			Impacts Total Transfer Capability 350 MW 100 MW
			TTC with All Lines In Service 2300 MW 1450 MW
<hr/>			
MARCY__765_345_AT1			FWD
Mon 04/23/2018	to	Mon 04/23/2018	(Import)
0500	Continuous	1730	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
MOSES__-ADIRNDCK_230_MA2			FWD
Mon 04/30/2018	to	Fri 05/04/2018	(Import)
0700	Continuous	1530	MOSES SOUTH 2300 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<hr/>			
HURLYAVE-ROSETON__345_303			FWD
Mon 04/30/2018	to	Fri 05/25/2018	(Import)
0800	Continuous	1600	UPNY CONED 4100 MW
Work scheduled by: CHGE			Impacts Total Transfer Capability 1000 MW
			TTC with All Lines In Service 5100 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Wed 10/31/2018
 0001 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

NIAGARA_KINTIGH_345_NS1-38

Mon 05/07/2018 to Fri 05/11/2018
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES_ADIRNDCK_230_MA2

Mon 05/07/2018 to Fri 05/11/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MOSES_ADIRNDCK_230_MA2

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

CLAY_EDIC_345_1-16

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 OSWEGO EXPORT **4850 MW**
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

WETHSRFD-MEYER_230_85/87

Tue 05/15/2018 to Fri 06/01/2018
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

MARCY_765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 05/28/2018 to Fri 06/01/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P

Mon 05/28/2018 to Fri 06/01/2018
 0700 Continuous 2000
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
SCH - OH - NY 2000 MW 1600 MW
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 2000 MW 1600 MW

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1750 MW
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

FRASER_-GILBOA___345_GF5-35

Mon 09/10/2018 to Fri 10/05/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4400 MW
 Impacts Total Transfer Capability 700 MW
 TTC with All Lines In Service 5100 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA__345_230_AT4

Fri 09/14/2018 to Fri 09/14/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2000 MW 1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/17/2018 to Fri 09/21/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/17/2018 to Fri 09/21/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CLAY___-EDIC___345_2-15

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line	Start	End	Time	Day	Zone	FWD	REV
BECK	Mon 10/01/2018	Fri 10/05/2018	0500	Continuous	1700	(Import)	(Export)
Work scheduled by: NYPA						SCH - OH - NY	
						900 MW	800 MW
						Impacts Total Transfer Capability	1100 MW 800 MW
						TTC with All Lines In Service	2000 MW 1600 MW
MOSES	Mon 10/01/2018	Wed 10/03/2018	0700	Continuous	1530	(Import)	
Work scheduled by: NYPA						MOSES SOUTH	
						2100 MW	
						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
PANNELL	Mon 10/01/2018	Fri 10/05/2018	0700	Continuous	1700	(Import)	
Work scheduled by: NYPA						WEST CENTRAL	
						1300 MW	
						Impacts Total Transfer Capability	950 MW
						TTC with All Lines In Service	2250 MW
MARCY	Thu 10/04/2018	Fri 10/05/2018	0500	Continuous	1730	(Import)	
Work scheduled by: NYPA						MOSES SOUTH	
						1700 MW	
						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
						ARR: 19	
MOSES	Mon 10/08/2018	Fri 10/12/2018	0700	Continuous	1530	(Import)	
Work scheduled by: NYPA						MOSES SOUTH	
						2100 MW	
						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY- MASSENA	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	1730	(Import)	
Work scheduled by: NYPA						MOSES SOUTH	
						1550 MW	
						Impacts Total Transfer Capability	1600 MW
						TTC with All Lines In Service	3150 MW
CHATGUAY- MASSENA	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	1730	(Import)	(Export)
Work scheduled by: NYPA						SCH - HQ - NY	
						0 MW	0 MW
						Impacts Total Transfer Capability	1500 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100	Continuous	1730	MOSES SOUTH 1750 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1400 MW
			TTC with All Lines In Service 3150 MW
MARCY___765_345_AT2			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100	Continuous	1730	MOSES SOUTH 1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1450 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100	Continuous	1730	CENTRAL EAST - VC 2265 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 710 MW
			TTC with All Lines In Service 2975 MW
MASSENA_-MARCY___765_MSU1			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100	Continuous	1730	MOSES SOUTH 500 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import) (Export)
0100	Continuous	1730	SCH - HQ - NY 475 MW 1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability 1025 MW 0 MW
			TTC with All Lines In Service 1500 MW 1000 MW
MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA_765_7040			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100		1730	MOSES SOUTH 500 MW
Work scheduled by:			Impacts Total Transfer Capability 2650 MW
			TTC with All Lines In Service 3150 MW
MASSENA_-MARCY___765_MSU1 & MARCY_SO_SERIES_COMP_I/S			FWD
Sat 10/13/2018	to	Sat 10/27/2018	(Import)
0100		1730	CENTRAL EAST - VC 2080 MW
Work scheduled by:			Impacts Total Transfer Capability 895 MW
			TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -MASSENA_230_MMS1 & MOSES -MASSENA_230_MMS2

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

LEEDS -HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

KINTIGH -ROCHESTR_345_SRL-39

Mon 10/29/2018 to Fri 11/02/2018
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES -ADIRNDCK_230_MAL

Mon 10/29/2018 to Fri 11/02/2018
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

MOSES -ADIRNDCK_230_MAL

Mon 11/05/2018 to Fri 11/09/2018
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY_345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2925 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

MARCY_765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	1700 MW
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Friday ,December 08, 2017 to Sunday ,June 09, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 11/19/2018 to Wed 11/21/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 11/26/2018 to Fri 12/21/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1000 MW
 TTC with All Lines In Service 5100 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

ARR: 19

MOSES___-ADIRNDCK_230_MA1

Wed 12/26/2018 to Fri 12/28/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW