

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-HQ_LIMIT_800</b>					REV
Thu 06/08/2017	to	Sun 12/10/2017	<u>by HQ</u>	<u>12/08/2017</u>	(Export)
0600	Continuous	1800			<b>800 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1000 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>					FWD REV
Sat 10/28/2017	to	Mon 12/11/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>12/08/2017</u>
1501	Continuous	0859			(Import) (Export)
Work scheduled by: NYISO					<b>1950 MW 1350 MW</b>
					Impacts Total Transfer Capability 350 MW 100 MW
					TTC with All Lines In Service 2300 MW 1450 MW
<b>SCH-NYISO-IMO_LIMIT_1400</b>					REV
Wed 11/01/2017	to	Mon 04/30/2018			(Export)
0001	Continuous	2359			<b>1700 MW</b>
Work scheduled by: IESO					Impacts Total Transfer Capability 200 MW
					TTC with All Lines In Service 1900 MW
<b>MARION_-FARRAGUT_345_C3403</b>					FWD REV
Fri 11/17/2017	to	Sat 12/23/2017	<u>EXTENDED</u>	<u>by CE</u>	<u>11/28/2017</u>
0801	Continuous	0100			(Import) (Export)
Work scheduled by: ConEd					<b>2300 MW 1450 MW</b>
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2300 MW 1450 MW
<b>EGRDNCTY_345_138_AT1</b>					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			<b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
<b>EGRDNCTY_345_138_AT2</b>					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			<b>1250 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 1500 MW
<b>SPRNBRK_-EGRDNCTR_345_Y49</b>					FWD
Sun 11/19/2017	to	Sun 12/24/2017	<u>by CE</u>	<u>11/23/2017</u>	(Import)
0001	Continuous	0300			<b>775 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 725 MW
					TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>					FWD		
Mon 11/20/2017	to	Wed 12/06/2017	<b><u>EXTENDED</u></b>	<b><u>by HQ</u></b>	<b><u>12/08/2017</u></b>	(Import)	
1800	Continuous	0559				<b>2850 MW</b>	
Work scheduled by: HQ					MOSES SOUTH		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	3150 MW	
<b>CHAT_DC_GC2</b>					REV		
Mon 11/20/2017	to	Wed 12/06/2017	<b><u>EXTENDED</u></b>	<b><u>by HQ</u></b>	<b><u>12/08/2017</u></b>	(Export)	
1800	Continuous	0559				<b>500 MW</b>	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	500 MW	
					TTC with All Lines In Service	1000 MW	
<b>SCH-HQ-NYISO_LIMIT_1200</b>					FWD		
Mon 11/20/2017	to	Wed 12/06/2017	<b><u>EXTENDED</u></b>	<b><u>by HQ</u></b>	<b><u>12/08/2017</u></b>	(Import)	
1800	Continuous	0559				<b>1200 MW</b>	
Work scheduled by: HQ					SCH - HQ - NY		
					Impacts Total Transfer Capability	300 MW	
					TTC with All Lines In Service	1500 MW	
<b>E13THSTA-FARRAGUT_345_45</b>					FWD		
Sun 11/26/2017	to	Tue 05/15/2018		<b><u>by CE</u></b>	<b><u>12/06/2017</u></b>	(Import)	
0001	Continuous	2359				<b>3800 MW</b>	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD		
Sun 11/26/2017	to	Tue 05/15/2018		<b><u>by CE</u></b>	<b><u>12/06/2017</u></b>	(Import)	
0001	Continuous	2359				<b>3800 MW</b>	
Work scheduled by: ConEd					SPR/DUN-SOUTH		
					Impacts Total Transfer Capability	800 MW	
					TTC with All Lines In Service	4600 MW	
<b>CEDARS__-ROSEMNTB_115_2/22</b>					FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	<b><u>UPDATED</u></b>	<b><u>by HQ</u></b>	<b><u>11/22/2017</u></b>	(Import)	(Export)
0700	Continuous	1600				<b>95 MW</b>	<b>100 MW</b>
Work scheduled by: HQ					<b>ARR: 38</b>	SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	104 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW
<b>DENNISON-ROSEMNTB_115_2/22</b>					FWD	REV	
Mon 11/27/2017	to	Thu 12/07/2017	<b><u>UPDATED</u></b>	<b><u>by HQ</u></b>	<b><u>11/22/2017</u></b>	(Import)	(Export)
0700	Continuous	1600				<b>95 MW</b>	<b>100 MW</b>
Work scheduled by: HQ					<b>ARR: 38</b>	SCH - HQ_CEDARS	
					Impacts Total Transfer Capability	104 MW	0 MW
					TTC with All Lines In Service	199 MW	100 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>SCH-HQ_CEDARS-NYISO_LIMIT_100</b>							FWD	
Mon 11/27/2017	to	Thu 12/07/2017	<b>UPDATED</b>	<b>by HQ</b>	<b>11/22/2017</b>		(Import)	
0700	Continuous	1600				SCH - HQ_CEDARS	<b>100 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability	99 MW	
						TTC with All Lines In Service	199 MW	
<hr/>								
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>							FWD	
Sun 12/03/2017	to	Tue 12/05/2017					(Import)	
0001		0300				UPNY CONED	<b>3800 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service	5100 MW	
<hr/>								
<b>MARCY_SO_SERIES_COMP_I/S</b>							FWD	
Mon 12/04/2017	to	Fri 12/08/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>12/08/2017</b>		(Import)	
0001	Continuous	0318				CENTRAL EAST - VC	<b>2740 MW</b>	
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW	
						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>LEEDS___-PLSNTVLY_345_92</b>							FWD	
Mon 12/04/2017	to	Mon 12/18/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/12/2017</b>		(Import)	
0001	Continuous	0300				UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service	5100 MW	
<hr/>								
<b>PLSNTVLY_345KV_RNS5</b>							FWD	
Mon 12/04/2017	to	Mon 12/18/2017	<b>UPDATED</b>	<b>by NYISO</b>	<b>09/12/2017</b>		(Import)	
0001	Continuous	0300				UPNY CONED	<b>3800 MW</b>	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1300 MW	
						TTC with All Lines In Service	5100 MW	
<hr/>								
<b>MARCY___765_345_AT2</b>							FWD	
Mon 12/04/2017	to	Fri 12/08/2017	<b>UPDATED</b>	<b>by NYPA</b>	<b>11/13/2017</b>		(Import)	
0500	Continuous	1700				MOSES SOUTH	<b>1700 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW	
					<b>ARR: 19</b>	TTC with All Lines In Service	3150 MW	
<hr/>								
<b>NRTH1385-NOR HBR__138_601</b>							FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>12/07/2017</b>		(Import)	(Export)
0700	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_602</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018				
0700		2359				
Work scheduled by:			SCH - NPX_1385	0 MW	0 MW	
			Impacts Total Transfer Capability	200 MW	200 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>NRTH1385-NOR HBR__138_601 &amp; NRTH1385-NOR HBR__138_603</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018				
0700		2359				
Work scheduled by:			SCH - NPX_1385	0 MW	0 MW	
			Impacts Total Transfer Capability	200 MW	200 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>NRTH1385-NOR HBR__138_602</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>12/07/2017</u>	
0700	Continuous	2359				
Work scheduled by: LI			SCH - NPX_1385	100 MW	100 MW	
			Impacts Total Transfer Capability	100 MW	100 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>NRTH1385-NOR HBR__138_602 &amp; NRTH1385-NOR HBR__138_603</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018				
0700		2359				
Work scheduled by:			SCH - NPX_1385	0 MW	0 MW	
			Impacts Total Transfer Capability	200 MW	200 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>NRTH1385-NOR HBR__138_603</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>12/07/2017</u>	
0700	Continuous	2359				
Work scheduled by: LI			SCH - NPX_1385	100 MW	100 MW	
			Impacts Total Transfer Capability	100 MW	100 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>NRTH1385-NRTHPORT_138_NNC</b>					FWD	REV
Mon 12/04/2017	to	Fri 02/02/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>12/07/2017</u>	
0700	Continuous	2359				
Work scheduled by: LI			SCH - NPX_1385	0 MW	0 MW	
			Impacts Total Transfer Capability	200 MW	200 MW	
			TTC with All Lines In Service	200 MW	200 MW	
<b>LEEDS__345_LEEDS SVC</b>					FWD	
Mon 12/04/2017	to	Thu 12/07/2017	<u>EXTENDED</u>	<u>by NGRID</u>	<u>12/06/2017</u>	
0800	Continuous	1500				
Work scheduled by: NGrid			CENTRAL EAST - VC	2950 MW		
			Impacts Total Transfer Capability	25 MW		
			TTC with All Lines In Service	2975 MW		

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS\_\_\_\_345 LEEDS SVC & MARCY\_SO\_SERIES\_COMP\_I/S

FWD

Mon 12/04/2017 to Thu 12/07/2017  
0800 1500

(Import)

CENTRAL EAST - VC **2715 MW**  
Impacts Total Transfer Capability 260 MW  
TTC with All Lines In Service 2975 MW

Work scheduled by:

CHAT\_DC\_GC1

FWD

Wed 12/06/2017 to Wed 12/06/2017 UPDATED by HQ 12/05/2017  
0600 Daily 2300

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT\_DC\_GC1

REV

Wed 12/06/2017 to Wed 12/06/2017 UPDATED by HQ 12/05/2017  
0600 Daily 2300

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

Wed 12/06/2017 to Wed 12/06/2017  
0600 2300

(Import)

MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by:

CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

REV

Wed 12/06/2017 to Wed 12/06/2017  
0600 2300

(Import) (Export)

SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

CHAT\_DC\_GC2

FWD

Wed 12/06/2017 to Wed 12/06/2017 UPDATED by HQ 12/05/2017  
0600 Daily 2300

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT\_DC\_GC2

REV

Wed 12/06/2017 to Wed 12/06/2017 UPDATED by HQ 12/05/2017  
0600 Daily 2300

(Export)

SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-HQ-NYISO_LIMIT_700</b>						FWD	
Wed 12/06/2017	to	Wed 12/06/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0600	Daily	2300				SCH - HQ - NY	<b>700 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1500 MW
<b>CHAT_DC_GC1</b>						FWD	
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>							REV
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)	
0500	Daily	2000				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	
Fri 12/08/2017	to	Fri 12/08/2017				(Import)	
0500		2000				MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	REV
Fri 12/08/2017	to	Fri 12/08/2017				(Import) (Export)	
0500		2000				SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	130 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
<b>CHAT_DC_GC2</b>						FWD	
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>							REV
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)	
0500	Daily	2000				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-HQ-NYISO_LIMIT_700</b>						FWD	
Fri 12/08/2017	to	Fri 12/08/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0500	Daily	2000				SCH - HQ - NY	<b>700 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1500 MW
<b>SCH-IMO-NYISO_LIMIT_900</b>						FWD	
Fri 12/08/2017	to	Fri 12/08/2017				(Import)	
0515	Continuous	1730				SCH - OH - NY	<b>1200 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	550 MW
						TTC with All Lines In Service	1750 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>						FWD	
Fri 12/08/2017	to	Mon 12/18/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>12/08/2017</u>	(Import)	
0942	Continuous	0300				CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW
						TTC with All Lines In Service	2975 MW
<b>CHAT_DC_GC1</b>						FWD	
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)	
0600	Daily	2000				MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>							REV
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)	
0600	Daily	2000				SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	
Sat 12/09/2017	to	Sat 12/09/2017				(Import)	
0600		2000				MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	REV
Sat 12/09/2017	to	Sat 12/09/2017				(Import)	(Export)
0600		2000				SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	130 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						FWD
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	2000				<b>2850 MW</b>
Work scheduled by: HQ						MOSES SOUTH
						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>						REV
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Export)
0600	Daily	2000				<b>500 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>						FWD
Sat 12/09/2017	to	Sat 12/09/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	2000				<b>700 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1500 MW
<b>SCH-HQ-NYISO_LIMIT_800</b>						FWD
Sat 12/09/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
2001	Daily	0559				<b>800 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 700 MW
						TTC with All Lines In Service 1500 MW
<b>SCH-HQ-NYISO_LIMIT_700</b>						FWD
Sun 12/10/2017	to	Sun 12/10/2017	<u>UPDATED</u>	<u>by HQ</u>	<u>12/05/2017</u>	(Import)
0600	Daily	1800				<b>700 MW</b>
Work scheduled by: HQ						SCH - HQ - NY
						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 1500 MW
<b>SCH-IMO-NYISO_LIMIT_700</b>						FWD
Mon 12/11/2017	to	Thu 12/14/2017		<u>by NGRID</u>	<u>12/06/2017</u>	(Import)
0630	Continuous	1430				<b>1000 MW</b>
Work scheduled by: NGrid						SCH - OH - NY
						Impacts Total Transfer Capability 750 MW
						TTC with All Lines In Service 1750 MW
<b>NIAGARA_-KINTIGH_345_NS1-38</b>						FWD
Mon 12/11/2017	to	Wed 12/20/2017	<u>UPDATED</u>	<u>by NYISO</u>	<u>10/20/2017</u>	(Import)
0800	Continuous	1600				<b>1700 MW</b>
Work scheduled by: NYSEG						DYSINGER EAST
						Impacts Total Transfer Capability 1450 MW
						TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-PJM\_LIMIT\_100**

Mon 12/11/2017 to Fri 12/15/2017  
 0900 Continuous 1400  
 Work scheduled by: PJM

REV  
 (Export)  
**400 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 1450 MW

**CHAT\_DC\_GC2**

Tue 12/12/2017 to Tue 12/12/2017  
 0900 Continuous 1700  
 Work scheduled by: HQ

FWD  
 (Import)  
**2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC2**

Tue 12/12/2017 to Tue 12/12/2017  
 0900 Continuous 1700  
 Work scheduled by: HQ

REV  
 (Export)  
**500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**SCH-HQ-NYISO\_LIMIT\_1200**

Tue 12/12/2017 to Tue 12/12/2017  
 0900 Continuous 1700  
 Work scheduled by: HQ

FWD  
 (Import)  
**1200 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 1500 MW

**N.SCTLND-LEEDS\_\_\_345\_93**

Wed 12/13/2017 to Fri 12/15/2017  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD  
 (Import)  
**2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**CHAT\_DC\_GC1**

Wed 12/13/2017 to Wed 12/13/2017  
 0830 Continuous 1500  
 Work scheduled by: HQ

FWD  
 (Import)  
**2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Wed 12/13/2017 to Wed 12/13/2017  
 0830 Continuous 1500  
 Work scheduled by: HQ

REV  
 (Export)  
**500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Wed 12/13/2017	to	Wed 12/13/2017		(Import)
0830		1500	MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 600 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>				FWD
Wed 12/13/2017	to	Wed 12/13/2017		(Import) (Export)
0830		1500	SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:				Impacts Total Transfer Capability 130 MW 1000 MW
				TTC with All Lines In Service 1500 MW 1000 MW
<hr/>				
<b>CHAT_DC_GC2</b>				FWD
Wed 12/13/2017	to	Wed 12/13/2017		(Import)
0830	Continuous	1500	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 3150 MW
<hr/>				
<b>CHAT_DC_GC2</b>				REV
Wed 12/13/2017	to	Wed 12/13/2017		(Export)
0830	Continuous	1500	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 500 MW
				TTC with All Lines In Service 1000 MW
<hr/>				
<b>SCH-HQ-NYISO_LIMIT_700</b>				FWD
Wed 12/13/2017	to	Wed 12/13/2017		(Import)
0830	Continuous	1500	SCH - HQ - NY	<b>700 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1500 MW
<hr/>				
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD
Fri 12/15/2017	to	Mon 03/19/2018	<b>UPDATED by NYISO 12/08/2017</b>	(Import) (Export)
1400	Continuous	0959	SCH - PJ - NY	<b>1950 MW 1350 MW</b>
Work scheduled by: NYISO				Impacts Total Transfer Capability 350 MW 100 MW
				TTC with All Lines In Service 2300 MW 1450 MW
<hr/>				
<b>MOSES_-ADIRNDCK_230_MA2</b>				FWD
Mon 12/18/2017	to	Fri 12/22/2017	<b>CANCELLED by NYPA 12/07/2017</b>	(Import)
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>HURLYAVE-ROSETON__345_303</b>							
Tue 12/19/2017	to	Tue 12/19/2017					
0800	Daily	1600			UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	5100 MW
<b>HOPATCON-RAMAPO__500_5018</b>							
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>		
0200	Continuous	1700			SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	200 MW 450 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>HOPATCON-RAMAPO__500_5018</b>							
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>		
0200	Continuous	1700			UPNY CONED	<b>5000 MW</b>	
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	5100 MW
<b>HOPATCON-RAMAPO__500_5018 &amp; S.RIPLEY-DUNKIRK__230_68</b>							
Tue 12/26/2017	to	Thu 12/28/2017					
0200		1700			SCH - PJ - NY	<b>1200 MW</b>	<b>1300 MW</b>
Work scheduled by:						Impacts Total Transfer Capability	1100 MW 150 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>RAMAPO__345_345_PAR3500</b>							
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>		
0200	Continuous	1700			SCH - PJ - NY	<b>2200 MW</b>	<b>1450 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>RAMAPO__345_345_PAR4500</b>							
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>		
0200	Continuous	1700			SCH - PJ - NY	<b>2200 MW</b>	<b>1450 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	100 MW 0 MW
						TTC with All Lines In Service	2300 MW 1450 MW
<b>RAMAPO__500_345_BK 1500</b>							
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>		
0200	Continuous	1700			SCH - PJ - NY	<b>2100 MW</b>	<b>1000 MW</b>
Work scheduled by: PJM						Impacts Total Transfer Capability	200 MW 450 MW
						TTC with All Lines In Service	2300 MW 1450 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO___500_345_BK 1500</b>					FWD	
Tue 12/26/2017	to	Thu 12/28/2017	<b>UPDATED</b>	<b>by CE</b>	<b>10/27/2017</b>	(Import)
0200	Continuous	1700				<b>5000 MW</b>
Work scheduled by: PJM					UPNY CONED	
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	5100 MW
<hr/>						
<b>S.RIPLEY-DUNKIRK_230_68 &amp; RAMAPO___345_345_PAR3500</b>					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import) (Export)
0200		1700				<b>1450 MW 1250 MW</b>
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	850 MW 200 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
<b>S.RIPLEY-DUNKIRK_230_68 &amp; RAMAPO___345_345_PAR4500</b>					FWD	REV
Tue 12/26/2017	to	Thu 12/28/2017				(Import) (Export)
0200		1700				<b>1450 MW 1250 MW</b>
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability	850 MW 200 MW
					TTC with All Lines In Service	2300 MW 1450 MW
<hr/>						
<b>DUNWODIE-SHORE_RD_345_Y50</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				<b>800 MW</b>
Work scheduled by: ConEd					CONED - LIPA	
					Impacts Total Transfer Capability	700 MW
					TTC with All Lines In Service	1500 MW
<hr/>						
<b>DUNWODIE_345KV_4</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
<b>DUNWODIE_345KV_6</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<hr/>						
<b>SHORE_RD_345_138_BK 1</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<b>EXTENDED</b>	<b>by LI</b>	<b>09/22/2017</b>	(Import)
0001	Continuous	2359				<b>1350 MW</b>
Work scheduled by: ConEd					CONED - LIPA	
					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 2</b>					FWD	
Tue 01/02/2018	to	Thu 01/04/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>09/22/2017</u>	(Import)
0001	Continuous	2359				CONED - LIPA <b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 150 MW	TTC with All Lines In Service 1500 MW
<b>MOSES -ADIRNDCK_230_MAI</b>					FWD	
Tue 01/02/2018	to	Fri 01/05/2018				(Import)
0700	Continuous	1730				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 850 MW	TTC with All Lines In Service 3150 MW
<b>LEEDS -PLSNTVLY_345_92</b>					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Wed 01/03/2018	to	Sat 01/06/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
<b>PLSNTVLY_345KV_RN5 &amp; PLSNTVLY_345KV_RN4</b>					FWD	
Fri 01/05/2018	to	Sun 01/07/2018				(Import)
0001		2359				UPNY CONED <b>3800 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD	
Mon 01/08/2018	to	Wed 01/10/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>09/12/2017</u>	(Import)
0001	Continuous	0300				UPNY CONED <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1300 MW	TTC with All Lines In Service 5100 MW
<b>EASTVIEW-SPRNBK_345_W64</b>					FWD	
Mon 01/08/2018	to	Fri 02/23/2018				(Import)
0001	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW	TTC with All Lines In Service 5100 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W99</b>					FWD
Mon 01/08/2018	to	Fri 02/23/2018			(Import)
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 750 MW
					TTC with All Lines In Service 5100 MW
<b>SPRNBRK_345KV_RNS5</b>					FWD
Mon 01/08/2018	to	Fri 02/23/2018			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>MARCY_765_345_AT2</b>					FWD
Mon 01/08/2018	to	Sun 01/14/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>11/20/2017</b>
0500	Continuous	2100			
Work scheduled by: NYPA					(Import)
					MOSES SOUTH <b>1700 MW</b>
					Impacts Total Transfer Capability 1450 MW
					TTC with All Lines In Service 3150 MW
<b>FRASER-COOPERS_345_33</b>					FWD
Mon 01/08/2018	to	Thu 01/11/2018			(Import)
0800	Continuous	1500		CENTRAL EAST - VC	<b>2395 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability 580 MW
					TTC with All Lines In Service 2975 MW
<b>N.SCTLND-ALPS_345_2</b>					FWD
Mon 01/08/2018	to	Fri 02/02/2018	<b>UPDATED</b>	<b>by NG</b>	<b>10/17/2017</b>
0800	Continuous	1400			
Work scheduled by: NGrid					(Import) (Export)
					SCH - NE - NY <b>900 MW 1600 MW</b>
					Impacts Total Transfer Capability 500 MW 0 MW
					TTC with All Lines In Service 1400 MW 1600 MW
<b>N.SCTLND-ALPS_345_2</b>					FWD
Mon 01/08/2018	to	Fri 02/02/2018	<b>UPDATED</b>	<b>by NG</b>	<b>10/17/2017</b>
0800	Continuous	1400			
Work scheduled by: NGrid					(Import) (Export)
					SCH - NPX_1385 <b>100 MW 100 MW</b>
					Impacts Total Transfer Capability 100 MW 100 MW
					TTC with All Lines In Service 200 MW 200 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR HBR_138_601</b>					FWD
Mon 01/08/2018	to	Fri 02/02/2018			(Import) (Export)
0800		1400		SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 200 MW 200 MW
					TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS\_\_\_\_\_345\_2 & NRTH1385-NOR HBR\_\_138\_602

Mon 01/08/2018 to Fri 02/02/2018  
0800 1400

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

N.SCTLND-ALPS\_\_\_\_\_345\_2 & NRTH1385-NOR HBR\_\_138\_603

Mon 01/08/2018 to Fri 02/02/2018  
0800 1400

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

PLSNTVLY-EFISHKIL\_345\_F37

Thu 01/11/2018 to Fri 01/12/2018  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1100 MW
TTC with All Lines In Service	5100 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 01/15/2018 to Fri 01/19/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MARCY\_\_\_765\_345\_AT2

Sat 01/20/2018 to Sat 01/20/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 01/22/2018 to Fri 01/26/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 01/29/2018 to Fri 02/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT2</b>				FWD	
Sat 02/03/2018	to	Sat 02/03/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
<b>ARR: 19</b>					
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD	
Mon 02/05/2018	to	Fri 02/09/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>MOSES___-ADIRNDCK_230_MA2</b>				FWD	
Mon 02/12/2018	to	Fri 02/16/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>HUDSONP_-FARRAGUT_345_B3402</b>				FWD	REV
Sun 02/18/2018	to	Sun 04/01/2018		(Import)	(Export)
0001	Continuous	2359	SCH - PJ - NY	<b>2300 MW</b>	<b>1450 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	2300 MW	1450 MW
<b>MARCY___-EDIC___345_UE1-7</b>				FWD	
Tue 02/20/2018	to	Fri 02/23/2018		(Import)	
0500	Continuous	1730	OSWEGO EXPORT	<b>5250 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	0 MW	
			TTC with All Lines In Service	5250 MW	
<b>ARR: 19&amp;16</b>					
<b>MOSES___-ADIRNDCK_230_MA1</b>				FWD	
Tue 02/20/2018	to	Fri 02/23/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>DUNWODIE_345KV_7</b>				FWD	
Sat 02/24/2018	to	Sat 02/24/2018	<b>UPDATED</b>	(Import)	
0001	Continuous	0030	<b>by CE</b>		
Work scheduled by: ConEd			<b>09/22/2017</b>	SPR/DUN-SOUTH	<b>3800 MW</b>
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_8</b>					FWD		
Sat 02/24/2018	to	Sat 02/24/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0030				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service		
<b>DUNWODIE-MOTTHAVN_345_72</b>					FWD		
Sat 02/24/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CE</u>	<u>09/22/2017</u>	(Import)	
0001	Continuous	0300				3800 MW	
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW	
					Impacts Total Transfer Capability	4600 MW	
					TTC with All Lines In Service		
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018				(Import)	(Export)
0001	Continuous	0300				700 MW	1300 MW
Work scheduled by: ConEd					SCH - NE - NY	300 MW	300 MW
					Impacts Total Transfer Capability	1400 MW	1600 MW
					TTC with All Lines In Service		
<b>LONG_MTN-PLSNTVLY_345_398</b>					FWD	REV	
Mon 02/26/2018	to	Wed 05/02/2018				(Import)	(Export)
0001	Continuous	0300				100 MW	100 MW
Work scheduled by: ConEd					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>MOSES__-ADIRNDCK_230_MAI</b>					FWD		
Mon 02/26/2018	to	Fri 03/02/2018				(Import)	
0700	Continuous	1730				2300 MW	
Work scheduled by: NYPA					MOSES SOUTH	850 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MOSES__-ADIRNDCK_230_MAI</b>					FWD		
Mon 03/05/2018	to	Fri 03/09/2018				(Import)	
0700	Continuous	1730				2300 MW	
Work scheduled by: NYPA					MOSES SOUTH	850 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>MARCY__-N.SCTLND_345_18</b>					FWD		
Tue 03/06/2018	to	Wed 03/07/2018				(Import)	
0600	Continuous	1530				2090 MW	
Work scheduled by: NYPA					CENTRAL EAST - VC	885 MW	
					Impacts Total Transfer Capability	2975 MW	
					TTC with All Lines In Service		

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 03/12/2018 to Fri 03/16/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**S.RIPLEY-DUNKIRK\_230\_68**

Mon 03/19/2018 to Fri 04/20/2018  
 1000 Continuous 1559  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
**SCH - PJ - NY 1950 MW 1350 MW**  
 Impacts Total Transfer Capability 350 MW 100 MW  
 TTC with All Lines In Service 2300 MW 1450 MW

-----  
**MARCY\_\_\_345KV\_CSC**

Mon 03/26/2018 to Fri 04/13/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 03/26/2018 to Thu 03/29/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**DUNWODIE\_345KV\_7**

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED by CE 09/22/2017**  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**DUNWODIE\_345KV\_8**

Sat 03/31/2018 to Sat 03/31/2018 **UPDATED by CE 09/22/2017**  
 0230 Continuous 0300  
 Work scheduled by: ConEd

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 04/02/2018 to Fri 04/06/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>								
<b>MALONE__-WILLIS__115_1-910</b>								REV
Tue 04/03/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>			(Export)
0700	Continuous	1530				SCH - HQ_CEDARS		<b>60 MW</b>
Work scheduled by: NYPA				<b>ARR: 38</b>		Impacts Total Transfer Capability		40 MW
						TTC with All Lines In Service		100 MW
<hr/>								
<b>SHOR_NPX-SHOREHAM_138_CSC</b>								FWD REV
Wed 04/04/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by LI</u>	<u>11/08/2017</u>			(Import) (Export)
0600	Continuous	1800				SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW	330 MW
						TTC with All Lines In Service	330 MW	330 MW
<hr/>								
<b>LINDN_CG-LNDVFT__345_V-3022</b>								FWD REV
Sun 04/08/2018	to	Fri 04/13/2018				SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
1400	Continuous	1800				Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM						TTC with All Lines In Service	315 MW	315 MW
<hr/>								
<b>MOSES__-ADIRNDCK_230_MA1</b>								FWD
Mon 04/09/2018	to	Fri 04/13/2018				MOSES SOUTH	<b>2300 MW</b>	
0700	Continuous	1730				Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>FRASER__-GILBOA__345_GF5-35</b>								FWD
Mon 04/09/2018	to	Fri 04/20/2018				CENTRAL EAST - VC	<b>2650 MW</b>	
0700	Continuous	1730				Impacts Total Transfer Capability	325 MW	
Work scheduled by: NYPA						TTC with All Lines In Service	2975 MW	
<hr/>								
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>								FWD
Mon 04/16/2018	to	Tue 05/01/2018				SCH - PJM_NEPTUNE	<b>0 MW</b>	
0001	Continuous	1800				Impacts Total Transfer Capability	660 MW	
Work scheduled by: PJM						TTC with All Lines In Service	660 MW	
<hr/>								
<b>NEWBRDGE-DUFFYAVE_345_501</b>								FWD
Mon 04/16/2018	to	Tue 05/01/2018				SCH - PJM_NEPTUNE	<b>0 MW</b>	
0001	Continuous	1800				Impacts Total Transfer Capability	660 MW	
Work scheduled by: PJM						TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE_345_138_BK_1</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>	
Work scheduled by: PJM			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
<b>NEWBRDGE_345_138_BK_2</b>				FWD	
Mon 04/16/2018	to	Tue 05/01/2018		(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>	
Work scheduled by: PJM			Impacts Total Transfer Capability	285 MW	
			TTC with All Lines In Service	660 MW	
<b>MOSES__-ADIRNDCK_230_MA1</b>				FWD	
Mon 04/16/2018	to	Fri 04/20/2018		(Import)	
0700	Continuous	1730	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>S.RIPLEY-DUNKIRK__230_68</b>				FWD	REV
Fri 04/20/2018	to	Sat 02/01/2020	<b>UPDATED by NYISO 12/08/2017</b>	(Import)	(Export)
1600	Continuous	0000	SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	350 MW	100 MW
			TTC with All Lines In Service	2300 MW	1450 MW
<b>MARCY__765_345_AT1</b>				FWD	
Mon 04/23/2018	to	Mon 04/23/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1750 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
<b>MOSES__-ADIRNDCK_230_MA2</b>				FWD	
Mon 04/30/2018	to	Fri 05/04/2018		(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
<b>HURLYAVE-ROSETON__345_303</b>				FWD	
Mon 04/30/2018	to	Fri 05/25/2018	<b>CANCELLED by CHGE 12/07/2017</b>	(Import)	
0800	Continuous	1600	UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1000 MW	
			TTC with All Lines In Service	5100 MW	

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_SO\_SERIES\_COMP\_I/S**

Tue 05/01/2018 to Wed 10/31/2018  
 0001 Continuous 2359  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

**NIAGARA\_KINTIGH\_345\_NS1-38**

Mon 05/07/2018 to Fri 05/11/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_ADIRNDCK\_230\_MA2**

Mon 05/07/2018 to Fri 05/11/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**MOSES\_ADIRNDCK\_230\_MA2**

Mon 05/14/2018 to Fri 05/18/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

**CLAY\_EDIC\_345\_1-16**

Mon 05/14/2018 to Fri 05/18/2018  
 0700 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 OSWEGO EXPORT **4850 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 5250 MW

**WETHSRFD-MEYER\_230\_85/87**

Tue 05/15/2018 to Fri 06/01/2018  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 DYSINGER EAST **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Mon 05/21/2018 to Fri 05/25/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 05/28/2018 to Fri 06/01/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**STLAWRNC-MOSES\_\_\_230\_L33P**

Mon 05/28/2018 to Fri 06/01/2018  
 0700 Continuous 2000

Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - OH - NY 2000 MW 1600 MW**  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

-----  
**MARCY\_\_\_765\_345\_AT1**

Sat 08/04/2018 to Sun 08/05/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH 1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
**MOSES SOUTH 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**FRASER\_\_-GILBOA\_\_\_345\_GF5-35**

Mon 09/10/2018 to Fri 10/05/2018  
 0700 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

-----  
**ROSETON\_-ROCKTVRN\_345\_311**

Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4400 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MARCY\_\_\_345KV\_CSC**

Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

CLAY\_\_\_-EDIC\_\_\_345\_2-15

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BECK</b> -NIAGARA 345_PA302		FWD		REV
Mon 10/01/2018 to Fri 10/05/2018				(Import) (Export)
0500 Continuous 1700				
Work scheduled by: NYPA		SCH - OH - NY		<b>900 MW 800 MW</b>
		Impacts Total Transfer Capability		1100 MW 800 MW
		TTC with All Lines In Service		2000 MW 1600 MW
<hr/>				
<b>MOSES</b> -ADIRNDCK 230_MA2				FWD
Mon 10/01/2018 to Wed 10/03/2018				(Import)
0700 Continuous 1530				
Work scheduled by: NYPA		MOSES SOUTH		<b>2100 MW</b>
		Impacts Total Transfer Capability		1050 MW
		TTC with All Lines In Service		3150 MW
<hr/>				
<b>PANNELL</b> -CLAY 345_1				FWD
Mon 10/01/2018 to Fri 10/05/2018				(Import)
0700 Continuous 1700				
Work scheduled by: NYPA		WEST CENTRAL		<b>1300 MW</b>
		Impacts Total Transfer Capability		950 MW
		TTC with All Lines In Service		2250 MW
<hr/>				
<b>MARCY</b> 765_345_AT2				FWD
Thu 10/04/2018 to Fri 10/05/2018				(Import)
0500 Continuous 1730				
Work scheduled by: NYPA	<b>ARR: 19</b>	MOSES SOUTH		<b>1700 MW</b>
		Impacts Total Transfer Capability		1450 MW
		TTC with All Lines In Service		3150 MW
<hr/>				
<b>MOSES</b> -ADIRNDCK 230_MA1				FWD
Mon 10/08/2018 to Fri 10/12/2018				(Import)
0700 Continuous 1530				
Work scheduled by: NYPA		MOSES SOUTH		<b>2100 MW</b>
		Impacts Total Transfer Capability		1050 MW
		TTC with All Lines In Service		3150 MW
<hr/>				
<b>CHATGUAY-MASSENA</b> 765_7040				FWD
Sat 10/13/2018 to Sat 10/27/2018				(Import)
0100 Continuous 1730				
Work scheduled by: NYPA		MOSES SOUTH		<b>1550 MW</b>
		Impacts Total Transfer Capability		1600 MW
		TTC with All Lines In Service		3150 MW
<hr/>				
<b>CHATGUAY-MASSENA</b> 765_7040				FWD
Sat 10/13/2018 to Sat 10/27/2018				REV
0100 Continuous 1730				(Import) (Export)
Work scheduled by: NYPA		SCH - HQ - NY		<b>0 MW 0 MW</b>
		Impacts Total Transfer Capability		1500 MW 1000 MW
		TTC with All Lines In Service		1500 MW 1000 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>1750 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1400 MW
<b>ARR: 19</b>		TTC with All Lines In Service	3150 MW
<b>MARCY___765_345_AT2</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
<b>ARR: 19</b>		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	CENTRAL EAST - VC	<b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	710 MW
		TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD	REV
Sat 10/13/2018	to Sat 10/27/2018	(Import)	(Export)
0100	Continuous 1730	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	895 MW
		TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5100MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES -MASSENA\_230\_MMS1 & MOSES -MASSENA\_230\_MMS2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**LEEDS -HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1000 MW
TTC with All Lines In Service	5100 MW

-----  
**KINTIGH -ROCHESTR\_345\_SRL-39**

Mon 10/29/2018 to Fri 11/02/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA1**

Mon 10/29/2018 to Fri 11/02/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA1**

Mon 11/05/2018 to Fri 11/09/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2300 MW</b>
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

-----  
**MARCY\_345KV\_CSC**

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2925 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2975 MW

-----  
**MARCY\_765\_345\_AT2**

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Sunday ,December 10, 2017 to Tuesday ,June 11, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5100MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Mon 11/19/2018 to Wed 11/21/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**HURLYAVE-ROSETON\_\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
**UPNY CONED 4100 MW**  
 Impacts Total Transfer Capability 1000 MW  
 TTC with All Lines In Service 5100 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/03/2018 to Fri 12/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Mon 12/17/2018 to Fri 12/21/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**ARR: 19**

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Wed 12/26/2018 to Fri 12/28/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW