

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45						FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)	
0001	Continuous	2359				3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
W49TH_ST-E13THSTA_345_M54						FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)	
0001	Continuous	2359				3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
HUDSONP_-FARRAGUT_345_B3402						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/14/2018</u>	(Import)	(Export)
0001	Continuous	2359				2600 MW	1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018				(Import)	(Export)
0001		2359				2000 MW	1300 MW
Work scheduled by:						Impacts Total Transfer Capability	750 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
MARION_-FARRAGUT_345_C3403						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/14/2018</u>	(Import)	(Export)
0001	Continuous	2359				2600 MW	1300 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
S.RIPLEY-DUNKIRK_230_68						FWD	REV
Wed 02/07/2018	to	Mon 04/30/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>01/22/2018</u>	(Import)	(Export)
1629	Continuous	0959				2600 MW	1300 MW
Work scheduled by: NYISO						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
SCH-NYISO-NE_LIMIT_600							REV
Sun 02/25/2018	to	Mon 03/05/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/21/2018</u>		(Export)
0001	Continuous	1400					800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1600 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
LONG_MTN-PLSNTVLY_345_398					(Import)	(Export)
Mon 02/26/2018	to	Tue 05/01/2018	UPDATED	by ISONE 02/21/2018	SCH - NE - NY	700 MW
0001	Continuous	0300			Impacts Total Transfer Capability	700 MW
Work scheduled by: ConEd					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
LONG_MTN-PLSNTVLY_345_398					(Import)	(Export)
Mon 02/26/2018	to	Tue 05/01/2018	UPDATED	by ISONE 02/21/2018	SCH - NPX_1385	100 MW
0001	Continuous	0300			Impacts Total Transfer Capability	100 MW
Work scheduled by: ConEd					TTC with All Lines In Service	200 MW
<hr/>					FWD	
DUNWODIE-MOTTHAVN_345_72					(Import)	
Thu 03/01/2018	to	Fri 04/06/2018	EXTENDED	by CONED 03/05/2018	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0200			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
<hr/>						REV
SCH-NYISO-NE_LIMIT_500						(Export)
Sun 03/04/2018	to	Sun 03/04/2018	UPDATED	by ISONE 03/01/2018	SCH - NE - NY	700 MW
0001	Continuous	0219			Impacts Total Transfer Capability	900 MW
Work scheduled by: NYISO					TTC with All Lines In Service	1600 MW
<hr/>					FWD	
OSWEGO_COMPLEX_AVR_O/S					(Import)	
Sun 03/04/2018	to	Sun 03/04/2018			CENTRAL EAST - VC	2870 MW
0900	Continuous	1000			Impacts Total Transfer Capability	105 MW
Work scheduled by: Gen					TTC with All Lines In Service	2975 MW
<hr/>					FWD	
SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4					(Import)	
Mon 03/05/2018	to	Mon 03/05/2018			SPR/DUN-SOUTH	3800 MW
0001		0030			Impacts Total Transfer Capability	800 MW
Work scheduled by:					TTC with All Lines In Service	4600 MW
<hr/>					FWD	
RAMAPO__-LADENTWN_345_W72					(Import)	
Mon 03/05/2018	to	Mon 03/05/2018			UPNY CONED	4400 MW
0700	Continuous	2359			Impacts Total Transfer Capability	1300 MW
Work scheduled by: ConEd					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 03/05/2018 to Fri 03/09/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SCH-IMO-NYISO_LIMIT_1300

Mon 03/05/2018 to Tue 03/13/2018
0730 Continuous 1730

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1600 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1750 MW

SCH-NYISO-NE_LIMIT_500

Mon 03/05/2018 to Tue 05/01/2018 **UPDATED by ISONE 02/21/2018**
1400 Continuous 0300

Work scheduled by: ConEd

REV
(Export)
SCH - NE - NY **700 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 1600 MW

MARCY___-N.SCTLND_345_18

Tue 03/06/2018 to Wed 03/07/2018 **UPDATED by NYPA 02/16/2018**
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2090 MW**
Impacts Total Transfer Capability 885 MW
TTC with All Lines In Service 2975 MW

SCH-HQ_CEDARS-NYISO_LIMIT_160

Wed 03/07/2018 to Fri 03/23/2018
0001 Continuous 0500

Work scheduled by: HQ

FWD
(Import)
SCH - HQ_CEDARS **160 MW**
Impacts Total Transfer Capability 39 MW
TTC with All Lines In Service 199 MW

SPRNBK__345KV_RS3 & SPRNBK__345KV_RS4

Wed 03/07/2018 to Wed 03/07/2018
1700 1730

Work scheduled by:

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

OSWEGO___-VOLNEY___345_12

Thu 03/08/2018 to Sat 03/10/2018 **EXTENDED by NGRID 03/09/2018**
0700 Continuous 1600

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB							
Fri 03/09/2018	to	Fri 03/09/2018					
0500	Continuous	1700			SCH - OH - NY	1350 MW	1450 MW
Work scheduled by: NYPA						Impacts Total Transfer Capability	400 MW 450 MW
						TTC with All Lines In Service	1750 MW 1900 MW
CHAT_DC_GC1						FWD	
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)	
2300	Continuous	0400			MOSES SOUTH	2850 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC1							REV
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>		(Export)
2300	Continuous	0400			SCH - HQ - NY		500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2						FWD	
Sat 03/10/2018	to	Sun 03/11/2018				(Import)	
2300		0400			MOSES SOUTH	2550 MW	
Work scheduled by:						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2						FWD	REV
Sat 03/10/2018	to	Sun 03/11/2018				(Import)	(Export)
2300		0400			SCH - HQ - NY	1370 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	130 MW 1000 MW
						TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC2						FWD	
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)	
2300	Continuous	0400			MOSES SOUTH	2850 MW	
Work scheduled by: HQ						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC2							REV
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>		(Export)
2300	Continuous	0400			SCH - HQ - NY		500 MW
Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK						IMPACTS	
DATE	TIME	STATUS	BY	DATE	LOCATION	FWD	REV
SCH-HQ-NYISO_LIMIT_1200							
Sat 03/10/2018	to Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>		FWD	
2300	Continuous				SCH - HQ - NY	(Import)	
Work scheduled by: HQ						1200 MW	
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1500 MW
CHAT_DC_GC1							
Sun 03/11/2018	to Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>		FWD	
2300	Continuous				MOSES SOUTH	(Import)	
Work scheduled by: HQ						2850 MW	
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC1							
Sun 03/11/2018	to Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>			REV
2300	Continuous				SCH - HQ - NY		(Export)
Work scheduled by: HQ						500 MW	
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
CHAT_DC_GC1 & CHAT_DC_GC2							
Sun 03/11/2018	to Mon 03/12/2018					FWD	
2300				0300	MOSES SOUTH	(Import)	
Work scheduled by:						2550 MW	
						Impacts Total Transfer Capability	600 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC1 & CHAT_DC_GC2							
Sun 03/11/2018	to Mon 03/12/2018					FWD	REV
2300				0300	SCH - HQ - NY	(Import)	(Export)
Work scheduled by:						1370 MW	0 MW
						Impacts Total Transfer Capability	130 MW
						TTC with All Lines In Service	1500 MW
							1000 MW
CHAT_DC_GC2							
Sun 03/11/2018	to Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>		FWD	
2300	Continuous				MOSES SOUTH	(Import)	
Work scheduled by: HQ						2850 MW	
						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	3150 MW
CHAT_DC_GC2							
Sun 03/11/2018	to Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>			REV
2300	Continuous				SCH - HQ - NY		(Export)
Work scheduled by: HQ						500 MW	
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1200

Sun 03/11/2018 to Mon 03/12/2018
2300 Continuous 0300

UPDATED by HQ 03/09/2018

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1200 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1500 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 03/12/2018 to Mon 03/12/2018
0600 Continuous 1600

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

MOSES__-ADIRNDCK_230_MA1

Mon 03/12/2018 to Fri 03/16/2018
0700 Continuous 1730

CANCELLED by NYPA 03/05/2018

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MOSES__-ADIRNDCK_230_MA2

Mon 03/12/2018 to Fri 03/16/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SCH-IMO-NYISO_LIMIT_1300

Wed 03/14/2018 to Tue 03/27/2018
0600 Continuous 1630

UPDATED by NGRID 03/09/2018

Work scheduled by: NGrid

FWD
(Import)
SCH - OH - NY **1600 MW**
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1750 MW

LEEDS__345KV_R94301

Thu 03/15/2018 to Thu 03/15/2018
0800 Daily(No Weekends) 1430

Work scheduled by: NGrid

FWD
(Import)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 1900 MW
TTC with All Lines In Service 5700 MW

NINEMILE-CLAY__345_8

Fri 03/16/2018 to Fri 03/16/2018
2000 Continuous 2100

Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5150 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCRIBA -VOLNEY 345_21				FWD
Sat 03/17/2018	to	Sat 03/17/2018		(Import)
0600	Daily	1500	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
EASTVIEW-SPRNBK 345_W79				FWD
Mon 03/19/2018	to	Mon 03/19/2018	<u>UPDATED</u> <u>by CONED</u> <u>02/01/2018</u>	(Import)
0001	Continuous	0030	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
BUCHAN_N-EASTVIEW 345_W93				FWD
Mon 03/19/2018	to	Sun 03/25/2018	<u>UPDATED</u> <u>by CONED</u> <u>02/01/2018</u>	(Import)
0001	Continuous	0200	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
RAMAPO -BUCHAN_N 345_Y94				FWD
Mon 03/19/2018	to	Fri 03/30/2018	<u>UPDATED</u> <u>by CONED</u> <u>02/01/2018</u>	(Import)
0001	Continuous	0100	UPNY CONED	4800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 5700 MW
W49TH_ST_345KV_6				FWD
Mon 03/19/2018	to	Tue 03/20/2018	<u>UPDATED</u> <u>by CONED</u> <u>01/02/2018</u>	(Import)
0200	Continuous	0200	SCH - PJM_HTP	350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8				FWD
Mon 03/19/2018	to	Tue 03/20/2018	<u>UPDATED</u> <u>by CONED</u> <u>01/02/2018</u>	(Import)
0200	Continuous	0200	SCH - PJM_HTP	350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
NINEMILE-CLAY 345_8				FWD
Tue 03/20/2018	to	Tue 03/20/2018		(Import)
1730	Continuous	1830	OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6					FWD	
Wed 03/21/2018	to	Wed 03/21/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>01/02/2018</u>	(Import)
0100	Continuous	0200				350 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 310 MW
						TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8					FWD	
Wed 03/21/2018	to	Wed 03/21/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>01/02/2018</u>	(Import)
0100	Continuous	0200				350 MW
Work scheduled by: ConEd					SCH - PJM_HTP	Impacts Total Transfer Capability 310 MW
						TTC with All Lines In Service 660 MW
HANAWAFL-COLTON__115_5					FWD	REV
Wed 03/21/2018	to	Wed 03/21/2018				(Import) (Export)
0600	Continuous	1200				150 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 49 MW 0 MW
						TTC with All Lines In Service 199 MW 100 MW
LAWRNCAV-HANAWAFL_115_5					FWD	REV
Wed 03/21/2018	to	Wed 03/21/2018				(Import) (Export)
0600	Continuous	1200				150 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 49 MW 0 MW
						TTC with All Lines In Service 199 MW 100 MW
DENNISON-LAWRNCAV_115_5					FWD	REV
Wed 03/21/2018	to	Sat 03/24/2018				(Import) (Export)
0600	Continuous	1500				150 MW 100 MW
Work scheduled by: NGrid					SCH - HQ_CEDARS	Impacts Total Transfer Capability 49 MW 0 MW
						TTC with All Lines In Service 199 MW 100 MW
VOLNEY__-CLAY__345_6					FWD	
Thu 03/22/2018	to	Thu 03/22/2018				(Import)
0730	Daily(No Weekends)	1700				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
CHATGUAY-MASSENA__765_7040					FWD	
Sat 03/24/2018	to	Wed 03/28/2018				(Import)
0001	Continuous	1800				1550 MW
Work scheduled by: HQ					MOSES SOUTH	Impacts Total Transfer Capability 1600 MW
						TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Work Scheduled by	SCH	FWD (Import)	REV (Export)
CHATGUAY-MASSENA__765_7040				
Sat 03/24/2018 to Wed 03/28/2018		SCH - HQ - NY	0 MW	0 MW
0001 Continuous 1800		Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: HQ		TTC with All Lines In Service	1500 MW	1000 MW
MARCY__345KV_CSC				
Mon 03/26/2018 to Fri 04/13/2018		CENTRAL EAST - VC	2925 MW	
0500 Continuous 1730		Impacts Total Transfer Capability	50 MW	
Work scheduled by: NYPA		TTC with All Lines In Service	2975 MW	
MOSES__-ADIRNDCK_230_MA2				
Mon 03/26/2018 to Thu 03/29/2018		MOSES SOUTH	2300 MW	
0700 Continuous 1530		Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA		TTC with All Lines In Service	3150 MW	
SCH-NYISO-HQ_CEDARS_LIMIT_0				
Mon 03/26/2018 to Fri 04/13/2018		SCH - HQ_CEDARS		0 MW
0800 Continuous 1600		Impacts Total Transfer Capability		100 MW
Work scheduled by: HQ		TTC with All Lines In Service		100 MW
MAINESBG-WATRCURE_345_30				
Mon 03/26/2018 to Tue 03/27/2018		SCH - PJ - NY	2000 MW	1300 MW
0900 Daily 1530		Impacts Total Transfer Capability	750 MW	0 MW
Work scheduled by: NYSEG		TTC with All Lines In Service	2750 MW	1300 MW
LONG_MTN-PLSNTVLY_345_398 & NRTH1385-NOR HBR__138_601				
Wed 03/28/2018 to Sat 03/31/2018		SCH - NPX_1385	0 MW	0 MW
0600 2359		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:		TTC with All Lines In Service	200 MW	200 MW
LONG_MTN-PLSNTVLY_345_398 & NRTH1385-NOR HBR__138_602				
Wed 03/28/2018 to Sat 03/31/2018		SCH - NPX_1385	0 MW	0 MW
0600 2359		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:		TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
LONG_MTN-PLSNTVLY_345_398 & NRTH1385-NOR HBR__138_603				
Wed 03/28/2018	to	Sat 03/31/2018		
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601				
Wed 03/28/2018	to	Sat 03/31/2018		
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602				
Wed 03/28/2018	to	Sat 03/31/2018		
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603				
Wed 03/28/2018	to	Sat 03/31/2018		
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602				
Wed 03/28/2018	to	Sat 03/31/2018		
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603				
Wed 03/28/2018	to	Sat 03/31/2018		
0600		2359	SCH - NPX_1385	0 MW 0 MW
Work scheduled by:			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603				
Wed 03/28/2018	to	Sat 03/31/2018		
0600	Continuous	2359	SCH - NPX_1385	100 MW 100 MW
Work scheduled by: LI			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NRTHPORT_138_NNC							
Wed 03/28/2018	to	Sat 03/31/2018					
0600	Continuous	2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
EASTVIEW-SPRNBK_345_W79						FWD	
Fri 03/30/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>02/01/2018</u>	(Import)	
0001	Continuous	0200			UPNY CONED	4350 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
BUCHAN_N-EASTVIEW_345_W93						FWD	
Fri 03/30/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>02/01/2018</u>	(Import)	
0001	Continuous	0200			UPNY CONED	4350 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
EASTVIEW-SPRNBK_345_W79						FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>02/01/2018</u>	(Import)	
0001	Continuous	0200			UPNY CONED	4350 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1350 MW
						TTC with All Lines In Service	5700 MW
RAMAPO_-BUCHAN_N_345_Y94						FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>02/01/2018</u>	(Import)	
0001	Continuous	0200			UPNY CONED	4800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	5700 MW
SHOR_NPX-SHOREHAM_138_CSC						FWD	REV
Mon 04/02/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NE</u>	<u>02/15/2018</u>	(Import)	(Export)
0700	Continuous	1700			SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	330 MW
						TTC with All Lines In Service	330 MW
MOSES_-ADIRNDCK_230_MAL						FWD	
Mon 04/02/2018	to	Fri 04/06/2018				(Import)	
0700	Continuous	1730			MOSES SOUTH	2300 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>VOLNEY__-MARCY__345_19</p> <p>Mon 04/02/2018 to Mon 04/02/2018 0800 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2825 MW</p> <p>Impacts Total Transfer Capability 150 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>VOLNEY__-MARCY__345_19</p> <p>Mon 04/02/2018 to Mon 04/02/2018 0800 Daily(No Weekends) 1630</p> <p>Work scheduled by: NGrid</p>	<p>ARR: 19</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4900 MW</p> <p>Impacts Total Transfer Capability 350 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>MALONE__-WILLIS__115_1-910</p> <p>Tue 04/03/2018 to Tue 04/03/2018 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p>UPDATED by NYPA 11/20/2017</p> <p>ARR: 38</p>	<p style="text-align: right;">REV (Export)</p> <p>SCH - HQ_CEDARS 60 MW</p> <p>Impacts Total Transfer Capability 40 MW</p> <p>TTC with All Lines In Service 100 MW</p>
<p>SHOR_NPX-SHOREHAM_138_CSC</p> <p>Wed 04/04/2018 to Thu 04/12/2018 0600 Continuous 1700</p> <p>Work scheduled by: LI</p>	<p>UPDATED by NE 02/15/2018</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - NPX_CSC 0 MW 0 MW</p> <p>Impacts Total Transfer Capability 330 MW 330 MW</p> <p>TTC with All Lines In Service 330 MW 330 MW</p>
<p>GILBOA__-N.SCTLND_345_GNS-1</p> <p>Thu 04/05/2018 to Thu 04/05/2018 0830 Daily(No Weekends) 1300</p> <p>Work scheduled by: NGrid</p>		<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2520 MW</p> <p>Impacts Total Transfer Capability 455 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>DUNWODIE_345KV_7</p> <p>Fri 04/06/2018 to Fri 04/06/2018 0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>EXTENDED by CONED 03/05/2018</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>
<p>DUNWODIE_345KV_8</p> <p>Fri 04/06/2018 to Fri 04/06/2018 0130 Continuous 0200</p> <p>Work scheduled by: ConEd</p>	<p>EXTENDED by CONED 03/05/2018</p>	<p style="text-align: right;">FWD (Import)</p> <p>SPR/DUN-SOUTH 3800 MW</p> <p>Impacts Total Transfer Capability 800 MW</p> <p>TTC with All Lines In Service 4600 MW</p>

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Line ID	Start Date	End Date	Time	Work by	Direction	Impact	TTC
LINDN_CG-LNDVFT_345_V-3022	Sun 04/08/2018	Fri 04/13/2018	1400 - 1800	PJM	FWD (Import)	SCH - PJM_VFT	0 MW
						Impacts Total Transfer Capability	315 MW
						TTC with All Lines In Service	315 MW
BECK--NIAGARA_345_PA302	Mon 04/09/2018	Fri 04/13/2018	0500 - 1700	NYPA	FWD (Import)	SCH - OH - NY	1100 MW
						Impacts Total Transfer Capability	650 MW
						TTC with All Lines In Service	1750 MW
MOSES--ADIRNDCK_230_MA1	Mon 04/09/2018	Fri 04/13/2018	0700 - 1730	NYPA	FWD (Import)	MOSES SOUTH	2300 MW
						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
FRASER--GILBOA_345_GF5-35	Mon 04/09/2018	Fri 04/20/2018	0700 - 1730	NYPA	FWD (Import)	CENTRAL EAST - VC	2650 MW
						Impacts Total Transfer Capability	325 MW
						TTC with All Lines In Service	2975 MW
PLSNTVLE-DUNWODIE_345_W89	Fri 04/13/2018	Fri 04/13/2018	0001 - 0100	ConEd	FWD (Import)	UPNY CONED	4000 MW
						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
EFISHKIL-WOOD_ST_345_F38	Fri 04/13/2018	Fri 04/13/2018	0001 - 2330	ConEd	FWD (Import)	UPNY CONED	4000 MW
						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
WOOD_ST--PLSNTVLE_345_Y86	Fri 04/13/2018	Fri 04/13/2018	0001 - 2330	ConEd	FWD (Import)	UPNY CONED	4000 MW
						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89			FWD
Fri 04/13/2018	to	Fri 04/13/2018	(Import)
2230	Continuous	2330	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW
WOOD_ST_-PLSNTVLE_345_Y87			FWD
Mon 04/16/2018	to	Mon 04/16/2018	(Import)
0001	Continuous	0100	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW
PLSNTVLE-DUNWODIE_345_W90			FWD
Mon 04/16/2018	to	Wed 04/18/2018	(Import)
0001	Continuous	2330	UPNY CONED 4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability 1700 MW
			TTC with All Lines In Service 5700 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
NEWBRDGE-DUFFYAVE_345_501			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_1			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
NEWBRDGE_345_138_BK_2			FWD
Mon 04/16/2018	to	Tue 05/01/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA1

Mon 04/16/2018 to Fri 04/20/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER 345_FRASER SVC

Mon 04/16/2018 to Fri 04/20/2018
0800 Continuous 1659

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2935 MW**
Impacts Total Transfer Capability 40 MW
TTC with All Lines In Service 2975 MW

CHAT_DC_GC1

Mon 04/16/2018 to Fri 05/25/2018
1700 Continuous 1800

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Mon 04/16/2018 to Fri 05/25/2018
1700 Continuous 1800

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

WOOD_ST_-PLSNTVLE_345_Y87

Wed 04/18/2018 to Wed 04/18/2018
2230 Continuous 2330

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST_345_F39

Fri 04/20/2018 to Fri 04/20/2018
0001 Continuous 0100

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y87

Fri 04/20/2018 to Sun 04/22/2018
0001 Continuous 2329

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 1700 MW
TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST_345_F39				FWD	
Sun 04/22/2018	to	Sun 04/22/2018		(Import)	
2230	Continuous	2329	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	<u>UPDATED</u> <u>by CONED</u> <u>02/01/2018</u>	(Import)	
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
EASTVIEW-SPRNBK_345_W79				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	<u>UPDATED</u> <u>by CONED</u> <u>02/01/2018</u>	(Import)	
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
MARCY_765_345_AT1				FWD	
Mon 04/23/2018	to	Mon 04/23/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
EDIC-N.SCTLND_345_14				FWD	
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	
0600	Continuous	1800	CENTRAL EAST - VC	2240 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	735 MW	
			TTC with All Lines In Service	2975 MW	
PLSNTVLE-DUNWODIE_345_W89				FWD	
Tue 04/24/2018	to	Thu 04/26/2018		(Import)	
0001	Continuous	2330	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
LOWVILLE-BOONVILLE_115_5				FWD	REV
Tue 04/24/2018	to	Tue 04/24/2018		(Import)	(Export)
0800	Daily(No Weekends)	1430	SCH - HQ_CEDARS	199 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	0 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Frequency	Duration	Work Scheduled by	Notes	Impact	FWD	REV
BULYMO__-BOONVILLE_115_6	Wed 04/25/2018	Wed 04/25/2018	0800	Daily	(No Weekends)	1430			(Import)	(Export)
							ARR: 38	SCH - HQ_CEDARS	199 MW	100 MW
								Impacts Total Transfer Capability	0 MW	0 MW
								TTC with All Lines In Service	199 MW	100 MW
OAKDALE_-FRASER___345_32	Thu 04/26/2018	Fri 04/27/2018	0700	Continuous		1700	<u>UPDATED</u> <u>by NYSEG</u> <u>03/09/2018</u>		(Import)	
								CENTRAL EAST - VC	2650 MW	
								Impacts Total Transfer Capability	325 MW	
								TTC with All Lines In Service	2975 MW	
MOSES__-ADIRNDCK_230_MA2	Mon 04/30/2018	Fri 05/04/2018	0700	Continuous		1530			(Import)	
								MOSES SOUTH	2300 MW	
								Impacts Total Transfer Capability	850 MW	
								TTC with All Lines In Service	3150 MW	
HOMRC_NY-MAINS_NY_345_47	Mon 04/30/2018	Fri 05/25/2018	0700	Continuous		1730			(Import)	(Export)
								SCH - PJ - NY	2500 MW	1300 MW
								Impacts Total Transfer Capability	250 MW	0 MW
								TTC with All Lines In Service	2750 MW	1300 MW
MARCY_SO_SERIES_COMP_I/S	Tue 05/01/2018	Mon 05/21/2018	0001	Continuous		0559			(Import)	
								CENTRAL EAST - VC	2740 MW	
								Impacts Total Transfer Capability	235 MW	
								TTC with All Lines In Service	2975 MW	
S.RIPLEY-DUNKIRK__230_68	Tue 05/01/2018	Sat 06/02/2018	1000	Continuous		1600	<u>UPDATED</u> <u>by PJM</u> <u>01/22/2018</u>		(Import)	(Export)
								SCH - PJ - NY	1950 MW	1350 MW
								Impacts Total Transfer Capability	150 MW	0 MW
								TTC with All Lines In Service	2100 MW	1350 MW
PLSNTVLY-WOOD_ST__345_F30	Wed 05/02/2018	Wed 05/02/2018	0001	Continuous		0100			(Import)	
								UPNY CONED	4000 MW	
								Impacts Total Transfer Capability	1700 MW	
								TTC with All Lines In Service	5700 MW	

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N. SCTLND-ALPS_____345_2			FWD	REV
			(Import)	(Export)
Wed 05/02/2018	to	Fri 05/04/2018		
0800	Continuous	1500	SCH - NE - NY	750 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	650 MW
			TTC with All Lines In Service	1400 MW
				1600 MW
N. SCTLND-ALPS_____345_2			FWD	REV
			(Import)	(Export)
Wed 05/02/2018	to	Fri 05/04/2018		
0800	Continuous	1500	SCH - NPX_1385	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
				200 MW
PLSNTVLY-WOOD_ST__345_F30			FWD	
			(Import)	
Fri 05/04/2018	to	Fri 05/04/2018		
2230	Continuous	2330	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
SCH-NYISO-NE_LIMIT_800				REV
				(Export)
Sun 05/06/2018	to	Sun 05/06/2018		
0600	Continuous	1900	SCH - NE - NY	1000 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1600 MW
NIAGARA_-KINTIGH__345_NS1-38			FWD	
			(Import)	
Mon 05/07/2018	to	Fri 05/11/2018		
0500	Continuous	1700	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
MOSES_-ADIRNDCK_230_MA2			FWD	
			(Import)	
Mon 05/07/2018	to	Fri 05/11/2018		
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
N. SCTLND-LEEDS_____345_93			FWD	
			(Import)	
Mon 05/07/2018	to	Fri 05/11/2018		
0800	Continuous	1500	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_800

Mon 05/07/2018 to Wed 05/23/2018
 0800 Continuous 1900
 Work scheduled by: ISONE

REV (Export) 1000 MW
 SCH - NE - NY
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1600 MW

ERIE E -S.RIPLEY_230_69 & WETHSRFD-MEYER 230_85/87

Sat 05/12/2018 to Fri 06/01/2018
 0700 1500
 Work scheduled by:

FWD (Import) 2850 MW
 DYSINGER EAST
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

WETHSRFD-MEYER 230_85/87

Sat 05/12/2018 to Fri 06/01/2018 **UPDATED by NYSEG 02/15/2018**
 0700 Continuous 1500
 Work scheduled by: NYSEG

FWD (Import) 2850 MW
 DYSINGER EAST
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA2

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD (Import) 2100 MW
 MOSES SOUTH
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

CLAY -EDIC 345_1-16

Mon 05/14/2018 to Fri 05/18/2018
 0700 Continuous 1700
 Work scheduled by: NYPA

FWD (Import) 4850 MW
 OSWEGO EXPORT
 Impacts Total Transfer Capability 400 MW
 TTC with All Lines In Service 5250 MW

N. SCTLND-LEEDS 345_94

Mon 05/14/2018 to Mon 05/14/2018
 0730 Daily(No Weekends) 1500
 Work scheduled by: NGrid

FWD (Import) 2650 MW
 CENTRAL EAST - VC
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

FROST_BR-LONG_MTN_345_352

Thu 05/17/2018 to Tue 05/22/2018
 0730 Continuous 1600
 Work scheduled by: ISONE

FWD REV (Import) (Export) 1150 MW 1600 MW
 SCH - NE - NY
 Impacts Total Transfer Capability 250 MW 0 MW
 TTC with All Lines In Service 1400 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

SCH-HQ-NYISO_LIMIT_1400

Mon 05/21/2018 to Fri 05/25/2018
0600 Continuous 1800

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1400 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1500 MW

FRASANNX-COOPERS__345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
0600 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANNX_345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MAI

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 2000

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1600 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2000 MW 1600 MW

MARCY_SO_SERIES_COMP_I/S

Fri 06/01/2018 to Wed 10/31/2018
1800 Continuous 2359

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
S.RIPLEY-DUNKIRK__230_68					
Sat 06/02/2018	to	Sat 02/01/2020	UPDATED by NYISO 01/22/2018		
1600	Continuous	0000			
Work scheduled by: NYISO				SCH - PJ - NY	
				Impacts Total Transfer Capability	1950 MW 1350 MW
				TTC with All Lines In Service	2100 MW 1350 MW
MARCY___765_345_AT1					
Sat 08/04/2018	to	Sun 08/05/2018			
0500	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	1750 MW
				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	3150 MW
MARCY___765_345_AT2					
Tue 09/04/2018	to	Sun 09/09/2018			
0500	Continuous	1730			
Work scheduled by: NYPA				MOSES SOUTH	1700 MW
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
CLRKSCRN-OAKDALE__345_36					
Thu 09/06/2018	to	Fri 09/07/2018			
0700	Continuous	1530			
Work scheduled by: NYSEG				CENTRAL EAST - VC	2650 MW
				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
FRASER__-GILBOA__345_GF5-35					
Mon 09/10/2018	to	Fri 10/05/2018			
0700	Continuous	1730			
Work scheduled by: NYPA				CENTRAL EAST - VC	2650 MW
				Impacts Total Transfer Capability	325 MW
				TTC with All Lines In Service	2975 MW
ROSETON_-ROCKTVRN_345_311					
Mon 09/10/2018	to	Fri 09/28/2018			
0800	Continuous	1600			
Work scheduled by: CHGE				UPNY CONED	4400 MW
				Impacts Total Transfer Capability	1300 MW
				TTC with All Lines In Service	5700 MW
MARCY___345KV_CSC					
Tue 09/11/2018	to	Tue 09/11/2018			
0500	Continuous	1730			
Work scheduled by: NYPA				CENTRAL EAST - VC	2925 MW
				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA__345_230_AT4

Fri 09/14/2018 to Fri 09/14/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2000 MW 1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/17/2018 to Fri 09/21/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/17/2018 to Fri 09/21/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CLAY___-EDIC___345_2-15

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Transfer ID	Start Date	End Date	Time	Duration	Work Scheduled by	Transfer Type	Impact	TTC
BECK - NIAGARA 345_PA302	Mon 10/01/2018	Fri 10/05/2018	0500	Continuous	1700	NYPA	SCH - OH - NY	900 MW
							Impacts Total Transfer Capability	1100 MW
							TTC with All Lines In Service	2000 MW
MOSES - ADIRNDCK 230_MA2	Mon 10/01/2018	Wed 10/03/2018	0700	Continuous	1530	NYPA	MOSES SOUTH	2100 MW
							Impacts Total Transfer Capability	1050 MW
							TTC with All Lines In Service	3150 MW
PANNELL - CLAY 345_1	Mon 10/01/2018	Fri 10/05/2018	0700	Continuous	1700	NYPA	WEST CENTRAL	1300 MW
							Impacts Total Transfer Capability	950 MW
							TTC with All Lines In Service	2250 MW
HUDSONP - FARRAGUT 345_B3402	Tue 10/02/2018	Tue 11/13/2018	0001	Continuous	2359	PJM	SCH - PJ - NY	2100 MW
							Impacts Total Transfer Capability	0 MW
							TTC with All Lines In Service	2100 MW
MARCY 765_345_AT2	Thu 10/04/2018	Fri 10/05/2018	0500	Continuous	1730	NYPA	MOSES SOUTH	1700 MW
							Impacts Total Transfer Capability	1450 MW
							TTC with All Lines In Service	3150 MW
								ARR: 19
MOSES - ADIRNDCK 230_MA1	Mon 10/08/2018	Fri 10/12/2018	0700	Continuous	1530	NYPA	MOSES SOUTH	2100 MW
							Impacts Total Transfer Capability	1050 MW
							TTC with All Lines In Service	3150 MW
CHAT_DC_GC2	Mon 10/08/2018	Fri 11/23/2018	0700	Continuous	1700	HQ	MOSES SOUTH	2850 MW
							Impacts Total Transfer Capability	300 MW
							TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Zone	Start Date	End Date	Time	Day	Work Scheduled by	Impact	TTC	REV	
CHAT_DC_GC2	Mon 10/08/2018	Fri 11/23/2018	0700	Continuous	HQ	SCH - HQ - NY	500 MW	(Export)	
	Work scheduled by: HQ						Impacts Total Transfer Capability	500 MW	
							TTC with All Lines In Service	1000 MW	
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1550 MW	(Import)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	1600 MW	
							TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	SCH - HQ - NY	0 MW	(Import) (Export)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW	1000 MW
							TTC with All Lines In Service	1500 MW	1000 MW
MARCY_765_345_AT1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1750 MW	(Import)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	1400 MW	
							TTC with All Lines In Service	3150 MW	
ARR: 19									
MARCY_765_345_AT2	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1700 MW	(Import)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW	
							TTC with All Lines In Service	3150 MW	
ARR: 19									
MASSENA_-MARCY_765_MSU1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	CENTRAL EAST - VC	2265 MW	(Import)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	710 MW	
							TTC with All Lines In Service	2975 MW	
MASSENA_-MARCY_765_MSU1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	500 MW	(Import)	
	Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
							TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Zone	FWD	REV
MASSENA -MARCY 765_MSU1	Sat 10/13/2018	Sat 10/27/2018		(Import)	(Export)
0100 Continuous 1730			SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW	0 MW
			TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 10/13/2018	Sat 10/27/2018		(Import)	
0100 1730			MOSES SOUTH	500 MW	
Work scheduled by:			Impacts Total Transfer Capability	2650 MW	
			TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S	Sat 10/13/2018	Sat 10/27/2018		(Import)	
0100 1730			CENTRAL EAST - VC	2080 MW	
Work scheduled by:			Impacts Total Transfer Capability	895 MW	
			TTC with All Lines In Service	2975 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 10/13/2018	Sat 10/27/2018		(Import)	(Export)
0100 1730			SCH - HQ - NY	850 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW	1000 MW
			TTC with All Lines In Service	1500 MW	1000 MW
LEEDS -HURLYAVE 345_301	Mon 10/22/2018	Fri 11/16/2018		(Import)	
0800 Continuous 1600			UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	5700 MW	
KINTIGH -ROCHESTR 345_SR1-39	Mon 10/29/2018	Fri 11/02/2018		(Import)	
0500 Continuous 1700			DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
MOSES -ADIRNDCK 230_MAI	Mon 10/29/2018	Fri 11/02/2018		(Import)	
0700 Continuous 1530			MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 11/05/2018 to Fri 11/09/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/19/2018 to Wed 11/21/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 11/26/2018 to Fri 12/21/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Friday ,March 09, 2018 to Sunday ,September08, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

FWD

Wed 12/26/2018 to Fri 12/28/2018
 0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW