

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>						FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)	
0001	Continuous	2359				3800 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>W49TH_ST-E13THSTA_345_M54</b>						FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)	
0001	Continuous	2359				3800 MW	
Work scheduled by: ConEd						SPR/DUN-SOUTH	
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/14/2018</u>	(Import)	(Export)
0001	Continuous	2359				2600 MW	1300 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018				(Import)	(Export)
0001		2359				2000 MW	1300 MW
Work scheduled by:						SCH - PJ - NY	
						Impacts Total Transfer Capability	750 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
<b>MARION_-FARRAGUT_345_C3403</b>						FWD	REV
Mon 01/15/2018	to	Thu 03/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/14/2018</u>	(Import)	(Export)
0001	Continuous	2359				2600 MW	1300 MW
Work scheduled by: ConEd						SCH - PJ - NY	
						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>						FWD	REV
Wed 02/07/2018	to	Mon 04/30/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>01/22/2018</u>	(Import)	(Export)
1629	Continuous	0959				2600 MW	1300 MW
Work scheduled by: NYISO						SCH - PJ - NY	
						Impacts Total Transfer Capability	150 MW 0 MW
						TTC with All Lines In Service	2750 MW 1300 MW
<b>LONG_MTN-PLSNTVLY_345_398</b>						FWD	REV
Mon 02/26/2018	to	Tue 05/01/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/21/2018</u>	(Import)	(Export)
0001	Continuous	0300				700 MW	1300 MW
Work scheduled by: ConEd						SCH - NE - NY	
						Impacts Total Transfer Capability	700 MW 300 MW
						TTC with All Lines In Service	1400 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LONG_MTN-PLSNTVLY_345_398</b>				
Mon 02/26/2018	to	Tue 05/01/2018	<b>UPDATED</b>	<b>by ISONE 02/21/2018</b>
0001	Continuous	0300		
Work scheduled by: ConEd				
			SCH - NPX_1385	FWD (Import) <b>100 MW</b>
			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
				REV (Export) <b>100 MW</b>
<b>DUNWODIE-MOTTHAVN_345_72</b>				
Thu 03/01/2018	to	Fri 04/06/2018	<b>EXTENDED</b>	<b>by CONED 03/05/2018</b>
0001	Continuous	0200		
Work scheduled by: ConEd				
			SPR/DUN-SOUTH	FWD (Import) <b>3800 MW</b>
			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>MOSES -ADIRNDCK_230_MA2</b>				
Mon 03/05/2018	to	Fri 03/09/2018		
0700	Continuous	1730		
Work scheduled by: NYPA				
			MOSES SOUTH	FWD (Import) <b>2300 MW</b>
			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>SCH-IMO-NYISO_LIMIT_1300</b>				
Mon 03/05/2018	to	Tue 03/13/2018		
0730	Continuous	1730		
Work scheduled by: NGrid				
			SCH - OH - NY	FWD (Import) <b>1600 MW</b>
			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	1750 MW
<b>SCH-NYISO-NE_LIMIT_500</b>				
Mon 03/05/2018	to	Tue 05/01/2018	<b>UPDATED</b>	<b>by ISONE 02/21/2018</b>
1400	Continuous	0300		
Work scheduled by: ConEd				
			SCH - NE - NY	REV (Export) <b>700 MW</b>
			Impacts Total Transfer Capability	900 MW
			TTC with All Lines In Service	1600 MW
<b>MARCY -N.SCTLND_345_18</b>				
Tue 03/06/2018	to	Wed 03/07/2018	<b>UPDATED</b>	<b>by NYPA 02/16/2018</b>
0500	Continuous	1730		
Work scheduled by: NYPA				
			CENTRAL EAST - VC	FWD (Import) <b>2090 MW</b>
			Impacts Total Transfer Capability	885 MW
			TTC with All Lines In Service	2975 MW
				<b>ARR: 19</b>
<b>SCH-HQ_CEDARS-NYISO_LIMIT_160</b>				
Wed 03/07/2018	to	Fri 03/23/2018		
0001	Continuous	0500		
Work scheduled by: HQ				
			SCH - HQ_CEDARS	FWD (Import) <b>160 MW</b>
			Impacts Total Transfer Capability	39 MW
			TTC with All Lines In Service	199 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**  
 Wed 03/07/2018 to Wed 03/07/2018  
 1700 1730  
 Work scheduled by:

FWD  
 (Import)  
**SPR/DUN-SOUTH 3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**OSWEGO\_\_-VOLNEY\_\_345\_12**  
 Thu 03/08/2018 to Sat 03/10/2018 **EXTENDED** **by NGRID** **03/09/2018**  
 0700 Continuous 1600  
 Work scheduled by: NGrid

FWD  
 (Import)  
**OSWEGO EXPORT 5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

**SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB**  
 Fri 03/09/2018 to Fri 03/09/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
**SCH - OH - NY 1350 MW 1450 MW**  
 Impacts Total Transfer Capability 400 MW 450 MW  
 TTC with All Lines In Service 1750 MW 1900 MW

**CHAT\_DC\_GC1**  
 Sat 03/10/2018 to Sun 03/11/2018 **UPDATED** **by HQ** **03/09/2018**  
 2300 Continuous 0400  
 Work scheduled by: HQ

FWD  
 (Import)  
**MOSES SOUTH 2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**  
 Sat 03/10/2018 to Sun 03/11/2018 **UPDATED** **by HQ** **03/09/2018**  
 2300 Continuous 0400  
 Work scheduled by: HQ

REV  
 (Export)  
**SCH - HQ - NY 500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**  
 Sat 03/10/2018 to Sun 03/11/2018  
 2300 0400  
 Work scheduled by:

FWD  
 (Import)  
**MOSES SOUTH 2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**  
 Sat 03/10/2018 to Sun 03/11/2018  
 2300 0400  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						FWD	
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)	
2300	Continuous	0400				MOSES SOUTH <b>2850 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW	
						TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC2</b>						REV	
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Export)	
2300	Continuous	0400				SCH - HQ - NY <b>500 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW	
						TTC with All Lines In Service 1000 MW	
<b>SCH-HQ-NYISO_LIMIT_1200</b>						FWD	
Sat 03/10/2018	to	Sun 03/11/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)	
2300	Continuous	0400				SCH - HQ - NY <b>1200 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW	
						TTC with All Lines In Service 1500 MW	
<b>CHAT_DC_GC1</b>						FWD	
Sun 03/11/2018	to	Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)	
2300	Continuous	0300				MOSES SOUTH <b>2850 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW	
						TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC1</b>						REV	
Sun 03/11/2018	to	Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Export)	
2300	Continuous	0300				SCH - HQ - NY <b>500 MW</b>	
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW	
						TTC with All Lines In Service 1000 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	
Sun 03/11/2018	to	Mon 03/12/2018				(Import)	
2300		0300				MOSES SOUTH <b>2550 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability 600 MW	
						TTC with All Lines In Service 3150 MW	
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD	REV
Sun 03/11/2018	to	Mon 03/12/2018				(Import)	(Export)
2300		0300				SCH - HQ - NY <b>1370 MW</b>	<b>0 MW</b>
Work scheduled by:						Impacts Total Transfer Capability 130 MW	1000 MW
						TTC with All Lines In Service 1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						FWD
Sun 03/11/2018	to	Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)
2300	Continuous	0300				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>						REV
Sun 03/11/2018	to	Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Export)
2300	Continuous	0300				SCH - HQ - NY <b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>						FWD
Sun 03/11/2018	to	Mon 03/12/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>03/09/2018</u>	(Import)
2300	Continuous	0300				SCH - HQ - NY <b>1200 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 1500 MW
<b>HUDSONTP-W49TH_ST_345_Y56</b>						FWD
Mon 03/12/2018	to	Mon 03/12/2018				(Import)
0600	Continuous	1600				SCH - PJM_HTP <b>0 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 660 MW
						TTC with All Lines In Service 660 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>						FWD
Mon 03/12/2018	to	Fri 03/16/2018				(Import)
0700	Continuous	1730				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>SCH-IMO-NYISO_LIMIT_1300</b>						FWD
Wed 03/14/2018	to	Tue 03/27/2018	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2018</u>	(Import)
0600	Continuous	1630				SCH - OH - NY <b>1600 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 1750 MW
<b>LEEDS___345KV_R94301</b>						FWD
Thu 03/15/2018	to	Thu 03/15/2018				(Import)
0800	Daily(No Weekends)	1430				UPNY CONED <b>3800 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 1900 MW
						TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NINEMILE-CLAY</b> _____ <b>345_8</b>				FWD
Fri 03/16/2018	to	Fri 03/16/2018		(Import)
2000	Continuous	2100	OSWEGO EXPORT	<b>5150 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 5250 MW
<b>SCRIBA</b> __- <b>VOLNEY</b> ___ <b>345_21</b>				FWD
Sat 03/17/2018	to	Sat 03/17/2018		(Import)
0600	Daily	1500	OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
<b>EASTVIEW-SPRNBRK</b> __ <b>345_W79</b>				FWD
Mon 03/19/2018	to	Mon 03/19/2018	<b>UPDATED</b>	(Import)
0001	Continuous	0030	<b>by CONED</b>	UPNY CONED
Work scheduled by: ConEd				<b>02/01/2018</b>
				<b>4350 MW</b>
				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>BUCHAN_N-EASTVIEW</b> __ <b>345_W93</b>				FWD
Mon 03/19/2018	to	Sun 03/25/2018	<b>UPDATED</b>	(Import)
0001	Continuous	0200	<b>by CONED</b>	UPNY CONED
Work scheduled by: ConEd				<b>02/01/2018</b>
				<b>4350 MW</b>
				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>RAMAPO</b> __- <b>BUCHAN_N</b> __ <b>345_Y94</b>				FWD
Mon 03/19/2018	to	Fri 03/30/2018	<b>UPDATED</b>	(Import)
0001	Continuous	0100	<b>by CONED</b>	UPNY CONED
Work scheduled by: ConEd				<b>02/01/2018</b>
				<b>4800 MW</b>
				Impacts Total Transfer Capability 900 MW
				TTC with All Lines In Service 5700 MW
<b>W49TH_ST_345KV_6</b>				FWD
Mon 03/19/2018	to	Tue 03/20/2018	<b>UPDATED</b>	(Import)
0200	Continuous	0200	<b>by CONED</b>	SCH - PJM_HTP
Work scheduled by: ConEd				<b>01/02/2018</b>
				<b>350 MW</b>
				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
<b>W49TH_ST_345KV_8</b>				FWD
Mon 03/19/2018	to	Tue 03/20/2018	<b>UPDATED</b>	(Import)
0200	Continuous	0200	<b>by CONED</b>	SCH - PJM_HTP
Work scheduled by: ConEd				<b>01/02/2018</b>
				<b>350 MW</b>
				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
<b>NINEMILE-CLAY</b>	<u>345_8</u>		FWD
Tue 03/20/2018	to	Tue 03/20/2018	(Import)
1730	Continuous	1830	OSWEGO EXPORT <b>5150 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 100 MW
			TTC with All Lines In Service 5250 MW
<hr/>			
<b>W49TH_ST_345KV_6</b>			FWD
Wed 03/21/2018	to	Wed 03/21/2018	(Import)
0100	Continuous	0200	SCH - PJM_HTP <b>350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 310 MW
			TTC with All Lines In Service 660 MW
<hr/>			
<b>W49TH_ST_345KV_8</b>			FWD
Wed 03/21/2018	to	Wed 03/21/2018	(Import)
0100	Continuous	0200	SCH - PJM_HTP <b>350 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability 310 MW
			TTC with All Lines In Service 660 MW
<hr/>			
<b>HANAWAFL-COLTON</b>	<u>115_5</u>		FWD      REV
Wed 03/21/2018	to	Wed 03/21/2018	(Import) (Export)
0600	Continuous	1200	SCH - HQ_CEDARS <b>150 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 49 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service 199 MW 100 MW
<hr/>			
<b>LAWRNCAV-HANAWAFL</b>	<u>115_5</u>		FWD      REV
Wed 03/21/2018	to	Wed 03/21/2018	(Import) (Export)
0600	Continuous	1200	SCH - HQ_CEDARS <b>150 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 49 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service 199 MW 100 MW
<hr/>			
<b>DENNISON-LAWRNCAV</b>	<u>115_5</u>		FWD      REV
Wed 03/21/2018	to	Sat 03/24/2018	(Import) (Export)
0600	Continuous	1500	SCH - HQ_CEDARS <b>150 MW 100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 49 MW 0 MW
<b>ARR: 38</b>			TTC with All Lines In Service 199 MW 100 MW
<hr/>			
<b>VOLNEY -CLAY</b>	<u>345_6</u>		FWD
Thu 03/22/2018	to	Thu 03/22/2018	(Import)
0730	Daily(No Weekends)	1700	OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability 0 MW
			TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 03/24/2018 to Wed 03/28/2018  
 0001 Continuous 1800  
 Work scheduled by: HQ

FWD  
 (Import)  
**MOSES SOUTH 1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Sat 03/24/2018 to Wed 03/28/2018  
 0001 Continuous 1800  
 Work scheduled by: HQ

FWD REV  
 (Import) (Export)  
**SCH - HQ - NY 0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

**MARCY\_\_345KV\_CSC**

Mon 03/26/2018 to Fri 04/13/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
**CENTRAL EAST - VC 2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 03/26/2018 to Thu 03/29/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
**MOSES SOUTH 2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Mon 03/26/2018 to Fri 04/13/2018  
 0800 Continuous 1600  
 Work scheduled by: HQ

REV  
 (Export)  
**SCH - HQ\_CEDARS 0 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 100 MW

**MAINESBG-WATRCURE\_345\_30**

Mon 03/26/2018 to Tue 03/27/2018  
 0900 Daily 1530  
 Work scheduled by: NYSEG

FWD REV  
 (Import) (Export)  
**SCH - PJ - NY 2000 MW 1300 MW**  
 Impacts Total Transfer Capability 750 MW 0 MW  
 TTC with All Lines In Service 2750 MW 1300 MW

**LONG\_MTN-PLSNTVLY\_345\_398 & NRTH1385-NOR HBR\_\_138\_601**

Wed 03/28/2018 to Sat 03/31/2018  
 0600 2359  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
**SCH - NPX\_1385 0 MW 0 MW**  
 Impacts Total Transfer Capability 200 MW 200 MW  
 TTC with All Lines In Service 200 MW 200 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG\_MTN-PLSNTVLY\_345\_398 & NRTH1385-NOR HBR\_\_138\_602

Wed 03/28/2018 to Sat 03/31/2018  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

LONG\_MTN-PLSNTVLY\_345\_398 & NRTH1385-NOR HBR\_\_138\_603

Wed 03/28/2018 to Sat 03/31/2018  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_601

Wed 03/28/2018 to Sat 03/31/2018  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_602

Wed 03/28/2018 to Sat 03/31/2018  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_601 & NRTH1385-NOR HBR\_\_138\_603

Wed 03/28/2018 to Sat 03/31/2018  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602

Wed 03/28/2018 to Sat 03/31/2018  
0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603

Wed 03/28/2018 to Sat 03/31/2018  
0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR__138_603</b>					FWD	REV
Wed 03/28/2018	to	Sat 03/31/2018			(Import)	(Export)
0600	Continuous	2359		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>					FWD	REV
Wed 03/28/2018	to	Sat 03/31/2018			(Import)	(Export)
0600	Continuous	2359		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Fri 03/30/2018	to	Sat 03/31/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/01/2018</u></b>	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>					FWD	
Fri 03/30/2018	to	Thu 04/12/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/01/2018</u></b>	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>EASTVIEW-SPRNBK__345_W79</b>					FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/01/2018</u></b>	
0001	Continuous	0200		UPNY CONED	<b>4350 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>RAMAPO__-BUCHAN_N_345_Y94</b>					FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<b><u>UPDATED</u></b>	<b><u>by CONED</u></b>	<b><u>02/01/2018</u></b>	
0001	Continuous	0200		UPNY CONED	<b>4800 MW</b>	
Work scheduled by: ConEd					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Mon 04/02/2018	to	Tue 04/03/2018	<b><u>UPDATED</u></b>	<b><u>by NE</u></b>	<b><u>02/15/2018</u></b>	
0700	Continuous	1700		SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES -ADIRNDCK_230_MA1</b>					FWD	
Mon 04/02/2018	to	Fri 04/06/2018			(Import)	
0700	Continuous	1730		MOSES SOUTH	<b>2300 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<b>VOLNEY -MARCY_345_19</b>					FWD	
Mon 04/02/2018	to	Mon 04/02/2018			(Import)	
0800	Daily(No Weekends)	1630		CENTRAL EAST - VC	<b>2825 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW
<b>VOLNEY -MARCY_345_19</b>					FWD	
Mon 04/02/2018	to	Mon 04/02/2018			(Import)	
0800	Daily(No Weekends)	1630		OSWEGO EXPORT	<b>4900 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW
<b>MALONE -WILLIS_115_1-910</b>						REV
Tue 04/03/2018	to	Tue 04/03/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>11/20/2017</b>	(Export)
0700	Continuous	1530				<b>60 MW</b>
Work scheduled by: NYPA					SCH - HQ_CEDARS	40 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>					FWD	REV
Wed 04/04/2018	to	Thu 04/12/2018	<b>UPDATED</b>	<b>by NE</b>	<b>02/15/2018</b>	(Import) (Export)
0600	Continuous	1700				<b>0 MW</b> <b>0 MW</b>
Work scheduled by: LI					SCH - NPX_CSC	330 MW
					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
<b>GILBOA -N.SCTLND_345_GNS-1</b>					FWD	
Thu 04/05/2018	to	Thu 04/05/2018			(Import)	
0830	Daily(No Weekends)	1300		CENTRAL EAST - VC	<b>2520 MW</b>	
Work scheduled by: NGrid					Impacts Total Transfer Capability	455 MW
					TTC with All Lines In Service	2975 MW
<b>DUNWODIE_345KV_7</b>					FWD	
Fri 04/06/2018	to	Fri 04/06/2018	<b>EXTENDED</b>	<b>by CONED</b>	<b>03/05/2018</b>	(Import)
0130	Continuous	0200				<b>3800 MW</b>
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_8**

Fri 04/06/2018 to Fri 04/06/2018 **EXTENDED** **by CONED** **03/05/2018**  
 0130 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Sun 04/08/2018 to Fri 04/13/2018  
 1400 Continuous 1800  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJM\_VFT **0 MW 0 MW**  
 Impacts Total Transfer Capability 315 MW 315 MW  
 TTC with All Lines In Service 315 MW 315 MW

**BECK\_\_-NIAGARA\_345\_PA302**

Mon 04/09/2018 to Fri 04/13/2018 **UPDATED** **by NYPA** **01/22/2018**  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1100 MW 950 MW**  
 Impacts Total Transfer Capability 650 MW 950 MW  
 TTC with All Lines In Service 1750 MW 1900 MW

**MOSES\_\_-ADIRNDCK\_230\_MA1**

Mon 04/09/2018 to Fri 04/13/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_\_-GILBOA\_\_345\_GF5-35**

Mon 04/09/2018 to Fri 04/20/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Fri 04/13/2018 to Fri 04/13/2018  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_\_345\_F38**

Fri 04/13/2018 to Fri 04/13/2018  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 04/13/2018 to Fri 04/13/2018  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE\_345\_W89

Fri 04/13/2018 to Fri 04/13/2018  
 2230 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 04/16/2018 to Mon 04/16/2018  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE\_345\_W90

Mon 04/16/2018 to Wed 04/18/2018  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE\_345\_501

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

NEWBRDGE\_345\_138\_BK\_1

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE\_345\_138\_BK\_2**

Mon 04/16/2018 to Tue 05/01/2018  
 0001 Continuous 1800  
 Work scheduled by: PJM

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**MOSES -ADIRNDCK\_230\_MAI**

Mon 04/16/2018 to Fri 04/20/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

**FRASER\_345\_FRASER SVC**

Mon 04/16/2018 to Fri 04/20/2018  
 0800 Continuous 1659  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2935 MW**  
 Impacts Total Transfer Capability 40 MW  
 TTC with All Lines In Service 2975 MW

**CHAT\_DC\_GC1**

Mon 04/16/2018 to Fri 05/25/2018  
 1700 Continuous 1800  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Mon 04/16/2018 to Fri 05/25/2018  
 1700 Continuous 1800  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

**WOOD\_ST -PLSNTVLE\_345\_Y87**

Wed 04/18/2018 to Wed 04/18/2018  
 2230 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_345\_F39**

Fri 04/20/2018 to Fri 04/20/2018  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Fri 04/20/2018 to Sun 04/22/2018  
 0001 Continuous 2329  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_\_345\_F39**

Sun 04/22/2018 to Sun 04/22/2018  
 2230 Continuous 2329  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sun 04/22/2018 to Sun 04/22/2018 **UPDATED by CONED 02/01/2018**  
 2330 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Sun 04/22/2018 to Sun 04/22/2018 **UPDATED by CONED 02/01/2018**  
 2330 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

**MARCY\_\_\_765\_345\_AT1**

Mon 04/23/2018 to Mon 04/23/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**EDIC\_\_\_-N.SCTLND\_345\_14**

Mon 04/23/2018 to Wed 04/25/2018  
 0600 Continuous 1800  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2240 MW**  
 Impacts Total Transfer Capability 735 MW  
 TTC with All Lines In Service 2975 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Tue 04/24/2018 to Thu 04/26/2018  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Frequency	Work Scheduled by	ARR	Transfer Type	FWD (Import)	REV (Export)	
LOWVILLE-BOONVILLE_115_5	Tue 04/24/2018	to	Tue 04/24/2018	0800	Daily(No Weekends)	1430	SCH - HQ_CEDARS	199 MW	100 MW	
Work scheduled by: NGrid							ARR: 38	Impacts Total Transfer Capability	0 MW	0 MW
							TTC with All Lines In Service	199 MW	100 MW	
BULYMO -BOONVILLE_115_6	Wed 04/25/2018	to	Wed 04/25/2018	0800	Daily(No Weekends)	1430	SCH - HQ_CEDARS	199 MW	100 MW	
Work scheduled by: NGrid							ARR: 38	Impacts Total Transfer Capability	0 MW	0 MW
							TTC with All Lines In Service	199 MW	100 MW	
OAKDALE -FRASER_345_32	Thu 04/26/2018	to	Fri 04/27/2018	0700	Continuous	1700	<u>UPDATED</u> <u>by NYSEG</u> <u>03/09/2018</u>	2650 MW		
Work scheduled by: NYSEG								Impacts Total Transfer Capability	325 MW	
							TTC with All Lines In Service	2975 MW		
MOSES -ADIRNDCK_230_MA2	Mon 04/30/2018	to	Fri 05/04/2018	0700	Continuous	1530		2300 MW		
Work scheduled by: NYPA								Impacts Total Transfer Capability	850 MW	
							TTC with All Lines In Service	3150 MW		
HOMRC_NY-MAINS_NY_345_47	Mon 04/30/2018	to	Fri 05/25/2018	0700	Continuous	1730	SCH - PJ - NY	2500 MW	1300 MW	
Work scheduled by: NYSEG								Impacts Total Transfer Capability	250 MW	0 MW
							TTC with All Lines In Service	2750 MW	1300 MW	
MARCY_SO_SERIES_COMP_I/S	Tue 05/01/2018	to	Mon 05/21/2018	0001	Continuous	0559		2740 MW		
Work scheduled by: NYISO								Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	2975 MW		
S.RIPLEY-DUNKIRK_230_68	Tue 05/01/2018	to	Sat 06/02/2018	1000	Continuous	1600	<u>UPDATED</u> <u>by PJM</u> <u>01/22/2018</u>	1950 MW	1350 MW	
Work scheduled by: PJM								Impacts Total Transfer Capability	150 MW	0 MW
							TTC with All Lines In Service	2100 MW	1350 MW	



# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD\_ST\_\_345\_F30

Wed 05/02/2018 to Wed 05/02/2018  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

N. SCTLND-ALPS\_\_\_\_345\_2

Wed 05/02/2018 to Fri 05/04/2018  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
 SCH - NE - NY **750 MW 1350 MW**  
 Impacts Total Transfer Capability 650 MW 250 MW  
 TTC with All Lines In Service 1400 MW 1600 MW

N. SCTLND-ALPS\_\_\_\_345\_2

Wed 05/02/2018 to Fri 05/04/2018  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD REV  
 (Import) (Export)  
 SCH - NPX\_1385 **100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

PLSNTVLY-WOOD\_ST\_\_345\_F30

Fri 05/04/2018 to Fri 05/04/2018  
 2230 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

SCH-NYISO-NE\_LIMIT\_800

Sun 05/06/2018 to Sun 05/06/2018  
 0600 Continuous 1900  
 Work scheduled by: ISONE

REV  
 (Export)  
 SCH - NE - NY **1000 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 1600 MW

NIAGARA\_-KINTIGH\_\_345\_NS1-38

Mon 05/07/2018 to Fri 05/11/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_-ADIRNDCK\_230\_MA2

Mon 05/07/2018 to Fri 05/11/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**N. SCTLND-LEEDS 345\_93**

Mon 05/07/2018 to Fri 05/11/2018  
0800 Continuous 1500

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

**SCH-NYISO-NE\_LIMIT\_800**

Mon 05/07/2018 to Wed 05/23/2018  
0800 Continuous 1900

Work scheduled by: ISONE

REV

(Export)

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

**ERIE E -S.RIPLEY\_230\_69 & WETHSRFD-MEYER 230\_85/87**

Sat 05/12/2018 to Fri 06/01/2018  
0700 1500

Work scheduled by:

FWD

(Import)

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**WETHSRFD-MEYER 230\_85/87**

Sat 05/12/2018 to Fri 06/01/2018  
0700 Continuous 1500

Work scheduled by: NYSEG

**UPDATED by NYSEG 02/15/2018**

FWD

(Import)

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**MOSES -ADIRNDCK\_230\_MA2**

Mon 05/14/2018 to Fri 05/18/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

**CLAY -EDIC 345\_1-16**

Mon 05/14/2018 to Fri 05/18/2018  
0700 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

**N. SCTLND-LEEDS 345\_94**

Mon 05/14/2018 to Mon 05/14/2018  
0730 Daily(No Weekends) 1500

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
<b>FROST_BR-LONG_MTN_345_352</b>		
Thu 05/17/2018 to Tue 05/22/2018		
0730 Continuous 1600		
Work scheduled by: ISONE		
	SCH - NE - NY	<b>1150 MW</b>
	Impacts Total Transfer Capability	250 MW
	TTC with All Lines In Service	1400 MW
		<b>1600 MW</b>
<hr/>		
<b>MARCY___765_345_AT2</b>		
Mon 05/21/2018 to Fri 05/25/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
	MOSES SOUTH	<b>1700 MW</b>
	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
		<b>ARR: 19</b>
<hr/>		
<b>SCH-HQ-NYISO_LIMIT_1400</b>		
Mon 05/21/2018 to Fri 05/25/2018		
0600 Continuous 1800		
Work scheduled by: HQ		
	SCH - HQ - NY	<b>1400 MW</b>
	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	1500 MW
<hr/>		
<b>FRASANX-COOPERS__345_UCC2-41</b>		
Mon 05/21/2018 to Fri 06/01/2018		
0600 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2500 MW</b>
	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>MARCY___-FRASANX_345_UCC2-41</b>		
Mon 05/21/2018 to Fri 06/01/2018		
0600 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2500 MW</b>
	Impacts Total Transfer Capability	475 MW
	TTC with All Lines In Service	2975 MW
		<b>ARR: 19</b>
<hr/>		
<b>MOSES___-ADIRNDCK_230_MA1</b>		
Mon 05/28/2018 to Fri 06/01/2018		
0700 Continuous 1730		
Work scheduled by: NYPA		
	MOSES SOUTH	<b>2100 MW</b>
	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
<b>STLAWRNC-MOSES___230_L33P</b>		
Mon 05/28/2018 to Fri 06/01/2018		
0700 Continuous 2000		
Work scheduled by: NYPA		
	SCH - OH - NY	<b>2000 MW</b>
	Impacts Total Transfer Capability	0 MW
	TTC with All Lines In Service	2000 MW
		<b>1600 MW</b>

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_SO\_SERIES\_COMP\_I/S**

Fri 06/01/2018 to Wed 10/31/2018  
 1800 Continuous 2359  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Sat 06/02/2018 to Sat 02/01/2020 **UPDATED by NYISO 01/22/2018**  
 1600 Continuous 0000  
 Work scheduled by: NYISO

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1950 MW 1350 MW**  
 Impacts Total Transfer Capability 150 MW 0 MW  
 TTC with All Lines In Service 2100 MW 1350 MW

**MARCY\_765\_345\_AT1**

Sat 08/04/2018 to Sun 08/05/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_765\_345\_AT2**

Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_345\_36**

Thu 09/06/2018 to Fri 09/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYSEG

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**FRASER\_GILBOA\_345\_GF5-35**

Mon 09/10/2018 to Fri 10/05/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**ROSETON-ROCKTVRN\_345\_311**

Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___345KV_CSC</b>		FWD
Tue 09/11/2018	to Tue 09/11/2018	(Import)
0500	Continuous 1730	CENTRAL EAST - VC <b>2925 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 50 MW
		TTC with All Lines In Service 2975 MW
<hr/>		
<b>MARCY___345KV_CSC &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD
Tue 09/11/2018	to Tue 09/11/2018	(Import)
0500	1730	CENTRAL EAST - VC <b>2690 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 285 MW
		TTC with All Lines In Service 2975 MW
<hr/>		
<b>MARCY___765_345_AT2</b>		FWD
Tue 09/11/2018	to Tue 09/11/2018	(Import)
0500	Continuous 1730	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<hr/>		
<b>NIAGARA__345_230_AT4</b>		FWD      REV
Fri 09/14/2018	to Fri 09/14/2018	(Import) (Export)
0500	Continuous 1700	SCH - OH - NY <b>2000 MW 1400 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 0 MW 200 MW
		TTC with All Lines In Service 2000 MW 1600 MW
<hr/>		
<b>NIAGARA_-ROCHESTR_345_NR2</b>		FWD
Mon 09/17/2018	to Fri 09/21/2018	(Import)
0500	Continuous 1700	DYSINGER EAST <b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MOSES___-ADIRNDCK_230_MAI</b>		FWD
Mon 09/17/2018	to Fri 09/21/2018	(Import)
0700	Continuous 1530	MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1050 MW
		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MOSES___-ADIRNDCK_230_MAI</b>		FWD
Mon 09/24/2018	to Fri 09/28/2018	(Import)
0700	Continuous 1530	MOSES SOUTH <b>2100 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1050 MW
		TTC with All Lines In Service 3150 MW

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY -EDIC 345_2-15</b>		FWD	
Mon 09/24/2018	to Fri 09/28/2018	(Import)	
0700	Continuous 1700	OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	400 MW
		TTC with All Lines In Service	5250 MW
<b>BECK -NIAGARA 345_PA302</b>		FWD	REV
Mon 10/01/2018	to Fri 10/05/2018	(Import)	(Export)
0500	Continuous 1700	SCH - OH - NY	<b>900 MW 800 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1100 MW 800 MW
		TTC with All Lines In Service	2000 MW 1600 MW
<b>MOSES -ADIRNDCK 230_MA2</b>		FWD	
Mon 10/01/2018	to Wed 10/03/2018	(Import)	
0700	Continuous 1530	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW
<b>PANNELL -CLAY 345_1</b>		FWD	
Mon 10/01/2018	to Fri 10/05/2018	(Import)	
0700	Continuous 1700	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	950 MW
		TTC with All Lines In Service	2250 MW
<b>HUDSONP -FARRAGUT 345_B3402</b>		FWD	REV
Tue 10/02/2018	to Tue 11/13/2018	(Import)	(Export)
0001	Continuous 2359	SCH - PJ - NY	<b>2100 MW 1350 MW</b>
Work scheduled by: PJM		Impacts Total Transfer Capability	0 MW 0 MW
		TTC with All Lines In Service	2100 MW 1350 MW
<b>MARCY 765_345_AT2</b>		FWD	
Thu 10/04/2018	to Fri 10/05/2018	(Import)	
0500	Continuous 1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW
<b>MOSES -ADIRNDCK 230_MA1</b>		FWD	
Mon 10/08/2018	to Fri 10/12/2018	(Import)	
0700	Continuous 1530	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1050 MW
		TTC with All Lines In Service	3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Dates	Time	Work by	Location	Direction	Impact	TTC
CHAT_DC_GC2	Mon 10/08/2018 to Fri 11/23/2018	0700 Continuous 1700	HQ	MOSES SOUTH	FWD (Import)	2850 MW	3150 MW
CHAT_DC_GC2	Mon 10/08/2018 to Fri 11/23/2018	0700 Continuous 1700	HQ	SCH - HQ - NY	REV (Export)	500 MW	1000 MW
CHATGUAY-MASSENA__765_7040	Sat 10/13/2018 to Sat 10/27/2018	0100 Continuous 1730	NYPA	MOSES SOUTH	FWD (Import)	1550 MW	3150 MW
CHATGUAY-MASSENA__765_7040	Sat 10/13/2018 to Sat 10/27/2018	0100 Continuous 1730	NYPA	SCH - HQ - NY	FWD (Import) REV (Export)	0 MW 0 MW	1500 MW 1000 MW
MARCY___765_345_AT1	Sat 10/13/2018 to Sat 10/27/2018	0100 Continuous 1730	NYPA	MOSES SOUTH	FWD (Import)	1750 MW	3150 MW
MARCY___765_345_AT2	Sat 10/13/2018 to Sat 10/27/2018	0100 Continuous 1730	NYPA	MOSES SOUTH	FWD (Import)	1700 MW	3150 MW
MASSENA_-MARCY___765_MSU1	Sat 10/13/2018 to Sat 10/27/2018	0100 Continuous 1730	NYPA	CENTRAL EAST - VC	FWD (Import)	2265 MW	2975 MW

ARR: 19

ARR: 19

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY_765_MSU1</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	Continuous 1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1</b>		FWD	REV
Sat 10/13/2018	to Sat 10/27/2018	(Import)	(Export)
0100	Continuous 1730	SCH - HQ - NY	<b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1025 MW 0 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	MOSES SOUTH	<b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	2650 MW
		TTC with All Lines In Service	3150 MW
<b>MASSENA_-MARCY_765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD	
Sat 10/13/2018	to Sat 10/27/2018	(Import)	
0100	1730	CENTRAL EAST - VC	<b>2080 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	895 MW
		TTC with All Lines In Service	2975 MW
<b>MOSES_-MASSENA_230_MMS1 &amp; MOSES_-MASSENA_230_MMS2</b>		FWD	REV
Sat 10/13/2018	to Sat 10/27/2018	(Import)	(Export)
0100	1730	SCH - HQ - NY	<b>850 MW 0 MW</b>
Work scheduled by:		Impacts Total Transfer Capability	650 MW 1000 MW
		TTC with All Lines In Service	1500 MW 1000 MW
<b>LEEDS_-HURLYAVE_345_301</b>		FWD	
Mon 10/22/2018	to Fri 11/16/2018	(Import)	
0800	Continuous 1600	UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE		Impacts Total Transfer Capability	1600 MW
		TTC with All Lines In Service	5700 MW
<b>KINTIGH_-ROCHESTR_345_SRL1-39</b>		FWD	
Mon 10/29/2018	to Fri 11/02/2018	(Import)	
0500	Continuous 1700	DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability	1450 MW
		TTC with All Lines In Service	3150 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 10/29/2018 to Fri 11/02/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 11/05/2018 to Fri 11/09/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_345KV\_CSC**

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAI**

Mon 11/19/2018 to Wed 11/21/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 11/26/2018 to Fri 11/30/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**HURLYAVE-ROSETON\_\_345\_303**

Mon 11/26/2018 to Fri 12/21/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,March 11, 2018 to Tuesday ,September10, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/03/2018 to Fri 12/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

Mon 12/10/2018 to Fri 12/14/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Mon 12/17/2018 to Fri 12/21/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Wed 12/26/2018 to Fri 12/28/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW