

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45					FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M54					FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
HUDSONP_-FARRAGUT_345_B3402					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>03/13/2018</u>	(Import) (Export)
0001	Continuous	2359				2600 MW 1300 MW
Work scheduled by: ConEd					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018				(Import) (Export)
0001		2359				2000 MW 1300 MW
Work scheduled by:					SCH - PJ - NY	750 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>03/13/2018</u>	(Import) (Export)
0001	Continuous	2359				2600 MW 1300 MW
Work scheduled by: ConEd					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Wed 02/07/2018	to	Thu 05/17/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>01/22/2018</u>	(Import) (Export)
1629	Continuous	0759				2600 MW 1300 MW
Work scheduled by: NYISO					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
LONG_MTN-PLSNTVLY_345_398					FWD	REV
Mon 02/26/2018	to	Tue 05/01/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/21/2018</u>	(Import) (Export)
0001	Continuous	0300				700 MW 1300 MW
Work scheduled by: ConEd					SCH - NE - NY	700 MW 300 MW
					Impacts Total Transfer Capability	1400 MW 1600 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398	FWD	REV
Mon 02/26/2018 to Tue 05/01/2018 UPDATED <u>by ISONE</u> <u>02/21/2018</u>	(Import)	(Export)
0001 Continuous 0300	SCH - NPX_1385	100 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	100 MW
	TTC with All Lines In Service	200 MW
<hr/>		
DUNWODIE-MOTTHAVN_345_72	FWD	
Thu 03/01/2018 to Fri 04/06/2018 EXTENDED <u>by CONED</u> <u>03/05/2018</u>	(Import)	
0001 Continuous 0200	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
<hr/>		
SCH-IMO-NYISO_LIMIT_1300	FWD	
Mon 03/05/2018 to Tue 03/13/2018	(Import)	
0730 Continuous 1730	SCH - OH - NY	1600 MW
Work scheduled by: NGrid	Impacts Total Transfer Capability	150 MW
	TTC with All Lines In Service	1750 MW
<hr/>		
SCH-NYISO-NE_LIMIT_500		REV
Mon 03/05/2018 to Tue 05/01/2018 UPDATED <u>by ISONE</u> <u>02/21/2018</u>		(Export)
1400 Continuous 0300	SCH - NE - NY	700 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	900 MW
	TTC with All Lines In Service	1600 MW
<hr/>		
SCH-HQ_CEDARS-NYISO_LIMIT_160	FWD	
Wed 03/07/2018 to Fri 03/23/2018	(Import)	
0001 Continuous 0500	SCH - HQ_CEDARS	160 MW
Work scheduled by: HQ	Impacts Total Transfer Capability	39 MW
	TTC with All Lines In Service	199 MW
<hr/>		
CHAT_DC_GC1	FWD	
Sun 03/11/2018 to Mon 03/12/2018 UPDATED <u>by HQ</u> <u>03/09/2018</u>	(Import)	
2300 Continuous 0300	MOSES SOUTH	2850 MW
Work scheduled by: HQ	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
CHAT_DC_GC1		REV
Sun 03/11/2018 to Mon 03/12/2018 UPDATED <u>by HQ</u> <u>03/09/2018</u>		(Export)
2300 Continuous 0300	SCH - HQ - NY	500 MW
Work scheduled by: HQ	Impacts Total Transfer Capability	500 MW
	TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2					FWD
Sun 03/11/2018	to	Mon 03/12/2018			(Import)
2300		0300		MOSES SOUTH	2550 MW
Work scheduled by:					Impacts Total Transfer Capability 600 MW
					TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2					FWD
Sun 03/11/2018	to	Mon 03/12/2018			(Import) (Export)
2300		0300		SCH - HQ - NY	1370 MW 0 MW
Work scheduled by:					Impacts Total Transfer Capability 130 MW 1000 MW
					TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2					FWD
Sun 03/11/2018	to	Mon 03/12/2018	UPDATED	by HQ	03/09/2018
2300	Continuous	0300			
Work scheduled by: HQ					(Import)
					MOSES SOUTH 2850 MW
					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW

CHAT_DC_GC2					REV
Sun 03/11/2018	to	Mon 03/12/2018	UPDATED	by HQ	03/09/2018
2300	Continuous	0300			
Work scheduled by: HQ					(Export)
					SCH - HQ - NY 500 MW
					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1200					FWD
Sun 03/11/2018	to	Mon 03/12/2018	UPDATED	by HQ	03/09/2018
2300	Continuous	0300			
Work scheduled by: HQ					(Import)
					SCH - HQ - NY 1200 MW
					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 1500 MW

HUDSONTP-W49TH_ST_345_Y56					FWD
Mon 03/12/2018	to	Mon 03/12/2018			(Import)
0600	Continuous	1600			
Work scheduled by: ConEd					SCH - PJM_HTP 0 MW
					Impacts Total Transfer Capability 660 MW
					TTC with All Lines In Service 660 MW

MOSES__-ADIRNDCK_230_MA2					FWD
Mon 03/12/2018	to	Thu 03/15/2018	UPDATED	by NYPA	03/15/2018
0700	Continuous	0938			
Work scheduled by: NYPA					(Import)
					MOSES SOUTH 2300 MW
					Impacts Total Transfer Capability 850 MW
					TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1300					FWD	
Wed 03/14/2018	to	Sat 03/24/2018	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2018</u>	(Import)
0600	Continuous	1630				1600 MW
Work scheduled by: NGrid					SCH - OH - NY	150 MW
					Impacts Total Transfer Capability	1750 MW
					TTC with All Lines In Service	1750 MW
LEEDS_345KV_R94301					FWD	
Thu 03/15/2018	to	Thu 03/15/2018				(Import)
0800	Daily(No Weekends)	1430				3800 MW
Work scheduled by: NGrid					UPNY CONED	1900 MW
					Impacts Total Transfer Capability	5700 MW
					TTC with All Lines In Service	5700 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Fri 03/16/2018	to	Fri 03/16/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/15/2018</u>	(Import) (Export)
0600	Continuous	1600				0 MW 0 MW
Work scheduled by: LI					SCH - NPX_CSC	330 MW 330 MW
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
LONG_MTN-PLSNTVLY_345_398 & ROTTRDAM-EASTOVER_230_38					FWD	REV
Fri 03/16/2018	to	Fri 03/16/2018				(Import) (Export)
0900		1100				600 MW 1100 MW
Work scheduled by:					SCH - NE - NY	800 MW 500 MW
					Impacts Total Transfer Capability	1400 MW 1600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
ROTTRDAM-EASTOVER_230_38					FWD	REV
Fri 03/16/2018	to	Fri 03/16/2018				(Import) (Export)
0900	Daily(No Weekends)	1100				1400 MW 1600 MW
Work scheduled by: NGrid					SCH - NE - NY	0 MW 0 MW
					Impacts Total Transfer Capability	1400 MW 1600 MW
					TTC with All Lines In Service	1400 MW 1600 MW
NINEMILE-CLAY_345_8					FWD	
Fri 03/16/2018	to	Fri 03/16/2018				(Import)
2000	Continuous	2100				5150 MW
Work scheduled by: NGrid					OSWEGO EXPORT	100 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	5250 MW
SCRIBA_-VOLNEY_345_21					FWD	
Sat 03/17/2018	to	Sat 03/17/2018				(Import)
0600	Daily	1500				5250 MW
Work scheduled by: NGrid					OSWEGO EXPORT	0 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2					FWD
Sat 03/17/2018	to	Sat 03/17/2018			(Import)
0800	Continuous	1500		CONED - LIPA	1350 MW
Work scheduled by: LI					Impacts Total Transfer Capability 150 MW
					TTC with All Lines In Service 1500 MW
EASTVIEW-SPRNBK_345_W79					FWD
Mon 03/19/2018	to	Mon 03/19/2018	<u>UPDATED</u>	<u>by CONED</u> <u>03/16/2018</u>	(Import)
0001	Continuous	0030		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
BUCHAN_N-EASTVIEW_345_W93					FWD
Mon 03/19/2018	to	Sun 03/25/2018	<u>UPDATED</u>	<u>by CONED</u> <u>03/16/2018</u>	(Import)
0001	Continuous	0200		UPNY CONED	4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW
					TTC with All Lines In Service 5700 MW
RAMAPO_-BUCHAN_N_345_Y94					FWD
Mon 03/19/2018	to	Fri 03/30/2018	<u>UPDATED</u>	<u>by CONED</u> <u>03/16/2018</u>	(Import)
0001	Continuous	0100		UPNY CONED	4800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 900 MW
					TTC with All Lines In Service 5700 MW
DUNWODIE_345KV_8					FWD
Mon 03/19/2018	to	Sat 03/31/2018			(Import)
0001	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
W49TH_ST_345KV_6					FWD
Mon 03/19/2018	to	Tue 03/20/2018	<u>UPDATED</u>	<u>by CONED</u> <u>03/15/2018</u>	(Import)
0200	Continuous	0200		SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 310 MW
					TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8					FWD
Mon 03/19/2018	to	Tue 03/20/2018	<u>UPDATED</u>	<u>by CONED</u> <u>03/15/2018</u>	(Import)
0200	Continuous	0200		SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability 310 MW
					TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1000

Mon 03/19/2018 to Fri 03/23/2018
 0700 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 SCH - OH - NY **1300 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 1750 MW

NINEMILE-CLAY 345_8

Tue 03/20/2018 to Tue 03/20/2018
 1730 Continuous 1830
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5150 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_6

Wed 03/21/2018 to Wed 03/21/2018 **UPDATED by CONED 03/15/2018**
 0100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Wed 03/21/2018 to Wed 03/21/2018 **UPDATED by CONED 03/15/2018**
 0100 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

VOLNEY_-CLAY 345_6

Thu 03/22/2018 to Thu 03/22/2018
 0730 Daily(No Weekends) 1700
 Work scheduled by: NGrid

FWD
 (Import)
 OSWEGO EXPORT **5250 MW**
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 5250 MW

MARCY 345KV_CSC

Mon 03/26/2018 to Fri 04/13/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/26/2018 to Fri 04/13/2018
 0500 Continuous 1800
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ_CEDARS **0 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 100 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES ___-ADIRNDCK_230_MA2					FWD	
Mon 03/26/2018	to	Thu 03/29/2018			(Import)	
0700	Continuous	1530			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
<hr/>						
MAINESBG-WATRCURE_345_30					FWD	REV
Mon 03/26/2018	to	Tue 03/27/2018			(Import)	(Export)
0900	Daily	1530			SCH - PJ - NY	2000 MW 1300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	750 MW 0 MW
					TTC with All Lines In Service	2750 MW 1300 MW
<hr/>						
W49TH_ST_345KV_6					FWD	
Tue 03/27/2018	to	Tue 03/27/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/15/2018</u>	(Import)
0100	Continuous	0159			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
<hr/>						
W49TH_ST_345KV_8					FWD	
Tue 03/27/2018	to	Tue 03/27/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/15/2018</u>	(Import)
0100	Continuous	0159			SCH - PJM_HTP	350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
<hr/>						
HANAWAFL-COLTON___115_5					FWD	REV
Wed 03/28/2018	to	Wed 03/28/2018			(Import)	(Export)
0600	Continuous	1200			SCH - HQ_CEDARS	150 MW 100 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<hr/>						
LAWRNCAV-HANAWAFL_115_5					FWD	REV
Wed 03/28/2018	to	Wed 03/28/2018			(Import)	(Export)
0600	Continuous	1200			SCH - HQ_CEDARS	150 MW 100 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
<hr/>						
DENNISON-LAWRNCAV_115_5					FWD	REV
Wed 03/28/2018	to	Sat 03/31/2018			(Import)	(Export)
0600	Continuous	1500			SCH - HQ_CEDARS	150 MW 100 MW
Work scheduled by: NGrid				ARR: 38	Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79						FWD
Fri 03/30/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
BUCHAN_N-EASTVIEW_345_W93						FWD
Fri 03/30/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
EASTVIEW-SPRNBK__345_W79						FWD
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				4350 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 1350 MW
						TTC with All Lines In Service 5700 MW
RAMAPO__-BUCHAN_N_345_Y94						FWD
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				4800 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability 900 MW
						TTC with All Lines In Service 5700 MW
SHOR_NPX-SHOREHAM_138_CSC						FWD REV
Mon 04/02/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NE</u>	<u>02/15/2018</u>	(Import) (Export)
0700	Continuous	1700				0 MW 0 MW
Work scheduled by: ISONE						SCH - NPX_CSC
						Impacts Total Transfer Capability 330 MW 330 MW
						TTC with All Lines In Service 330 MW 330 MW
MOSES__-ADIRNDCK_230_MA1						FWD
Mon 04/02/2018	to	Fri 04/06/2018				(Import)
0700	Continuous	1730				2300 MW
Work scheduled by: NYPA						MOSES SOUTH
						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
VOLNEY__-MARCY__345_19						FWD
Mon 04/02/2018	to	Mon 04/02/2018				(Import)
0800	Daily(No Weekends)	1630				2825 MW
Work scheduled by: NGrid						CENTRAL EAST - VC
						Impacts Total Transfer Capability 150 MW
						TTC with All Lines In Service 2975 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY -MARCY 345_19					FWD	
Mon 04/02/2018	to	Mon 04/02/2018			(Import)	
0800	Daily(No Weekends)	1630		OSWEGO EXPORT	4900 MW	
Work scheduled by: NGrid			ARR: 19	Impacts Total Transfer Capability	350 MW	
				TTC with All Lines In Service	5250 MW	
MALONE -WILLIS 115_1-910					REV	
Tue 04/03/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>11/20/2017</u>	(Export)
0700	Continuous	1530		SCH - HQ_CEDARS	60 MW	
Work scheduled by: NYPA			ARR: 38	Impacts Total Transfer Capability	40 MW	
				TTC with All Lines In Service	100 MW	
SHOR_NPX-SHOREHAM 138_CSC					FWD	REV
Wed 04/04/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by NE</u>	<u>02/15/2018</u>	(Import) (Export)
0600	Continuous	1700		SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW	330 MW
				TTC with All Lines In Service	330 MW	330 MW
GILBOA -N.SCTLND 345_GNS-1					FWD	
Thu 04/05/2018	to	Thu 04/05/2018			(Import)	
0830	Daily(No Weekends)	1300		CENTRAL EAST - VC	2520 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	455 MW	
				TTC with All Lines In Service	2975 MW	
DUNWODIE_345KV_7					FWD	
Fri 04/06/2018	to	Fri 04/06/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/05/2018</u>	(Import)
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					FWD	
Fri 04/06/2018	to	Fri 04/06/2018	<u>EXTENDED</u>	<u>by CONED</u>	<u>03/05/2018</u>	(Import)
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service	4600 MW	
LINDN_CG-LNDVFT 345_V-3022					FWD	REV
Sun 04/08/2018	to	Fri 04/13/2018			(Import) (Export)	
1400	Continuous	1800		SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW	315 MW
				TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK___-NIAGARA___345_PA302	FWD	REV
Mon 04/09/2018 to Fri 04/13/2018 UPDATED by NYPA 01/22/2018	(Import)	(Export)
0500 Continuous 1700	1100 MW	950 MW
Work scheduled by: NYPA	SCH - OH - NY	Impacts Total Transfer Capability 650 MW 950 MW
	TTC with All Lines In Service	1750 MW 1900 MW
<hr/>		
MOSES___-ADIRNDCK_230_MAI	FWD	
Mon 04/09/2018 to Fri 04/13/2018	(Import)	
0700 Continuous 1730	MOSES SOUTH	2300 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
FRASER___-GILBOA___345_GF5-35	FWD	
Mon 04/09/2018 to Fri 04/20/2018	(Import)	
0700 Continuous 1730	CENTRAL EAST - VC	2650 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
Fri 04/13/2018 to Fri 04/13/2018	(Import)	
0001 Continuous 0100	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
EFISHKIL-WOOD_ST___345_F38	FWD	
Fri 04/13/2018 to Fri 04/13/2018	(Import)	
0001 Continuous 2330	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
WOOD_ST_-PLSNTVLE_345_Y86	FWD	
Fri 04/13/2018 to Fri 04/13/2018	(Import)	
0001 Continuous 2330	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
PLSNTVLE-DUNWODIE_345_W89	FWD	
Fri 04/13/2018 to Fri 04/13/2018	(Import)	
2230 Continuous 2330	UPNY CONED	4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability	1700 MW
	TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 04/14/2018 to Thu 04/19/2018
 0100 Continuous 0600
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 04/14/2018 to Thu 04/19/2018
 0100 Continuous 0600
 Work scheduled by: HQ

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC1

Sat 04/14/2018 to Fri 05/25/2018
 1700 Continuous 1800
 Work scheduled by: HQ

FWD
 (Import)
 MOSES SOUTH **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sat 04/14/2018 to Fri 05/25/2018
 1700 Continuous 1800
 Work scheduled by: HQ

REV
 (Export)
 SCH - HQ - NY **500 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1000 MW

WOOD_ST_-PLSNTVLE_345_Y87

Mon 04/16/2018 to Mon 04/16/2018
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W90

Mon 04/16/2018 to Wed 04/18/2018
 0001 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **0 MW**
 Impacts Total Transfer Capability 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 04/16/2018 to Tue 05/01/2018
 0001 Continuous 1800
 Work scheduled by: PJM

FWD
 (Import)
 SCH - PJM_NEPTUNE **375 MW**
 Impacts Total Transfer Capability 285 MW
 TTC with All Lines In Service 660 MW

MOSES__-ADIRNDCK_230_MA1

Mon 04/16/2018 to Fri 04/20/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER__345_FRASER SVC

Mon 04/16/2018 to Fri 04/20/2018
 0800 Continuous 1659
 Work scheduled by: NYSEG

FWD
 (Import)
 CENTRAL EAST - VC **2935 MW**
 Impacts Total Transfer Capability 40 MW
 TTC with All Lines In Service 2975 MW

WOOD_ST_-PLSNTVLE_345_Y87

Wed 04/18/2018 to Wed 04/18/2018
 2230 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F39

Fri 04/20/2018 to Fri 04/20/2018
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87				FWD	
Fri 04/20/2018	to	Sun 04/22/2018		(Import)	
0001	Continuous	2329	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
EFISHKIL-WOOD_ST__345_F39				FWD	
Sun 04/22/2018	to	Sun 04/22/2018		(Import)	
2230	Continuous	2329	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	UPDATED	by CONED	03/16/2018
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
EASTVIEW-SPRNBK__345_W79				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	UPDATED	by CONED	03/16/2018
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
MARCY___765_345_AT1				FWD	
Mon 04/23/2018	to	Mon 04/23/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
EDIC___-N.SCTLND_345_14				FWD	
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	
0600	Continuous	1800	CENTRAL EAST - VC	2240 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	735 MW	
			TTC with All Lines In Service	2975 MW	
CEDARS_-ROSEMNTB_115_2/22				FWD	REV
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	(Export)
0830	Continuous	1530	SCH - HQ_CEDARS	95 MW	100 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	104 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCHEDULED WORK		IMPACTS	
Date	Time	Zone	Value
SCH-HQ_CEDARS-NYISO_LIMIT_100			
Mon 04/23/2018	0830	to	Wed 04/25/2018 1530
Work scheduled by: HQ			
		SCH - HQ_CEDARS	100 MW
		Impacts Total Transfer Capability	99 MW
		TTC with All Lines In Service	199 MW
PLSNTVLE-DUNWODIE_345_W89			
Tue 04/24/2018	0001	to	Thu 04/26/2018 2330
Work scheduled by: ConEd			
		UPNY CONED	4000 MW
		Impacts Total Transfer Capability	1700 MW
		TTC with All Lines In Service	5700 MW
LOWVILLE-BOONVILLE_115_5			
Tue 04/24/2018	0800	to	Tue 04/24/2018 1430
Work scheduled by: NGrid			
		SCH - HQ_CEDARS	199 MW
		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	199 MW
			REV (Export) 100 MW
			FWD (Import) 100 MW
			ARR: 38
BULYMO__-BOONVILLE_115_6			
Wed 04/25/2018	0800	to	Wed 04/25/2018 1430
Work scheduled by: NGrid			
		SCH - HQ_CEDARS	199 MW
		Impacts Total Transfer Capability	0 MW
		TTC with All Lines In Service	199 MW
			REV (Export) 100 MW
			FWD (Import) 100 MW
			ARR: 38
OAKDALE_-FRASER_345_32			
Thu 04/26/2018	0700	to	Fri 04/27/2018 1700
Work scheduled by: NYSEG			
		CENTRAL EAST - VC	2650 MW
		Impacts Total Transfer Capability	325 MW
		TTC with All Lines In Service	2975 MW
			FWD (Import)
			UPDATED by NYSEG 03/09/2018
MOSES_-ADIRNDCK_230_MA2			
Mon 04/30/2018	0700	to	Fri 05/04/2018 1530
Work scheduled by: NYPA			
		MOSES SOUTH	2300 MW
		Impacts Total Transfer Capability	850 MW
		TTC with All Lines In Service	3150 MW
			FWD (Import)
HOMRC_NY-MAINS_NY_345_47			
Mon 04/30/2018	0700	to	Fri 05/25/2018 1730
Work scheduled by: NYSEG			
		SCH - PJ - NY	2500 MW
		Impacts Total Transfer Capability	250 MW
		TTC with All Lines In Service	2750 MW
			REV (Export) 1300 MW
			FWD (Import) 1300 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY_SO_SERIES_COMP_I/S						FWD		
Tue 05/01/2018	to	Mon 05/21/2018				(Import)		
0001	Continuous	0559			CENTRAL EAST - VC	2740 MW		
Work scheduled by: NYISO						Impacts Total Transfer Capability	235 MW	
						TTC with All Lines In Service	2975 MW	
PLSNTVLY-WOOD_ST_345_F30						FWD		
Wed 05/02/2018	to	Wed 05/02/2018				(Import)		
0001	Continuous	0100			UPNY CONED	4000 MW		
Work scheduled by: ConEd						Impacts Total Transfer Capability	1700 MW	
						TTC with All Lines In Service	5700 MW	
NRTH1385-NOR HBR_138_601						FWD	REV	
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>	(Import)	(Export)	
0600	Continuous	2359			SCH - NPX_1385	100 MW	100 MW	
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602						FWD	REV	
Wed 05/02/2018	to	Sat 05/05/2018				(Import)	(Export)	
0600		2359			SCH - NPX_1385	0 MW	0 MW	
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603						FWD	REV	
Wed 05/02/2018	to	Sat 05/05/2018				(Import)	(Export)	
0600		2359			SCH - NPX_1385	0 MW	0 MW	
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602						FWD	REV	
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>	(Import)	(Export)	
0600	Continuous	2359			SCH - NPX_1385	100 MW	100 MW	
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW	100 MW
						TTC with All Lines In Service	200 MW	200 MW
NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603						FWD	REV	
Wed 05/02/2018	to	Sat 05/05/2018				(Import)	(Export)	
0600		2359			SCH - NPX_1385	0 MW	0 MW	
Work scheduled by:						Impacts Total Transfer Capability	200 MW	200 MW
						TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NOR HBR__138_603							
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>		
0600	Continuous	2359				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
NRTH1385-NRTHPORT_138_NNC							
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>		
0600	Continuous	2359				SCH - NPX_1385	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS____345_2							
Wed 05/02/2018	to	Fri 05/04/2018					
0800	Continuous	1500				SCH - NE - NY	750 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	650 MW
						TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS____345_2							
Wed 05/02/2018	to	Fri 05/04/2018					
0800	Continuous	1500				SCH - NPX_1385	100 MW
Work scheduled by: NGrid						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_601							
Wed 05/02/2018	to	Fri 05/04/2018					
0800		1500				SCH - NPX_1385	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_602							
Wed 05/02/2018	to	Fri 05/04/2018					
0800		1500				SCH - NPX_1385	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS____345_2 & NRTH1385-NOR HBR__138_603							
Wed 05/02/2018	to	Fri 05/04/2018					
0800		1500				SCH - NPX_1385	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Fri 05/04/2018 to Fri 05/04/2018
 2230 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

SCH-NYISO-NE_LIMIT_800

Sun 05/06/2018 to Sun 05/06/2018
 0600 Continuous 1900
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1000 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1600 MW

NIAGARA_-KINTIGH__345_NS1-38

Mon 05/07/2018 to Fri 05/11/2018
 0500 Continuous 1700
 Work scheduled by: NYPA

FWD
 (Import)
 DYSINGER EAST **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA2

Mon 05/07/2018 to Fri 05/11/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

N.SCTLND-LEEDS__345_93

Mon 05/07/2018 to Fri 05/11/2018
 0800 Continuous 1500
 Work scheduled by: NGrid

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

SCH-NYISO-NE_LIMIT_800

Mon 05/07/2018 to Wed 05/23/2018
 0800 Continuous 1900
 Work scheduled by: ISONE

REV
 (Export)
 SCH - NE - NY **1000 MW**
 Impacts Total Transfer Capability 600 MW
 TTC with All Lines In Service 1600 MW

ERIE E_-S.RIPLEY_230_69 & WETHSRFD-MEYER__230_85/87

Sat 05/12/2018 to Thu 05/17/2018
 0700 0759
 Work scheduled by:

FWD
 (Import)
 DYSINGER EAST **2850 MW**
 Impacts Total Transfer Capability 300 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<p>WETHSRFD-MEYER <u>230_85/87</u></p> <p>Sat 05/12/2018 to Fri 06/01/2018 0700 Continuous 1500</p> <p>Work scheduled by: NYSEG</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>MOSES <u>-ADIRNDCK_230_MA2</u></p> <p>Mon 05/14/2018 to Fri 05/18/2018 0700 Continuous 1530</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>MOSES SOUTH 2100 MW</p> <p>Impacts Total Transfer Capability 1050 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>CLAY <u>-EDIC_345_1-16</u></p> <p>Mon 05/14/2018 to Fri 05/18/2018 0700 Continuous 1700</p> <p>Work scheduled by: NYPA</p>	<p style="text-align: right;">FWD (Import)</p> <p>OSWEGO EXPORT 4850 MW</p> <p>Impacts Total Transfer Capability 400 MW</p> <p>TTC with All Lines In Service 5250 MW</p>
<p>N.SCTLND-LEEDS <u>345_94</u></p> <p>Mon 05/14/2018 to Mon 05/14/2018 0730 Daily(No Weekends) 1500</p> <p>Work scheduled by: NGrid</p>	<p style="text-align: right;">FWD (Import)</p> <p>CENTRAL EAST - VC 2650 MW</p> <p>Impacts Total Transfer Capability 325 MW</p> <p>TTC with All Lines In Service 2975 MW</p>
<p>FROST_BR-LONG_MTN_345_352</p> <p>Thu 05/17/2018 to Tue 05/22/2018 0730 Continuous 1600</p> <p>Work scheduled by: ISONE</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - NE - NY 1150 MW 1600 MW</p> <p>Impacts Total Transfer Capability 250 MW 0 MW</p> <p>TTC with All Lines In Service 1400 MW 1600 MW</p>
<p>ERIE E <u>-S.RIPLEY_230_69 & WETHSRFD-MEYER_230_85/87</u></p> <p>Thu 05/17/2018 to Fri 06/01/2018 0800 1500</p> <p>Work scheduled by:</p>	<p style="text-align: right;">FWD (Import)</p> <p>DYSINGER EAST 2850 MW</p> <p>Impacts Total Transfer Capability 300 MW</p> <p>TTC with All Lines In Service 3150 MW</p>
<p>S.RIPLEY-DUNKIRK_230_68</p> <p>Thu 05/17/2018 to Sat 06/16/2018 0800 Continuous 1600</p> <p>Work scheduled by: PJM</p>	<p style="text-align: right;">FWD REV (Import) (Export)</p> <p>SCH - PJ - NY 1950 MW 1350 MW</p> <p>Impacts Total Transfer Capability 150 MW 0 MW</p> <p>TTC with All Lines In Service 2100 MW 1350 MW</p>

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Mon 05/21/2018 to Fri 05/25/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

SCH-HQ-NYISO_LIMIT_1400

Mon 05/21/2018 to Fri 05/25/2018
0600 Continuous 1800

Work scheduled by: HQ

FWD
(Import)
SCH - HQ - NY **1400 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 1500 MW

FRASANX-COOPERS__345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
0600 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MARCY___-FRASANX_345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
CENTRAL EAST - VC **2500 MW**
Impacts Total Transfer Capability 475 MW
TTC with All Lines In Service 2975 MW

MOSES___-ADIRNDCK_230_MAI

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES___230_L33P

Mon 05/28/2018 to Fri 06/01/2018
0700 Continuous 2000

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1600 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2000 MW 1600 MW

MARCY_SO_SERIES_COMP_I/S

Fri 06/01/2018 to Wed 10/31/2018
1800 Continuous 2359

Work scheduled by: NYISO

FWD
(Import)
CENTRAL EAST - VC **2740 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
S. RIPLEY-DUNKIRK__230_68		
Sat 06/16/2018 to Sat 02/01/2020		
1601 Continuous 0000		
Work scheduled by: NYISO		
UPDATED by NYISO 01/22/2018		
	SCH - PJ - NY	1950 MW 1350 MW
	Impacts Total Transfer Capability	150 MW 0 MW
	TTC with All Lines In Service	2100 MW 1350 MW
<hr/>		
MARCY___765_345_AT1		
Sat 08/04/2018 to Sun 08/05/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
ARR: 19		
	MOSES SOUTH	1750 MW
	Impacts Total Transfer Capability	1400 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
MARCY___765_345_AT2		
Tue 09/04/2018 to Sun 09/09/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
ARR: 19		
	MOSES SOUTH	1700 MW
	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
CLRKSCRN-OAKDALE__345_36		
Thu 09/06/2018 to Fri 09/07/2018		
0700 Continuous 1530		
Work scheduled by: NYSEG		
	CENTRAL EAST - VC	2650 MW
	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
FRASER__-GILBOA__345_GF5-35		
Mon 09/10/2018 to Fri 10/05/2018		
0700 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	2650 MW
	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
ROSETON_-ROCKTVRN_345_311		
Mon 09/10/2018 to Fri 09/28/2018		
0800 Continuous 1600		
Work scheduled by: CHGE		
	UPNY CONED	4400 MW
	Impacts Total Transfer Capability	1300 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
MARCY___345KV_CSC		
Tue 09/11/2018 to Tue 09/11/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	2925 MW
	Impacts Total Transfer Capability	50 MW
	TTC with All Lines In Service	2975 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA__345_230_AT4

Fri 09/14/2018 to Fri 09/14/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2000 MW 1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/17/2018 to Fri 09/21/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/17/2018 to Fri 09/21/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CLAY___-EDIC___345_2-15

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK___-NIAGARA_345_PA302	FWD	REV
Mon 10/01/2018 to Fri 10/05/2018	(Import)	(Export)
0500 Continuous 1700	SCH - OH - NY	900 MW 800 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1100 MW 800 MW
	TTC with All Lines In Service	2000 MW 1600 MW
<hr/>		
MOSES___-ADIRNDCK_230_MA2	FWD	
Mon 10/01/2018 to Wed 10/03/2018	(Import)	
0700 Continuous 1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
PANNELL_-CLAY___345_1	FWD	
Mon 10/01/2018 to Fri 10/05/2018	(Import)	
0700 Continuous 1700	WEST CENTRAL	1300 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	950 MW
	TTC with All Lines In Service	2250 MW
<hr/>		
HUDSONP_-FARRAGUT_345_B3402	FWD	REV
Tue 10/02/2018 to Tue 11/13/2018	(Import)	(Export)
0001 Continuous 2359	SCH - PJ - NY	2100 MW 1350 MW
Work scheduled by: PJM	Impacts Total Transfer Capability	0 MW 0 MW
	TTC with All Lines In Service	2100 MW 1350 MW
<hr/>		
MARCY___765_345_AT2	FWD	
Thu 10/04/2018 to Fri 10/05/2018	(Import)	
0500 Continuous 1730	MOSES SOUTH	1700 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
		ARR: 19
<hr/>		
MOSES___-ADIRNDCK_230_MA1	FWD	
Mon 10/08/2018 to Fri 10/12/2018	(Import)	
0700 Continuous 1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability	1050 MW
	TTC with All Lines In Service	3150 MW
<hr/>		
CHAT_DC_GC2	FWD	
Mon 10/08/2018 to Fri 11/23/2018	(Import)	
0700 Continuous 1700	MOSES SOUTH	2850 MW
Work scheduled by: HQ	Impacts Total Transfer Capability	300 MW
	TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event	Start	End	Time	Day	Zone	Direction	Impact	TTC
CHAT_DC_GC2	Mon 10/08/2018	Fri 11/23/2018	0700	Continuous	HQ	SCH - HQ - NY	500 MW	1000 MW
						(Export)		
						Impacts Total Transfer Capability	500 MW	
						TTC with All Lines In Service		1000 MW
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1550 MW	3150 MW
						(Import)		
						Impacts Total Transfer Capability	1600 MW	
						TTC with All Lines In Service		3150 MW
CHATGUAY-MASSENA_765_7040	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	SCH - HQ - NY	0 MW	1000 MW
						(Import) (Export)		
						Impacts Total Transfer Capability	1500 MW	1000 MW
						TTC with All Lines In Service	1500 MW	1000 MW
MARCY_765_345_AT1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1750 MW	3150 MW
						(Import)		
						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service		3150 MW
								ARR: 19
MARCY_765_345_AT2	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	1700 MW	3150 MW
						(Import)		
						Impacts Total Transfer Capability	1450 MW	
						TTC with All Lines In Service		3150 MW
								ARR: 19
MASSENA -MARCY_765_MSU1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	CENTRAL EAST - VC	2265 MW	2975 MW
						(Import)		
						Impacts Total Transfer Capability	710 MW	
						TTC with All Lines In Service		2975 MW
MASSENA -MARCY_765_MSU1	Sat 10/13/2018	Sat 10/27/2018	0100	Continuous	NYPA	MOSES SOUTH	500 MW	3150 MW
						(Import)		
						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service		3150 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Zone	FWD	REV
MASSENA -MARCY 765_MSU1	Sat 10/13/2018	Sat 10/27/2018		(Import)	(Export)
0100 Continuous 1730			SCH - HQ - NY	475 MW	1000 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1025 MW	0 MW
			TTC with All Lines In Service	1500 MW	1000 MW
MASSENA -MARCY 765_MSU1 & CHATGUAY-MASSENA 765_7040	Sat 10/13/2018	Sat 10/27/2018		FWD	
0100 1730			MOSES SOUTH	500 MW	
Work scheduled by:			Impacts Total Transfer Capability	2650 MW	
			TTC with All Lines In Service	3150 MW	
MASSENA -MARCY 765_MSU1 & MARCY_SO_SERIES_COMP_I/S	Sat 10/13/2018	Sat 10/27/2018		FWD	
0100 1730			CENTRAL EAST - VC	2080 MW	
Work scheduled by:			Impacts Total Transfer Capability	895 MW	
			TTC with All Lines In Service	2975 MW	
MOSES -MASSENA 230_MMS1 & MOSES -MASSENA 230_MMS2	Sat 10/13/2018	Sat 10/27/2018		FWD	REV
0100 1730			SCH - HQ - NY	850 MW	0 MW
Work scheduled by:			Impacts Total Transfer Capability	650 MW	1000 MW
			TTC with All Lines In Service	1500 MW	1000 MW
LINDN_CG-LNDVFT 345_V-3022	Mon 10/22/2018	Thu 10/25/2018		FWD	REV
0800 Continuous 1500			SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
LEEDS -HURLYAVE 345_301	Mon 10/22/2018	Fri 11/16/2018		FWD	
0800 Continuous 1600			UPNY CONED	4100 MW	
Work scheduled by: CHGE			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	5700 MW	
KINTIGH -ROCHESTR 345_SRL-39	Mon 10/29/2018	Fri 11/02/2018		FWD	
0500 Continuous 1700			DYSINGER EAST	1700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MAI

Mon 10/29/2018 to Fri 11/02/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 11/05/2018 to Fri 11/09/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2925 MW
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
MOSES SOUTH 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 11/19/2018 to Wed 11/21/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 11/26/2018 to Fri 12/21/2018
 0800 Continuous 1600
 Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Saturday ,March 17, 2018 to Monday ,September16, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Wed 12/26/2018 to Fri 12/28/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW