

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_45					FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M54					FWD	
Sun 11/26/2017	to	Tue 05/15/2018	<u>UPDATED</u>	<u>by CE</u>	<u>02/15/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
HUDSONP_-FARRAGUT_345_B3402					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>03/13/2018</u>	(Import) (Export)
0001	Continuous	2359				2600 MW 1300 MW
Work scheduled by: ConEd					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018				(Import) (Export)
0001		2359				2000 MW 1300 MW
Work scheduled by:					SCH - PJ - NY	750 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
MARION_-FARRAGUT_345_C3403					FWD	REV
Mon 01/15/2018	to	Sun 04/15/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>03/13/2018</u>	(Import) (Export)
0001	Continuous	2359				2600 MW 1300 MW
Work scheduled by: ConEd					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
S.RIPLEY-DUNKIRK_230_68					FWD	REV
Wed 02/07/2018	to	Thu 05/17/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>01/22/2018</u>	(Import) (Export)
1629	Continuous	0759				2600 MW 1300 MW
Work scheduled by: NYISO					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2750 MW 1300 MW
					TTC with All Lines In Service	
LONG_MTN-PLSNTVLY_345_398					FWD	REV
Mon 02/26/2018	to	Tue 05/01/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>02/21/2018</u>	(Import) (Export)
0001	Continuous	0300				700 MW 1300 MW
Work scheduled by: ConEd					SCH - NE - NY	700 MW 300 MW
					Impacts Total Transfer Capability	1400 MW 1600 MW
					TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-PLSNTVLY_345_398	FWD	REV
Mon 02/26/2018 to Tue 05/01/2018 0001 Continuous 0300	<u>UPDATED</u> by <u>ISONE</u> <u>02/21/2018</u>	(Import) (Export)
Work scheduled by: ConEd	SCH - NPX_1385	100 MW 100 MW
	Impacts Total Transfer Capability	100 MW 100 MW
	TTC with All Lines In Service	200 MW 200 MW
DUNWODIE-MOTTHAVN_345_72	FWD	
Thu 03/01/2018 to Fri 04/06/2018 0001 Continuous 0200	<u>EXTENDED</u> by <u>CONED</u> <u>03/05/2018</u>	(Import)
Work scheduled by: ConEd	SPR/DUN-SOUTH	3800 MW
	Impacts Total Transfer Capability	800 MW
	TTC with All Lines In Service	4600 MW
SCH-IMO-NYISO_LIMIT_1300	FWD	
Mon 03/05/2018 to Tue 03/13/2018 0730 Continuous 1730		(Import)
Work scheduled by: NGrid	SCH - OH - NY	1600 MW
	Impacts Total Transfer Capability	150 MW
	TTC with All Lines In Service	1750 MW
SCH-NYISO-NE_LIMIT_500		REV
Mon 03/05/2018 to Tue 05/01/2018 1400 Continuous 0300	<u>UPDATED</u> by <u>ISONE</u> <u>02/21/2018</u>	(Export)
Work scheduled by: ConEd	SCH - NE - NY	700 MW
	Impacts Total Transfer Capability	900 MW
	TTC with All Lines In Service	1600 MW
SCH-HQ_CEDARS-NYISO_LIMIT_160	FWD	
Wed 03/07/2018 to Fri 03/23/2018 0001 Continuous 0500		(Import)
Work scheduled by: HQ	SCH - HQ_CEDARS	160 MW
	Impacts Total Transfer Capability	39 MW
	TTC with All Lines In Service	199 MW
MOSES -ADIRNDCK_230_MA2	FWD	
Mon 03/12/2018 to Thu 03/15/2018 0700 Continuous 0938	<u>UPDATED</u> by <u>NYPA</u> <u>03/15/2018</u>	(Import)
Work scheduled by: NYPA	MOSES SOUTH	2300 MW
	Impacts Total Transfer Capability	850 MW
	TTC with All Lines In Service	3150 MW
SCH-IMO-NYISO_LIMIT_1300	FWD	
Wed 03/14/2018 to Sat 03/24/2018 0600 Continuous 1630	<u>UPDATED</u> by <u>NGRID</u> <u>03/09/2018</u>	(Import)
Work scheduled by: NGrid	SCH - OH - NY	1600 MW
	Impacts Total Transfer Capability	150 MW
	TTC with All Lines In Service	1750 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS ____ 345KV_R94301				
Thu 03/15/2018 to Thu 03/15/2018				FWD
0800 Daily(No Weekends) 1430				(Import)
Work scheduled by: NGrid		UPNY CONED		3800 MW
		Impacts Total Transfer Capability		1900 MW
		TTC with All Lines In Service		5700 MW
<hr/>				
SHOR_NPX-SHOREHAM_138_CSC				FWD REV
Fri 03/16/2018 to Fri 03/16/2018	UPDATED	by LI	03/15/2018	(Import) (Export)
0600 Continuous 1600				
Work scheduled by: LI		SCH - NPX_CSC		0 MW 0 MW
		Impacts Total Transfer Capability		330 MW 330 MW
		TTC with All Lines In Service		330 MW 330 MW
<hr/>				
LONG_MTN-PLSNTVLY_345_398 & ROTTRDAM-EASTOVER_230_38				FWD REV
Fri 03/16/2018 to Fri 03/16/2018				(Import) (Export)
0900 1100				
Work scheduled by:		SCH - NE - NY		600 MW 1100 MW
		Impacts Total Transfer Capability		800 MW 500 MW
		TTC with All Lines In Service		1400 MW 1600 MW
<hr/>				
ROTTRDAM-EASTOVER_230_38				FWD REV
Fri 03/16/2018 to Fri 03/16/2018				(Import) (Export)
0900 Daily(No Weekends) 1100				
Work scheduled by: NGrid		SCH - NE - NY		1400 MW 1600 MW
		Impacts Total Transfer Capability		0 MW 0 MW
		TTC with All Lines In Service		1400 MW 1600 MW
<hr/>				
NINEMILE-CLAY ____ 345_8				FWD
Fri 03/16/2018 to Fri 03/16/2018				(Import)
2000 Continuous 2100				
Work scheduled by: NGrid		OSWEGO EXPORT		5150 MW
		Impacts Total Transfer Capability		100 MW
		TTC with All Lines In Service		5250 MW
<hr/>				
SCRIBA ____ -VOLNEY ____ 345_21				FWD
Sat 03/17/2018 to Sat 03/17/2018				(Import)
0600 Daily 1500				
Work scheduled by: NGrid		OSWEGO EXPORT		5250 MW
		Impacts Total Transfer Capability		0 MW
		TTC with All Lines In Service		5250 MW
<hr/>				
SHORE_RD_345_138_BK_2				FWD
Sat 03/17/2018 to Sat 03/17/2018				(Import)
0800 Continuous 1500				
Work scheduled by: LI		CONED - LIPA		1350 MW
		Impacts Total Transfer Capability		150 MW
		TTC with All Lines In Service		1500 MW

ARR: 77

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EASTVIEW-SPRNBK__345_W79

Mon 03/19/2018 to Mon 03/19/2018
 0001 Continuous 0030
 Work scheduled by: ConEd

UPDATED by CONED 03/16/2018

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

BUCHAN_N-EASTVIEW_345_W93

Mon 03/19/2018 to Sun 03/25/2018
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 03/16/2018

FWD
 (Import)
 UPNY CONED **4350 MW**
 Impacts Total Transfer Capability 1350 MW
 TTC with All Lines In Service 5700 MW

RAMAPO__-BUCHAN_N_345_Y94

Mon 03/19/2018 to Fri 03/30/2018
 0001 Continuous 0100
 Work scheduled by: ConEd

UPDATED by CONED 03/16/2018

FWD
 (Import)
 UPNY CONED **4800 MW**
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 5700 MW

DUNWODIE_345KV_8

Mon 03/19/2018 to Sat 03/31/2018
 0001 Continuous 0200
 Work scheduled by: ConEd

FWD
 (Import)
 SPR/DUN-SOUTH **3800 MW**
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Mon 03/19/2018 to Tue 03/20/2018
 0200 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 03/15/2018

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 03/19/2018 to Tue 03/20/2018
 0200 Continuous 0200
 Work scheduled by: ConEd

UPDATED by CONED 03/15/2018

FWD
 (Import)
 SCH - PJM_HTP **350 MW**
 Impacts Total Transfer Capability 310 MW
 TTC with All Lines In Service 660 MW

SCH-IMO-NYISO_LIMIT_1000

Mon 03/19/2018 to Fri 03/23/2018
 0700 Continuous 1400
 Work scheduled by: NYSEG

FWD
 (Import)
 SCH - OH - NY **1300 MW**
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 1750 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY_____345_8				FWD
Tue 03/20/2018	to	Tue 03/20/2018		(Import)
1730	Continuous	1830	OSWEGO EXPORT	5150 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 5250 MW
W49TH_ST_345KV_6				FWD
Wed 03/21/2018	to	Wed 03/21/2018	<u>UPDATED</u> <u>by CONED</u> <u>03/15/2018</u>	(Import)
0100	Continuous	0200	SCH - PJM_HTP	350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
W49TH_ST_345KV_8				FWD
Wed 03/21/2018	to	Wed 03/21/2018	<u>UPDATED</u> <u>by CONED</u> <u>03/15/2018</u>	(Import)
0100	Continuous	0200	SCH - PJM_HTP	350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability 310 MW
				TTC with All Lines In Service 660 MW
VOLNEY__-CLAY_____345_6				FWD
Thu 03/22/2018	to	Thu 03/22/2018		(Import)
0730	Daily(No Weekends)	1700	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability 0 MW
				TTC with All Lines In Service 5250 MW
MARCY_____345KV_CSC				FWD
Mon 03/26/2018	to	Fri 04/13/2018		(Import)
0500	Continuous	1730	CENTRAL EAST - VC	2925 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 50 MW
				TTC with All Lines In Service 2975 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0				REV
Mon 03/26/2018	to	Fri 04/13/2018		(Export)
0500	Continuous	1800	SCH - HQ_CEDARS	0 MW
Work scheduled by: HQ				Impacts Total Transfer Capability 100 MW
				TTC with All Lines In Service 100 MW
MOSES__-ADIRNDCK_230_MA2				FWD
Mon 03/26/2018	to	Thu 03/29/2018		(Import)
0700	Continuous	1530	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability 850 MW
				TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
MAINESBG-WATRCURE_345_30						
Mon 03/26/2018	to	Tue 03/27/2018				
0900	Daily	1530		SCH - PJ - NY	2000 MW	1300 MW
Work scheduled by: NYSEG					Impacts Total Transfer Capability	750 MW 0 MW
					TTC with All Lines In Service	2750 MW 1300 MW
W49TH_ST_345KV_6						
Tue 03/27/2018	to	Tue 03/27/2018	<u>UPDATED</u>	<u>by CONED 03/15/2018</u>		
0100	Continuous	0159		SCH - PJM_HTP	350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8						
Tue 03/27/2018	to	Tue 03/27/2018	<u>UPDATED</u>	<u>by CONED 03/15/2018</u>		
0100	Continuous	0159		SCH - PJM_HTP	350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	310 MW
					TTC with All Lines In Service	660 MW
HANAWAFL-COLTON__115_5						
Wed 03/28/2018	to	Wed 03/28/2018				
0600	Continuous	1200		SCH - HQ_CEDARS	150 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
						ARR: 38
LAWRNCAV-HANAWAFL_115_5						
Wed 03/28/2018	to	Wed 03/28/2018				
0600	Continuous	1200		SCH - HQ_CEDARS	150 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
						ARR: 38
DENNISON-LAWRNCAV_115_5						
Wed 03/28/2018	to	Sat 03/31/2018				
0600	Continuous	1500		SCH - HQ_CEDARS	150 MW	100 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	49 MW 0 MW
					TTC with All Lines In Service	199 MW 100 MW
						ARR: 38
EASTVIEW-SPRNBK__345_W79						
Fri 03/30/2018	to	Sat 03/31/2018	<u>UPDATED</u>	<u>by CONED 03/16/2018</u>		
0001	Continuous	0200		UPNY CONED	4350 MW	
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93					FWD	
Fri 03/30/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
EASTVIEW-SPRNBK_345_W79					FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				UPNY CONED 4350 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
RAMAPO_-BUCHAN_N_345_Y94					FWD	
Mon 04/02/2018	to	Thu 04/12/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>03/16/2018</u>	(Import)
0001	Continuous	0200				UPNY CONED 4800 MW
Work scheduled by: ConEd					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 04/02/2018	to	Tue 04/03/2018	<u>UPDATED</u>	<u>by NE</u>	<u>02/15/2018</u>	(Import) (Export)
0700	Continuous	1700				SCH - NPX_CSC 0 MW 0 MW
Work scheduled by: ISONE					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
MOSES_-ADIRNDCK_230_MAI					FWD	
Mon 04/02/2018	to	Fri 04/06/2018				(Import)
0700	Continuous	1730				MOSES SOUTH 2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW
VOLNEY_-MARCY_345_19					FWD	
Mon 04/02/2018	to	Mon 04/02/2018				(Import)
0800	Daily(No Weekends)	1630				CENTRAL EAST - VC 2825 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	2975 MW
VOLNEY_-MARCY_345_19					FWD	
Mon 04/02/2018	to	Mon 04/02/2018				(Import)
0800	Daily(No Weekends)	1630				OSWEGO EXPORT 4900 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	5250 MW

ARR: 19

ARR: 19

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event ID	Start Date	End Date	Status	By	Effective Date	Work Scheduled by	Impact	REV
MALONE__-WILLIS__115_1-910	Tue 04/03/2018	Tue 04/03/2018	UPDATED	by NYPA	11/20/2017	0700 Continuous 1530	SCH - HQ_CEDARS Impacts Total Transfer Capability TTC with All Lines In Service	REV (Export) 60 MW 40 MW 100 MW
						Work scheduled by: NYPA		ARR: 38
SHOR_NPX-SHOREHAM_138_CSC	Wed 04/04/2018	Thu 04/12/2018	UPDATED	by NE	02/15/2018	0600 Continuous 1700	SCH - NPX_CSC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) (Export) 0 MW 0 MW 330 MW 330 MW 330 MW 330 MW
						Work scheduled by: LI		
GILBOA__-N.SCTLND_345_GNS-1	Thu 04/05/2018	Thu 04/05/2018				0830 Daily(No Weekends) 1300	CENTRAL EAST - VC Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 2520 MW 455 MW 2975 MW
						Work scheduled by: NGrid		
DUNWODIE_345KV_7	Fri 04/06/2018	Fri 04/06/2018	EXTENDED	by CONED	03/05/2018	0130 Continuous 0200	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 3800 MW 800 MW 4600 MW
						Work scheduled by: ConEd		
DUNWODIE_345KV_8	Fri 04/06/2018	Fri 04/06/2018	EXTENDED	by CONED	03/05/2018	0130 Continuous 0200	SPR/DUN-SOUTH Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) 3800 MW 800 MW 4600 MW
						Work scheduled by: ConEd		
LINDN_CG-LNDVFT__345_V-3022	Sun 04/08/2018	Fri 04/13/2018				1400 Continuous 1800	SCH - PJM_VFT Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) (Export) 0 MW 0 MW 315 MW 315 MW 315 MW 315 MW
						Work scheduled by: PJM		
BECK____-NIAGARA__345_PA302	Mon 04/09/2018	Fri 04/13/2018	UPDATED	by NYPA	01/22/2018	0500 Continuous 1700	SCH - OH - NY Impacts Total Transfer Capability TTC with All Lines In Service	FWD (Import) (Export) 1100 MW 950 MW 650 MW 950 MW 1750 MW 1900 MW
						Work scheduled by: NYPA		

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 04/09/2018 to Fri 04/13/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2300 MW
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER_-GILBOA___345_GF5-35

Mon 04/09/2018 to Fri 04/20/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
CENTRAL EAST - VC 2650 MW
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

PLSNTVLE-DUNWODIE_345_W89

Fri 04/13/2018 to Fri 04/13/2018
 0001 Continuous 0100
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F38

Fri 04/13/2018 to Fri 04/13/2018
 0001 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y86

Fri 04/13/2018 to Fri 04/13/2018
 0001 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE_345_W89

Fri 04/13/2018 to Fri 04/13/2018
 2230 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
UPNY CONED 4000 MW
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

CHATGUAY-MASSENA__765_7040

Sat 04/14/2018 to Thu 04/19/2018
 0100 Continuous 0600
 Work scheduled by: HQ

FWD
 (Import)
MOSES SOUTH 1550 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040			FWD	REV
Sat 04/14/2018	to	Thu 04/19/2018	(Import) (Export)	
0100	Continuous	0600	SCH - HQ - NY	0 MW 0 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	1500 MW 1000 MW
			TTC with All Lines In Service	1500 MW 1000 MW
CHAT_DC_GC1			FWD	
Sat 04/14/2018	to	Fri 05/25/2018	(Import)	
1700	Continuous	1800	MOSES SOUTH	2850 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
CHAT_DC_GC1				REV
Sat 04/14/2018	to	Fri 05/25/2018	(Export)	
1700	Continuous	1800	SCH - HQ - NY	500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
WOOD_ST_-PLSNTVLE_345_Y87			FWD	
Mon 04/16/2018	to	Mon 04/16/2018	(Import)	
0001	Continuous	0100	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
PLSNTVLE-DUNWODIE_345_W90			FWD	
Mon 04/16/2018	to	Wed 04/18/2018	(Import)	
0001	Continuous	2330	UPNY CONED	4000 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE			FWD	
Mon 04/16/2018	to	Tue 05/01/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501			FWD	
Mon 04/16/2018	to	Tue 05/01/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1	FWD
Mon 04/16/2018 to Tue 05/01/2018	(Import)
0001 Continuous 1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM	Impacts Total Transfer Capability 285 MW
	TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2	FWD
Mon 04/16/2018 to Tue 05/01/2018	(Import)
0001 Continuous 1800	SCH - PJM_NEPTUNE 375 MW
Work scheduled by: PJM	Impacts Total Transfer Capability 285 MW
	TTC with All Lines In Service 660 MW

MOSES__-ADIRNDCK_230_MAL	FWD
Mon 04/16/2018 to Fri 04/20/2018	(Import)
0700 Continuous 1730	MOSES SOUTH 2300 MW
Work scheduled by: NYPA	Impacts Total Transfer Capability 850 MW
	TTC with All Lines In Service 3150 MW

FRASER__345_FRASER SVC	FWD
Mon 04/16/2018 to Fri 04/20/2018	(Import)
0800 Continuous 1659	CENTRAL EAST - VC 2935 MW
Work scheduled by: NYSEG	Impacts Total Transfer Capability 40 MW
	TTC with All Lines In Service 2975 MW

WOOD_ST_-PLSNTVLE_345_Y87	FWD
Wed 04/18/2018 to Wed 04/18/2018	(Import)
2230 Continuous 2330	UPNY CONED 4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability 1700 MW
	TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD_ST__345_F39	FWD
Fri 04/20/2018 to Fri 04/20/2018	(Import)
0001 Continuous 0100	UPNY CONED 4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability 1700 MW
	TTC with All Lines In Service 5700 MW

WOOD_ST_-PLSNTVLE_345_Y87	FWD
Fri 04/20/2018 to Sun 04/22/2018	(Import)
0001 Continuous 2329	UPNY CONED 4000 MW
Work scheduled by: ConEd	Impacts Total Transfer Capability 1700 MW
	TTC with All Lines In Service 5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EFISHKIL-WOOD_ST__345_F39				FWD	
Sun 04/22/2018	to	Sun 04/22/2018		(Import)	
2230	Continuous	2329	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW	
			TTC with All Lines In Service	5700 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	<u>UPDATED</u> <u>by CONED</u> <u>03/16/2018</u>	(Import)	
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
EASTVIEW-SPRNBRK__345_W79				FWD	
Sun 04/22/2018	to	Sun 04/22/2018	<u>UPDATED</u> <u>by CONED</u> <u>03/16/2018</u>	(Import)	
2330	Continuous	2359	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	1350 MW	
			TTC with All Lines In Service	5700 MW	
MARCY____765_345_AT1				FWD	
Mon 04/23/2018	to	Mon 04/23/2018		(Import)	
0500	Continuous	1730	MOSES SOUTH	1750 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	3150 MW	
EDIC____-N.SCTLND_345_14				FWD	
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	
0600	Continuous	1800	CENTRAL EAST - VC	2240 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	735 MW	
			TTC with All Lines In Service	2975 MW	
CEDARS__-ROSEMNTB_115_2/22				FWD	REV
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	(Export)
0830	Continuous	1530	SCH - HQ_CEDARS	95 MW	100 MW
Work scheduled by: HQ			Impacts Total Transfer Capability	104 MW	0 MW
			TTC with All Lines In Service	199 MW	100 MW
SCH-HQ_CEDARS-NYISO_LIMIT_100				FWD	
Mon 04/23/2018	to	Wed 04/25/2018		(Import)	
0830	Continuous	1530	SCH - HQ_CEDARS	100 MW	
Work scheduled by: HQ			Impacts Total Transfer Capability	99 MW	
			TTC with All Lines In Service	199 MW	

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE_345_W89

Tue 04/24/2018 to Thu 04/26/2018
 0001 Continuous 2330
 Work scheduled by: ConEd

FWD
 (Import)
 UPNY CONED **4000 MW**
 Impacts Total Transfer Capability 1700 MW
 TTC with All Lines In Service 5700 MW

LOWVILLE-BOONVILLE_115_5

Tue 04/24/2018 to Tue 04/24/2018
 0800 Daily(No Weekends) 1430
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **199 MW 100 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

BULYMO__-BOONVILLE_115_6

Wed 04/25/2018 to Wed 04/25/2018
 0800 Daily(No Weekends) 1430
 Work scheduled by: NGrid

ARR: 38

FWD REV
 (Import) (Export)
 SCH - HQ_CEDARS **199 MW 100 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 199 MW 100 MW

OAKDALE -FRASER___345_32

Thu 04/26/2018 to Fri 04/27/2018
 0700 Continuous 1700
 Work scheduled by: NYSEG

UPDATED by NYSEG 03/09/2018

FWD
 (Import)
 CENTRAL EAST - VC **2650 MW**
 Impacts Total Transfer Capability 325 MW
 TTC with All Lines In Service 2975 MW

MOSES__-ADIRNDCK_230_MA2

Mon 04/30/2018 to Fri 05/04/2018
 0700 Continuous 1530
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HOMRC_NY-MAINS_NY_345_47

Mon 04/30/2018 to Fri 05/25/2018
 0700 Continuous 1730
 Work scheduled by: NYSEG

FWD REV
 (Import) (Export)
 SCH - PJ - NY **2500 MW 1300 MW**
 Impacts Total Transfer Capability 250 MW 0 MW
 TTC with All Lines In Service 2750 MW 1300 MW

MARCY_SO_SERIES_COMP_I/S

Tue 05/01/2018 to Mon 05/21/2018
 0001 Continuous 0559
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
PLSNTVLY-WOOD_ST__345_F30						(Import)	
Wed 05/02/2018	to	Wed 05/02/2018					
0001	Continuous	0100			UPNY CONED	4000 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1700 MW
						TTC with All Lines In Service	5700 MW
NRTH1385-NOR HBR__138_601						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>		
0600	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_602						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018					
0600		2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_601 & NRTH1385-NOR HBR__138_603						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018					
0600		2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>		
0600	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_602 & NRTH1385-NOR HBR__138_603						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018					
0600		2359			SCH - NPX_1385	0 MW	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW 200 MW
						TTC with All Lines In Service	200 MW 200 MW
NRTH1385-NOR HBR__138_603						(Import)	(Export)
Wed 05/02/2018	to	Sat 05/05/2018	<u>UPDATED</u>	<u>by LI</u>	<u>03/14/2018</u>		
0600	Continuous	2359			SCH - NPX_1385	100 MW	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW 100 MW
						TTC with All Lines In Service	200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
NRTH1385-NRTHPORT_138_NNC							
Wed 05/02/2018	to	Sat 05/05/2018	UPDATED	by LI	03/14/2018		
0600	Continuous	2359				SCH - NPX_1385	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS_____345_2							
Wed 05/02/2018	to	Fri 05/04/2018				SCH - NE - NY	750 MW
0800	Continuous	1500				Impacts Total Transfer Capability	650 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS_____345_2							
Wed 05/02/2018	to	Fri 05/04/2018				SCH - NPX_1385	100 MW
0800	Continuous	1500				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_601							
Wed 05/02/2018	to	Fri 05/04/2018				SCH - NPX_1385	0 MW
0800		1500				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_602							
Wed 05/02/2018	to	Fri 05/04/2018				SCH - NPX_1385	0 MW
0800		1500				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
N.SCTLND-ALPS_____345_2 & NRTH1385-NOR HBR__138_603							
Wed 05/02/2018	to	Fri 05/04/2018				SCH - NPX_1385	0 MW
0800		1500				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
PLSNTVLY-WOOD_ST__345_F30							
Fri 05/04/2018	to	Fri 05/04/2018				UPNY CONED	4000 MW
2230	Continuous	2330				Impacts Total Transfer Capability	1700 MW
Work scheduled by: ConEd						TTC with All Lines In Service	5700 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>				
SCH-NYISO-NE_LIMIT_800				REV
Sun 05/06/2018	to	Sun 05/06/2018		(Export)
0600	Continuous	1900	SCH - NE - NY	1000 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1600 MW
<hr/>				
NIAGARA_KINTIGH_345_NS1-38				FWD
Mon 05/07/2018	to	Fri 05/11/2018		(Import)
0500	Continuous	1700	DYSINGER EAST	1700 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
MOSES_ADIRNDCK_230_MA2				FWD
Mon 05/07/2018	to	Fri 05/11/2018		(Import)
0700	Continuous	1530	MOSES SOUTH	2100 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
N.SCTLND-LEEDS_345_93				FWD
Mon 05/07/2018	to	Fri 05/11/2018		(Import)
0800	Continuous	1500	CENTRAL EAST - VC	2650 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	325 MW
			TTC with All Lines In Service	2975 MW
<hr/>				
SCH-NYISO-NE_LIMIT_800				REV
Mon 05/07/2018	to	Wed 05/23/2018		(Export)
0800	Continuous	1900	SCH - NE - NY	1000 MW
Work scheduled by: ISONE			Impacts Total Transfer Capability	600 MW
			TTC with All Lines In Service	1600 MW
<hr/>				
ERIE E_S.RIPLEY_230_69 & WETHSRFD-MEYER_230_85/87				FWD
Sat 05/12/2018	to	Thu 05/17/2018		(Import)
0700		0759	DYSINGER EAST	2850 MW
Work scheduled by:			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<hr/>				
WETHSRFD-MEYER_230_85/87				FWD
Sat 05/12/2018	to	Fri 06/01/2018	UPDATED by NYSEG 02/15/2018	(Import)
0700	Continuous	1500	DYSINGER EAST	2850 MW
Work scheduled by: NYSEG			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>			
MOSES -ADIRNDCK_230_MA2		FWD	
Mon 05/14/2018 to Fri 05/18/2018		(Import)	
0700 Continuous 1530		MOSES SOUTH 2100 MW	
Work scheduled by: NYPA		Impacts Total Transfer Capability 1050 MW	
		TTC with All Lines In Service 3150 MW	
<hr/>			
CLAY -EDIC 345_1-16		FWD	
Mon 05/14/2018 to Fri 05/18/2018		(Import)	
0700 Continuous 1700		OSWEGO EXPORT 4850 MW	
Work scheduled by: NYPA		Impacts Total Transfer Capability 400 MW	
		TTC with All Lines In Service 5250 MW	
<hr/>			
N. SCTLND-LEEDS 345_94		FWD	
Mon 05/14/2018 to Mon 05/14/2018		(Import)	
0730 Daily(No Weekends) 1500		CENTRAL EAST - VC 2650 MW	
Work scheduled by: NGrid		Impacts Total Transfer Capability 325 MW	
		TTC with All Lines In Service 2975 MW	
<hr/>			
FROST_BR-LONG_MTN_345_352		FWD	REV
Thu 05/17/2018 to Tue 05/22/2018		(Import)	(Export)
0730 Continuous 1600		SCH - NE - NY 1150 MW	1600 MW
Work scheduled by: ISONE		Impacts Total Transfer Capability 250 MW	0 MW
		TTC with All Lines In Service 1400 MW	1600 MW
<hr/>			
ERIE E -S.RIPLEY_230_69 & WETHSRFD-MEYER 230_85/87		FWD	
Thu 05/17/2018 to Fri 06/01/2018		(Import)	
0800 1500		DYSINGER EAST 2850 MW	
Work scheduled by:		Impacts Total Transfer Capability 300 MW	
		TTC with All Lines In Service 3150 MW	
<hr/>			
S. RIPLEY-DUNKIRK 230_68		FWD	REV
Thu 05/17/2018 to Sat 06/16/2018	UPDATED by PJM 01/22/2018	(Import)	(Export)
0800 Continuous 1600		SCH - PJ - NY 1950 MW	1350 MW
Work scheduled by: PJM		Impacts Total Transfer Capability 150 MW	0 MW
		TTC with All Lines In Service 2100 MW	1350 MW
<hr/>			
MARCY 765_345_AT2		FWD	
Mon 05/21/2018 to Fri 05/25/2018		(Import)	
0500 Continuous 1730		MOSES SOUTH 1700 MW	
Work scheduled by: NYPA	ARR: 19	Impacts Total Transfer Capability 1450 MW	
		TTC with All Lines In Service 3150 MW	
<hr/>			

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1400

Mon 05/21/2018 to Fri 05/25/2018
 0600 Continuous 1800
 Work scheduled by: HQ

FWD
 (Import)
 SCH - HQ - NY **1400 MW**
 Impacts Total Transfer Capability 100 MW
 TTC with All Lines In Service 1500 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
 0600 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MARCY_-FRASANNX_345_UCC2-41

Mon 05/21/2018 to Fri 06/01/2018
 0600 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 CENTRAL EAST - VC **2500 MW**
 Impacts Total Transfer Capability 475 MW
 TTC with All Lines In Service 2975 MW

MOSES_-ADIRNDCK_230_MA1

Mon 05/28/2018 to Fri 06/01/2018
 0700 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2100 MW**
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

STLAWRNC-MOSES_230_L33P

Mon 05/28/2018 to Fri 06/01/2018
 0700 Continuous 2000
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - OH - NY **2000 MW 1600 MW**
 Impacts Total Transfer Capability 0 MW 0 MW
 TTC with All Lines In Service 2000 MW 1600 MW

MARCY_SO_SERIES_COMP_I/S

Fri 06/01/2018 to Wed 10/31/2018
 1800 Continuous 2359
 Work scheduled by: NYISO

FWD
 (Import)
 CENTRAL EAST - VC **2740 MW**
 Impacts Total Transfer Capability 235 MW
 TTC with All Lines In Service 2975 MW

S.RIPLEY-DUNKIRK_230_68

Sat 06/16/2018 to Sat 02/01/2020 **UPDATED by NYISO 01/22/2018**
 1601 Continuous 0000
 Work scheduled by: NYISO

FWD REV
 (Import) (Export)
 SCH - PJ - NY **1950 MW 1350 MW**
 Impacts Total Transfer Capability 150 MW 0 MW
 TTC with All Lines In Service 2100 MW 1350 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Sat 08/04/2018 to Sun 08/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY___765_345_AT2

Tue 09/04/2018 to Sun 09/09/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

CLRKSCRN-OAKDALE__345_36

Thu 09/06/2018 to Fri 09/07/2018
0700 Continuous 1530

Work scheduled by: NYSEG

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

FRASER_-GILBOA__345_GF5-35

Mon 09/10/2018 to Fri 10/05/2018
0700 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 325 MW
TTC with All Lines In Service 2975 MW

ROSETON_-ROCKTVRN_345_311

Mon 09/10/2018 to Fri 09/28/2018
0800 Continuous 1600

Work scheduled by: CHGE

FWD
(Import)
UPNY CONED **4400 MW**
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 5700 MW

MARCY___345KV_CSC

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2925 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2975 MW

MARCY___345KV_CSC & MARCY_SO_SERIES_COMP_I/S

Tue 09/11/2018 to Tue 09/11/2018
0500 1730

Work scheduled by:

FWD
(Import)
CENTRAL EAST - VC **2690 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2975 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT2

Tue 09/11/2018 to Tue 09/11/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

NIAGARA_345_230_AT4

Fri 09/14/2018 to Fri 09/14/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **2000 MW 1400 MW**
Impacts Total Transfer Capability 0 MW 200 MW
TTC with All Lines In Service 2000 MW 1600 MW

NIAGARA_-ROCHESTR_345_NR2

Mon 09/17/2018 to Fri 09/21/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
DYSINGER EAST **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA1

Mon 09/17/2018 to Fri 09/21/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

MOSES_-ADIRNDCK_230_MA1

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CLAY_-EDIC_345_2-15

Mon 09/24/2018 to Fri 09/28/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

BECK_-NIAGARA_345_PA302

Mon 10/01/2018 to Fri 10/05/2018
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - OH - NY **900 MW 800 MW**
Impacts Total Transfer Capability 1100 MW 800 MW
TTC with All Lines In Service 2000 MW 1600 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES -ADIRNDCK_230_MA2

Mon 10/01/2018 to Wed 10/03/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

PANNELL -CLAY_345_1

Mon 10/01/2018 to Fri 10/05/2018
0700 Continuous 1700

Work scheduled by: NYPA

FWD
(Import)
WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

HUDSONP -FARRAGUT_345_B3402

Tue 10/02/2018 to Tue 11/13/2018
0001 Continuous 2359

Work scheduled by: PJM

FWD REV
(Import) (Export)
SCH - PJ - NY **2100 MW 1350 MW**
Impacts Total Transfer Capability 0 MW 0 MW
TTC with All Lines In Service 2100 MW 1350 MW

MARCY_765_345_AT2

Thu 10/04/2018 to Fri 10/05/2018
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
(Import)
MOSES SOUTH **1700 MW**
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MOSES -ADIRNDCK_230_MA1

Mon 10/08/2018 to Fri 10/12/2018
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 10/08/2018 to Fri 11/23/2018
0700 Continuous 1700

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 10/08/2018 to Fri 11/23/2018
0700 Continuous 1700

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **1550 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **0 MW 0 MW**
 Impacts Total Transfer Capability 1500 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

MARCY__765_345_AT1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1750 MW**
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2265 MW**
 Impacts Total Transfer Capability 710 MW
 TTC with All Lines In Service 2975 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **500 MW**
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY__765_MSU1

Sat 10/13/2018 to Sat 10/27/2018
 0100 Continuous 1730
 Work scheduled by: NYPA

FWD REV
 (Import) (Export)
 SCH - HQ - NY **475 MW 1000 MW**
 Impacts Total Transfer Capability 1025 MW 0 MW
 TTC with All Lines In Service 1500 MW 1000 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1 & CHATGUAY-MASSENA___765_7040

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD
 (Import)
MOSES SOUTH 500 MW
 Impacts Total Transfer Capability 2650 MW
 TTC with All Lines In Service 3150 MW

MASSENA_-MARCY___765_MSU1 & MARCY_SO_SERIES_COMP_I/S

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD
 (Import)
CENTRAL EAST - VC 2080 MW
 Impacts Total Transfer Capability 895 MW
 TTC with All Lines In Service 2975 MW

MOSES___-MASSENA_230_MMS1 & MOSES___-MASSENA_230_MMS2

Sat 10/13/2018 to Sat 10/27/2018
 0100 1730

Work scheduled by:

FWD REV
 (Import) (Export)
SCH - HQ - NY 850 MW 0 MW
 Impacts Total Transfer Capability 650 MW 1000 MW
 TTC with All Lines In Service 1500 MW 1000 MW

LINDN_CG-LNDVFT___345_V-3022

Mon 10/22/2018 to Thu 10/25/2018
 0800 Continuous 1500

Work scheduled by: PJM

FWD REV
 (Import) (Export)
SCH - PJM_VFT 0 MW 0 MW
 Impacts Total Transfer Capability 315 MW 315 MW
 TTC with All Lines In Service 315 MW 315 MW

LEEDS___-HURLYAVE_345_301

Mon 10/22/2018 to Fri 11/16/2018
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
UPNY CONED 4100 MW
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

KINTIGH_-ROCHESTR_345_SR1-39

Mon 10/29/2018 to Fri 11/02/2018
 0500 Continuous 1700

Work scheduled by: NYPA

FWD
 (Import)
DYSINGER EAST 1700 MW
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MAI

Mon 10/29/2018 to Fri 11/02/2018
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
MOSES SOUTH 2100 MW
 Impacts Total Transfer Capability 1050 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

Mon 11/05/2018 to Fri 11/09/2018
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MARCY___345KV_CSC

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730

Work scheduled by: NYPA

FWD
 (Import)
 CENTRAL EAST - VC **2925 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2975 MW

MARCY___765_345_AT2

Fri 11/16/2018 to Sat 11/17/2018
 0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD
 (Import)
 MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA1

Mon 11/19/2018 to Wed 11/21/2018
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

MOSES___-ADIRNDCK_230_MA2

Mon 11/26/2018 to Fri 11/30/2018
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON__345_303

Mon 11/26/2018 to Fri 12/21/2018
 0800 Continuous 1600

Work scheduled by: CHGE

FWD
 (Import)
 UPNY CONED **4100 MW**
 Impacts Total Transfer Capability 1600 MW
 TTC with All Lines In Service 5700 MW

MOSES___-ADIRNDCK_230_MA2

Mon 12/03/2018 to Fri 12/07/2018
 0700 Continuous 1530

Work scheduled by: NYPA

FWD
 (Import)
 MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Sunday ,March 18, 2018 to Tuesday ,September17, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA2

FWD

Mon 12/10/2018 to Fri 12/14/2018
 0700 Continuous 1530

(Import)

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

MARCY___765_345_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018
 0500 Continuous 1730

(Import)

MOSES SOUTH **1700 MW**
 Impacts Total Transfer Capability 1450 MW
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

ARR: 19

MOSES___-ADIRNDCK_230_MA1

FWD

Wed 12/26/2018 to Fri 12/28/2018
 0700 Continuous 1530

(Import)

MOSES SOUTH **2300 MW**
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA