

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/17/2018</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/17/2018</u>	(Import)
0001	Continuous	2359				<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	
Mon 01/15/2018	to	Wed 05/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>04/09/2018</u>	(Import) (Export)
0001	Continuous	2359				<b>2100 MW 1350 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Wed 05/30/2018				(Import) (Export)
0001		2359				<b>2050 MW 1300 MW</b>
Work scheduled by:					SCH - PJ - NY	
					Impacts Total Transfer Capability 50 MW 50 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	
Mon 01/15/2018	to	Wed 05/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>04/09/2018</u>	(Import) (Export)
0001	Continuous	2359				<b>2100 MW 1350 MW</b>
Work scheduled by: ConEd					SCH - PJ - NY	
					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>S.RIPLEY-DUNKIRK_230_68</b>					FWD	
Wed 02/07/2018	to	Mon 06/04/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>	(Import) (Export)
1629	Continuous	2000				<b>1950 MW 1350 MW</b>
Work scheduled by: NYISO					SCH - PJ - NY	
					Impacts Total Transfer Capability 150 MW 0 MW	
					TTC with All Lines In Service 2100 MW 1350 MW	
<b>CHAT_DC_GC1</b>					FWD	
Sat 04/14/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)
0100	Continuous	1800				<b>2850 MW</b>
Work scheduled by: HQ					MOSES SOUTH	
					Impacts Total Transfer Capability 300 MW	
					TTC with All Lines In Service 3150 MW	

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday, November 20, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC1**

Sat 04/14/2018 to Fri 05/25/2018  
0100 Continuous 1800

**UPDATED by HQ 04/11/2018**

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

REV  
(Export)

**STLAWRNC-MOSES 230\_L33P**

Mon 04/30/2018 to Tue 05/29/2018  
0456 Continuous 0659

**EXT FORCE by IESO 05/11/2018**

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 2000 MW

FWD REV  
(Import) (Export)

**SCH-HQ-NYISO\_LIMIT\_1200**

Thu 05/10/2018 to Fri 05/25/2018  
1500 Continuous 2100

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1500 MW

FWD  
(Import)

**ERIE E -S.RIPLEY\_230\_69 & WETHSRFD-S.PERRY\_230\_85**

Sat 05/12/2018 to Fri 06/01/2018  
0700 1500

Work scheduled by:

DYSINGER EAST  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**S.PERRY -MEYER 230\_87**

Sat 05/12/2018 to Fri 06/01/2018  
0700 Continuous 1500

**UPDATED by NYSEG 02/15/2018**

Work scheduled by: NYSEG

DYSINGER EAST  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**WETHSRFD-S.PERRY\_230\_85**

Sat 05/12/2018 to Fri 06/01/2018  
0700 Continuous 1500

**UPDATED by NYSEG 02/15/2018**

Work scheduled by: NYSEG

DYSINGER EAST  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

**MARCY 765\_345\_AT2**

Mon 05/14/2018 to Sat 05/19/2018  
0500 Continuous 2300

**UPDATED by NYPA 05/16/2018**

Work scheduled by: NYPA

**ARR: 19**

MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD	REV
<b>HOMR_NYW-PIERC_NY_345_48</b>					(Import)	(Export)
Mon 05/14/2018	to	Fri 05/18/2018	<u>UPDATED</u>	<u>by NYSEG</u>	<u>05/14/2018</u>	
0800	Continuous	2000				
Work scheduled by: NYSEG					SCH - PJ - NY	<b>2100 MW</b>
					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	2100 MW
<hr/>					FWD	REV
<b>SCH-NE-NYISO_LIMIT_400</b>					(Import)	(Export)
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>	
1500	Continuous	1859				
Work scheduled by: ISONE					SCH - NE - NY	<b>600 MW</b>
					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
<hr/>					FWD	REV
<b>SCH-NYISO-NE_LIMIT_1100</b>					(Import)	(Export)
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>	
1500	Continuous	1859				
Work scheduled by: ISONE					SCH - NE - NY	<b>1300 MW</b>
					Impacts Total Transfer Capability	300 MW
					TTC with All Lines In Service	1600 MW
<hr/>					FWD	REV
<b>NRTH1385-NOR_HBR_138_601</b>					(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>	
0600	Continuous	2359				
Work scheduled by: LI					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
<b>NRTH1385-NOR_HBR_138_601 &amp; NRTH1385-NOR_HBR_138_602</b>					(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018				
0600		2359				
Work scheduled by:					SCH - NPX_1385	<b>0 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
<b>NRTH1385-NOR_HBR_138_601 &amp; NRTH1385-NOR_HBR_138_603</b>					(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018				
0600		2359				
Work scheduled by:					SCH - NPX_1385	<b>0 MW</b>
					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	200 MW
<hr/>					FWD	REV
<b>NRTH1385-NOR_HBR_138_602</b>					(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>	
0600	Continuous	2359				
Work scheduled by: LI					SCH - NPX_1385	<b>100 MW</b>
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Tue 05/15/2018 to Wed 05/23/2018  
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Tue 05/15/2018 to Wed 05/23/2018 **EXTENDED** **by LI** **05/17/2018**  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Tue 05/15/2018 to Wed 05/23/2018 **EXTENDED** **by LI** **05/17/2018**  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**DUNWODIE\_345KV\_3**

Wed 05/16/2018 to Wed 05/16/2018  
 0201 Continuous 0230

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

-----  
**DUNWODIE\_345KV\_4**

Wed 05/16/2018 to Wed 05/16/2018  
 0201 Continuous 0230

Work scheduled by: ConEd

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3800 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	4600 MW

-----  
**PLSNTVLE-DUNWODIE\_345\_W89**

Wed 05/16/2018 to Wed 05/16/2018  
 0201 Continuous 0230

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

-----  
**MARCY\_SO\_SERIES\_COMP\_I/S**

Wed 05/16/2018 to Fri 05/18/2018  
 1704 Continuous 2059

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2740 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

Wed 05/16/2018 to Wed 05/16/2018  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

Wed 05/16/2018 to Wed 05/16/2018  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Wed 05/16/2018 to Wed 05/16/2018  
 1730 Continuous 1800  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Thu 05/17/2018 to Thu 05/17/2018  
 0001 0030  
 Work scheduled by:

FWD  
 (Import)  
 SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Fri 05/18/2018 to Fri 05/18/2018 **CANCELLED by ConEd 05/16/2018**  
 0001 Continuous 0100  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_\_345\_F38**

Fri 05/18/2018 to Fri 05/18/2018 **CANCELLED by ConEd 05/16/2018**  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Fri 05/18/2018 to Fri 05/18/2018 **CANCELLED by ConEd 05/16/2018**  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PLSNTVLE-DUNWODIE_345_W89</b>					FWD	
Fri 05/18/2018	to	Fri 05/18/2018	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>05/16/2018</u></b>	(Import)
2230	Continuous	2330				UPNY CONED <b>4000 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1700 MW	
					TTC with All Lines In Service 5700 MW	
<b>MILLWOOD_345KV_18</b>					FWD	
Sat 05/19/2018	to	Sat 05/19/2018				(Import)
0001	Continuous	0030				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	(Import)
2100	Continuous	2300				CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 710 MW	
					TTC with All Lines In Service 2975 MW	
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	(Import)
2100	Continuous	2300				MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 2650 MW	
					TTC with All Lines In Service 3150 MW	
<b>MASSENA_-MARCY___765_MSU1</b>					FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	(Import) (Export)
2100	Continuous	2300				SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1025 MW 0 MW	
					TTC with All Lines In Service 1500 MW 1000 MW	
<b>SCH-HQ-NYISO_LIMIT_0</b>					FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	(Import)
2100	Continuous	2300				SCH - HQ - NY <b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1500 MW	
					TTC with All Lines In Service 1500 MW	
<b>SCH-NYISO-HQ_LIMIT_0</b>					REV	
Sat 05/19/2018	to	Sat 05/19/2018	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	(Export)
2100	Continuous	2300				SCH - HQ - NY <b>0 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1000 MW	
					TTC with All Lines In Service 1000 MW	

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RS3 &amp; SPRNBK__345KV_RS4</b>					FWD
Sun 05/20/2018	to	Sun 05/20/2018			(Import)
2130		2200		SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by:					Impacts Total Transfer Capability 1400 MW
					TTC with All Lines In Service 4600 MW
<b>CLAY__-EDIC__345_1-16</b>					FWD
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/01/2018</u>
0700	Continuous	1530		OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 5250 MW
<b>MOSES__-ADIRNDCK_230_MA2</b>					FWD
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>
0700	Continuous	1730		MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 1050 MW
					TTC with All Lines In Service 3150 MW
<b>SCH-HQ-NYISO_LIMIT_1400</b>					FWD
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>
0700	Continuous	1800		SCH - HQ - NY	<b>1400 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 100 MW
					TTC with All Lines In Service 1500 MW
<b>FRASANX-COOPERS__345_UCC2-41</b>					FWD
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>
0700	Continuous	1730		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>					FWD
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>
0700	Continuous	1730		CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 475 MW
					TTC with All Lines In Service 2975 MW
<b>SCH-NYISO-NE_LIMIT_900</b>					REV
Mon 05/21/2018	to	Mon 05/21/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>
0730	Continuous	1859		SCH - NE - NY	<b>1100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
<b>FROST_BR-LONG_MTN_345_352</b>		
Mon 05/21/2018 to Tue 05/22/2018		(Import) (Export)
0730 Continuous 1600		
Work scheduled by: ISONE		
<b><u>CANCELLED</u> by ISONE <u>05/20/2018</u></b>		
SCH - NE - NY	<b>1150 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	250 MW	0 MW
TTC with All Lines In Service	1400 MW	1600 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>		
Mon 05/21/2018 to Tue 05/22/2018		(Export)
1900 Continuous 1600		
Work scheduled by: ISONE		
<b><u>CANCELLED</u> by ISONE <u>05/20/2018</u></b>		
SCH - NE - NY		<b>1400 MW</b>
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1600 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>		
Tue 05/22/2018 to Wed 05/23/2018		(Import)
0500 Continuous 0300		
Work scheduled by: ORU		
<b><u>UPDATED</u> by CONED <u>05/20/2018</u></b>		
UPNY CONED	<b>4800 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	5700 MW	
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR_HBR_138_601</b>		
Tue 05/22/2018 to Wed 05/23/2018		(Import) (Export)
0800 2359		
Work scheduled by:		
<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR_HBR_138_602</b>		
Tue 05/22/2018 to Wed 05/23/2018		(Import) (Export)
0800 2359		
Work scheduled by:		
<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW
<b>N.SCTLND-ALPS_345_2 &amp; NRTH1385-NOR_HBR_138_603</b>		
Tue 05/22/2018 to Wed 05/23/2018		(Import) (Export)
0800 2359		
Work scheduled by:		
<b>SCH - NPX_1385</b>	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW
<b>N.SCTLND-ALPS_345_2</b>		
Tue 05/22/2018 to Thu 05/24/2018		(Import) (Export)
0800 Continuous 1500		
Work scheduled by: NGrid		
<b>SCH - NE - NY</b>	<b>750 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	650 MW	250 MW
TTC with All Lines In Service	1400 MW	1600 MW



# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday, November 20, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
<b>N. SCTLND-ALPS 345_2</b>				
Tue 05/22/2018	to	Thu 05/24/2018		
0800	Continuous	1500	SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	100 MW
			TTC with All Lines In Service	200 MW
<b>DENNISON-NORFOLK 115_4</b>				
Tue 05/22/2018	to	Tue 05/22/2018		
0815	Daily(No Weekends)	1615	SCH - HQ_CEDARS	<b>150 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	40 MW
			TTC with All Lines In Service	190 MW
<b>WOOD_ST -PLSNTVLE 345_Y87</b>				
Wed 05/23/2018	to	Wed 05/23/2018		
0301	Continuous	0330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
<b>DUNWODIE 345KV_6</b>				
Wed 05/23/2018	to	Thu 05/24/2018		
0301	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE 345KV_8</b>				
Wed 05/23/2018	to	Thu 05/24/2018		
0301	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE 345_W90</b>				
Wed 05/23/2018	to	Thu 05/24/2018		
0301	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
<b>BECK -NIAGARA 345_PA302</b>				
Wed 05/23/2018	to	Thu 05/24/2018		
0500	Continuous	1800	SCH - OH - NY	<b>900 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability	1100 MW
			TTC with All Lines In Service	2000 MW

**ARR: 38**

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday, November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_601**

Wed 05/23/2018 to Wed 05/23/2018  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_602**

Wed 05/23/2018 to Wed 05/23/2018  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**FROST\_BR-SOUTHNGT\_345\_329 & NRTH1385-NOR HBR\_\_138\_603**

Wed 05/23/2018 to Wed 05/23/2018  
0700 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

**SCH-NE-NYISO\_LIMIT\_400**

Wed 05/23/2018 to Thu 05/24/2018  
0700 Continuous 1500

Work scheduled by: ISONE

	FWD
	(Import)
SCH - NE - NY	<b>600 MW</b>
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1400 MW

**SCH-NYISO-NE\_LIMIT\_700**

Wed 05/23/2018 to Thu 05/24/2018  
0700 Continuous 1500

Work scheduled by: ISONE

	REV
	(Export)
SCH - NE - NY	<b>900 MW</b>
Impacts Total Transfer Capability	700 MW
TTC with All Lines In Service	1600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

Thu 05/24/2018 to Thu 05/24/2018  
0130 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Sat 05/26/2018 to Sat 05/26/2018  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4000 MW</b>
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>WOOD_ST_-PLSNTVLE_345_Y86</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	0030	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>EFISHKIL-WOOD_ST__345_F38</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
0001	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>SCH-NYISO-HQ_LIMIT_800</b>				REV
Sat 05/26/2018	to	Sat 05/26/2018		(Export)
0700	Continuous	1800	SCH - HQ - NY	<b>800 MW</b>
Work scheduled by: HQ				Impacts Total Transfer Capability 200 MW
				TTC with All Lines In Service 1000 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
2300	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>				FWD
Sat 05/26/2018	to	Sat 05/26/2018		(Import)
2300	Continuous	2330	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1700 MW
				TTC with All Lines In Service 5700 MW
<b>EASTVIEW-SPRNBK__345_W78</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<b>UPDATED by CONED 05/16/2018</b>	(Import)
0300	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW
<b>MILLWOOD-EASTVIEW_345_W85</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<b>UPDATED by CONED 05/16/2018</b>	(Import)
0300	Continuous	0200	UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 1350 MW
				TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SPRNBK\_\_345KV\_RNS3**

Mon 05/28/2018 to Tue 05/29/2018  
0300 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 05/16/2018**

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD  
(Import)

**SCH-IMO-NYISO\_LIMIT\_1000**

Tue 05/29/2018 to Fri 06/01/2018  
0500 Continuous 1700

Work scheduled by: NYPA

**UPDATED by NYISO 05/15/2018**

SCH - OH - NY **1300 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 2000 MW

FWD  
(Import)

**STLAWRNC-MOSES\_\_230\_L33P**

Tue 05/29/2018 to Fri 06/01/2018  
0700 Continuous 2000

Work scheduled by: NYPA

**UPDATED by NYPA 05/09/2018**

SCH - OH - NY **2000 MW 1600 MW**  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 2000 MW 1600 MW

FWD REV  
(Import) (Export)

**BROWNFLS-TAYLORVL\_115\_4**

Tue 05/29/2018 to Sat 06/02/2018  
0700 Continuous 1800

Work scheduled by: NGrid

**ARR: 38**

SCH - HQ\_CEDARS **70 MW 40 MW**  
Impacts Total Transfer Capability 120 MW 0 MW  
TTC with All Lines In Service 190 MW 40 MW

FWD REV  
(Import) (Export)

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Wed 05/30/2018 to Wed 05/30/2018  
0600 Continuous 1000

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE-DUFFYAVE\_345\_501**

Wed 05/30/2018 to Wed 05/30/2018  
0600 Continuous 1000

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

**NEWBRDGE\_345\_138\_BK\_1**

Wed 05/30/2018 to Wed 05/30/2018  
0600 Continuous 1000

Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

FWD  
(Import)

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	ARR	SCH	FWD	REV
<b>NEWBRDGE_345_138_BK_2</b>	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	1000		SCH - PJM_NEPTUNE	FWD (Import) <b>375 MW</b>	
					Work scheduled by: LI		Impacts Total Transfer Capability	285 MW	
							TTC with All Lines In Service	660 MW	
<b>SCH-NYISO-NE_LIMIT_800</b>	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	1800		SCH - NE - NY	REV (Export) <b>1000 MW</b>	
					Work scheduled by: ISONE		Impacts Total Transfer Capability	600 MW	
							TTC with All Lines In Service	1600 MW	
<b>DENNISON-ROSEMNTB_115_2/22</b>	Thu 05/31/2018	Thu 05/31/2018	0800	Daily(No Weekends)	1630		SCH - HQ_CEDARS	FWD (Import)	REV (Export)
					Work scheduled by: NGrid	<b>ARR: 38</b>	Impacts Total Transfer Capability	95 MW	40 MW
							TTC with All Lines In Service	190 MW	40 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>	Fri 06/01/2018	Wed 10/31/2018	1800	Continuous	2359		CENTRAL EAST - VC	FWD (Import) <b>2740 MW</b>	
					Work scheduled by: NYISO		Impacts Total Transfer Capability	235 MW	
							TTC with All Lines In Service	2975 MW	
<b>SCH-IMO_NY_NIAG_CB_3122_W/BB</b>	Sat 06/02/2018	Sat 06/02/2018	0500	Continuous	1700		SCH - OH - NY	FWD (Import)	REV (Export)
					Work scheduled by: NYPA		Impacts Total Transfer Capability	300 MW	200 MW
							TTC with All Lines In Service	2000 MW	1600 MW
<b>BROWNFLS-TAYLORVL_115_3</b>	Mon 06/04/2018	Sat 06/09/2018	0700	Continuous	1800		SCH - HQ_CEDARS	FWD (Import)	REV (Export)
					Work scheduled by: NGrid	<b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	40 MW
							TTC with All Lines In Service	190 MW	40 MW
<b>BROWNFLS-TAYLORVL_115_3</b>	Mon 06/04/2018	Sat 06/09/2018	0700	Daily	1800		SCH - HQ_CEDARS	FWD (Import)	REV (Export)
					Work scheduled by: NGrid	<b>CANCELLED by NGrid 05/16/2018</b> <b>ARR: 38</b>	Impacts Total Transfer Capability	120 MW	40 MW
							TTC with All Lines In Service	190 MW	40 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**LEEDS\_345\_LEEDS SVC**

Mon 06/04/2018 to Fri 06/15/2018  
 0800 Continuous 1500  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW

**LEEDS\_345\_LEEDS SVC & MARCY\_SO\_SERIES\_COMP\_I/S**

Mon 06/04/2018 to Fri 06/15/2018  
 0800 1500  
 Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC **2715 MW**  
 Impacts Total Transfer Capability 260 MW  
 TTC with All Lines In Service 2975 MW

**BROWNFLS-TAYLORVL\_115\_4**

Mon 06/11/2018 to Sat 06/16/2018  
 0700 Continuous 1800  
 Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 06/18/2018 to Thu 06/21/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD  
 (Import)  
 DYSINGER EAST **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**BROWNFLS-TAYLORVL\_115\_3**

Mon 06/18/2018 to Sat 06/23/2018  
 0700 Continuous 1800  
 Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **70 MW 40 MW**  
 Impacts Total Transfer Capability 120 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**S.RIPLEY-DUNKIRK\_230\_68**

Fri 06/22/2018 to Sat 02/01/2020  
 2000 Continuous 0000  
 Work scheduled by: NYISO

**UPDATED by NYISO 05/14/2018**

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **1950 MW 1350 MW**  
 Impacts Total Transfer Capability 150 MW 0 MW  
 TTC with All Lines In Service 2100 MW 1350 MW

**SCH-NYISO-IMO\_NIAGARA\_CB\_3022**

Thu 06/28/2018 to Thu 06/28/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1300 MW 1150 MW**  
 Impacts Total Transfer Capability 700 MW 450 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1** FWD  
 (Import)  
 Sat 08/04/2018 to Sun 08/05/2018 **UPDATED by NYPA 04/17/2018**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2** FWD  
 (Import)  
 Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_\_345\_36** FWD  
 (Import)  
 Thu 09/06/2018 to Fri 09/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYSEG  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**FRASER\_-GILBOA\_\_345\_GF5-35** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 10/05/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**ROSETON\_-ROCKTVRN\_345\_311** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

**MARCY\_\_\_345KV\_CSC** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730  
 Work scheduled by:  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_345\_230\_AT4**

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MAL**

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW



# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345\_230\_AT4**

Mon 09/24/2018 to Fri 09/28/2018  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	2000 MW	1400 MW
Impacts Total Transfer Capability	0 MW	200 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	4850 MW
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

**WATRCURE\_345\_230\_BK 1**

Mon 09/24/2018 to Thu 09/27/2018  
0800 Continuous 1530

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	2100 MW	1350 MW
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

**BECK\_\_-NIAGARA\_345\_PA302**

Mon 10/01/2018 to Fri 10/05/2018  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	900 MW	800 MW
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 10/01/2018 to Wed 10/03/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2100 MW
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**PANNELL\_-CLAY\_\_345\_1**

Mon 10/01/2018 to Fri 10/05/2018  
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	1300 MW
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP\_-FARRAGUT\_345\_B3402

Tue 10/02/2018 to Tue 11/13/2018  
 0001 Continuous 2359  
 Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2100 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

MARCY\_\_\_765\_345\_AT2

Thu 10/04/2018 to Fri 10/05/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 10/08/2018 to Fri 10/12/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

CHAT\_DC\_GC2

Mon 10/08/2018 to Fri 11/23/2018  
 0700 Continuous 1700  
 Work scheduled by: HQ

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

CHAT\_DC\_GC2

Mon 10/08/2018 to Fri 11/23/2018  
 0700 Continuous 1700  
 Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

CHATGUAY-MASSENA\_\_\_765\_7040

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730  
 Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>1550 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	3150 MW

CHATGUAY-MASSENA\_\_\_765\_7040

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730  
 Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1400 MW
		TTC with All Lines In Service 3150 MW
<b>MARCY___765_345_AT2</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA	<b>ARR: 19</b>	Impacts Total Transfer Capability 1450 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import) (Export)
0100	Continuous 1730	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	1730	MOSES SOUTH <b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<b>MASSENA_-MARCY___765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	1730	CENTRAL EAST - VC <b>2080 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 895 MW
		TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday, November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----

**MOSES -MASSENA\_230\_MMS1 & MOSES -MASSENA\_230\_MMS2**

Sat 10/13/2018 to Sat 10/27/2018  
0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----

**STONYRDG-HILLSIDE\_230\_72**

Wed 10/17/2018 to Thu 10/18/2018  
0800 Continuous 1530

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

-----

**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 10/22/2018 to Thu 10/25/2018  
0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

-----

**LEEDS -HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

-----

**KINTIGH -ROCHESTR\_345\_SRL-39**

Mon 10/29/2018 to Fri 11/02/2018  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----

**MOSES -ADIRNDCK\_230\_MA1**

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

-----

**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Sat 11/03/2018 to Sun 11/18/2018  
0001 Continuous 1800

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE-DUFFYAVE_345_501</b>			FWD
Sat 11/03/2018	to	Sun 11/18/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 660 MW
			TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_1</b>			FWD
Sat 11/03/2018	to	Sun 11/18/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<b>NEWBRDGE_345_138_BK_2</b>			FWD
Sat 11/03/2018	to	Sun 11/18/2018	(Import)
0001	Continuous	1800	SCH - PJM_NEPTUNE <b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability 285 MW
			TTC with All Lines In Service 660 MW
<b>MOSES -ADIRNDCK_230_MA1</b>			FWD
Mon 11/05/2018	to	Fri 11/09/2018	(Import)
0700	Continuous	1530	MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 850 MW
			TTC with All Lines In Service 3150 MW
<b>FROST_BR-LONG_MTN_345_352</b>			FWD      REV
Sun 11/11/2018	to	Sun 11/11/2018	(Import) (Export)
0700	Continuous	1800	SCH - NE - NY <b>1300 MW 1600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability 100 MW 0 MW
			TTC with All Lines In Service 1400 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_1000</b>			FWD
Sun 11/11/2018	to	Sun 11/11/2018	(Import)
0700	Continuous	1800	SCH - NE - NY <b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability 200 MW
			TTC with All Lines In Service 1400 MW
<b>MARCY 345KV_CSC</b>			FWD
Fri 11/16/2018	to	Sat 11/17/2018	(Import)
0500	Continuous	1730	CENTRAL EAST - VC <b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability 50 MW
			TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_\_345\_303

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MARCY\_\_\_765\_345\_AT2

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,May 21, 2018 to Wednesday,November 20, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Wed 12/26/2018 to Fri 12/28/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LEEDS\_\_\_345\_LEEDS SVC**

Mon 03/11/2019 to Fri 03/22/2019  
 0800 Continuous 1600

Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW