

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_45</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
<b>W49TH_ST-E13THSTA_345_M54</b>					FWD	
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>	(Import)
0001	Continuous	2359				3800 MW
Work scheduled by: ConEd					SPR/DUN-SOUTH	800 MW
					Impacts Total Transfer Capability	4600 MW
					TTC with All Lines In Service	
<b>HUDSONP_-FARRAGUT_345_B3402</b>					FWD	REV
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				2100 MW 1350 MW
Work scheduled by: ConEd					SCH - PJ - NY	0 MW 0 MW
					Impacts Total Transfer Capability	2100 MW 1350 MW
					TTC with All Lines In Service	
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Sat 06/30/2018				(Import) (Export)
0001		2359				2050 MW 1300 MW
Work scheduled by:					SCH - PJ - NY	50 MW 50 MW
					Impacts Total Transfer Capability	2100 MW 1350 MW
					TTC with All Lines In Service	
<b>MARION_-FARRAGUT_345_C3403</b>					FWD	REV
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>	(Import) (Export)
0001	Continuous	2359				2100 MW 1350 MW
Work scheduled by: ConEd					SCH - PJ - NY	0 MW 0 MW
					Impacts Total Transfer Capability	2100 MW 1350 MW
					TTC with All Lines In Service	
<b>S.RIPLEY-DUNKIRK_230_68</b>					FWD	REV
Wed 02/07/2018	to	Mon 06/04/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>	(Import) (Export)
1629	Continuous	2000				1950 MW 1350 MW
Work scheduled by: NYISO					SCH - PJ - NY	150 MW 0 MW
					Impacts Total Transfer Capability	2100 MW 1350 MW
					TTC with All Lines In Service	
<b>CHAT_DC_GC1</b>					FWD	
Sat 04/14/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)
0100	Continuous	1800				2850 MW
Work scheduled by: HQ					MOSES SOUTH	300 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sat 04/14/2018	to	Fri 05/25/2018	<b>UPDATED</b>	<b>by HQ</b>	<b>04/11/2018</b>	(Export)
0100	Continuous	1800				<b>500 MW</b>
Work scheduled by: HQ						500 MW
						1000 MW
<b>STLAWRNC-MOSES 230_L33P</b>						FWD REV
Mon 04/30/2018	to	Tue 05/29/2018	<b>EXT FORCE</b>	<b>by IESO</b>	<b>05/11/2018</b>	(Import) (Export)
0456	Continuous	0659				<b>2000 MW 1600 MW</b>
Work scheduled by: IESO						0 MW 0 MW
						2000 MW 1600 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>						FWD
Thu 05/10/2018	to	Fri 05/25/2018				(Import)
1500	Continuous	2100				<b>1200 MW</b>
Work scheduled by: HQ						300 MW
						1500 MW
<b>ERIE E -S.RIPLEY_230_69 &amp; WETHSRFD-S.PERRY_230_85</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018				(Import)
0700		1500				<b>2850 MW</b>
Work scheduled by:						300 MW
						3150 MW
<b>S.PERRY -MEYER 230_87</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG						300 MW
						3150 MW
<b>WETHSRFD-S.PERRY_230_85</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG						300 MW
						3150 MW
<b>MARCY 765_345_AT2</b>						FWD
Mon 05/14/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)
0500	Continuous	2300				<b>1700 MW</b>
Work scheduled by: NYPA						1450 MW
						3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>						FWD	REV
<b>HOMR_NYW-PIERC_NY_345_48</b>						(Import)	(Export)
Mon 05/14/2018	to	Fri 05/18/2018	<u>UPDATED</u>	<u>by NYSEG</u>	<u>05/14/2018</u>		
0800	Continuous	2000				SCH - PJ - NY	<b>2100 MW</b>
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2100 MW
<hr/>						FWD	REV
<b>SCH-NE-NYISO_LIMIT_400</b>						(Import)	(Export)
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>		
1500	Continuous	1859				SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1400 MW
<hr/>						FWD	REV
<b>SCH-NYISO-NE_LIMIT_1100</b>						(Import)	(Export)
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>		
1500	Continuous	1859				SCH - NE - NY	<b>1300 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1600 MW
<hr/>						FWD	REV
<b>NRTH1385-NOR_HBR__138_601</b>						(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>		
0600	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<hr/>						FWD	REV
<b>NRTH1385-NOR_HBR__138_601 &amp; NRTH1385-NOR_HBR__138_602</b>						(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018				SCH - NPX_1385	<b>0 MW</b>
0600		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<hr/>						FWD	REV
<b>NRTH1385-NOR_HBR__138_601 &amp; NRTH1385-NOR_HBR__138_603</b>						(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018				SCH - NPX_1385	<b>0 MW</b>
0600		2359				Impacts Total Transfer Capability	200 MW
Work scheduled by:						TTC with All Lines In Service	200 MW
<hr/>						FWD	REV
<b>NRTH1385-NOR_HBR__138_602</b>						(Import)	(Export)
Tue 05/15/2018	to	Wed 05/23/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>		
0600	Continuous	2359				SCH - NPX_1385	<b>100 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**NRTH1385-NOR HBR\_\_138\_602 & NRTH1385-NOR HBR\_\_138\_603**

Tue 05/15/2018 to Wed 05/23/2018  
 0600 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NOR HBR\_\_138\_603**

Tue 05/15/2018 to Wed 05/23/2018 **EXTENDED** **by LI** **05/17/2018**  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**NRTH1385-NRTHPORT\_138\_NNC**

Tue 05/15/2018 to Wed 05/23/2018 **EXTENDED** **by LI** **05/17/2018**  
 0600 Continuous 2359

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

-----  
**MARCY\_SO\_SERIES\_COMP\_I/S**

Wed 05/16/2018 to Fri 05/18/2018  
 1704 Continuous 2059

Work scheduled by: NYSEG

	FWD
	(Import)
CENTRAL EAST - VC	<b>2740 MW</b>
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	2975 MW

-----  
**SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4**

Thu 05/17/2018 to Thu 05/17/2018  
 0001 0030

Work scheduled by:

	FWD
	(Import)
SPR/DUN-SOUTH	<b>3200 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	4600 MW

-----  
**MILLWOOD\_345KV\_18**

Sat 05/19/2018 to Sat 05/19/2018  
 0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	1350 MW
TTC with All Lines In Service	5700 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 05/19/2018 to Sat 05/19/2018 **UPDATED** **by NYPA** **05/16/2018**  
 2100 Continuous 2300

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>							FWD	
<b>MASSENA_-MARCY_765_MSU1</b>							(Import)	
Sat 05/19/2018	to	Sat 05/19/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/16/2018</u>			
2100	Continuous	2300				MOSES SOUTH	<b>500 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	2650 MW	
						TTC with All Lines In Service	3150 MW	
<hr/>								
<b>MASSENA_-MARCY_765_MSU1</b>							FWD	REV
Sat 05/19/2018	to	Sat 05/19/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/16/2018</u>		(Import)	(Export)
2100	Continuous	2300				SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1025 MW	0 MW
						TTC with All Lines In Service	1500 MW	1000 MW
<hr/>								
<b>SCH-HQ-NYISO_LIMIT_0</b>							FWD	
Sat 05/19/2018	to	Sat 05/19/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/16/2018</u>		(Import)	
2100	Continuous	2300				SCH - HQ - NY	<b>0 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1500 MW	
						TTC with All Lines In Service	1500 MW	
<hr/>								
<b>SCH-NYISO-HQ_LIMIT_0</b>								REV
Sat 05/19/2018	to	Sat 05/19/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/16/2018</u>			(Export)
2100	Continuous	2300				SCH - HQ - NY	<b>0 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1000 MW	
						TTC with All Lines In Service	1000 MW	
<hr/>								
<b>SPRNBK_345KV_RS3 &amp; SPRNBK_345KV_RS4</b>							FWD	
Sun 05/20/2018	to	Sun 05/20/2018					(Import)	
2130		2200				SPR/DUN-SOUTH	<b>3200 MW</b>	
Work scheduled by:						Impacts Total Transfer Capability	1400 MW	
						TTC with All Lines In Service	4600 MW	
<hr/>								
<b>CLAY_-EDIC_345_1-16</b>							FWD	
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/01/2018</u>		(Import)	
0700	Continuous	1530				OSWEGO EXPORT	<b>4850 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	400 MW	
						TTC with All Lines In Service	5250 MW	
<hr/>								
<b>MOSES_-ADIRNDCK_230_MA2</b>							FWD	
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>		(Import)	
0700	Continuous	1730				MOSES SOUTH	<b>2100 MW</b>	
Work scheduled by: NYPA						Impacts Total Transfer Capability	1050 MW	
						TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-HQ-NYISO_LIMIT_1400</b>						FWD	
Mon 05/21/2018	to	Fri 05/25/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>	(Import)	
0700	Continuous	1800				SCH - HQ - NY	<b>1400 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	1500 MW
<b>FRASANX-COOPERS_345_UCC2-41</b>						FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>MARCY_-FRASANX_345_UCC2-41</b>						FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)	
0700	Continuous	1730				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>SCH-NYISO-NE_LIMIT_900</b>						REV	
Mon 05/21/2018	to	Mon 05/21/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Export)	
0730	Continuous	1859				SCH - NE - NY	<b>1100 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1600 MW
<b>FROST_BR-LONG_MTN_345_352</b>						FWD	REV
Mon 05/21/2018	to	Tue 05/22/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Import)	(Export)
0730	Continuous	1600				SCH - NE - NY	<b>1150 MW 1600 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	250 MW 0 MW
						TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>						REV	
Mon 05/21/2018	to	Tue 05/22/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Export)	
1900	Continuous	1600				SCH - NE - NY	<b>1400 MW</b>
Work scheduled by: ISONE						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	1600 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>						FWD	
Tue 05/22/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/20/2018</u>	(Import)	
0500	Continuous	0300				UPNY CONED	<b>4800 MW</b>
Work scheduled by: ORU						Impacts Total Transfer Capability	900 MW
						TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS 345\_2 & NRTH1385-NOR HBR 138\_601

Tue 05/22/2018 to Wed 05/23/2018  
0800 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

N.SCTLND-ALPS 345\_2 & NRTH1385-NOR HBR 138\_602

Tue 05/22/2018 to Wed 05/23/2018  
0800 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

N.SCTLND-ALPS 345\_2 & NRTH1385-NOR HBR 138\_603

Tue 05/22/2018 to Wed 05/23/2018  
0800 2359

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

N.SCTLND-ALPS 345\_2

Tue 05/22/2018 to Thu 05/24/2018  
0800 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NE - NY	750 MW	1350 MW
Impacts Total Transfer Capability	650 MW	250 MW
TTC with All Lines In Service	1400 MW	1600 MW

N.SCTLND-ALPS 345\_2

Tue 05/22/2018 to Thu 05/24/2018  
0800 Continuous 1500

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

DENNISON-NORFOLK 115\_4

Tue 05/22/2018 to Tue 05/22/2018 **CANCELLED by NGrid 05/22/2018**  
0815 Daily(No Weekends) 1615

Work scheduled by: NGrid **ARR: 38**

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	150 MW	40 MW
Impacts Total Transfer Capability	40 MW	0 MW
TTC with All Lines In Service	190 MW	40 MW

WOOD\_ST\_-PLSNTVLE 345\_Y87

Wed 05/23/2018 to Wed 05/23/2018  
0301 Continuous 0330

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4000 MW
Impacts Total Transfer Capability	1700 MW
TTC with All Lines In Service	5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_6</b>			FWD	
Wed 05/23/2018	to	Thu 05/24/2018	(Import)	
0301	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_8</b>			FWD	
Wed 05/23/2018	to	Thu 05/24/2018	(Import)	
0301	Continuous	0200	SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W90</b>			FWD	
Wed 05/23/2018	to	Thu 05/24/2018	(Import)	
0301	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW
<b>BECK_-NIAGARA_345_PA302</b>			FWD	REV
Wed 05/23/2018	to	Thu 05/24/2018	(Import)	(Export)
0500	Continuous	1800	SCH - OH - NY	<b>900 MW 800 MW</b>
Work scheduled by: IESO			Impacts Total Transfer Capability	1100 MW 800 MW
			TTC with All Lines In Service	2000 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_400</b>			FWD	
Wed 05/23/2018	to	Thu 05/24/2018	(Import)	
0700	Continuous	1500	<b>CANCELLED by ISONE 05/22/2018</b>	SCH - NE - NY
Work scheduled by: ISONE			Impacts Total Transfer Capability	<b>600 MW</b>
			TTC with All Lines In Service	800 MW
<b>SCH-NYISO-NE_LIMIT_700</b>				REV
Wed 05/23/2018	to	Thu 05/24/2018		(Export)
0700	Continuous	1500	<b>CANCELLED by ISONE 05/22/2018</b>	SCH - NE - NY
Work scheduled by: ISONE			Impacts Total Transfer Capability	<b>900 MW</b>
			TTC with All Lines In Service	700 MW
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>			FWD	
Thu 05/24/2018	to	Thu 05/24/2018	(Import)	
0130	Continuous	0200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	1700 MW
			TTC with All Lines In Service	5700 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**PLSNTVLE-DUNWODIE\_345\_W89**

Sat 05/26/2018 to Sat 05/26/2018  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Sat 05/26/2018 to Sat 05/26/2018  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**EFISHKIL-WOOD\_ST\_345\_F38**

Sat 05/26/2018 to Sat 05/26/2018  
0001 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**SCH-NYISO-HQ\_LIMIT\_800**

Sat 05/26/2018 to Sat 05/26/2018  
0700 Continuous 1800

Work scheduled by: HQ

REV  
(Export)  
**SCH - HQ - NY 800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Sat 05/26/2018 to Sat 05/26/2018  
2300 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Sat 05/26/2018 to Sat 05/26/2018  
2300 Continuous 2330

Work scheduled by: ConEd

FWD  
(Import)  
**UPNY CONED 4000 MW**  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 5700 MW

**EASTVIEW-SPRNBK\_345\_W78**

Mon 05/28/2018 to Tue 05/29/2018  
0300 Continuous 0200

Work scheduled by: ConEd

**UPDATED by CONED 05/16/2018**

FWD  
(Import)  
**UPNY CONED 4350 MW**  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MILLWOOD-EASTVIEW_345_W85</b>					FWD	
Mon 05/28/2018	to	Tue 05/29/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/16/2018</u>	(Import)
0300	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 1350 MW	
					TTC with All Lines In Service 5700 MW	
<b>SPRNBRK_345KV_RNS3</b>					FWD	
Mon 05/28/2018	to	Tue 05/29/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/16/2018</u>	(Import)
0300	Continuous	0200				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability 800 MW	
					TTC with All Lines In Service 4600 MW	
<b>SCH-IMO-NYISO_LIMIT_1000</b>					FWD	
Tue 05/29/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/15/2018</u>	(Import)
0500	Continuous	1700				SCH - OH - NY <b>1300 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 700 MW	
					TTC with All Lines In Service 2000 MW	
<b>STLAWRNC-MOSES_230_L33P</b>					FWD	
Tue 05/29/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/09/2018</u>	REV (Export)
0700	Continuous	2000				SCH - OH - NY <b>2000 MW</b> <b>1600 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 0 MW 0 MW	
					TTC with All Lines In Service 2000 MW 1600 MW	
<b>BROWNFLS-TAYLORVL_115_4</b>					FWD	
Tue 05/29/2018	to	Sat 06/02/2018				REV (Export)
0700	Continuous	1800				SCH - HQ_CEDARS <b>70 MW</b> <b>40 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 120 MW 0 MW	
<b>ARR: 38</b>					TTC with All Lines In Service 190 MW 40 MW	
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD	
Wed 05/30/2018	to	Wed 05/30/2018				(Import)
0600	Continuous	1000				SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 660 MW	
					TTC with All Lines In Service 660 MW	
<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD	
Wed 05/30/2018	to	Wed 05/30/2018				(Import)
0600	Continuous	1000				SCH - PJM_NEPTUNE <b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability 660 MW	
					TTC with All Lines In Service 660 MW	

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start Date	End Date	Time	Duration	Work Scheduled by	Schedule	Impact	TTC	FWD	REV
NEWBRDGE_345_138_BK_1	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	LI	SCH - PJM_NEPTUNE	375 MW	285 MW	(Import)	
				1000		Impacts Total Transfer Capability		660 MW		
						TTC with All Lines In Service				
NEWBRDGE_345_138_BK_2	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	LI	SCH - PJM_NEPTUNE	375 MW	285 MW	(Import)	
				1000		Impacts Total Transfer Capability		660 MW		
						TTC with All Lines In Service				
SCH-NYISO-NE_LIMIT_800	Wed 05/30/2018	Wed 05/30/2018	0600	Continuous	ISONE	SCH - NE - NY	1000 MW	600 MW	(Export)	
				1800		Impacts Total Transfer Capability		1600 MW		
						TTC with All Lines In Service				
DENNISON-ROSEMNTB_115_2/22	Thu 05/31/2018	Thu 05/31/2018	0800	Daily(No Weekends)	NGrid	SCH - HQ_CEDARS	95 MW	0 MW	(Import)	(Export)
				1630		Impacts Total Transfer Capability		40 MW		
						TTC with All Lines In Service		190 MW		40 MW
										<b>ARR: 38</b>
MARCY_SO_SERIES_COMP_I/S	Fri 06/01/2018	Wed 10/31/2018	1800	Continuous	NYISO	CENTRAL EAST - VC	2740 MW	235 MW	(Import)	
				2359		Impacts Total Transfer Capability		2975 MW		
						TTC with All Lines In Service				
SCH-IMO_NY_NIAG_CB_3122_W/BB	Sat 06/02/2018	Sat 06/02/2018	0500	Continuous	NYPA	SCH - OH - NY	1700 MW	200 MW	(Import)	(Export)
				1700		Impacts Total Transfer Capability		1400 MW		
						TTC with All Lines In Service		2000 MW		1600 MW
BROWNFLS-TAYLORVL_115_3	Mon 06/04/2018	Sat 06/09/2018	0700	Continuous	NGrid	SCH - HQ_CEDARS	70 MW	0 MW	(Import)	(Export)
				1800		Impacts Total Transfer Capability		40 MW		
						TTC with All Lines In Service		190 MW		40 MW
										<b>ARR: 38</b>

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS_345_LEEDS SVC</b>				FWD	
Mon 06/04/2018	to	Fri 06/15/2018		(Import)	
0800	Continuous	1500	CENTRAL EAST - VC	<b>2950 MW</b>	
Work scheduled by: NGrid			Impacts Total Transfer Capability	25 MW	
			TTC with All Lines In Service	2975 MW	
<b>LEEDS_345_LEEDS SVC &amp; MARCY_SO_SERIES_COMP_I/S</b>				FWD	
Mon 06/04/2018	to	Fri 06/15/2018		(Import)	
0800		1500	CENTRAL EAST - VC	<b>2715 MW</b>	
Work scheduled by:			Impacts Total Transfer Capability	260 MW	
			TTC with All Lines In Service	2975 MW	
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD	REV
Mon 06/11/2018	to	Sat 06/16/2018		(Import)	(Export)
0700	Continuous	1800	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>				FWD	
Mon 06/18/2018	to	Thu 06/21/2018		(Import)	
0500	Continuous	1700	DYSINGER EAST	<b>1700 MW</b>	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW	
			TTC with All Lines In Service	3150 MW	
<b>BROWNFLS-TAYLORVL_115_3</b>				FWD	REV
Mon 06/18/2018	to	Sat 06/23/2018		(Import)	(Export)
0700	Continuous	1800	SCH - HQ_CEDARS	<b>70 MW</b>	<b>40 MW</b>
Work scheduled by: NGrid			Impacts Total Transfer Capability	120 MW	0 MW
			TTC with All Lines In Service	190 MW	40 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>				FWD	REV
Fri 06/22/2018	to	Sat 02/01/2020	<b>UPDATED by NYISO 05/14/2018</b>	(Import)	(Export)
2000	Continuous	0000	SCH - PJ - NY	<b>1950 MW</b>	<b>1350 MW</b>
Work scheduled by: NYISO			Impacts Total Transfer Capability	150 MW	0 MW
			TTC with All Lines In Service	2100 MW	1350 MW
<b>SCH-NYISO-IMO_NIAGARA_CB_3022</b>				FWD	REV
Thu 06/28/2018	to	Thu 06/28/2018		(Import)	(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1300 MW</b>	<b>1150 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	700 MW	450 MW
			TTC with All Lines In Service	2000 MW	1600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT1** FWD  
 (Import)  
 Sat 08/04/2018 to Sun 08/05/2018 **UPDATED by NYPA 04/17/2018**  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1750 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 3150 MW

**MARCY\_\_\_765\_345\_AT2** FWD  
 (Import)  
 Tue 09/04/2018 to Sun 09/09/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA **ARR: 19**  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

**CLRKSCRN-OAKDALE\_\_345\_36** FWD  
 (Import)  
 Thu 09/06/2018 to Fri 09/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYSEG  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**FRASER\_-GILBOA\_\_345\_GF5-35** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 10/05/2018  
 0700 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2650 MW**  
 Impacts Total Transfer Capability 325 MW  
 TTC with All Lines In Service 2975 MW

**ROSETON\_-ROCKTVRN\_345\_311** FWD  
 (Import)  
 Mon 09/10/2018 to Fri 09/28/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE  
 UPNY CONED **4400 MW**  
 Impacts Total Transfer Capability 1300 MW  
 TTC with All Lines In Service 5700 MW

**MARCY\_\_\_345KV\_CSC** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

**MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S** FWD  
 (Import)  
 Tue 09/11/2018 to Tue 09/11/2018  
 0500 1730  
 Work scheduled by:  
 CENTRAL EAST - VC **2690 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MARCY\_\_\_765\_345\_AT2**

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**NIAGARA\_345\_230\_AT4**

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

**DUNWODIE-MOTTHAVN\_345\_71**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_3**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**NIAGARA\_-ROCHESTR\_345\_NR2**

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

**MOSES\_-ADIRNDCK\_230\_MAL**

Mon 09/17/2018 to Fri 09/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_\_345\_230\_AT4**

Mon 09/24/2018 to Fri 09/28/2018  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>2000 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	0 MW	200 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MOSES\_\_-ADIRNDCK\_230\_MAI**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**CLAY\_\_-EDIC\_\_345\_2-15**

Mon 09/24/2018 to Fri 09/28/2018  
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
OSWEGO EXPORT	<b>4850 MW</b>
Impacts Total Transfer Capability	400 MW
TTC with All Lines In Service	5250 MW

**WATRCURE\_345\_230\_BK 1**

Mon 09/24/2018 to Thu 09/27/2018  
0800 Continuous 1530

Work scheduled by: NYSEG

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2100 MW</b>	<b>1350 MW</b>
Impacts Total Transfer Capability	0 MW	0 MW
TTC with All Lines In Service	2100 MW	1350 MW

**BECK\_\_-NIAGARA\_345\_PA302**

Mon 10/01/2018 to Fri 10/05/2018  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	<b>900 MW</b>	<b>800 MW</b>
Impacts Total Transfer Capability	1100 MW	800 MW
TTC with All Lines In Service	2000 MW	1600 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

Mon 10/01/2018 to Wed 10/03/2018  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

**PANNELL\_-CLAY\_\_345\_1**

Mon 10/01/2018 to Fri 10/05/2018  
0700 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
WEST CENTRAL	<b>1300 MW</b>
Impacts Total Transfer Capability	950 MW
TTC with All Lines In Service	2250 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**HUDSONP\_-FARRAGUT\_345\_B3402**

Tue 10/02/2018 to Tue 11/13/2018  
 0001 Continuous 2359  
 Work scheduled by: PJM

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2100 MW 1350 MW**  
 Impacts Total Transfer Capability 0 MW 0 MW  
 TTC with All Lines In Service 2100 MW 1350 MW

-----  
**MARCY\_\_\_765\_345\_AT2**

Thu 10/04/2018 to Fri 10/05/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

**ARR: 19**

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MAL**

Mon 10/08/2018 to Fri 10/12/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHAT\_DC\_GC2**

Mon 10/08/2018 to Fri 11/23/2018  
 0700 Continuous 1700  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHAT\_DC\_GC2**

Mon 10/08/2018 to Fri 11/23/2018  
 0700 Continuous 1700  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

-----  
**CHATGUAY-MASSENA\_\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

-----  
**CHATGUAY-MASSENA\_\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY___765_345_AT1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>1750 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1400 MW
<b>ARR: 19</b>		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MARCY___765_345_AT2</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>1700 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1450 MW
<b>ARR: 19</b>		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	CENTRAL EAST - VC <b>2265 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 710 MW
		TTC with All Lines In Service 2975 MW
<hr/>		
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	Continuous 1730	MOSES SOUTH <b>500 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MASSENA_-MARCY___765_MSU1</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import) (Export)
0100	Continuous 1730	SCH - HQ - NY <b>475 MW 1000 MW</b>
Work scheduled by: NYPA		Impacts Total Transfer Capability 1025 MW 0 MW
		TTC with All Lines In Service 1500 MW 1000 MW
<hr/>		
<b>MASSENA_-MARCY___765_MSU1 &amp; CHATGUAY-MASSENA_765_7040</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	1730	MOSES SOUTH <b>500 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 2650 MW
		TTC with All Lines In Service 3150 MW
<hr/>		
<b>MASSENA_-MARCY___765_MSU1 &amp; MARCY_SO_SERIES_COMP_I/S</b>		FWD
Sat 10/13/2018	to Sat 10/27/2018	(Import)
0100	1730	CENTRAL EAST - VC <b>2080 MW</b>
Work scheduled by:		Impacts Total Transfer Capability 895 MW
		TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES -MASSENA\_230\_MMS1 & MOSES -MASSENA\_230\_MMS2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 1730

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**STONYRDG-HILLSIDE\_230\_72**

Wed 10/17/2018 to Thu 10/18/2018  
 0800 Continuous 1530

Work scheduled by: NYSEG

	FWD
	(Import)
DYSINGER EAST	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

-----  
**LINDN\_CG-LNDVFT\_345\_V-3022**

Mon 10/22/2018 to Thu 10/25/2018  
 0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

-----  
**LEEDS -HURLYAVE\_345\_301**

Mon 10/22/2018 to Fri 11/16/2018  
 0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	<b>4100 MW</b>
Impacts Total Transfer Capability	1600 MW
TTC with All Lines In Service	5700 MW

-----  
**KINTIGH -ROCHESTR\_345\_SRL-39**

Mon 10/29/2018 to Fri 11/02/2018  
 0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----  
**MOSES -ADIRNDCK\_230\_MA1**

Mon 10/29/2018 to Fri 11/02/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>2100 MW</b>
Impacts Total Transfer Capability	1050 MW
TTC with All Lines In Service	3150 MW

-----  
**NEPTUNE -DUFFYAVE\_345\_NEPTUNE**

Sat 11/03/2018 to Sun 11/18/2018  
 0001 Continuous 1800

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE-DUFFYAVE_345_501</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>			FWD	
Sat 11/03/2018	to	Sun 11/18/2018	(Import)	
0001	Continuous	1800	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
<b>MOSES__-ADIRNDCK_230_MA1</b>			FWD	
Mon 11/05/2018	to	Fri 11/09/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW
			TTC with All Lines In Service	3150 MW
<b>FROST_BR-LONG_MTN_345_352</b>			FWD	REV
Sun 11/11/2018	to	Sun 11/11/2018	(Import)	(Export)
0700	Continuous	1800	SCH - NE - NY	<b>1300 MW 1600 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	100 MW 0 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_1000</b>			FWD	
Sun 11/11/2018	to	Sun 11/11/2018	(Import)	
0700	Continuous	1800	SCH - NE - NY	<b>1200 MW</b>
Work scheduled by: ISONE			Impacts Total Transfer Capability	200 MW
			TTC with All Lines In Service	1400 MW
<b>MARCY___345KV_CSC</b>			FWD	
Fri 11/16/2018	to	Sat 11/17/2018	(Import)	
0500	Continuous	1730	CENTRAL EAST - VC	<b>2925 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW
			TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

Mon 11/19/2018 to Wed 11/21/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/26/2018 to Fri 11/30/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_\_345\_303

Mon 11/26/2018 to Fri 12/21/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/03/2018 to Fri 12/07/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/10/2018 to Fri 12/14/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

MARCY\_\_\_765\_345\_AT2

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,May 22, 2018 to Thursday ,November 21, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

Wed 12/26/2018 to Fri 12/28/2018  
 0700 Continuous 1530

Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

-----  
**LEEDS\_\_\_345\_LEEDS SVC**

Mon 03/11/2019 to Fri 03/22/2019  
 0800 Continuous 1600

Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2950 MW**  
 Impacts Total Transfer Capability 25 MW  
 TTC with All Lines In Service 2975 MW