

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<hr/>					FWD
<b>E13THSTA-FARRAGUT_345_45</b>					(Import)
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>
0001	Continuous	2359			
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
<b>W49TH_ST-E13THSTA_345_M54</b>					(Import)
Sun 11/26/2017	to	Thu 05/31/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/22/2018</u>
0001	Continuous	2359			
Work scheduled by: ConEd					SPR/DUN-SOUTH <b>3800 MW</b>
					Impacts Total Transfer Capability 800 MW
					TTC with All Lines In Service 4600 MW
<hr/>					FWD
<b>HUDSONP_-FARRAGUT_345_B3402</b>					REV
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>
0001	Continuous	2359			
Work scheduled by: ConEd					SCH - PJ - NY <b>2100 MW 1350 MW</b>
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					FWD
<b>HUDSONP_-FARRAGUT_345_B3402 &amp; MARION_-FARRAGUT_345_C3403</b>					REV
Mon 01/15/2018	to	Sat 06/30/2018			
0001		2359			
Work scheduled by:					SCH - PJ - NY <b>2050 MW 1300 MW</b>
					Impacts Total Transfer Capability 50 MW 50 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					FWD
<b>MARION_-FARRAGUT_345_C3403</b>					REV
Mon 01/15/2018	to	Sat 06/30/2018	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/22/2018</u>
0001	Continuous	2359			
Work scheduled by: ConEd					SCH - PJ - NY <b>2100 MW 1350 MW</b>
					Impacts Total Transfer Capability 0 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					FWD
<b>S.RIPLEY-DUNKIRK_230_68</b>					REV
Wed 02/07/2018	to	Mon 06/04/2018	<u>UPDATED</u>	<u>by NYISO</u>	<u>05/14/2018</u>
1629	Continuous	2000			
Work scheduled by: NYISO					SCH - PJ - NY <b>1950 MW 1350 MW</b>
					Impacts Total Transfer Capability 150 MW 0 MW
					TTC with All Lines In Service 2100 MW 1350 MW
<hr/>					FWD
<b>CHAT_DC_GC1</b>					(Import)
Sat 04/14/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by HQ</u>	<u>04/11/2018</u>
0100	Continuous	1510			
Work scheduled by: HQ					MOSES SOUTH <b>2850 MW</b>
					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

Seasonal Limits

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sat 04/14/2018	to	Wed 05/23/2018	<b>UPDATED</b>	<b>by HQ</b>	<b>04/11/2018</b>	(Export)
0100	Continuous	1510				<b>500 MW</b>
Work scheduled by: HQ						500 MW
						1000 MW
<b>STLAWRNC-MOSES 230_L33P</b>						FWD REV
Mon 04/30/2018	to	Tue 05/29/2018	<b>EXT FORCE</b>	<b>by IESO</b>	<b>05/11/2018</b>	(Import) (Export)
0456	Continuous	0659				<b>2000 MW 1600 MW</b>
Work scheduled by: IESO						0 MW 0 MW
						2000 MW 1600 MW
<b>SCH-HQ-NYISO_LIMIT_1200</b>						FWD
Thu 05/10/2018	to	Fri 05/25/2018				(Import)
1500	Continuous	2100				<b>1200 MW</b>
Work scheduled by: HQ						300 MW
						1500 MW
<b>ERIE E -S.RIPLEY_230_69 &amp; WETHSRFD-S.PERRY_230_85</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018				(Import)
0700		1500				<b>2850 MW</b>
Work scheduled by:						300 MW
						3150 MW
<b>S.PERRY_-MEYER 230_87</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG						300 MW
						3150 MW
<b>WETHSRFD-S.PERRY_230_85</b>						FWD
Sat 05/12/2018	to	Fri 06/01/2018	<b>UPDATED</b>	<b>by NYSEG</b>	<b>02/15/2018</b>	(Import)
0700	Continuous	1500				<b>2850 MW</b>
Work scheduled by: NYSEG						300 MW
						3150 MW
<b>MARCY 765_345_AT2</b>						FWD
Mon 05/14/2018	to	Sat 05/19/2018	<b>UPDATED</b>	<b>by NYPA</b>	<b>05/16/2018</b>	(Import)
0500	Continuous	2300				<b>1700 MW</b>
Work scheduled by: NYPA						1450 MW
						3150 MW

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>HOMR_NYW-PIERC_NY_345_48</b>							
Mon 05/14/2018	to	Fri 05/18/2018	<u>UPDATED</u>	<u>by NYSEG</u>	<u>05/14/2018</u>		
0800	Continuous	2000				SCH - PJ - NY	2100 MW
Work scheduled by: NYSEG						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	2100 MW
							1350 MW
<b>SCH-NE-NYISO_LIMIT_400</b>							
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>		
1500	Continuous	1859				SCH - NE - NY	600 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	1400 MW
<b>SCH-NYISO-NE_LIMIT_1100</b>							
Mon 05/14/2018	to	Mon 05/21/2018	<u>UPDATED</u>	<u>by ISONE</u>	<u>05/11/2018</u>		
1500	Continuous	1859				SCH - NE - NY	1300 MW
Work scheduled by: ISONE						Impacts Total Transfer Capability	300 MW
						TTC with All Lines In Service	1600 MW
<b>NRTH1385-NOR_HBR_138_601 &amp; NRTH1385-NOR_HBR_138_603</b>							
Tue 05/15/2018	to	Tue 05/22/2018					
0600		1923				SCH - NPX_1385	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR_HBR_138_602 &amp; NRTH1385-NOR_HBR_138_603</b>							
Tue 05/15/2018	to	Tue 05/22/2018					
0600		1923				SCH - NPX_1385	0 MW
Work scheduled by:						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR_HBR_138_603</b>							
Tue 05/15/2018	to	Tue 05/22/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>		
0600	Continuous	1923				SCH - NPX_1385	100 MW
Work scheduled by: LI						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>							
Tue 05/15/2018	to	Tue 05/22/2018	<u>EXTENDED</u>	<u>by LI</u>	<u>05/17/2018</u>		
0600	Continuous	1923				SCH - NPX_1385	0 MW
Work scheduled by: LI						Impacts Total Transfer Capability	200 MW
						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR_138_601 &amp; NRTH1385-NOR HBR_138_602</b>					FWD	REV
Tue 05/15/2018 to Tue 05/22/2018					(Import) (Export)	
0600		1933			SCH - NPX_1385	<b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_602</b>					FWD	REV
Tue 05/15/2018 to Tue 05/22/2018					(Import) (Export)	
0600	Continuous	1933	<b><u>EXTENDED</u></b>	<b><u>by LI</u></b>	<b><u>05/17/2018</u></b>	
Work scheduled by: LI					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>NRTH1385-NOR HBR_138_601</b>					FWD	REV
Tue 05/15/2018 to Tue 05/22/2018					(Import) (Export)	
0600	Continuous	1952	<b><u>EXTENDED</u></b>	<b><u>by LI</u></b>	<b><u>05/17/2018</u></b>	
Work scheduled by: LI					SCH - NPX_1385	<b>100 MW 100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>MARCY_SO_SERIES_COMP_I/S</b>					FWD	
Wed 05/16/2018 to Fri 05/18/2018					(Import)	
1704	Continuous	2059			CENTRAL EAST - VC	<b>2740 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	235 MW
					TTC with All Lines In Service	2975 MW
<b>MILLWOOD_345KV_18</b>					FWD	
Sat 05/19/2018 to Sat 05/19/2018					(Import)	
0001	Continuous	0030			UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1350 MW
					TTC with All Lines In Service	5700 MW
<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Sat 05/19/2018 to Sat 05/19/2018					(Import)	
2100	Continuous	2300	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	
Work scheduled by: NYPA					CENTRAL EAST - VC	<b>2265 MW</b>
					Impacts Total Transfer Capability	710 MW
					TTC with All Lines In Service	2975 MW
<b>MASSENA_-MARCY_765_MSU1</b>					FWD	
Sat 05/19/2018 to Sat 05/19/2018					(Import)	
2100	Continuous	2300	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>05/16/2018</u></b>	
Work scheduled by: NYPA					MOSES SOUTH	<b>500 MW</b>
					Impacts Total Transfer Capability	2650 MW
					TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Event Name	Start	End	Status	By	Effective Date	Zone	FWD (Import)	REV (Export)	
MASSENA -MARCY 765 MSU1	Sat 05/19/2018 2100	Sat 05/19/2018 2300	UPDATED	NYPA	05/16/2018	SCH - HQ - NY	475 MW	1000 MW	
Work scheduled by: NYPA							Impacts Total Transfer Capability	1025 MW	0 MW
							TTC with All Lines In Service	1500 MW	1000 MW
SCH-HQ-NYISO_LIMIT_0	Sat 05/19/2018 2100	Sat 05/19/2018 2300	UPDATED	NYPA	05/16/2018	SCH - HQ - NY	0 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	1500 MW	
							TTC with All Lines In Service	1500 MW	
SCH-NYISO-HQ_LIMIT_0	Sat 05/19/2018 2100	Sat 05/19/2018 2300	UPDATED	NYPA	05/16/2018	SCH - HQ - NY		0 MW	
Work scheduled by: NYPA							Impacts Total Transfer Capability		1000 MW
							TTC with All Lines In Service		1000 MW
SPRNBK 345KV_RS3 & SPRNBK 345KV_RS4	Sun 05/20/2018 2130	Sun 05/20/2018 2200				SPR/DUN-SOUTH	3200 MW		
Work scheduled by:							Impacts Total Transfer Capability	1400 MW	
							TTC with All Lines In Service	4600 MW	
SCH-HQ-NYISO_LIMIT_1400	Mon 05/21/2018 0700	Thu 05/24/2018 2359	UPDATED	HQ	04/11/2018	SCH - HQ - NY	1400 MW		
Work scheduled by: HQ							Impacts Total Transfer Capability	100 MW	
							TTC with All Lines In Service	1500 MW	
CLAY -EDIC 345_1-16	Mon 05/21/2018 0700	Fri 05/25/2018 1530	UPDATED	NYPA	05/01/2018	OSWEGO EXPORT	4850 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	400 MW	
							TTC with All Lines In Service	5250 MW	
MOSES -ADIRNDCK_230_MA2	Mon 05/21/2018 0700	Fri 05/25/2018 1730	UPDATED	NYPA	05/10/2018	MOSES SOUTH	2100 MW		
Work scheduled by: NYPA							Impacts Total Transfer Capability	1050 MW	
							TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASANX-COOPERS__345_UCC2-41</b>					FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>MARCY__-FRASANX_345_UCC2-41</b>					FWD	
Mon 05/21/2018	to	Fri 06/01/2018	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/10/2018</u>	(Import)
0700	Continuous	1730				CENTRAL EAST - VC <b>2500 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	475 MW
					TTC with All Lines In Service	2975 MW
<b>SCH-NYISO-NE_LIMIT_900</b>						REV
Mon 05/21/2018	to	Mon 05/21/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Export)
0730	Continuous	1859				SCH - NE - NY <b>1100 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1600 MW
<b>FROST_BR-LONG_MTN_345_352</b>					FWD	REV
Mon 05/21/2018	to	Tue 05/22/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Import) (Export)
0730	Continuous	1600				SCH - NE - NY <b>1150 MW 1600 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW 0 MW
					TTC with All Lines In Service	1400 MW 1600 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>						REV
Mon 05/21/2018	to	Tue 05/22/2018	<u>CANCELLED</u>	<u>by ISONE</u>	<u>05/20/2018</u>	(Export)
1900	Continuous	1600				SCH - NE - NY <b>1400 MW</b>
Work scheduled by: ISONE					Impacts Total Transfer Capability	200 MW
					TTC with All Lines In Service	1600 MW
<b>LADENTWN-BUCHAN_S_345_Y88</b>					FWD	
Tue 05/22/2018	to	Wed 05/23/2018	<u>UPDATED</u>	<u>by CONED</u>	<u>05/20/2018</u>	(Import)
0500	Continuous	0300				UPNY CONED <b>4800 MW</b>
Work scheduled by: ORU					Impacts Total Transfer Capability	900 MW
					TTC with All Lines In Service	5700 MW
<b>N.SCTLND-ALPS____345_2 &amp; NRTH1385-NOR_HBR__138_603</b>					FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018				(Import) (Export)
0800		1923				SCH - NPX_1385 <b>0 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	200 MW 200 MW
					TTC with All Lines In Service	200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>N. SCTLND-ALPS 345_2 &amp; NRTH1385-NOR HBR 138_602</b>			FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018		(Import) (Export)
0800		1933		
Work scheduled by:			SCH - NPX_1385	0 MW 0 MW
			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>N. SCTLND-ALPS 345_2 &amp; NRTH1385-NOR HBR 138_601</b>			FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018		(Import) (Export)
0800		1952		
Work scheduled by:			SCH - NPX_1385	0 MW 0 MW
			Impacts Total Transfer Capability	200 MW 200 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>N. SCTLND-ALPS 345_2</b>			FWD	REV
Tue 05/22/2018	to	Thu 05/24/2018		(Import) (Export)
0800	Continuous	1500		
Work scheduled by: NGrid			SCH - NE - NY	750 MW 1350 MW
			Impacts Total Transfer Capability	650 MW 250 MW
			TTC with All Lines In Service	1400 MW 1600 MW
<b>N. SCTLND-ALPS 345_2</b>			FWD	REV
Tue 05/22/2018	to	Thu 05/24/2018		(Import) (Export)
0800	Continuous	1500		
Work scheduled by: NGrid			SCH - NPX_1385	100 MW 100 MW
			Impacts Total Transfer Capability	100 MW 100 MW
			TTC with All Lines In Service	200 MW 200 MW
<b>DENNISON-NORFOLK 115_4</b>			FWD	REV
Tue 05/22/2018	to	Tue 05/22/2018		(Import) (Export)
0815	Daily(No Weekends)	1615		
Work scheduled by: NGrid			SCH - HQ_CEDARS	150 MW 40 MW
			Impacts Total Transfer Capability	40 MW 0 MW
			TTC with All Lines In Service	190 MW 40 MW
<b>BECK -NIAGARA 345_PA302</b>			FWD	REV
Wed 05/23/2018	to	Thu 05/24/2018		(Import) (Export)
0500	Continuous	1800		
Work scheduled by: IESO			SCH - OH - NY	900 MW 800 MW
			Impacts Total Transfer Capability	1100 MW 800 MW
			TTC with All Lines In Service	2000 MW 1600 MW
<b>SCH-NE-NYISO_LIMIT_400</b>			FWD	REV
Wed 05/23/2018	to	Thu 05/24/2018		(Import)
0700	Continuous	1500		
Work scheduled by: ISONE			SCH - NE - NY	600 MW
			Impacts Total Transfer Capability	800 MW
			TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE\_LIMIT\_700

Wed 05/23/2018 to Thu 05/24/2018  
 0700 Continuous 1500  
 Work scheduled by: ISONE

**CANCELLED by ISONE 05/22/2018**

SCH - NE - NY  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 1600 MW

REV  
 (Export)

SCH-NYISO-HQ\_LIMIT\_800

Fri 05/25/2018 to Thu 05/31/2018  
 0001 Continuous 1600  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1000 MW

REV  
 (Export)

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 0330  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

FWD  
 (Import)

DUNWODIE\_345KV\_6

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

DUNWODIE\_345KV\_8

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD  
 (Import)

PLSNTVLE-DUNWODIE\_345\_W90

Fri 05/25/2018 to Fri 05/25/2018  
 0301 Continuous 1830  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

FWD  
 (Import)

WOOD\_ST\_-PLSNTVLE\_345\_Y87

Fri 05/25/2018 to Fri 05/25/2018  
 1800 Continuous 1830  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

FWD  
 (Import)



# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLE-DUNWODIE\_345\_W89

Sat 05/26/2018 to Sat 05/26/2018  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Sat 05/26/2018 to Sat 05/26/2018  
 0001 Continuous 0030  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

EFISHKIL-WOOD\_ST\_345\_F38

Sat 05/26/2018 to Sat 05/26/2018  
 0001 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

PLSNTVLE-DUNWODIE\_345\_W89

Sat 05/26/2018 to Sat 05/26/2018  
 2300 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

WOOD\_ST\_-PLSNTVLE\_345\_Y86

Sat 05/26/2018 to Sat 05/26/2018  
 2300 Continuous 2330  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 1700 MW  
 TTC with All Lines In Service 5700 MW

EASTVIEW-SPRNBK\_345\_W78

Mon 05/28/2018 to Tue 05/29/2018 **UPDATED by CONED 05/16/2018**  
 0300 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

MILLWOOD-EASTVIEW\_345\_W85

Mon 05/28/2018 to Tue 05/29/2018 **UPDATED by CONED 05/16/2018**  
 0300 Continuous 0200  
 Work scheduled by: ConEd

FWD  
 (Import)  
 UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 1350 MW  
 TTC with All Lines In Service 5700 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS3</b>				FWD
Mon 05/28/2018	to	Tue 05/29/2018	<u>UPDATED</u> <u>by CONED</u> <u>05/16/2018</u>	(Import)
0300	Continuous	0200		<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 4600 MW
<b>SCH-NE-NYISO_LIMIT_400</b>				FWD
Mon 05/28/2018	to	Mon 05/28/2018		(Import)
0600	Continuous	1800		<b>600 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 800 MW
				TTC with All Lines In Service 1400 MW
<b>SCH-NYISO-NE_LIMIT_1100</b>				REV
Mon 05/28/2018	to	Mon 05/28/2018		(Export)
0600	Continuous	1800		<b>1300 MW</b>
Work scheduled by: ISONE				Impacts Total Transfer Capability 300 MW
				TTC with All Lines In Service 1600 MW
<b>SCH-IMO-NYISO_LIMIT_1000</b>				FWD
Tue 05/29/2018	to	Fri 06/01/2018	<u>UPDATED</u> <u>by NYISO</u> <u>05/15/2018</u>	(Import)
0500	Continuous	1700		<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 700 MW
				TTC with All Lines In Service 2000 MW
<b>STLAWRNC-MOSES__230_L33P</b>				FWD REV
Tue 05/29/2018	to	Fri 06/01/2018	<u>UPDATED</u> <u>by NYPA</u> <u>05/09/2018</u>	(Import) (Export)
0700	Continuous	2000		<b>2000 MW 1600 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability 0 MW 0 MW
				TTC with All Lines In Service 2000 MW 1600 MW
<b>BROWNFLS-TAYLORVL_115_4</b>				FWD REV
Tue 05/29/2018	to	Sat 06/02/2018		(Import) (Export)
0700	Continuous	1800		<b>70 MW 40 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability 120 MW 0 MW
<b>ARR: 38</b>				TTC with All Lines In Service 190 MW 40 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD
Wed 05/30/2018	to	Wed 05/30/2018		(Import)
0600	Continuous	1000		<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability 660 MW
				TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE-DUFFYAVE\_345\_501**

Wed 05/30/2018 to Wed 05/30/2018  
 0600 Continuous 1000  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Wed 05/30/2018 to Wed 05/30/2018  
 0600 Continuous 1000  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Wed 05/30/2018 to Wed 05/30/2018  
 0600 Continuous 1000  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

**DENNISON-ROSEMNTB\_115\_2/22**

Thu 05/31/2018 to Thu 05/31/2018  
 0800 Daily(No Weekends) 1630  
 Work scheduled by: NGrid

**ARR: 38**

FWD REV  
 (Import) (Export)  
 SCH - HQ\_CEDARS **95 MW 40 MW**  
 Impacts Total Transfer Capability 95 MW 0 MW  
 TTC with All Lines In Service 190 MW 40 MW

**MARCY\_SO\_SERIES\_COMP\_I/S**

Fri 06/01/2018 to Wed 10/31/2018  
 1800 Continuous 2359  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2740 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 2975 MW

**SCH-IMO\_NY\_NIAG\_CB\_3122\_W/BB**

Sat 06/02/2018 to Sat 06/02/2018  
 0500 Continuous 1700  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - OH - NY **1700 MW 1400 MW**  
 Impacts Total Transfer Capability 300 MW 200 MW  
 TTC with All Lines In Service 2000 MW 1600 MW

**SCH-NYISO-HQ\_LIMIT\_800**

Sat 06/02/2018 to Sat 06/02/2018  
 0700 Continuous 1800  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **800 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<b>BROWNFLS-TAYLORVL_115_3</b>					
Mon 06/04/2018	to	Sat 06/09/2018			
0700	Continuous	1800			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>LEEDS_345_LEEDS SVC</b>					
Mon 06/04/2018	to	Fri 06/15/2018			
0800	Continuous	1500			
Work scheduled by: NGrid					
				CENTRAL EAST - VC	<b>2950 MW</b>
				Impacts Total Transfer Capability	25 MW
				TTC with All Lines In Service	2975 MW
<b>LEEDS_345_LEEDS SVC &amp; MARCY_SO_SERIES_COMP_I/S</b>					
Mon 06/04/2018	to	Fri 06/15/2018			
0800		1500			
Work scheduled by:					
				CENTRAL EAST - VC	<b>2715 MW</b>
				Impacts Total Transfer Capability	260 MW
				TTC with All Lines In Service	2975 MW
<b>BROWNFLS-TAYLORVL_115_4</b>					
Mon 06/11/2018	to	Sat 06/16/2018			
0700	Continuous	1800			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>NIAGARA_-ROCHESTR_345_NR2</b>					
Mon 06/18/2018	to	Thu 06/21/2018			
0500	Continuous	1700			
Work scheduled by: NYPA					
				DYSINGER EAST	<b>1700 MW</b>
				Impacts Total Transfer Capability	1450 MW
				TTC with All Lines In Service	3150 MW
<b>BROWNFLS-TAYLORVL_115_3</b>					
Mon 06/18/2018	to	Sat 06/23/2018			
0700	Continuous	1800			
Work scheduled by: NGrid			<b>ARR: 38</b>		
				SCH - HQ_CEDARS	<b>70 MW 40 MW</b>
				Impacts Total Transfer Capability	120 MW 0 MW
				TTC with All Lines In Service	190 MW 40 MW
<b>S.RIPLEY-DUNKIRK_230_68</b>					
Fri 06/22/2018	to	Sat 02/01/2020	<b>UPDATED</b>	<b>by NYISO</b>	<b>05/14/2018</b>
2000	Continuous	0000			
Work scheduled by: NYISO					
				SCH - PJ - NY	<b>1950 MW 1350 MW</b>
				Impacts Total Transfer Capability	150 MW 0 MW
				TTC with All Lines In Service	2100 MW 1350 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2975MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>5700MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

	FWD	REV
	(Import)	(Export)
<hr/>		
<b>SCH-NYISO-IMO_NIAGARA_CB_3022</b>		
Thu 06/28/2018 to Thu 06/28/2018		
0500 Continuous 1700		
Work scheduled by: NYPA		
	SCH - OH - NY	<b>1300 MW</b>
	Impacts Total Transfer Capability	700 MW
	TTC with All Lines In Service	2000 MW
		<b>1150 MW</b>
		450 MW
		1600 MW
<hr/>		
<b>MARCY___765_345_AT1</b>		
Sat 08/04/2018 to Sun 08/05/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
	<b>UPDATED</b>	<b>by NYPA</b>
	<b>04/17/2018</b>	
	MOSES SOUTH	<b>1750 MW</b>
	Impacts Total Transfer Capability	1400 MW
	TTC with All Lines In Service	3150 MW
		<b>ARR: 19</b>
<hr/>		
<b>MARCY___765_345_AT2</b>		
Tue 09/04/2018 to Sun 09/09/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
	MOSES SOUTH	<b>1700 MW</b>
	Impacts Total Transfer Capability	1450 MW
	TTC with All Lines In Service	3150 MW
		<b>ARR: 19</b>
<hr/>		
<b>CLRKSCRN-OAKDALE__345_36</b>		
Thu 09/06/2018 to Fri 09/07/2018		
0700 Continuous 1530		
Work scheduled by: NYSEG		
	CENTRAL EAST - VC	<b>2650 MW</b>
	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>FRASER__-GILBOA__345_GF5-35</b>		
Mon 09/10/2018 to Fri 10/05/2018		
0700 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2650 MW</b>
	Impacts Total Transfer Capability	325 MW
	TTC with All Lines In Service	2975 MW
<hr/>		
<b>ROSETON_-ROCKTVRN_345_311</b>		
Mon 09/10/2018 to Fri 09/28/2018		
0800 Continuous 1600		
Work scheduled by: CHGE		
	UPNY CONED	<b>4400 MW</b>
	Impacts Total Transfer Capability	1300 MW
	TTC with All Lines In Service	5700 MW
<hr/>		
<b>MARCY___345KV_CSC</b>		
Tue 09/11/2018 to Tue 09/11/2018		
0500 Continuous 1730		
Work scheduled by: NYPA		
	CENTRAL EAST - VC	<b>2925 MW</b>
	Impacts Total Transfer Capability	50 MW
	TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC & MARCY\_SO\_SERIES\_COMP\_I/S

Tue 09/11/2018 to Tue 09/11/2018  
0500 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Tue 09/11/2018 to Tue 09/11/2018  
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

NIAGARA\_\_345\_230\_AT4

Fri 09/14/2018 to Fri 09/14/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **2000 MW 1400 MW**  
Impacts Total Transfer Capability 0 MW 200 MW  
TTC with All Lines In Service 2000 MW 1600 MW

DUNWODIE-MOTTHAVN\_345\_71

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_3

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_5

Sat 09/15/2018 to Mon 09/17/2018  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

NIAGARA\_-ROCHESTR\_345\_NR2

Mon 09/17/2018 to Fri 09/21/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

Work Scheduled	Start	End	Day	Time	Zone	Impact	TTC	FWD	REV
MOSES - ADIRNDCK_230_MA1	Mon 09/17/2018	Fri 09/21/2018		0700	Continuous	1530		FWD	
Work scheduled by: NYPA								(Import)	
								MOSES SOUTH	2100 MW
								Impacts Total Transfer Capability	1050 MW
								TTC with All Lines In Service	3150 MW
NIAGARA 345_230_AT4	Mon 09/24/2018	Fri 09/28/2018		0500	Continuous	1700		FWD	REV
Work scheduled by: NYPA								(Import)	(Export)
								SCH - OH - NY	2000 MW 1400 MW
								Impacts Total Transfer Capability	0 MW 200 MW
								TTC with All Lines In Service	2000 MW 1600 MW
MOSES - ADIRNDCK_230_MA1	Mon 09/24/2018	Fri 09/28/2018		0700	Continuous	1530		FWD	
Work scheduled by: NYPA								(Import)	
								MOSES SOUTH	2100 MW
								Impacts Total Transfer Capability	1050 MW
								TTC with All Lines In Service	3150 MW
CLAY - EDIC 345_2-15	Mon 09/24/2018	Fri 09/28/2018		0700	Continuous	1700		FWD	
Work scheduled by: NYPA								(Import)	
								OSWEGO EXPORT	4850 MW
								Impacts Total Transfer Capability	400 MW
								TTC with All Lines In Service	5250 MW
WATRCURE 345_230_BK 1	Mon 09/24/2018	Thu 09/27/2018		0800	Continuous	1530		FWD	REV
Work scheduled by: NYSEG								(Import)	(Export)
								SCH - PJ - NY	2100 MW 1350 MW
								Impacts Total Transfer Capability	0 MW 0 MW
								TTC with All Lines In Service	2100 MW 1350 MW
BECK - NIAGARA 345_PA302	Mon 10/01/2018	Fri 10/05/2018		0500	Continuous	1700		FWD	REV
Work scheduled by: NYPA								(Import)	(Export)
								SCH - OH - NY	900 MW 800 MW
								Impacts Total Transfer Capability	1100 MW 800 MW
								TTC with All Lines In Service	2000 MW 1600 MW
MOSES - ADIRNDCK_230_MA2	Mon 10/01/2018	Wed 10/03/2018		0700	Continuous	1530		FWD	
Work scheduled by: NYPA								(Import)	
								MOSES SOUTH	2100 MW
								Impacts Total Transfer Capability	1050 MW
								TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL_-CLAY_345_1</b>			FWD	
Mon 10/01/2018	to	Fri 10/05/2018	(Import)	
0700	Continuous	1700	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>			FWD	REV
Tue 10/02/2018	to	Tue 11/13/2018	(Import)	(Export)
0001	Continuous	2359	SCH - PJ - NY	<b>2100 MW 1350 MW</b>
Work scheduled by: PJM			Impacts Total Transfer Capability	0 MW 0 MW
			TTC with All Lines In Service	2100 MW 1350 MW
<b>MARCY_765_345_AT2</b>			FWD	
Thu 10/04/2018	to	Fri 10/05/2018	(Import)	
0500	Continuous	1730	MOSES SOUTH	<b>1700 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1450 MW
			TTC with All Lines In Service	3150 MW
<b>MOSES_-ADIRNDCK_230_MA1</b>			FWD	
Mon 10/08/2018	to	Fri 10/12/2018	(Import)	
0700	Continuous	1530	MOSES SOUTH	<b>2100 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>			FWD	
Mon 10/08/2018	to	Fri 11/23/2018	(Import)	
0700	Continuous	1700	MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW
			TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>				REV
Mon 10/08/2018	to	Fri 11/23/2018		(Export)
0700	Continuous	1700	SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ			Impacts Total Transfer Capability	500 MW
			TTC with All Lines In Service	1000 MW
<b>CHATGUAY-MASSENA_765_7040</b>			FWD	
Sat 10/13/2018	to	Sat 10/27/2018	(Import)	
0100	Continuous	1730	MOSES SOUTH	<b>1550 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW
			TTC with All Lines In Service	3150 MW

ARR: 19



# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

-----  
**CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**MARCY\_\_765\_345\_AT1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1750 MW</b>
Impacts Total Transfer Capability	1400 MW
TTC with All Lines In Service	3150 MW

-----  
**MARCY\_\_765\_345\_AT2**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

**ARR: 19**

	FWD
	(Import)
MOSES SOUTH	<b>1700 MW</b>
Impacts Total Transfer Capability	1450 MW
TTC with All Lines In Service	3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2265 MW</b>
Impacts Total Transfer Capability	710 MW
TTC with All Lines In Service	2975 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

-----  
**MASSENA\_-MARCY\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040**

Sat 10/13/2018 to Sat 10/27/2018  
 0100 Continuous 1730

Work scheduled by:

	FWD
	(Import)
MOSES SOUTH	<b>500 MW</b>
Impacts Total Transfer Capability	2650 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA\_-MARCY\_\_\_765\_MSU1 & MARCY\_SO\_SERIES\_COMP\_I/S

Sat 10/13/2018 to Sat 10/27/2018  
0100 1730

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2080 MW**  
Impacts Total Transfer Capability 895 MW  
TTC with All Lines In Service 2975 MW

MOSES\_-MASSENA\_230\_MMS1 & MOSES\_-MASSENA\_230\_MMS2

Sat 10/13/2018 to Sat 10/27/2018  
0100 1730

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

STONYRDG-HILLSIDE\_230\_72

Wed 10/17/2018 to Thu 10/18/2018  
0800 Continuous 1530

Work scheduled by: NYSEG

FWD  
(Import)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Mon 10/22/2018 to Thu 10/25/2018  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

LEEDS\_-HURLYAVE\_345\_301

Mon 10/22/2018 to Fri 11/16/2018  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 5700 MW

KINTIGH\_-ROCHESTR\_345\_SR1-39

Mon 10/29/2018 to Fri 11/02/2018  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_-ADIRNDCK\_230\_MAL

Mon 10/29/2018 to Fri 11/02/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Sat 11/03/2018 to Sun 11/18/2018  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Sat 11/03/2018 to Sun 11/18/2018  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Sat 11/03/2018 to Sun 11/18/2018  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Sat 11/03/2018 to Sun 11/18/2018  
0001 Continuous 1800

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**MOSES\_-ADIRNDCK\_230\_MA1**

Mon 11/05/2018 to Fri 11/09/2018  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**FROST\_BR-LONG\_MTN\_345\_352**

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800

Work scheduled by: ISONE

FWD REV  
(Import) (Export)  
SCH - NE - NY **1300 MW 1600 MW**  
Impacts Total Transfer Capability 100 MW 0 MW  
TTC with All Lines In Service 1400 MW 1600 MW

**SCH-NE-NYISO\_LIMIT\_1000**

Sun 11/11/2018 to Sun 11/11/2018  
0700 Continuous 1800

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1200 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_345KV\_CSC

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

FWD  
 (Import)  
 CENTRAL EAST - VC **2925 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_\_765\_345\_AT2

Fri 11/16/2018 to Sat 11/17/2018  
 0500 Continuous 1730  
 Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 MOSES SOUTH **1700 MW**  
 Impacts Total Transfer Capability 1450 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA1

Mon 11/19/2018 to Wed 11/21/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 11/26/2018 to Fri 11/30/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

HURLYAVE-ROSETON\_\_345\_303

Mon 11/26/2018 to Fri 12/21/2018  
 0800 Continuous 1600  
 Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED **4100 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 5700 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/03/2018 to Fri 12/07/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MA2

Mon 12/10/2018 to Fri 12/14/2018  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **2300 MW**  
 Impacts Total Transfer Capability 850 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, May 23, 2018 to Friday, November 22, 2019

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	5700MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY\_\_\_765\_345\_AT2

FWD

Mon 12/17/2018 to Fri 12/21/2018  
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

MOSES\_\_\_-ADIRNDCK\_230\_MAI

FWD

Wed 12/26/2018 to Fri 12/28/2018  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

LEEDS\_\_\_345\_LEEDS SVC

FWD

Mon 03/11/2019 to Fri 03/22/2019  
0800 Continuous 1600

(Import)

Work scheduled by: NGrid

CENTRAL EAST - VC **2950 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2975 MW